

INITIAL NOTIFICATION OF AN
ISSUE REPORTABLE PURSUANT
TO 10CFR21

DATE: January 14, 1992

TO: NRC OPERATIONS CENTER
FACSIMILE NO. 301-492-8187
CONFIRMATION NO. 301-951-0550

REF.: TU ELECTRIC, GLEN ROSK, TEXAS
COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NO: 50-445, OL NO. NPP-87
DOCKET NO: 50-446, CP NO. CPPR-127

SUBJECT - P21R-92-001

DESCRIPTION

PAGE 1 of 1

On 01/09/92, a reportable deficiency was identified involving check valve P/N 72543 (swing arm) on Borg Warner Model No. 75510 which is not completely interchangeable with the original part. The valve is a 3"-900lb. swing check valve.

Specifically, P/N 72543 was supplied to CPSES with a certificate of conformance stating the supplied parts were equivalent in fit, form and function. Recently, the part has been found to have a different geometrical configuration than the original part and would provide a potential for failure of the valve to properly close.

The defect was identified during outage related, planned replacement and inspection.

ADDITIONAL ACTIONS PLANNED

A complete written report will be submitted no later than 02/13/92.

ADDITIONAL NOTIFICATIONS

NRC Region IV staff
CPSES NRC Resident staff

LICENSEE CONTACT(S)

W. G. Guldmond, Manager, Site Licensing, (817) 897-8739

CONFIRMATION OF FACSIMILE

BY: _____ (TU ELECTRIC)
TO: _____ (NRC OPS CTR)
AT: _____ (TIME)

000177

JE27 1/6