



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-238t
Writer's Direct al Number:
(717) 948-8005

January 30, 1992
C311-91-2020

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Three Mile Island Nuclear Station, Unit I (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Response to Generic Letter 91-11
Resolution of Generic Issues 48 and 49

This letter transmits the GPU Nuclear response to the guidance contained in Enclosure 1 to Generic Letter 91-11. A review completed by Plant Operations and Plant Engineering department personnel verified that appropriate administrative controls have been implemented to satisfy the recommendations and requirements of the enclosure.

The concern identified by Generic Issue 48, inadvertent paralleling of power supplies, is prevented at TMI-1 by a combination of procedural controls, plant operations surveillance checks, and both electrical and mechanical interlocks.

TMI-1 has implemented administrative time limits to restrict the period that a vital bus is powered from a power supply other than an inverter as recommended by Generic Issue 49. The period is limited to 72 hours unless specifically approved by the Plant Operations Director.

As a result of the review, it was determined that TMI-1 is in full compliance with GL 91-11. Therefore, no additional action is required.

Sincerely,

T. G. Broughton
Vice President & Director, TMI-1

WGH 030016

Attachment

cc: Administrator, Region I
TMI-1 Senior Project Manager
TMI-1 Senior Resident Inspector

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

9202040407 920130
PDR ADOCK 05000289
PDR


A027

METROPOLITAN EDISON COMPANY
JERSEY CENTRAL POWER AND LIGHT COMPANY
PENNSYLVANIA ELECTRIC COMPANY
GENERAL PUBLIC UTILITIES NUCLEAR CORPORATION

Three Mile Island Nuclear Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289



Response to Generic Letter 91-11
Resolution of Generic Issues 48 and 49

This letter is submitted in response to Generic Letter 91-11 entitled "Resolution of Generic Issues 48, 'LOCs for Class 1E Vital Instrument Buses,' and 49, 'Interlocks and LOCs for Class 1E Tie Breakers.'" All statements contained in this response have been reviewed, and all such statements made and matter set forth therein are true and correct to the best of my knowledge.



T. G. Broughton
Vice President and Director, TMI-1

Signed and sworn before me this
30th day of January, 1992.


Notary Public

Member, Pennsylvania Association of Notaries