

**Florida
Power**
CORPORATION

June 11, 1984
3F0684-03

Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Control of Heavy Loads - Phase I (NUREG-0612)

Dear Mr. Denton:

This letter is in response to the Nuclear Regulatory Commission's concerns regarding the control of heavy loads, phase I (NRC to FPC letter 3N-0583-17, dated May 19, 1983). Florida Power Corporation (FPC) with consultation from the Stone & Webster Engineering Corporation (SWEC) reviewed these concerns and has identified actions necessary to ensure that the intent of NUREG - 0612 is satisfied.

There are ten (10) copies of the SWEC's report including applicable analyses attached. The following is a summary together with FPC's position .

NRC Concern: FPC should resolve the longitudinal stiffener and trolley bumper deficiencies on the fuel (auxiliary) building crane and reactor building polar crane.

FPC Position: The attached analysis shows that the longitudinal stiffeners are not required to prevent girder buckling. Therefore FPC has no plans to modify the crane with regards to longitudinal stiffeners.

FPC will add trolley bumpers to both the reactor building polar crane and auxiliary building crane. It is anticipated that these bumpers will be added during Refuel V scheduled for Spring 1985.

NRC Concern: FPC should complete the design verification of the intake structure crane.

FPC Response: The design was verified to meet the requirements of CMAA 70 and ANSI B30-2-0. A copy of the design Verification is attached.

Two analyses were deferred from the "six-month" effort to be included in the "nine-month" work scope. FPC (via SWEC) has completed these analyses and has transmitted them under separate covers (November 23, 1983). The following positions reflect interim corrective actions FPC will implement until such time as the NRC staff has accepted the "nine-month" analyses.

8406140130 840611
PDR ADDCK 05000302
P PDR

*A033 Limited Distribution
1/10*

A. Potential drop of Spent Fuel Divider Gate

1. FPC will prohibit the movement of the spent fuel pool divider gate until after fifty (50) days following transfer of spent fuel to the spent fuel pools.
2. Only spent fuel shall be placed in the vicinity of the gate handling areas.

B. Potential drop of Reactor Building Tendon Jack


1. As shown in Appendix G, Calculation 8 of the NUREG-0612 Nine Month Report, the Spent Fuel Pool Missile Shields will not fail due to the drop of the Reactor Building Tendon Jack. Therefore, no interim restrictions on the movement of the jack is deemed necessary.

One additional change to our previous status requires further discussion. The Reactor Vessel Head and Internals Special Lifting Device (tripod) was removed from the Reactor Building between Refuel III and Refuel IV. Non-destructive examinations identified some surface indications. Research into the tripod's construction and pre-service testing failed to produce adequate documentation of welding methodology and load testing. Therefore FPC performed both documented weld repairs and a load test. This subject was addressed in LER 83-17 by FPC and Information Notice No. 83-71 by the NRC. Region II and Babcock & Wilcox (tripod supplier) have reviewed the repairs/tests. FPC considers our tripod to be a substantially upgraded component as a result. Since the Nine-Month analyses demonstrate the ability of the plant to be shut down following a postulated reactor vessel head drop, the tripod is not considered safety-related. Furthermore, the difficulty in performing adequate non-destructive exams (NDE) on a prior-to-use basis overweighs any increased assurance of its structural integrity. Therefore FPC proposes to perform the following in-service tests:

- a) A 10 minute hold immediately after the head has been lifted to a height of less than one foot with documented visual exam of the tripods' performance on each head lift.
- b) A thorough NDE every third refueling cycle (e.g., prior to Refuel VII, X, etc.). This interval should equal approximately 4.5 to 6 years.

Our project manager requested we identify the status of FPC's actions with regard to Generic letter 83-42. FPC has forwarded a copy of Generic Letter 83-42 to the A/E firm working on the design of our upgrade/replacement of FHCR-5 which FPC is making single failure proof. Its concerns will be addressed in the appropriate specification(s).

Sincerely,



G. R. Westafer
Manager
Nuclear Operations Licensing and Fuel Management

GRW/ddl

Attachments

cc: Mr. J. P. O'Reilly, Regional Administrator
U.S. Nuclear Regulatory Commission, Region II
101 Marietta Street, Suite 2900
Atlanta, GA 30303

STONE & WEBSTER ENGINEERING CORPORATION

CHERRY HILL OPERATIONS CENTER

3 EXECUTIVE CAMPUS, P.O. BOX 5200

CHERRY HILL, NEW JERSEY 08034

TWX: 710-892-0147
710-892-0148



BOSTON
NEW YORK
CHERRY HILL, N.J.
DENVER
CHICAGO
HOUSTON
PORTLAND, OREGON
SAN DIEGO
WASHINGTON, D.C.

DESIGN
CONSTRUCTION
REPORTS
EXAMINATIONS
CONSULTING
ENGINEERING

Florida Power Corporation
Attention Mr. E. E. Froats
Nuclear Project Management Engineer
3201 34th Street, South
St. Petersburg, FL 33733

August 1, 1983
J.O.No. 14235.17
SWCR-150

SWEC TASK .17
CONTROL OF HEAVY LOADS
CRYSTAL RIVER - UNIT 3

Reference: FPC Letter No. WPN83-0615 dated June 8, 1983

SWEC has reviewed the Franklin Research Center's (FRC's) Technical Evaluation Report (TER) submitted by the NRC to Florida Power Corporation (FPC) as Enclosure 1 to NRC Letter No. 3N-0583-17 dated May 19, 1983. The following information is presented to address the NRC's concerns of the control of heavy loads - Phase 1, as identified by FRC in its TER. SWEC believes that this information will allow the NRC to complete its evaluation of Phase 1.

The TER identifies the following areas in which additional licensee action is necessary to ensure that the overall intent of NUREG-0612, Section 5.1.1, is satisfied.

- 1a. FPC should resolve the longitudinal stiffener and trolley bumper deficiencies on the fuel (auxiliary) building crane and reactor building polar crane.
- 2a. FPC should complete the design verification of the intake structure crane.

With respect to Item 1a, SWEC has performed a detailed analysis to evaluate the potential for buckling of the auxiliary building crane's main girder. The results of the analysis show that the longitudinal stiffeners, while not meeting the minimum moment of inertia required by CMAA 70, are not required to prevent girder buckling. The analysis is shown in Enclosure 1.

Further, SWEC has determined that trolley bumpers can be added to both the reactor building polar crane and the auxiliary building crane with little impact. The trolley bumpers for the auxiliary building crane can be conveniently added during the upgrade of the crane to single-failureproof criteria.

SWEC has completed the design verification of the intake structure crane, as required by Item 2a. In summary, the crane meets the design requirements of CMAA 70 and ANSI B30-2-0. A detailed design verification is enclosed as Enclosure 2.


In addition, the TER identifies the following areas in which additional licensee interim action in accordance with NUREG-0612, Section 5.3, is necessary. This is to ensure that handling of heavy loads will be performed in a safe manner until implementation of the general guidelines of NUREG-0612, Section 5.1, is complete.

- 1b. FPC should prohibit the movement of the pool divider gate over spent fuel in the spent fuel pool.
- 2b. FPC should limit the use of the 5-ton jack over the fuel building until the issue of impact on spent fuel is resolved and appropriate actions are completed.

In response to Item 1b, SWEC has prepared calculations (Enclosure 3), which show that if the gate is dropped on the fuel pool floor, the pool floor will not fail, thereby preventing loss of cooling water. Note that the liner is penetrated, thereby allowing some seepage through the concrete, which would be compensated for by the borated water makeup capability. However, because of potential damage to spent or partially spent fuel (Enclosure 4), SWEC believes the following precautions should be included in CR3 operating procedures.

- o Only totally spent fuel shall be placed in the vicinity of the gate handling area.
- o The gate may be moved only after 50 days following transfer of spent fuel to the spent fuel pools.

For Item 2b, SWEC has performed calculations (Enclosure 5), which show that if the 5-ton jack (weight 7,000 lb) is dropped over the fuel building, the spent fuel pool missile shields will prevent the jack from falling into the pool. Based on this, SWEC believes that movement of the jack can be unrestricted.



T. J. Lanza
Project Engineer

Enclosures

EHM:ACD

ENCLOSURE 1

FHCR-5 CRANE GIRDER BUCKLING ANALYSIS

STONE & WEBSTER ENGINEERING CORPORATION

CALCULATION TITLE PAGE

*SEE INSTRUCTIONS ON REVERSE SIDE

A 5010 84 (FRONT)

CLIENT & PROJECT Florida Power Corp. - Crystal River - 3		PAGE 1 OF 33 including attachments.
CALCULATION TITLE (Indicative of the Objective): FHCR-5 Auxiliary Bldg Crane Crane Gridder Buckling Analysis		QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER

CALCULATION IDENTIFICATION NUMBER				OPTIONAL WORK PACKAGE NO.
J.O. OR W.O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	
14235.	Structural	14235.17-603	—	—

* APPROVALS - SIGNATURE & DATE			REV. NO. OR NEW CALC NO.	SUPERSEDES * CALC. NO. OR REV. NO.	CONFIRMATION * REQUIRED (✓)	
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)			YES	NO
R. D. Salter 7/25/83	Philips 7/29/83	Genneth Wialock 7/29/83	1E-1	—	✓	

DISTRIBUTION *

GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)
RECORDS MGT. FILES (OR FIRE FILE IF NONE)	Bldg 6/32d				

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. FPC
14235.17 - C03

REVISION

PAGE

2

ASD1061

PREPARED / DATE
R. Salko 7/25/83

REVIEWER / CHECKER / DATE
P. A. A. 7/25/83

INDEPENDENT REVIEWER / DATE
K. J. Locky 7/29/83

SUBJECT / TITLE
FHCR-5 Crane Gider Buckling Analysis

QA CATEGORY / CODE CLASS
I / NSR

TABLE OF CONTENTS

PAGE	DESCRIPTION
1	TITLE PAGE
2	TABLE OF CONTENTS
3	HISTORICAL DATA
4	CALCULATION SUMMARY
5	DESIGN CHECK LIST
6	RECORD OF CONFIRMATIONS
7	<i>Computer Index.</i>
8	BODY OF CALCULATION

ATTACHMENTS :

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A501061

J.O./W.O./CALCULATION NO. 14235.17 - C03	RPC	REVISION	PAGE 3
---	-----	----------	-----------

PREPARER/DATE	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE
---------------	-----------------------	---------------------------

SUBJECT/TITLE FHCR-5 Crane Guder Buckling Analysis	QA CATEGORY/CODE CLASS I/MSR
---	---------------------------------

Historical Data Rev

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A5010 61

J.O./W.O./CALCULATION NO.

14235.17 C03

FPC

REVISION

PAGE

4.0

PREPARER/DATE

R. D. Baker 7/25/83

REVIEWER/CHECKER/DATE

STERNA 7/25/83

INDEPENDENT REVIEWER/DATE

Kenneth W. Siebeck 7/29/83

SUBJECT/TITLE

FHCR-5 Crane Girder Buckling Analysis

QA CATEGORY CODE CLASS

I/NSR

FHCR-5 - Auxiliary Building Crane

Crane Girder Buckling Analysis

Objective of Calculation.

The purpose of this calculation is to check the main girders of the Auxiliary Building Crane (FHCR-5) for buckling. This analysis is required due to the determination of the Tera Corporation report (Jan., 1982) which shows insufficient moment of inertia for the longitudinal stiffeners.

Calculation Method/ Assumptions.

For the purpose of the analysis a detailed finite element computer model was prepared using "Ansys" rev. 3 (ST-360). One of the crane girders was completely modelled with the exception of the longitudinal stiffeners. These stiffeners were left out in order to determine if the girder was adequate without them.

Two different loading locations were analyzed. These locations were judged to be the worst cases for the girders. The loads were provide by Whitting Corporation.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A5010 61

J.O./W.C./CALCULATION NO.

14235.17 - C03 - FPC

REVISION

PAGE

4.1

PREPARER/DATE

R. D. Salkin 7/25/83

REVIEWER/CHECKER/DATE

R. Salkin 7-29-83

INDEPENDENT REVIEWER/DATE

R. Wislocky 7/29/83

SUBJECT/TITLE

FIHCR-5 Crane Girder Buckling Analysis

QA CATEGORY/CODE CLASS

I/NSR

Calculation Method/Assumptions (con't)

and represent the maximum wheel loads from the trolley for both guiders

Confirmation Reg'd. → $\left(\begin{array}{l} 96,000 \text{ lb} \\ 79,000 \text{ lb} \end{array} \right)$ rear main hook wheels
Aux. hook wheels.

The original design specification (refer: # 4) section 4.00 states that this crane is a class A crane as classified by CMAA-70. (refer: # 5). Accordingly, all class A cranes are required to take $2\frac{1}{2}$ % of the live load for lateral loading (section 3.3.2.1.2, CMAA-70). This would represent 2.4 kips and 1.975 kips at the trolley wheel locations. These loads were assumed to have very little contribution to this analysis but were included by providing a simple static calculation.

The results of the computer analysis provide the element stresses for the applied loadings. The acceptable stresses for the prevention of buckling are provided in the body of this calculation and are based on the AISC steel design code and other established references.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

14235.17-003

FISC

REVISION

PAGE

4.2

45010.81

PREPARER/DATE

R. D. Walker 7/25/83

REVIEWER/CHECKER/DATE

L. Williams 7-29-83

INDEPENDENT REVIEWER/DATE

Ronald Wilosky 7/29/83

SUBJECT/TITLE

FHCR-5 Crane Girders Buckling Analysis

QA CATEGORY/CODE CLASS

I/NSR

Preferences & Sources of Information

- 1.) Manual of Steel Construction 8th ed. AISC,
- 2.) Steel Structures Design and Behavior, Salmon and Johnson, 1971, International Textbooks Company.
- 3.) Ansys-BCS rev. 3 ST-360 Update 67L Swanson Analysis System, Inc
- 4.) "Detailed Specification for Cranes - Crystal River Plant - Unit No 3 Florida Power Corporation" # GA1-RO-2690, Gilbert Associates, Inc. 9-12-68
- 5.) "CMAA specification # 70" 1975 Revision.
- 6.) Crystal River - Unit No 3 - Florida Power Corp Vendor Drawings:
 - a) Whiting Corp U-62238
 - b) " " U-62279
 - c) " " U-63718

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. 14235.17 - 001-	FPC	REVISION	PAGE 6
--	-----	----------	-----------

45010 81

PREPARED BY/DATE R. J. S. / 7/25/83	REVIEWER/CHECKER/DATE B. TERSALA 7/25/83	INDEPENDENT REVIEWER/DATE K. M. W. / 7/29/83
SUBJECT/TITLE FHCR-5 Crane Gider Buckling Analysis		QA CATEGORY/CODE CLASS I/MSR.

RECORD OF CONFIRMATIONS

PAGE NO.	DESCRIPTION	REFERENCE	CONFIRMATION DATE
4.1 88	Max. trolley wheel loads		

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. FPC
14235,17-C01

REVISION

PAGE

7

45010 61

PREPARER/DATE R. D. Salko 7/25/83	REVIEWER/CHECKER/DATE STP 72583	INDEPENDENT REVIEWER/DATE Kulislocky 7/29/83
SUBJECT/TITLE FHCR-5 Crane Gider Buckling Analysis		QA CATEGORY/CODE CLASS I INSR

Computer Index

Charge No.
SDW
CDC
BLS SCWCHB

Status
G - Good Run
V - Void Run
Micro. fiche
Micro. film

Run No.	Job No.	Date	Status*	Prepared By	Checked By	Description
A		7/25/83	G	R. D. Salko	B. T. R. Salko	Ansys Prep 7, for Gider geometry, nodes & elements
B		7/25/83	G	R. D. Salko	P. T. R. Salko	Ansys static analysis of Crane Gider.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

14235.17 CO1 FPC

REVISION

PAGE

8

45010.61

PREPARER/DATE

R.D. Eakin 7/25/83

REVIEWER/CHECKER/DATE

STEVEN A. 7/29/83

INDEPENDENT REVIEWER/DATE

Stabilocky 7/29/83


SUBJECT/TITLE

FHCR-5 Crane Girder Buckling Analysis

QA CATEGORY/CODE CLASS

I/NSR


Computer Input



Type of Analysis - Linear Static (KAN=0)

Ansys Element Type - stiff3

Loading	Case	Nodes	Load	Confirmation
Case I		164	48 k	Rigid.
		364	48 "	
		122	39.5 "	
		322	39.5 "	
Case II		110	48	Rigid.
		310	48	
		62	39.5	
		262	39.5	



Typical cross section


CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O. W.O. / CALCULATION NO. FPC 14235.19-003	REVISION 0	PAGE 9
PREPARED / DATE R. S. Salku 7/25/03	REVIEWER / CHECKER / DATE K. R. ... 7/28/03	INDEPENDENT REVIEWER / DATE ... 7/29/03
SUBJECT / TITLE FHCR-5 Crane Girder Buckling Analysis		QA CATEGORY / CODE CLASS I / NSR

Computer Plot
of Crane Girder

x
y



EPLT ANSYS 1

DO PLOT COMMAND
1)

FPC AUX BLSG CRANE GIRDER

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. FPC

14235.17 - C03

REVISION

PAGE

10

DRER/DATE

R.S. Salter 7/25/83

REVIEWER/CHECKER/DATE

R. J. IV-12 7/25/83

INDEPENDENT REVIEWER/DATE

H. Shillock 7/29/83


QA CATEGORY/CODE CLASS

I/NSR

SUBJECT/TITLE

FHCR-5 Crane Buckling Buckling Analysis

x
y



Top & Bottom
Flanges.

EMPTY AREA

REPORT CONTAINS
13

FPC MAIL ROOM CRANE DIVISION


CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

4501061

J.O./W.O./CALCULATION NO. <i>FPC</i> <i>14235.17-C03</i>		REVISION	PAGE <i>11</i>
PREPARED/DATE <i>R.D. Baker 7/25/83</i>	REVIEWER/CHECKER/DATE <i>STANLEY 7/25/83</i>	INDEPENDENT REVIEWER/DATE <i>R. Wilcox 7/29/83</i>	
SUBJECT/TITLE <i>FHCR-5 Crane Girder Buckling Analysis</i>		QA CATEGORY/CODE CLASS <i>I/NSR</i>	

y
x



*Transverse
Stiffeners*

EPLT ANSYS 1

FPC MAX BLDG CRANE GIRDER


EPLT ANSYS
11

CALCULATION SHEET


STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. 14235.17 - C03	FPC	REVISION	PAGE 12
PREPARER/DATE R.J. Zalka 7/25/83	REVIEWER/CHECKER/DATE PETER NA 7/25/83	INDEPENDENT REVIEWER/DATE Bullock 7/29/83	
SUBJECT/TITLE FHCR-7 Crane Gider Buckling Analysis		QA CATEGORY/CODE CLASS I/NSR	

45010 61



Computer Plot of
Web (side A)
Section 1 of 3



EXPLOT COMMANDS-
1)


Panel
Section
Types

ANSYS

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. 14235.17-C03	REVISION	PAGE 13
PREPARED BY/DATE R.D. Salko 7/25/83	REVIEWER/CHECKER/DATE R. T. ... 7/25/83	INDEPENDENT REVIEWER/DATE ... 7/29/83
SUBJECT/TITLE FHCR-7 Crane Girder Buckling Analysis		QA CATEGORY/CODE CLASS I/NSR



Computer Plot of
Web - Side A
Section 2 of 3

258	254	252	258	271	288	288	298	304	316	322	328
133	148	164	179	195	212	228	246	263	280	296	311
251	257	263	269	275	281	287	293	299	311	317	323
136	150	167	181	198	216	233	248	266	283	297	314
252	258	264	270	276	282	288	294	299	312	318	324
139	153	170	184	201	218	235	252	269	286	300	317
253	259	265	271	277	283	289	295	301	313	319	325
141	155	172	186	203	220	237	254	271	288	302	319
254	260	266	272	278	284	290	296	302	314	320	326
148	156	173	187	204	221	238	255	272	289	303	319
255	261	267	273	279	285	291	297	303	315	321	327

4 @ 21" 16" 16" 16" 16" 18" 4 @ 21" 5 6 7 6 5

EMPLY ANSYS 8


EXPLOT COMMAND
1)

ANSYS

CALCULATION SHEET

J.O./W.O./CALCULATION NO. 14235.17-C03	FPC	REVISION	PAGE 14
PREPARED/DATE R J Salko 7/25/83	REVIEWER/CHECKER/DATE K. P. ... 7/28/83	INDEPENDENT REVIEWER/DATE M. ... 7/29/83	
SUBJECT/TITLE FHCR-5 Crane Girder Buckling Analysis		QA CATEGORY/CODE CLASS I/NSR	

Computer Plot of
Web Side A
Section 3 of 3



Panel
Section
Types.

EPLT ANSYS 3


EXPLOT COMMANDS-
1)

ANSYS


CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. 141235.17-C03	REVISION EPL	PAGE 15
PREPARED/DATE R. J. Balkin 7/25/83	REVIEWED/CHECKER/DATE K. J. K. 7/25/83	INDEPENDENT REVIEWER/DATE K. J. K. 7/29/83
PROJECT/TITLE FHCR-5 Crane Girder Buckling Analysis		QA CATEGORY/CODE CLASS I/NSR



Computer Plot
of Web Side B
Section 1 of 3



EXPLOT COMMAND-
1)

EPLT ANSYS 4


ANSYS

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. FPC 14235.17-203	REVISION	PAGE 16
---	----------	------------

PREPARER/DATE R. J. Faulkner 7/25/83	REVIEWER/CHECKER/DATE B. J. ... 7/25/83	INDEPENDENT REVIEWER/DATE ... 7/29/83
SUBJECT/TITLE FHCR-5 Crane Girder Buckling Analysis		QA CATEGORY/CODE CLASS I/NSR



Computer Plot
of Web side B
Section 2 of 3

126	143	159	174	189	205	221	236	249	261	273	284	291	306	322	338
127	144	160	175	190	206	222	237	249	259	275	288	298	307	323	339
131	147	163	178	193	211	226	240	248	261	279	289	294	310	325	339
134	149	165	180	197	212	228	241	248	261	282	288	296	313	327	339
137	151	168	182	200	215	231	243	254	265	285	290	299	316	329	339

EPLY ANSYS 5

2) XPLUT CONTINU-

ANSYS

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. <i>FPC</i> <i>14235.17-003</i>		REVISION	PAGE <i>17</i>
PREPARED/DATE <i>R.D. Walker 7/25/83</i>	REVIEWER/CHECKER/DATE <i>R.D. Walker 7/25/83</i>	INDEPENDENT REVIEWER/DATE <i>R. Kelly 7/29/83</i>	
PROJECT/TITLE <i>FHR-5 Crane Girder Buckling Analysis</i>		QA CATEGORY/CODE CLASS <i>I/NSR</i>	



Computer Plot of
Web Side B
Section 3 of 3

1.28	1.34	1.48	1.48	1.52	1.58	1.64	1.68	1.72	1.77
337	364	371	388	404	423	437	446	453	460
1.28	1.35	1.41	1.47	1.53	1.59	1.65	1.70	1.75	1.78
338	365	376	386	402	420	426	443	449	460
1.28	1.38	1.48	1.48	1.54	1.62	1.68	1.71	1.76	1.78
341	368	373	385	401	418	432	438	446	458
1.31	1.37	1.43	1.48	1.55	1.61	1.67	1.72	1.77	1.83
344	369	375	382	400	415	431	438	446	458
1.32	1.38	1.44	1.50	1.58	1.63	1.68	1.73	1.78	1.83
347	384	378	386	408	418	431	438	446	458

EXPLOT COMMAND-
1)

EXPLT ANSYS 6

EXP7

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. **FR**
14235.17 - C03

REVISION

PAGE

18

45010 61

PREPARED/DATE
R. S. Baker 7/25/83

REVIEWER/CHECKER/DATE
B. STEPSAKA 7/28/83

INDEPENDENT REVIEWER/DATE
J. Buckley 7/29/83

SUBJECT/TITLE
FHCR-5 Crane Girder Buckling Analysis

QA CATEGORY/CODE CLASS
I/MSR

Element Stress Requirements for Crane Girder

Required distance between flanges to web thickness ratio $\frac{h}{t}$ (no stiffeners)
(For Vertical Buckling)

no stiffeners $\frac{h}{t} = \frac{14000}{\sqrt{F_y(F_y + 16.5)}} = \frac{14000}{\sqrt{36(36 + 16.5)}} = 322$

with stiffeners (max spacing, $a = 1/2 \times h$)

$$\frac{h}{t} = \frac{2000}{\sqrt{36}} = 333$$

check depth-to-thickness ratio of the webs

$$d \leq 260t = 260 \left(\frac{5}{16}\right) = 81.25''$$

$$a/h \leq \left[\frac{260}{(h/t)}\right]^2 = 1.17 \quad \text{for } h = 75''$$

Shear

$$F_v = \frac{F_y}{2.89} (C_v) \leq 0.4 F_y \quad (\text{eq. 1})$$

for

$$C_v = \frac{45,000 k}{F_y (h/t)^2} \quad \text{when } C_v < 0.8 \quad \text{or} \quad C_v = \frac{190 \sqrt{k}}{h/t \sqrt{F_y}} \quad \text{for } C_v > 0.8$$

$$k = 4.00 + \frac{5.34}{(a/h)^2} \quad \text{for } a/h < 1.0 \quad \text{or} \quad k = 5.34 + \frac{4.00}{(a/h)^2} \quad \text{for } a/h > 1.0$$

Reference

AISC
sec 1.10.2
&
Salmon &
Johnson
page 567

AISC
Commentary
page 5-131
&
sec 1.10.5.3

AISC
1.10.5.2

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. FPC
14235.17-003

REVISION

PAGE

45010.61

PREPARER/DATE R.D. Eaker 7/25/83	REVIEWER/CHECKER/DATE P. TORSALE 7/25/83	INDEPENDENT REVIEWER/DATE R. Stucky 7/29/83
SUBJECT/TITLE FHCR-5 Crane Girder Buckling Analysis		QA CATEGORY/ CODE CLASS I / NSR

Shear (cont.)

Critical Shear

$$\tau_{cr} = \frac{\pi^2 E K}{12(1-\mu^2)(h/t)^2}$$

Reference

Salmon & Johnson
Pg 539

Bending in Plane of Web.

$$F_{CR} = \frac{954 (10^3)}{(h/t)^2}$$

Salmon & Johnson
page 541

$$F_b = .6 F_{CR}$$

Factor of safety = 1.67

AISC
sec
1.5.14.4

Combined Bending & Shear

$$\left[\frac{f_b}{F_{CR} \text{ (pure bending)}} \right]^2 + \left[\frac{v}{\tau_{CR} \text{ (pure shear)}} \right]^2 < 1$$

Salmon & Johnson.
page 542

use only when $\tau_{actual} > .4 \tau_{CRITICAL}$

Transverse Compression.

$$F_{CR} = k_c \frac{\pi^2 E}{12(1-\mu^2)(h/t)^2}$$

Salmon & Johnson
page 543

where $k_c = \left[\frac{4}{(a/h)^2} + 5.5 \right]$

page 545

$$F_4 = \frac{F_{CR}}{1.67}$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. 14235.17-C03	FPC	REVISION	PAGE 20
---	-----	----------	------------

A5010 61

PREPARED/DATE R. S. Salkin 7/25/83	REVIEWER/CHECKER/DATE PETER SAGA 7/25/83	INDEPENDENT REVIEWER/DATE M. S. Salkin 7/29/83
SUBJECT/TITLE FHCR5 Crane Girder Buckling Analysis		QA CATEGORY/CODE CLASS I/NSR

Check Top & Bottom Flanges

Lateral Torsional Buckling.

- Lateral torsional buckling need not be investigated for a box section whose depth is less than 6 times its width.

$$d = 77 \quad w = 14$$


$$6(14) = 84 > 77 \quad \text{OK}$$

Reference.

AISC 8th
Sec

1.5.1.44

Bending Properties of Girder




$$A = 2(14) + 2\left(\frac{5}{16}\right)75 = 75. \text{ in}^2$$

$$I_o = 2\left[\frac{5/16(75)^3}{12}\right] + 2\left[\frac{(75)^2}{2}1(14)\right]$$

$$I_o = 21972 + 39375 = 61350$$

Load Case 2



Moment (k-in) 18356 18814

$$f_{b2} = \frac{Mc}{I} = \frac{18814(75)}{61350(2)} = 11.22 \text{ ksi}$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. 14235.17-C03	FPC	REVISION	PAGE 21
---	-----	----------	------------

A5010 51

PREPARED/DATE R. J. Salkin 7/25/83	REVIEWER/CHECKER/DATE PETERSON 7/25/83	INDEPENDENT REVIEWER/DATE M. S. Salkin 7/29/83
SUBJECT/TITLE FHCR-5 Crane Girder Buckling Analysis		QA CATEGORY/CODE CLASS I/NSR

Flange Compression Buckling & Allowable Bending Stress

$$b/t \leq \frac{190}{\sqrt{F_y}} = 31.6 > \frac{10}{1''}$$

$$f_a = \text{negligible} \quad d/t = 75/5/6 = 240 > \frac{640}{\sqrt{F_y}} = 106$$

$$b/t = \frac{238}{\sqrt{36}} = 39.6 > 10''$$

$$\therefore F_b = 0.6 F_y = 21.6 \text{ ksi}$$

Check Web Crippling. (worst case is panel section 4)

Actual Applied:

$$F_{web} = \frac{48 \text{ k}}{5/6(23)} = 6.6 \text{ ksi}$$

23" = maximum panel span for web crippling

Allowable Web Crippling stress.

$$F_{allow} = \left[5.5 + \frac{4}{(23/56)^2} \right] \frac{10,000}{(179)^2} = 9.11 > 6.6 \text{ ksi}$$

Reference.

AISC 8th
sect. 1.9.2.2
subparagraph 3
"
subparagraph 4

AISC 8th
sec 1.5.1.4.4
sec 1.9

AEC
1.10.10.2

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

14235.17-003

FPC

REVISION

PAGE

22

A5010 81

PREPARED/DATE

R. D. Salkin 7/25/83

REVIEWER/CHECKER/DATE

B. TERSAGI 7/25/83

INDEPENDENT REVIEWER/DATE

7/29/83

SUBJECT/TITLE


FHCR-5 Crane Guide Buckling Analysis

QA CATEGORY/CODE CLASS

I/NSR

Summary of Allowable Stresses for Web

Constants: $t = 5/16"$
 $E = 29000 \text{ ksi}$
 $F_y = 36 \text{ ksi}$
 $\mu = 0.3$



Section Type	h	a	a/h	h/t	Shear				Bending $F_b \text{ ksi}$	Transverse Compression	
					k	C_v	F_v	ϕ_{qCR}		k_c	F_A
1	30	9	0.3	96	63.3	2.62	14.4	N.R.	21.6	49.9	21.6
2	30	18	0.6	96	18.8	1.43	14.4	N.R.	21.6	16.6	21.6
3	56	18	0.32	179	56.1	1.32	14.4	N.R.	21.6	44.5	21.6
4	56	23	.411	179	35.6	1.05	13.1	N.R.	21.6	29.2	21.6
5	75	43	.57	240	20.2	.443	5.51	9.2	9.94	17.7	8.05
6	75	18	0.24	240	96.7	1.30	14.4	N.R.	9.94	75.0	21.6
7	75	16	0.21	240	125.1	1.45	14.4	N.R.	9.94	96.2	21.6

N.R. not required

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

▲501061

J.O./W.O./CALCULATION NO.

FPC

REVISION

PAGE

14235.17 C03

23

PREPARED/DATE

R. S. Zalkin 7/25/83

REVIEWER/CHECKER/DATE

R. S. Zalkin 7/25/83

INDEPENDENT REVIEWER/DATE

Rublocky 7/29/83

SUBJECT/TITLE

FHCR-5 Crane Guider Buckling Analysis

QA CATEGORY/CODE CLASS


I/NSR

Summary of Results.

The abbreviated list below represent the worst case sections of elements for the particular load case.

(UNITS: KSI)

Load Case 1



Section	Element #	S _x	S _y	Shear $\frac{\tau_{xy}}{2}$
1	449	0.55	-0.4	2.6
	453	-0.71	0	1.8
	454	0.18	0.32	2.6
	456	0.48	0	1.8
2	443	-9.6	1.08	-0.49
	445	-1.9	-1.0	-2.0
	447	-1.0	1.3	0.19
	448	-8.3	0.83	0.29
3	431	1.0	0.83	-1.6
	433	4.8	1.1	-3.8
	435	-8.1	-1.7	-6.1
	437	-4.0	0	-4.1
	440	-3.8	0.33	-3.2
	441	-7.4	-1.4	-4.8
	442	3.2	0.7	2.7
432	0.7	0.62	-1.1	
4	425	-3.2	-1.6	0
	426	-1.2	-0.67	-0.68
	427	-1.77	0.56	-0.87
	428	0.32	1.6	-1.3
	423	-3.2	-2.0	-0.29
	420	-1.0	-0.7	-0.8
	418	-0.6	0.8	-1.11
415	0.7	2.0	-1.8	

By Inspection the stress in section 5, 6, & 7 are minor

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. FPC
14235.17-003

REVISION

PAGE

24

AS010.61

PREPARED / DATE
R. D. Salko 7/25/83

REVIEWER / CHECKER / DATE
R. T. PERMA 7/25/83

INDEPENDENT REVIEWER / DATE
R. J. SLOTT 7/29/83

SUBJECT / TITLE
FHCR-5 Crane Gider Buckling Analysis

QA CATEGORY / CODE CLASS
I/NSR

Load Case 2

(Units: ksc)

Section	Element #	S _x	S _y	S _{xy}
1	453 (456)	-0.18	0.24	4.9
	449 (454)	-2.77	-0.47	7.7
	7 (12)	-0.18	0.23	4.9
	8 (14)	2.78	-0.47	7.7
2	477 (445)	-1.85	3.4	1.8
	448 (443)	-12.7	-2.7	6.2
	21 (15)	-1.87	3.4	1.8
	22 (16)	-12.7	-2.7	6.2
3	440 (437)	-1.4	2.7	-5.1
	441 (435)	-9.9	-4.8	-5.9
	442 (433)	3.18	-1.9	-1.9
	432 (431)	0.8	1.1	-1.4
	27 (23)	-1.4	2.7	-0.55
	28 (24)	-10.0	-4.8	-5.9
	29 (26)	3.2	-1.9	-2.0
43 (38)	0.8	1.1	-1.4	
4	425 (423)	-0.30	-0.68	-3.5
	426 (420)	0.73	-2.6	-3.0
	427 (418)	0.17	-1.1	-1.5
	428 (415)	0.83	1.5	-1.7
	37 (30)	-0.30	-0.73	3.5
	41 (31)	0.75	-2.6	3.0
	42 (35)	0.19	-1.1	1.6
44 (40)	0.87	1.6	1.7	
5	273 (280)	-3.57	-9.6	1.6
	285 (289)	0.6	9.2	-0.4
	291 (295)	-3.62	-9.1	-2.84
	299 (303)	0.53	8.7	-0.85
	306 (311)	-0.41	-7.8	-1.3
	316 (320)	0.52	7.8	-1.4
	359 (354)	-0.39	-4.7	-1.3
	368 (364)	0.37	4.7	-1.5
358 (365)	0	0	2.2	

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

FAC

REVISION

PAGE

14235.17-C03

25

A5010.81

PREPARED/DATE

R. D. Walker 7/25/83

REVIEWER/CHECKER/DATE

~~STETZ~~ 7/25/83

INDEPENDENT REVIEWER/DATE

~~Walker~~ 7/29/83

SUBJECT/TITLE

FHCR-5 Crane Gider Buckling Analysis

QA CATEGORY/CODE CLASS

I/NSR

Load Case 2 (cont)

Section	Element #	S_x ⁱⁿ	S_y ⁱⁿ	Z_{xy} ⁱⁿ
5	174 (179)	-0.5	-8.7	.29
	182 (187)	0.66	8.8	.24
	159 (164)	-3.0	-8.8	-.93
	168 (173)	0.52	8.5	.46
	143 (148)	-2.9	-8.2	2.5
	151 (156)	0.48	7.9	1.16
	126 (133)	-0.35	-6.9	1.33
	137 (142)	0.5	6.9	1.4
	95 (116)	-0.4	-4.8	1.4
103 (125)	0.4	4.8	1.6	
6	257	-0.6	-9.23	0
	268	0.7	9.3	0.10
	189	-.78	-8.8	0.22
	200	0.77	8.9	0.11
	337	-.46	-5.7	-1.3
	347	-.47	5.7	-1.5
	109	-.50	-5.8	1.3
	120	.47	5.9	1.55
7	224	-.84	-9.0	.10
	233	0.9	9.1	.20
	240	-0.86	-9.0	.343
	250	0.86	9.2	.22
	205	-0.82	-8.9	.16
	217	-0.87	9.0	.15

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A5010 81

J.O./W.O./CALCULATION NO. 14235.17-C03	REVISION FRC	PAGE 26
PREPARED/DATE R.D. Sauter 7/25/83	REVIEWER/CHECKER/DATE K. Reiberg 7-29-83	INDEPENDENT REVIEWER/DATE M. Slattery 7/29/83
SUBJECT/TITLE FHCR-5 Crane Gider Buckling Analysis		QA CATEGORY/CODE CLASS I/NSR

Addition Stress Due to Dead Weight of Gider.

Density of Steel = $.2833 \times 10^{-3} \text{ k/in}^3$


X-sec Area: 75 in^2

Approx number of stiffeners = 30 - say all are $75 \times 10 \times 3/8$

wt of stiffeners = $30(75 \cdot 10 \cdot 3/8) \cdot .2833 \times 10^{-3} = 2.39 \text{ k}$

equivalent wt/ft for stiffeners = $\frac{2.39}{46'} = .052 \text{ k/ft}$

Total uniform dead load wt = $75(12)(.2833 \times 10^{-3}) + .052 = .307 \text{ k/ft}$



$M_{max} = 81.2 \text{ k-ft} = 974 \text{ k-in.}$


$V_{max} = 7.06 \text{ k}$

% of Max Moment = $\frac{974 \text{ k-in.}}{18814 \text{ k-in.}} = .05$ or 5%

(see page 20)

Maximum Compressive Stress on Web Due to Weak Axis.


For lateral loads on a Class A crane use 2 1/2% of Applied Concentrated loads (CMAA # 70)



$I = 2 \left[\frac{1(14)^3}{12} \right] + \frac{75(10.875^2 - 10.25^2)}{12} = 1765$

$M_{max} = 470 \text{ k-in.}$

$S_{yy} = \frac{470(10.875)}{1765(2)} = 1.42 \text{ ksi}$



CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

▲5010 61

J.O./W.O./CALCULATION NO. FPC

REVISION

PAGE

14235.17-003

27

PREPARED/DATE

R. D. Baiker 7/25/83

REVIEWER/CHECKER/DATE

K. Schubert 7-29-83

INDEPENDENT REVIEWER/DATE

M. S. S. 7/29/83

SUBJECT/TITLE

FHCR-5 Crane Gider Buckling Analysis

QA CATEGORY / CODE CLASS

I/NSR

Evaluation of Elements Stresses

(included a 5% increase for dead wt to all element stress plus and addition 1.42 ksi for weak axis compression in the web.)

Load Case 1

By inspection all of the element stresses for this load case are well below the allowable values for each of the sections.

Load Case 2 - By inspection accept all stresses but the following:

Section 5 elements

$$F_b = 9.94 \text{ ksi} \quad F_v = 5.51 \text{ ksi}$$

$$\text{Combined shear & Bend} \quad \left[\frac{F_b}{F_{CR}} \right]^2 + \left[\frac{F_v}{\tau_{CR}} \right]^2 \leq 1$$

$$\tau_{CR} = 9.2 \text{ ksi}$$

$$F_{CR} = \frac{954(10)^3}{(240)^2} = 16.56 \text{ ksi}$$

Element 273(280)

$$S_y = 1.42 + 1.05(9.6) = 11.5 \text{ ksi}$$

$$\tau_{\text{factor}} = 1.05(1.6) = 1.68 \text{ ksi}$$

$$\frac{F_{CR}}{16.56} > \frac{F_b}{11.5} > \frac{F_b}{9.94} \text{ ksi}$$

$$\text{margin of safety} = 1.44 \quad \underline{\text{Accept}}$$

Element 291(295)

$$S_y = 1.42 + 1.05(9.1) = 11.0$$

$$\tau_{vy} = 1.05(2.84) = 3.0 \text{ ksi}$$

$$\text{Check Bending.} \quad \frac{F_{CR}}{16.56} > \frac{F_b}{11.00} > \frac{F_b}{9.94} \text{ ksi}$$

$$\text{margin of Safety} = 1.5 \quad \underline{\text{accept}}$$

check combined is not required $.4(9.2) = 3.68 > 3.12 \text{ ksi}$

Conclusions.

The results of the computer analysis show that the webs of the girders are adequate against buckling without the longitudinal stiffeners. Although the comparison of element stress with allowable stresses show that the second load case has a small margin of acceptance (14% minimum) but these critical elements and stresses are highly localized and close to the flanges. The allowable stresses represent overall average cross-sectional stresses and don't take into consideration that the stresses will vary across the section. The first load case shows some high shear stresses at the supports but these are well below the allowable.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A501051

J.O./W.O./CALCULATION NO.

14235.17-003

FPC

REVISION

PAGE

PREPARED/DATE

R. D. Salkin 7/25/83

REVIEWER/CHECKER/DATE

R. Schubert 7-29-83

INDEPENDENT REVIEWER/DATE

R. Willock 7/29/83

SUBJECT/TITLE

FHCR-5 Crane Guide Buckling Analysis

QA CATEGORY/CODE CLASS

I/NSR

List of Attachments

- 1.) Check calculation for Independent Reviewer Load case 3

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

REVISION

PAGE

14235.17-C03

45010 51

PREPARED / DATE

Kuzilofsky 7/29/83

REVIEWER / CHECKER / DATE

INDEPENDENT REVIEWER / DATE

SUBJECT / TITLE

Alternate check for R salter calc "position of LOAD"


QA CATEGORY / CODE CLASS

ATTACHMENT I
CALC. NO. C01
JO 14235.17
PAGE 1 OF 4






Load Case 3

Comparison of Load Case 2 & 3

Case 3



Case 2



A comparison of the above two load cases shows that a section between the point loads of load case two (load location for maximum load on the girder.) and the support can have a higher combination of shear and compressive stress than provided by load case two.

In order to locate the worst section for combined moment and shear

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION


▲5010 61

PREPARED / DATE <i>Kukilochy</i>		J.O./W.O./CALCULATION NO. <i>14235.17-C03</i>	REVISION	PAGE
REVIEWER / CHECKER / DATE		INDEPENDENT REVIEWER / DATE		
SUBJECT / TITLE <i>Alternate check of SALTER calc "POSITION OF LOAD"</i>			QA CATEGORY / CODE CLASS	

a strudl computer run was done (computer run C) which provides a set of influence lines using 5-ft sections along the girder.

Strudl Model

ATTACHMENT 1
CALC. NO. C03
JO 14235.17
PAGE 2 OF 4



The 48k and 39.5k loads are rolled across the girder and the force on each of the members is calculated for each of the load locations.

Loading Steps

#	48k @ Joint	39.5k @ JOINT
2	1	3
3	2	4
4	3	5
5	4	6
6	5	7
7	6	8
8	7	9

10- Dead load of Girder.

Results of Strudl Influence lines.

A comparison of the Influence lines with the shear and moment diagram on page 1 of the attachment shows that member 2 under load step 3 could produce a higher combination of shear and moment

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A5010 61

J.O./W.O./CALCULATION NO. 14235.17-C03		REVISION	PAGE
PREPARED / DATE <i>K. J. Locky</i>	REVIEWER / CHECKER / DATE	INDEPENDENT REVIEWER / DATE	
SUBJECT / TITLE Accelerate check of SACRES coil "POSTION of LOAD"			QA CATEGORY / CODE CLASS

ATTACHMENT 1
CALC. NO. C03
JO 14235.17
PAGE 3 OF 4

on this section than was considered in the first two original load cases. This load case is more accurately shown on page 1 of this attachment and shall be considered therein as load case 3.

Due to the similarity of load step 5 & 6 of the strudl model with that of load case 2 the member forces and moments were neglected.

Elements Stresses for load Case 3

In order to check the elements stress for this section the stresses provided in the Ansys Run load case 2 will be proportion up by the differences between the calculated values shown of page 1 of this attachment.

$$\% \text{ increase for Moment} = \frac{6936 - 5186}{5186} \times 100 = 34\%$$

$$\% \text{ increase for shear} = \frac{57.8 - 43.22}{43.22} = 34\%$$

Therefore increase all shear and normal stresses by 34% in the element between 5 & 15 feet from the support.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A5010.61

J.O./W.O./CALCULATION NO.

14235.17 - C03

REVISION

PAGE

PREPARER/DATE

Kwislocky 7/29/83

REVIEWER/CHECKER/DATE

INDEPENDENT REVIEWER/DATE

SUBJECT/TITLE

QA CATEGORY/CODE CLASS

ATTACHMENT 1
CALC. NO. C03
JO 14235.17
PAGE 4 OF 4

The elements in consideration are list below:

Load Case 2

Load Case 3

Section	Elements	Sx	Sy	τ_{xy}	Sx'	Sy	τ_{xy}
5	326 (322)	-5.24	-6.66	-1.27	0.7	-8.9	-1.7
	328 (323)	0	-3.17	-2.11	0	-4.24	-2.83
	331 (325)	0	-1.30	-2.28	0	-4.02	-3.05
	333 (327)	0	3.18	-2.11	0	4.26	-2.83
	334 (330)	.524	6.77	-1.49	0.70	9.07	-2.00
6	342 (337)	-1.46	-5.7	-1.35	-0.616	-7.6	-1.8
	345 (338)	-.21	-2.9	-1.9	-.28	-3.9	-2.5
	348 (341)	0	-.15	-2.2	0	-2.01	-2.9
	350 (344)	0.2	2.7	-2.1	0.27	3.6	-2.8
	351 (347)	0.47	5.7	-1.5	0.63	7.6	-10.2
5	359 (354)	-.39	-4.7	-1.3	.52	6.3	1.7
	362 (355)	-.13	-2.3	-1.9	.17	3.1	2.5
	365 (358)	-0.0	0.0	-2.17	0	0	2.9
	367 (360)	0.0	2.3	-2.1	0	3.1	2.8
	368 (364)	.37	4.7	-1.55	.50	6.3	2.08
	374 (371)	-.28	-3.7	-1.26	.37	5.0	1.69
	379 (373)	-.124	.186	-2.22	.17	0.25	2.97
	382 (378)	.244	3.56	-1.6	.33	4.77	2.14
	390 (388)	-.15	-2.7	-1.4	.20	3.6	1.9
	396 (385)	0.22	.48	-1.81	.30	0.64	2.42
	399 (395)	-.72	2.4	-1.9	1.0	3.2	2.5
	406 (404)	0.29	-1.7	-2.0	0.4	2.3	2.68
	410 (401)	1.1	-.20	-1.6	1.5	0.27	2.1
413 (408)	1.0	2.2	2.22	1.34	3.0	2.97	

Conclusion.

The stress produced in the above element are not as critical as those shown in Load case 2 for similar section parts.

ENCLOSURE 2

EVALUATION OF THE INTAKE GANTRY
CRANE TO CMAA-70 AND ANSI B30.2.0

EVALUATION OF THE INTAKE GANTRY CRANE
TO CMAA-70 AND ANSI B30.2.0

CRYSTAL RIVER - UNIT NO. 3
FLORIDA POWER CORPORATION

REVISION 0, June 28, 1983

STONE & WEBSTER ENGINEERING CORPORATION

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.00 Introduction.....	3
2.00 CMAA vs EOCI and the Crystal River Crane.....	4
2.01 General.....	4
2.02 Paragraph Listing of Major Differences in Industry Specifications.....	4
2.03 Comparison of Differences & Extent of Crane Compliance.....	5
3.00 ANSI B30.2.0 vs USAS B30.2.0 and the Crystal River Crane.....	12
3.01 General.....	12
3.02 Paragraph Listing of Major Differences in Safety Standards.....	12
3.03 Comparison of Differences & Extent of Crane Compliance.....	13
4.00 Conclusions.....	16
5.00 Recommendations.....	17
6.00 References.....	18

1.00 INTRODUCTION

The Crystal River Unit No. 3 Intake Gantry Crane was designed in 1970 and built in 1971. The NRC's letter of December 22, 1980, Enclosure 3, Paragraph 2.1-3.e requires verification that the crane design complies with the guidelines of CMAA Specification 70, (dated 1975) and Chapter 2-1 of ANSI B30.2.0-1976. Both of these documents were published after the design for the Intake Gantry Crane was established.

The manufacturer's industry specification to which this crane was designed to is EOCI #61, dated 1961. The national safety standard to which the crane was designed to is USAS B30.2.0 dated 1967.

Section 2.00 of this report compares CMAA-70 with EOCI-61, and specifies the extent of compliance of the Crystal River Intake Gantry Crane with CMAA-70. Section 3.00 of this report compares Chapter 2-1 of ANSI B30.2.0 with Chapter 2-1 of USAS B30.2.0, and specifies the extent of compliance of the Crystal River Intake Gantry Crane with ANSI B30.2.0.

Section 4.00 of this report summarizes the findings of the Intake Gantry Crane comparison to CMAA-70 and ANSI B30.2.0. Section 5.00 provides Stone & Webster's recommendations with regard to these findings.

2.00 CMAA vs EOCI AND THE CRYSTAL RIVER CRANE

2.01 General

The CMAA No. 70 specification is basically a rewrite of the EOCI #61 Specification. Much of the criteria is therefore the same or very similar, with some areas becoming less stringent. Additionally, the CMAA specification addresses areas of crane design that are considered standard in the industry but were not addressed in the original EOCI document.

In addition to the EOCI document, the Intake Gantry Crane was designed to the criteria of the Whiting Crane Company a member of the CMAA organization, and to the technical requirements of the procurement specification, No. RO-2872. With the addition of these requirements, the design of the Intake Gantry Crane in many cases surpasses the requirements of CMAA-70.

Areas of major difference between the CMAA and EOCI documents are listed under paragraph 2.02, with a description of these differences and the extent of Intake Gantry Crane compliance to CMAA being covered under paragraph 2.03.

2.02 Paragraph Listing of Major Differences in Industry Specifications.

<u>Topic</u>	<u>CMAA Paragraph No.</u>	<u>EOCI Paragraph No.</u>
a. Material Requirements	3.1	16.A
b. Welding	3.2	17.A
c. Impact Allowance	3.3.2.1.1.3	18.B.1.a(3)
d. Lateral Forces	3.3.2.1.2	18.B.1.b
e. Torsional Forces	3.3.2.1.3.2&3	18.B.1.c(2)&(3)
f. Bending Stress	3.3.2.2	18.B.2
g. Longitudinal Stiffeners	3.3.3.1.1	18.C.1.a
h. Allowable Compressive Stress	3.3.3.1.3	18.c.1.b
i. Fatigue Considerations	3.3.3.1.3	(not covered)
j. Hoist Rope Requirements	4.2.1	24.A
k. Drum Design	4.4.1	26.A
l. Drum Groove Design	4.4.3.1&2	(not covered)
m. Gear Design	4.5.2	27.
n. Bridge Brake Design	4.7.2.2	31.A.1.b
o. Hoist Brake Design	4.7.4.2	31.B.1
p. Bumpers	4.12	(not covered)
q. Static Control Systems	5.4.6	(not covered)
r. Undervoltage/Restart Protection	5.6.2&3	38.A

2.03 Comparison of Differences & Extent of Crane Compliance.

a. Material Requirements

CMAA-70 specifies ASTM-A36 as the basic structural steel. EOCI-61 specifies ASTM-A7 as the basic structural steel.

The Intake Gantry Crane complies with CMAA-70 in that ASTM-A36 steel was used.

b. Welding

CMAA-70 specifies welding to be in accordance with AWS D14.1. EOCI-61 specifies welding to be in accordance with AWS recommendations.

The Intake Gantry Crane complies with CMAA-70 in that welding was in accordance with the Whiting crane company procedures which in turn meet the requirements of AWS D14.1.

c. Impact Allowance

CMAA-70, requires that crane design calculations include an impact allowance of 0.5% of the load per foot per minute of hoisting speed but not less than 15%. EOCI-61 specifies only a minimum allowance of 15%. Therefore, for cranes with hoist speeds in excess of 30 feet per minute, it is possible that the impact allowance applied under EOCI-61 will be less than that required by CMAA-70.

The Intake Gantry Crane complies with CMAA-70 in that the maximum hoist speed is 13 fpm, resulting in an impact loading condition of 15%.

d. Lateral Forces

CMAA-70 specifies the lateral load due to acceleration or deceleration to be 2½% the live load and crane bridge (exclusive of end trucks and ties) for Class A cranes and 5% for Class B, C and D cranes. Additionally, CMAA-70 specifies the lateral load, due to wind, to be 5 pounds per square foot of projected bridge girder area, multiplied by 1.6 when the distance between exposed girder surfaces is greater than the

depth of the girder.

EOCI-61 specifies the lateral load due to acceleration or deceleration to be 5% of the above loads, with the lateral load, due to wind, being 10 pounds per square foot of projected girder area.

The Intake Gantry Crane complies with CMAA-70 in that the requirements of EOCI are more conservative than CMAA. Additionally, this crane was designed for a lateral wind loading of 30 pounds per square foot in the non-operating condition.

e. Torsional Forces

CMAA-70 specifies that the following forces causing twisting moments; overhanging loads and lateral forces acting eccentric to the horizontal neutral axis, be multiplied by the distance from the force to the shear center of the girder section. EOCI-61 requires that these forces be multiplied by the distance from the force to the center of gravity of the girder.

The Intake Gantry Crane complies with CMAA-70 in that there are no substantial over hanging loads, and in that the box girders are symmetrical about the neutral axis. Note, that the loads imposed by the 7,700 lb bridge walkway are distributed over the cranes 105 ft. girder length resulting in a negligible twisting moment.

f. Bending Stress

CMAA-70 requires that the combined bending stress include a wind load of 5 pounds per square foot for outdoor cranes. EOCI-61 does not address the addition of this wind load for outdoor cranes.

The Intake Gantry Crane complies with CMAA-70 in that the girder structural calculations include a wind force of 10 pounds per square foot in the operating mode and a wind force of 30 pounds per square foot in the non-operating mode.

g. Longitudinal Stiffeners

CMAA-70 gives criteria for the h/t web plate ratio based upon the number of longitudinal stiffeners used in the compression area of the web plate, either none, one or two.

EOCI-61 gives a slightly different criteria for the h/t web plate ratio, but only for the case where longitudinal stiffeners are not used in the compression area of the web plates.

The Intake Gantry Crane has been supplied with one longitudinal stiffener, as indicated below, complying with the requirements of CMAA-70.

h(depth of web) = 71" t(thickness of web)= 5/16"

Per CMAA-70:

The h/t ratio of the web plate, when provided with transverse stiffeners or diaphragms is limited by the use of longitudinal stiffeners, as follows:

The h/t ratio of the web shall not exceed:

$$\frac{h}{t} = C(k + 1) \sqrt{\frac{17.6}{f_c}} \quad \text{nor shall it exceed } M$$

Where: The coefficients C and M are as tabulated below:

Longitudinal stiffeners	C	M		
None	81	188*		
One	162	376		
Two	243	564		
<u>h/t</u>	<u>C(k + 1)√17.6/fc</u>	<u>M</u>	<u>No. of Stf. by CMAA-70</u>	<u>No. Stf. Provided</u>
227	324	376	1	1

Note that the most conservative approach has been used for a symmetrical girder, which is the case where the maximum stresses are assumed to equal the basic allowable stresses. Using this approach the CMAA-70 $c(k + 1) \sqrt{17.6/f_c}$ equation governing the longitudinal web plate stiffeners reduces to 2C, which is the smallest possible value for this equation.

h. Allowable Compressive Stress

CMAA-70 requires a reduction in the maximum allowable compressive stress (17,600 psi for A36 steel) if the b/c ratio of the girder exceeds 38.

EOCI-61 requires a similar reduction in the maximum allowable compressive stress (16,000 psi for A7 steel) however, this reduction is required only if the b/c ration exceeds 41.

The Intake Gantry Crane complies with CMAA-70 in that A36 steel was used with a maximum allowable compressive stress of 17,600, and in that b(distance between web plates) = $21\frac{1}{2}$ inches, and c(thickness of top cover plate) = $\frac{3}{4}$ inch, resulting in a b/c of 28.7.

i. Fatigue Considerations

CMAA-70 provides substantial guidance with respect to fatigue failure by indicating allowable stress ranges for various structural members in joints under repeated loads. EOCI-61 does not address fatigue failure.

The Intake Gantry Crane inherently complies with CMAA-70 since the number of heavy lifts made by the crane is far less than 20,000 and therefore, fatigue is not a consideration.

j. Hoist Rope Requirements

CMAA-70 requires that the rated capacity load plus the bottom block, divided by the number of parts of rope, not exceed 20% of the published rope breaking strength. EOCI-61 requires that only the rated capacity load divided by the number of parts of rope not exceed 20% of the published rope breaking strength.

The Intake Gantry Crane complies with CMAA-70 in that it has 8 parts of 1 inch 6 x 37 fiber center hoisting rope. Per the Third Edition of The Whiting Handbook, the breaking strength of one part of rope is 39.8 tons. With a safety factor of five and eight parts of rope, the reeving system capacity is 63.7 tons. The hoists rated capacity is 50 tons.

k. Drum Design

CMAA-70 requires that the drum be designed to withstand combined crushing and bending loads. EOCI-61 requires only that the drum be designed to withstand maximum bending and crushing loads with no stipulation that these loads be combined.

The Intake Gantry Crane complies with CMAA-70 in that the drum design was based upon a combination of crushing and bending loads.

l. Drum Groove Design

CMAA-70 provides a recommendation for the minimum drum groove depth and minimum drum groove pitch. EOCI-61 provides no similar guidance.

The Intake Gantry Crane complies with the recommendations of CMAA-70 as indicated below:

Hoisting Rope Diam(in)	Drum Groove Depth (in)	Drum Groove Pitch(in)	CMAA-70 Recommended Min. Depth (in)	CMAA-70 Recommended Min. Pitch(i
1	13/32	1 1/8	12/32	1 1/8

m. Gear Design

CMAA-70 requires that gearing horsepower ratings be based on certain American Gear Manufacturers Association (AGMA) standards and provides a method for determining allowable horsepower. EOCI-61 addresses gears, however similar design guidance is not provided.

The Intake Gantry Crane complies with CMAA-70 in that the cranes gearing was based upon the AGMA standards referenced in CMAA-70.

n. Bridge Brake Design

CMAA-70 requires that bridge brakes, for cranes that are cab controlled with cab on trolley, have a torque rating of at least 75% of the bridge motor. EOCI-61 has a similar requirement, except that the torque rating of the bridge brake is only a minimum of 50% of the bridge motor.

The Intake Gantry Crane inherently complies with CMAA-70 in that the crane is pendant controlled only, and has no cab.

o. Hoist Brake Design

CMAA-70 requires that hoist holding brakes, when used with a method of control braking other than mechanical, have torque ratings no less than 125% of the hoist motor torque. When used with a mechanical braking system, or if two holding brakes are used, the brake torque rating is to be no less 100% of the hoist motor torque

EOCI-61 specifies hoist braking, but only implies that the braking torque be at least equal to the motor torque.

The Intake Gantry Crane complies with CMAA-70 in that the hoist brake has a torque rating of at least 100% of the motor torque, and is used in conjunction with a mechanical l d brake.

p. Bumpers

CMAA-70 provides substantial guidance as to when bridge and trolley bumpers are required, and specifies some specific design requirements. EOCI-61 makes no mention of bumpers.

The Intake Gantry Crane complies with CMAA-70 in that both the bridge and the trolley are provided with double acting spring bumpers. Due to the slow speed of the bridge (75 fpm) and the trolley (50 fpm) the design of these spring bumpers meet the deceleration rate and energy absorbtion capacity specified in CMAA-70.

q. Static Control Systems

CMAA-70 provides substantial guidance for the use of static control systems. EOCI-61 makes no mention of static controls and primarily gives requirements for magnetic controls.

With regard to static controls, the Intake Gantry Crane inherently complies with CMAA-70, since such controls were not used. The controls for this crane are A-C magnetic reversing.

r. Undervoltage/Restart Protection

CMAA-70 requires that cranes not equipped with spring-return controllers or momentary contact pushbuttons be provided with a device that will disconnect all motors upon power failure and will not permit any motor to be restarted until the controller handle is brought to the "OFF" position, or a reset switch or button is operated. Undervoltage protection is required if spring-return controllers or momentary contact push buttons are not used.

EOCI-61 requires undervoltage protection for all control arrangements and requires momentary contact pushbuttons for floor controlled pendant operated cranes. EOCI-61 however, does not address spring-return controllers or the requirement for restart protection.

The Intake Gantry Crane complies with CMAA-70 in that momentary contact pushbuttons were provided for pendant operation. In addition, this crane was also provided with an undervoltage mainline magnetic contractor utilizing a start button for resetting.

3.00 ANSI B30.2.0 VS USAS B30.2.0 AND THE CYRSTAL RIVER CRANE

3.01 General

The ANSI B30.2.0 - 1976 safety standard is basically a rewrite of the USAS B30.2.0-1967 safety standard. Much of the criteria is therefore the same or very similar, with some areas becoming less stringent.

In addition to the USAS document, the Intake Gantry Crane was designed to the criteria of the Whiting Crane Company, a member of the CMAA organization, and to the technical requirements of the procurement specification, No. RO-2872. With the addition of these requirements, the design of the Intake Gantry Crane in many areas surpasses the requirements of ANSI.

Areas of major difference between the ANSI and USAS documents are listed under paragraph 3.02, with a description of these differences and the extent of Intake Gantry Crane compliance to ANSI being covered under paragraph 3.03.

3.02 Paragraph Listing of Major Differences in Safety Standards

<u>Topic</u>	<u>ANSI Paragraph No.</u>	<u>USAS Para. No.</u>
a. Clearances	2-1.2	2-1.2
b. Welded Construction	2-1.4.1	2-1.3.2
c. Girders	2-1.4.2	2-1.3.4
d. Cab Clearances	2-1.5.1.c	2-1.4.1b
e. Toeboards & Handrails	2-1.7.3	2-1.6.3
f. Ladders	2-1.7.4c	2-1.6.4c
g. Egress from Cab	2-1.7.5	(not covered)
h. Bridge & Trolley Bumpers	2-1.8	2-1.7
i. Electrical Equipment	2-1.10.1a	2.1.9.1a
j. Hoisting ropes	2-1.11.2a	2-1.10.2a
k. Hooks	2-1.11.4	2-1.10.4

3.03 Comparison of Differences & Extent of Crane Compliance

a. Clearances

ANSI B30.2.0 does not specify clearance dimensions. USAS B30.2.0 specifies a 3" overhead and 2" lateral clearance from obstructions and a 4" clearance between parallel cranes.

The Intake Gantry Crane complies with the less specific ANSI document as well as with the USAS document.

b. Welded Construction

ANSI B30.2.0 specifies welding to be in accordance with AWS D14.1. USAS B30.2.0 specifies welding to be in accordance with AWS D2.0-66.

The Intake Gantry Crane complies with the ANSI document in that welding was in accordance with the Whiting crane company procedures which in turn meet the requirements of AWS D14.1

c. Girders

ANSI B30.2.0 specifies the girder design to be in accordance with either CMAA #70, AISC, or AISE Std. #6. USAS B30.2.0 specifies the girders to be of adequate design.

The Intake Gantry Crane complies with the ANSI document, in that allowable stresses and main design features of the girders comply with CMAA-70.

d. Cab Clearances

ANSI B30.2.0 does not specify specific clearance dimensions. USAS B30.2.0 specifies that an operators cab have at least 3" clearance from all fixed structures.

The Intake Gantry Crane inherently complies with the less specific ANSI document since this crane does not have an operator's cab.

e. Toeboards & Handrails

ANSI B30.2.0 specifies that toeboards and handrails be in accordance with ANSI 12.1. USAS B30.2.0 specifies that these items be in accordance with USAS A14.3-1956.

The Intake Gantry Crane complies with the intent of the ANSI document in that toeboards and handrails have been provided and meet the major requirements of ANSI A12.1.

f. Ladders

ANSI B30.2.0 specifies that ladders be in accordance with ANSI 14.3 which in turn requires cages on ladders greater than 20 ft. USAS B30.2.0 specifies that ladders be in accordance with USAS A14.3-1956.

The Intake Gantry Crane complies with the ANSI document in that the crane's access ladder is caged.

g. Egress from Cab

ANSI B30.2.0 recommends a means of egress from the operator's cab for emergencies. USAS B30.2.0 does not address emergency cab egress.

The Intake Gantry Crane inherently complies with the ANSI document since this crane does not have an operator's cab.

h. Bridge & Trolley Bumpers

ANSI B30.2.0 requires the use of bumpers on other automatic means of equivalent effect if the bridge or trolley operates near the end of its travel. The trolley bumpers are also required to have an energy absorbing capacity to stop the trolley when traveling at least 50% of rated speed. USAS B30.2.0 only recommends the use of bumpers.

The Intake Gantry Crane complies with the ANSI document in that both the bridge and trolley are provided with double acting spring bumpers designed to provide the required energy absorption.

i. Electrical Equipment

ANSI B30.2.0 specifies that wiring and equipment comply with ANSI C-1, Article 610 (NFPA 70) which inturn requires a 30" walkway width in front of electrical enclosures. USAS B30.2.0 specifies that wiring and equipment comply with Article 610 of USAS C1-1965.

The Intake Gantry Crane meets the intent of the ANSI document with regard to electrical wiring and equipment. However, the walkway width is 30 inches total, and therefore a clearance of 30 inches in front of all electrical enclosures may not be provided.

j. Hoisting Ropes

ANSI B30.2.0 requires selection of hoisting ropes based on the rated load plus the weight of the load block. USAS B30.2.0 requires selection of hoisting ropes based only upon the rated load.

The Intake Gantry Crane complies with the ANSI document in that the hoisting cables have sufficient breaking strength to accomodate the rated load plus the weight of the load block with a safety factor of at least five.

k. Hooks

ANSI B30.2.0 requires safety latches unless the application makes the use of the latch impractical. USAS B30.2.0 does not address hook safety latches.

The Intake Gantry Crane complies with the ANSI document in that a hook safety latch is provided.

4.00 CONCLUSIONS

The Crystal River Unit No. 3 Intake Gantry Crane complies with the major design requirements of the industry specification CMAA-70. This crane also complies with the safety standards of ANSI B30.2.0 - 1976, except that some electrical enclosures may not have 30 inches of clearance in front of the enclosure.

5.00 RECOMMENDATIONS

The only areas of non compliance involve the ANSI B30.2.0 requirement on clearance in front of electrical enclosures.

The clearance in front of electrical enclosures is not an item which affects the safe handling of loads, and therefor no change is recommended.

6.00 REFERENCES

6.01 Standards and Specifications

- a. CMAA Specification #70 (CMAA-70), 1975
Crane Manufacturers Association of America
"Specifications for Electric Overhead
Traveling Cranes".
- b. EOCI Specification #61 (EOCI-61), 1961,
Electric Overhead Crane Institute
"Specifications for Electric Overhead
Traveling Cranes".
- c. ANSI B30.2.0-1976, American National Stan-
dards Institute, Safety Standard "Overhead
and Gantry Cranes".
- d. USAS B30.2.0-1967, United States of America
Standards Institute, Safety Code "Overhead
and Gantry Cranes"
- e. Gilbert Associates' Specification RO-2872,
February 18, 1970 "Requirement Outline
Intake Gantry Crane, Crystal River-Unit No. 3"
- f. Whiting Corporation Engineering Standard
L703, February 20, 1970, "Drum Design".

6.02 Letters

Nuclear Regulatory Commission letter, December
22, 1980, "To All Licensees of Operating Plants
and Applicants for Operating Licenses and Holders
of Construction Permits" Subject: Control of
Heavy Loads.

6.03 Handbooks

Whiting Crane Handbook, Third Edition, April 1967
Whiting Corporation (Table 12-Weight And Strength
of Wire Ropes - 6 x 37, page 81)

6.04 Drawings

<u>Whiting Drawing No.</u>	<u>Whiting Drawing Title</u>
U-65088	Girder Detail
U-64400	Gen'l Arrgm't of a 2 motor Gantry Bridge
U-64401	Gen'l Arrgm't of a 2 motor Gantry Bridge
U-52976	Gen'l arrgm't of a 2 Motor RW Trolley

ENCLOSURE 3

LOAD DROP ANALYSIS FOR SFHT-7

45010 81

J.O./W.O./CALCULATION NO. 14235.17 / FPC / CC1		REVISION 0	PAGE 1
PREPARED BY/DATE R. Schubert 5/13/83	REVIEWER/CHECKER/DATE R.D. Suter 6/13/83	INDEPENDENT REVIEWER/DATE Goneth Wolocky 7/6/83	
SUBJECT/TITLE CRYSTAL RIVER 3 LOAD DROP ANALYSIS		QA CATEGORY/CODE CLASS I/NSR	

REFERENCES

- 1) Proceedings of the ASCE, Journal of the Structural Division. Vol 105 No. ST3. March 1979. p. 547
"Structural Response of R/C Slabs to Tornado Missiles"
by P. McMahon, S. Sen, B. Meyers, K. Buchert
- 2) USNRC Standard Review Plan. NUREG-0800
Appendix A
- 3) "Theory of Plates and Shells", by Timoshenko 2nd Edition
McGrawHill Book Co.
- 4) ACI 349 APPENDIX C
"SPECIAL PROVISIONS FOR IMPULSIVE AND IMPACTIVE LOADS"
- 5) "Yield Line Analysis of Slabs" by L.L. Jones & R.H. Wood
American Elsevier Publishing Co. Inc N.Y. 1963
- 6) "Theory and Analysis of Plates" by Rudolph Szilard
Prentice Hall, Inc. Englewood Cliffs, N.J. 1974
- 7) "Building Code Requirements for Reinforced Concrete" ACI 318-77
American Concrete Institute, Detroit Michigan
- 8) "Formulas for Stress & Strain" 5th Edition by R. Bark & W. Young
McGrawHill Publishers N.Y. N.Y.
- 9) NLS Report 3874, 1981 "The Control of Heavy Loads at
Crystal River 3, NUREG 0612, Six Month Report
- 10) Stone & Webster Engineering Corp Computer Program ST-331
"Single Barrier Mass Missile Impact" Version 00 Level 00
- 11) Stone & Webster Engineering Corp. Topical Report SWECO 7703
"Missile - Barrier Interaction"
- 12) "Structural Analysis and Design of Nuclear Plant Facilities"
American Society of Civil Engineers 1980
- 13) "Introduction to Structural Dynamics" by John M. Biggs
McGrawHill Book Co. N.Y. 1964
- 14) GAI DWG SC-421-019 REV 6
- 15) GAI DWG SC-400-015 REV 4

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

AS010 81

J.O./W.O./CALCULATION NO. K235.17/FPC/001	REVISION 0	PAGE 1.1
--	---------------	-------------

PREPARED BY/DATE K. Schuyler 5/13/83	REVIEWER/CHECKER/DATE R. D. Butler 6/13/83	INDEPENDENT REVIEWER/DATE Kenneth Wislocky 7/6/83
---	---	--

SUBJECT/TITLE CRYSTAL RNER LOAD DROP ANALYSIS	QA CATEGORY/CODE CLASS I NSR
--	---------------------------------

REFERENCES (CONT.)

- (6) "DESIGN OF STRUCTURES FOR MISSILE IMPACT"
RECHTEL TOPICAL REPORT EC-TOP-C.Δ 2B/2.

AS01081

J.O./W.O./CALCULATION NO.

14235.17/FPC C-01

REVISION

0

PAGE

2

PREPARED BY

R. Schubert 5/13/83

REVIEWER/CHECKER/DATE

R. D. Salko 6/13/83

INDEPENDENT REVIEWER/DATE

Gareth W. W. 7/6/83

SUBJECT/TITLE

CRYSTAL RIVER 3 LOAD DROP ANALYSIS

QA CATEGORY/MODE CLASS

I/NSR

ASSUMPTIONS

1. Initial velocity of missile when dropped is zero
2. The missile strikes the target normal to the surface.
3. Any intermediate targets are ignored. Primary target takes full impact.
4. No crushing of the missile is used
5. The load may be dropped at any location in the crane travel area except where physical interference is present
6. If drag forces are present, they may be considered.
7. Lift height is assumed to be the maximum that is physically possible, unless otherwise stated
8. The most critical condition based on target failure is analyzed. All other conditions, if not considered, are less critical.
9. Analysis is based on a bilinear elastic-plastic curve that represents a true stress/strain relationship
10. Initially the effects of existing loads and deflections are ignored until the target passes the drop analysis. Upon passing, the effects of existing loads & deflections will be checked if their effect is critical
11. Compression steel is ignored in determining Ultimate Moment Capacity
12. Concrete Slab and beam boundary conditions are based on available information and conservative assumptions
13. Concrete slabs and beams are assumed to deform plastically at failure, and separate into segments at the yield lines.
14. Failure is considered when the ductility ratio exceeds that as stated in Ref 2
15. If the energy absorption analysis indicates the target is acceptable, a localized check for perforation, scabbing, penetration, and spalling will be done.

45010 51

J.O./W.O./CALCULATION NO.

14235.17/FPC C-01

REVISION

0

PAGE

3

PREPARER/DATE

R. J. Satter 5/13/83

REVIEWER/CHECKER/DATE

R. J. Satter 6/13/83

INDEPENDENT REVIEWER/DATE

Kenneth W. Satter 7/6/83

SUBJECT/TITLE

CRYSTAL RIVER 3 LOAD DROP ANALYSIS

QA CATEGORY/ CODE CLASS

I/NSR

ASSUMPTIONS

16. Structural member checked as a column with $KL/r \leq 22$ length effects are ignored, axial loads & deflections only are checked
17. Columns will first be checked ignoring length effects
18. Passing columns will again be checked with length effects if it is critical
19. Initial deflection to be considered with load drop deflections will include dead load and any permanently fixed load such as equipment. Earthquake, creep, etc. deflections will be neglected.
20. A combination of structures may be present to resist the load drop, however to simplify analysis only one structure may be analyzed
21. When more than one block assembly exists (ie main & auxiliary hook) the more critical load shall be incorporated into the analysis. UOS.
22. Structural Steel supporting concrete slabs shall not be included in developing barrier resistance
23. FPC/CR3 FSAR Section 5.4.5.1 states that any vertical seismic response is assumed to be insignificant. Therefore no induced accelerations other than gravity are considered and all load drops will be assumed to have zero velocity at the time of the drop.
24. The ratio $\eta = E_s/E_c$ is assumed to remain constant during impact & resistance, any increase in E_c due to dynamic increase factor is assumed negligible

45010 61

J.O./W.O./CALCULATION NO. 14235.17/FPC C-01		REVISION 0	PAGE 4
REFERENCE DATE R. [unclear] 5-16-83	REVIEWER/CHECKER/DATE R. J. [unclear] 6/13/83	INDEPENDENT REVIEWER/DATE Genneth [unclear] 7/6/83	
SUBJECT/TITLE CRYSTAL RIVER 3 LOAD DROP ANALYSIS		QA CATEGORY/CODE CLASS I/NSR	

METHOD OF ANALYSIS

As presented in Ref. #1, the effective mass-plastic impact method is used in analysing the response of target structures to missiles 'dropped' from cranes.

This method evaluates an effective mass for the structural barrier and treats the impact as a plastic collision between the missile and the effective mass. The strain energy of the target at maximum response, is used to balance the residual kinetic energy of the target-missile combination.

The impact is modeled as a missile of mass, M_m , and striking velocity, V_s , impacting a spring-backed target mass M_e . The spring is bilinear and a function of the resistance-displacement properties of the target.

For plastic collisions with short duration impacts the target displacements and spring forces are small during impact and can conservatively be neglected. Therefore the missile and target masses attain the same velocity at the end of impact. The strain energy required to stop the target-missile combination is then the sum of the kinetic energy of the missile and the target masses at the end of the duration of impact.

$$E_s = \frac{M_m V_m^2}{2} + \frac{M_e V^2}{2}$$

Conservation of momentum gives the velocities of missile M_m & M_e after impact

$$M_m V_s = (M_m + M_e) V'$$

$$(Eq. 1) \quad V' = \frac{M_m V_s}{M_m + M_e}$$

Substituting equation 1 into the Energy Equation above gives the required target strain energy of

$$(Eq. 2) \quad E_s = \frac{M_m^2 V_s^2}{2(M_m + M_e)}$$

PREPARED / DATE

K. Schulz 5-16-83

REVIEWER / CHECKER / DATE

R. J. Salko 6/13/83

INDEPENDENT REVIEWER / DATE

Kenneth Nickky 7/6/83


SUBJECT / TITLE

CRYSTAL RIVER 3 LOAD DROP ANALYSIS METHOD

QA CATEGORY / CODE CLASS

I / NSR

The target strain energy is defined as the area under the bilinear resistance / displacement curve for the structural target as shown below.



R_m = Plastic resistance

x_e = Yield displacement

x_m = Max. displacement

For elastic/plastic response (without concurrent loads)

$$R(x) = kx \quad (0 < x \leq x_e) \quad k = \text{Elastic Spring Constant} = \frac{R_m}{x_e}$$

$$R(x) = kx_e = R_m \quad (x_e < x \leq x_m)$$

Therefore the target strain energy is:

$$E_s = R_m (x_m \cdot x_e / 2)$$

$$(Eq. 3) \quad x_m = \frac{E_s}{R_m} + \frac{x_e}{2}$$

The corresponding ductility ratio (Ref 1)

$$(Eq. 4) \quad \mu = \frac{x_m}{x_e} = \frac{E_s}{x_e R_m} + \frac{1}{2}$$

This ductility ratio must be less than the limits imposed by Ref. 2

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

AS010 81

J.O./W.O./CALCULATION NO.

14235.17/FPC C01

REVISION

0

PAGE

6

PREPARED / DATE

Philly 5-16-83

REVIEWER / CHECKER / DATE

R D. S. / K 6/13/83

INDEPENDENT REVIEWER / DATE

Gene W. Wislocky 7/6/83

SUBJECT / TITLE

CRYSTAL RIVER 3 LOAD DROP ANALYSIS METHOD


QA CATEGORY / CODE CLASS

I / NSR

If the ductility ratio of the structural target exceeds the allowables as presented in Ref. 2, then no further analysis is required. The target is insufficient for the crane drop.

If the ductility ratio of the structural target is less than the allowable as presented in Ref 2, a check of existing dead load and live load deflections along with missile deflections must be performed.

$$\chi' = \chi_e - \chi_0$$



χ0 = DL/LL deflection

The target strain energy is defined as the area below the Resistance displacement curve but above the dead/live load resistance.

Therefore the target strain energy is:

$$E_s = \frac{1}{2} K (\chi_e - \chi_0)^2 + K (\chi_e - \chi_0) (\chi_m - \chi_e)$$

Thus the maximum deflection is:

$$\chi_m = \frac{E_s}{K (\chi_e - \chi_0)} + \frac{\chi_e + \chi_0}{2}$$

The ductility ratio

(Eq. 5)
$$\chi_d = \frac{E_s}{R_m (\chi_e - \chi_0)} + \frac{1 + \chi_0/\chi_e}{2}$$

AS010 61

J.O./W.O./CALCULATION NO.

14235.17 / FPC / 001

REVISION

0

PAGE

7

PREPARED / DATE

R. J. S. / 6-2-83

REVIEWER / CHECKER / DATE

R. J. S. / 6/13/83

INDEPENDENT REVIEWER / DATE

Kenneth W. / 7/6/83

SUBJECT / TITLE

CRYSTAL RIVER 3 LOAD DROP ANALYSIS METHOD

QA CATEGORY / CODE CLASS

I / NSR

Load drop target structures that are qualified by allowable ductility ratio for overall structural response will be checked for localized damage to ensure the target's localized capacity for resisting the load drop. (applicable to slabs and beams) Localized effects include:

Perforation: missile passes through the target

Scabbing: ejection of material from the back face of target

Penetration: displacement of the missile into the target

Spalling: ejection of material from the front face of target

Scabbing effect will be the controlling localized condition because scabbing occurs before perforation; and penetration and spalling pose no risk to systems on the back side of target structure. As per Ref 12 p 318 Punching Shear is implicit in the formulas for penetration, scabbing, etc.

The method of analysis will be that of Ref 11 where the scabbing threshold velocity is calculated and compared to the impact velocity of the load drop. A threshold velocity greater than the impact velocity indicates that scabbing will not occur at that impact velocity and therefore it can be concluded that no localized damage will occur.

Acceptable alternate formulas are: The Modified NDRC Formula and The Bechtel Formula as presented in Ref 12

T = Barrier thickness (in)

D = load diameter

t = missile wall thickness

m = mass of missile

$\frac{2t}{D} = 1.0$ for solid missile

equivalent diameter = $\sqrt{\frac{4 \text{Area}}{\pi}}$

Procedure for checking scabbing:

1. calculate $T^{(n)}/D^{(n)}$

2. calculate $2t^{(n)}/D^{(n)}$

3. using T/D & $2t/D$ in Figure B.3-1 Ref. 11 find KE/T^3 (ksi)

4. calculate KE : $[KE = KE/T^3 \times T^3]$

5. calculate threshold velocity $v = \sqrt{\frac{KE \times 2}{m}}$

6. Compare threshold velocity with calculated impact velocity

7. If threshold velocity > impact velocity scabbing will not occur
If threshold velocity < impact velocity reduce height of load drop

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A501061

J.O./W.O./CALCULATION NO.

14235.17/FPC C01

REVISION

0

PAGE

8

PREPARED BY/DATE

R. Schubert 5-17-83

REVIEWER/CHECKER/DATE

R. S. Salter 6/13/83

INDEPENDENT REVIEWER/DATE

Kemeth Wislocky 7/1/83

SUBJECT/TITLE

LOAD DROP ANALYSIS / RESISTANCE / DISPLACEMENTS CR3

QA CATEGORY / CODE CLASS

I / NSR

SLABS

simple supports

RESISTANCE^K Ref 5

DISPLACEMENT^{FT}



$$R = 2\pi M_u^+ (DIF)$$


$$\chi_e^{(H)} = C_1 \frac{R a^2}{E I_e} (1 - \nu^2)$$

b/a	1.0	1.2	1.4	1.6	1.8	2.0	∞	Ref 6
C ₁	0.01120	0.0129	0.0138	0.0142	0.0144	0.0144	0.0145	

fixed support

RESISTANCE^K Ref 5

DISPLACEMENT^{FT}



$$R = 2\pi (M_u^+ + M_u^-) (DIF)$$

$$\chi_e^{(H)} = C_1 \frac{R a^2}{E I_e} (1 - \nu^2)$$

b/a	1.0	1.2	1.4	1.6	1.8	2.0	∞	Ref 6
C ₁	0.00560	0.00647	0.00691	0.00712	0.00720	0.00722	0.00725	

M - FT.K
 R - K
 E - K/FT²
 I - FT⁴/FT

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION


A5010 51

J.O./W.O./CALCULATION NO. 14235.17 / FPC / CO1	REVISION 0	PAGE 9
---	---------------	-----------

PREPARED DATE K. Schubert 5-17-83	REVIEWER/CHECKER/DATE R. D. Sailer 6/13/83	INDEPENDENT REVIEWER/DATE Renneth Wislocky 7/6/83
--------------------------------------	---	--


SUBJECT/TITLE LOAD DROP ANALYSIS RESISTANCE / DISPLACEMENT CR3	QA CATEGORY / CODE CLASS 1 NR
---	----------------------------------

CONCRETE BEAMS



$$R = \frac{4M_u}{L} \text{ (DIF)}$$

$$\chi_e = \frac{RL^3}{48EI}$$



$$R = \frac{4(M_u + M_j)}{L} \text{ (DIF)}$$

$$\chi_e = \frac{RL^3}{192EI}$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

4-5010 61

J.O./W.O./CALCULATION NO.

14295.17/FPC/C01

REVISION

0

PAGE

10

PREPARED/DATE

R. Schubert 5-17-83

REVIEWER/CHECKER/DATE

R. D. Sullivan 6/13/83

INDEPENDENT REVIEWER/DATE

Ronald H. Webster 7/6/83

SUBJECT/TITLE

LOAD DROP ANALYSIS / RESISTANCE / DISPLACEMENTS

CR3

QA CATEGORY/CODE CLASS

I NSC

COLUMNS

Concentrically loaded, short column (height \leq 3 thickness)

$$R = 0.70 [0.85 f_c (A_g - A_s) + A_s f_y]$$

$$\lambda_e = \frac{R L}{A_c E_T + A_s E_s}$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A501051

J.O./W.O./CALCULATION NO.

14235.17 / FPC / C01

REVISION

0

PAGE

11

PREPARED BY

R. J. Salter 5-16-83

REVIEWER/CHECKER/DATE

R. J. Salter 6/13/83

INDEPENDENT REVIEWER/DATE

Samuel Webster 7/6/83

SUBJECT/TITLE

CRANE LOAD DROP COMPUTER/HAND CALC COMPARISON

QA CATEGORY/ CODE CLASS

I / NSR

Stone & Webster computer program "Single Based Mass-Missile Impact" ST-331, Version 00, Level 00, will be used to check various 'target' capabilities for postulated crane load drops.

The computer analysis approach is similar to the mass-plastic impact method as presented in Ref. 1.

As a means for comparing the two methods a trial check will be done to compare the results of a hand calculation and the computer run.

The trial run will be modeled as follows:

slab: 10ft x 20ft, 2ft thick, #11 bars @ 6" EWEF TOP & BOTTOM


$f'_c = 4 \text{ ksi}$, $f_y = 60 \text{ ksi}$, fixed on all sides

missile: point load, 100k weight, 10ft drop strikes @ center

$$\text{mass} = 100^k / 32.2^{\text{ft/s}^2} = 3.1 \frac{k \cdot s^2}{ft}$$


Mass-Plastic Impact Method

Effective Moment of Inertia: based on an effective thickness



REF
 D = depth to tens steel
 I_{cr} = cracked moment of inertia
 I_g = gross moment of inertia

$$I_g = \frac{1}{12}(12)(24)^3 = 13824 \text{ in}^4 =$$



$$\frac{12x^2}{2} - 24.96(24-x) = 0$$

$$6x^2 + 24.96x - 549 = 0$$

$$x = 7.7 \text{ in}$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. 1423517 / FRC 001		REVISION 0	PAGE 12
PREPARED / DATE K. Scheraga 5-16-83	REVIEWER / CHECKER / DATE R. D. Saika 6/13/83	INDEPENDENT REVIEWER / DATE Kenneth Wislocky 7/6/83	
SUBJECT / TITLE CRANE LOAD DROP COMPUTER / HAND CALC COMPARISON		QA CATEGORY / CODE CLASS I / NSR	

$$I_{cr} = \frac{1}{3} (12)(7.7)^3 + 24.96(22-7.7)^2 = 6930 \text{ in}^4$$

$$I_e = \frac{1}{2} (I_{cr} + I_g) = 10377 \text{ in}^4 = 0.5004 \text{ ft}^4 \quad (\text{Ref. 4})$$

Ultimate Moment Capacity of 12" section of slab

$$M_u = \phi A_s f_y (d - a/2)$$

$$a = \frac{A_s f_y}{.85 f_c b} = \frac{3.12(60)}{.85(4)(12)} = 4.59 \text{ in}$$

$$M_u = 0.9(3.12)(60 \text{ ksi})(22 - 4.59/2)$$

$$M_u = 3320 \text{ in-k} = 276 \text{ ft-k}$$

Effective Target Mass = Use 1/6 Volume of Concrete in failure cone as per SBMMI ST-33 (1/6 is the ratio of

$$M_e = \frac{150 \text{ k/ft}^3}{6(32.2)} \times 1\pi(5')^2 \times 2' = 0.1219 \text{ k-ft}$$

Mass Factor in Ref 13 p. 214
Engineer will determine if less conservative M_e should be used

Peak Resistance of slab 'R' Ref 5 p 266

$$R = 2\pi(M^+ + M^-)$$

$$R = 4\pi(276 \text{ in-k}) = 3468 \text{ k}$$

DYN. INCR FACT = 1.1

$$R = 3815 \text{ k} \quad \text{as per Ref. 4}$$

Yield Displacement

$$\chi_e = C \frac{R_d^2}{D} \quad \text{Ref 6 p. 654}$$

$$\chi_e = 0.00722 \frac{3815 \text{ k} (10 \text{ ft})^2}{(5.184 \times 10^3 \text{ k/ft}^3) (0.5004 \text{ ft})} (1-.25^2)$$

[Use $\frac{I_e}{h}$ in place of h for R]

$$\chi_e = 0.120 \text{ in} = 0.010 \text{ ft}$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A5010.61

J.O./W.O./CALCULATION NO. 14235.17/FPC 001	REVISION 0	PAGE 13
---	---------------	------------

PREPARED BY/DATE R. J. Salter 5/16/83	REVIEWER/CHECKER/DATE R. J. Salter 6/13/83	INDEPENDENT REVIEWER/DATE Kenneth Wislocky 7/6/83
--	---	--

SUBJECT/TITLE CRANE LOAD DROP COMPUTER/HAND CALC COMPARISON	QA CATEGORY/CODE CLASS 1 N/A
--	---------------------------------

IMPACT ANALYSIS

Velocity of Missile:

$$V_m = \sqrt{2gh} = \sqrt{2(32.2)(10)} = 25.4 \text{ ft/s}$$

Required Target Strain Energy

$$E_s = \frac{M_m^2 V_m^2}{2(M_m + M_c)}$$

$$E_s = \frac{(3.1)^2 (25.4)^2}{2(3.1 + 0.1219)} = 962 \text{ ft-lb}$$

Ductility Ratio

$$\mu_1 = \frac{E_s}{7.2 R_m} + \frac{1}{2}$$

$$\mu_1 = \frac{962 \text{ ft-lb}}{0.010^2 (3815)} + \frac{1}{2}$$

$$\mu_1 = 25.7$$

Comparison with Computer Run Attachment #1 shows a very good comparison between the hand calculation and the computer run. Therefore it can be concluded that the computer will give an analysis similar to the hand calculation presented here.

TEST RUN FOR THEORETICAL APPROACH---COMPARISON FOR HAND CALCULATION

DATA ON MISSILE, BARRIER, AND LOAD COMBINATION EQUATION

BARRIER FORCE DISPLACEMENT RELATIONSHIP

KIPS	FEET
3015.0	0.0100
3015.0	0.1000
3015.0	0.5000

0.0 KIPS EQUIVALENT STATIC FORCE == LOAD 1
 0.0 KIPS EQUIVALENT CONSTANT DYNAMIC FORCE == LOAD 2
 0.0 KIP-SEC MISSILE IMPULSE RESISTED BY FORCE AT BARRIER SUPPORT PLUS BARRIER INERTIA DURING MOMENTUM TRANSFER == LOAD 3
 70.740 KIP-SEC MISSILE IMPULSE RESISTED ONLY BY BARRIER INERTIA DURING MOMENTUM TRANSFER == LOAD 4
 24.4 FPS BARRIER INITIAL VELOCITY DUE TO LOAD 4

BARRIER EQUIVALENT HEIGHT	MISSILE HEIGHT LOAD 3	MISSILE HEIGHT LOAD 4	BARRIER PLASTIC FORCE	BARRIER EFFEC. YIELD DEFLECTION	BARRIER PERIOD
KIPS	KIPS	KIPS	KIPS	FT	SEC
3.925	0.000	100.000	3015.0	0.0100	0.0036

RESULTS OF TIME HISTORY ANALYSIS FOR MISSILE IMPACT WITH OTHER LOADS

1 TIME HISTORY NUMBER	2 DURATION OF LOAD 3 SEC	3 MISSILE FORCE LOAD 3 KIPS	4 FORCE AT BARRIER SUPPORT KIPS	5 TIME OF MAX BARRIER DEFLECTION SEC	6 MAXIMUM BARRIER DEFLECTION FT	7 MAXIMUM BARRIER DUCTILITY	8 MAXIMUM BARRIER VELOCITY FT/SEC	9 FINAL BARRIER RESISTING MECHANISM
0	0.0	0.0	3015.0	0.020039	0.2569	25.69	24.40	SPECIAL BARRIER SPRING

Attachment #1 pg 2 of 2
 14235.17-C-01
 FPC CR 1
 REV 1/2/83
 REV 2/2/83
 REV 3/3/83
 REV 7/2/83

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

14235.17-C-01

REVISION

0

PAGE

67

ASD1081

PREPARED BY/DATE

R. D. Salter 6/9/83

REVIEWER/CHECKER/DATE

K. Salinger 6/13/83

INDEPENDENT REVIEWER/DATE


H. Salter 7/6/83

SUBJECT/TITLE

Load Drop Analysis for SFHT-7

QA CATEGORY/CODE CLASS

I NSL



EI 162' 0"

Reference Drawing RPC

Concrete for Spent Fuel Tank A & B

S 421 141
E 400-104

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO. FPC

REVISION

PAGE

14235.17-C-01

0

68

A5010.61

PREPARED/DATE

R. J. Baker 6/9/83

REVIEWER/CHECKER/DATE

R. Seuberg 6-13-83

INDEPENDENT REVIEWER/DATE

Hometh... 7/10/83



SUBJECT/TITLE

Load Drop Analysis for SFHT-7

QA CATEGORY/CODE CLASS

I NSR

SFHT-7



Reference Drawgs

- FPC-SC-400-008
- SC-400-007
- SC-421-141
- SC-421-142

J.O./R.O./CALCULATION NO. FAC 14235.17-C-01	REVISION 0	PAGE (8)
PREPARED/DATE R.D. Sullivan 6/9/83	CHECKED/DATE R. Williams 6-15-83	INDEPENDENT REVIEWER/DATE Thomas A. Brown 6/14/83
SUBJECT/TITLE Spent Fuel Pool Gate Hoist Drop Analysis for S.F.H.T.-7		
QA CATEGORY/CODE CLASS I DSE		

S.F.H.T.-7 Spent Fuel Pool Gate Hoist

Discussion

This hoist is located on a monorail at EL 197.10 on column line 302A of the Auxiliary Bldg. The purpose of the hoist is to remove the gate between spent fuel pools A & B. The gate is the only pick-up item for this hoist. Two load drops case are considered for analysis. The first drop is to allow the gate to fall from maximum lifting height to the bottom of the wall opening. A wall segment equal to the remaining height of the wall and the width of the opening is analysed as a column in compression. The second drop will analyze the bottom slab of the spent fuel pool. Since the fuel racks are resting in the bottom of the pools the gate can only hit the concrete directly by sliding between the wall and racks. For the ease of calculation the gate is assumed to hit the middle of the slab.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

45010.61

J.O./W.O./CALCULATION NO.

14235.17-C-01

FPC

REVISION

0

PAGE

70

PREPARED/DATE

R. S. Sutter 6/9/83

REVIEWED/CHECKER/DATE

R. Schuler 6-13-83

INDEPENDENT REVIEWER/DATE

Glenneth A. ... 6/83

SUBJECT/TITLE

Load Drop Analysis for SFHT-7

QA CATEGORY/ CODE CLASS

I NSR

Input Data for SBMNI Program (ST-331)

Drop #1 on 4 ft wall between pools.


Gate wt = 3.9 k
Total Drop wt = 3.9

Drop height = 5 + (162 - 133) = 34'
wt of barrier = 1/6' x 3' x 14.75' x .15 k/ft² = 4.425 k.
Missile Mass = $\frac{3.9^k}{322^{ft/sec^2}}$ = .121 k-sec²/ft

Velocity @ impact = $V_i = \sqrt{2gh} = \sqrt{2(32.2 \text{ ft/sec}^2) 34 \text{ ft}} = 46.8 \text{ ft/sec}$

Momentum @ impact = $46.8 \text{ ft/sec} \times .121 \text{ k-sec}^2/\text{ft} = 5.67 \text{ k-sec}$

* Assume a 3 ft effective length



Resistance Curve

* Assume: that the wall steel doesn't act in compression.

$P_u = \phi [0.85 f'_c A_g]$ $F'_c = 3000 \text{ psi}$



$\phi = .70$ (ACI-318-77 sec 9.3.2)

$P_u = .7 (.85) 3 (4' \times 3') 144 \text{ ft}^2 = 3084^k$

$\Delta = \frac{RL}{AE} = \frac{3855^k (14.75)^2}{12 \text{ ft}^2 (449568 \text{ k/ft}^2)}$ = .0105

$E = 57000 \sqrt{3000} = 3122 \times 10^3 = 449568 \text{ k/ft}^2$

$R = DIP = P_u = 1.25 (3084) = 3855^k$



CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

45010.01

J.O./W.O./CALCULATION NO. 14235.17-C-01	FPC	REVISION 0	PAGE 71
--	-----	---------------	------------

PREPARED/DATE R. D. Sutter 6/9/83	REVIEWER/CHECKER/DATE K. [unclear] 6-13-83	INDEPENDENT REVIEWER/DATE [unclear] 6/83
SUBJECT/TITLE LOAD DROP ANALYSIS for SEIT-7		QA CATEGORY/CODE CLASS I N52

Drop #2 - Bottom slab of Fuel Pools.

Gate wt = 3.9

Total Drop Load = 3.9

Missile Mass = $\frac{3.9}{32.2} = .121$

Height of Drop = $5' + (162.0" - 118.25) \cdot 4875'$

Velocity @ Impact (no water drag) $V_c = \sqrt{2gh} = \sqrt{2(32.2)48.75} = 56.03$

Momentum @ Impact = $V_c \times M_{missile} = 56.03 \times .121 = 6.78$


Assume a 12 ft diameter fan radius for the yield line circle

Effective Target Wt = $\frac{1}{6} \cdot .15 \pi \left(\frac{12}{2}\right)^2 5 = 14.137$

Minimum Ultimate Moment Capacity, M_u

Use an average of the rebar arrangement to determine A_s

$A_s = \frac{1.27 + 2(1.27)}{2} = 1.905$



$a = \frac{1.905(40)}{.85(3)(12)} = 2.49$

$M_u = \phi A_s f_y (d - a/2) = 0.9(1.905)40(56 - \frac{2.49}{2}) = 3755 \text{ k-in} = 313 \text{ k-ft}$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

45010 61

J.O./W.O./CALCULATION NO. FDC

14235.17-C-01

REVISION

0

PAGE

72

PREPARER/DATE

P. J. Salkin 6/9/83

REVIEWER/CHECKER/DATE

[Signature] 6/13/83

INDEPENDENT REVIEWER/DATE

[Signature] 7/6/83

SUBJECT/TITLE

Load Drop Analysis for SFHT-7

QA CATEGORY/CODE CLASS

I NSR

Check Impact Velocity of Missile Through Water (see Reference #16)

h = 5' w = 3900 lb H = 43.75'
L = 28' d = 39" = 3.25'

$$V_0 = \sqrt{2gh} = \sqrt{2(32.2)5'} = 17.9 \text{ ft/sec}$$

$$R_0 = \frac{V_0 d}{\nu} = \frac{17.9 \cdot 3.25}{.93 \times 10^{-5}} = 6.25 \times 10^6 \quad \nu = .93 \times 10^{-5} \text{ for water viscosity.}$$

$$L/d = \frac{28'}{3.25'} = 8.61 \quad C_D = 1.33$$

$$A_0 = \frac{39 \times 1}{144} = .271 \text{ ft}^2$$

$$a = \frac{\gamma_0 C_D A_0}{2W} = \frac{62.4 (1.33) .271}{2(3900)} = .0029 \text{ ft}^{-1}$$

$$2aL = .1624$$

$$2aH = .2538$$

$$b = \frac{\gamma g}{W} = \frac{62.4 (32.2)}{3900} = .5152$$

$$\gamma_m = \frac{3900}{39 (28)^{1/4} 144} = 514 \text{ lb/ft}^2$$

$$V_2 = \left[g \left(1 - \frac{\gamma}{\gamma_m} \right) / a \right]^{1/2} = \left[32.2 \left(1 - \frac{62.4}{514} \right) \frac{1}{.0029} \right]^{1/2} = 98.8 \text{ ft/sec.}$$

$$Z_2(H) = V_2^2 + e^{-2aH} \left\{ \frac{b A_0}{2a} \left[e^{2aL} (1 - 2aL) - 1 \right] + V_0^2 + \frac{g}{a} \left(e^{\frac{2aL \gamma}{\gamma_m}} - 1 \right) \right\}$$

$$Z_2(H) = 98.8^2 + e^{-.2538} \left\{ \frac{.5152 (.271)}{2 (.0029)^2} \left[e^{.1624} (1 - .1624) - 1 \right] + 17.9^2 + \frac{32.2}{.0029} \left(e^{\frac{.1624 \cdot 62.4}{514}} - 1 \right) \right\}$$

$$Z_2(H) = 9761 + .7758 \{ -122 + 320.4 - 9518 \} = 2530$$

$$V = \sqrt{Z_2(H)} = \sqrt{2530} = 50.3 \text{ ft/sec.}$$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

FPC

REVISION

PAGE

14235.17-C-01

0

13

45010 61

PREPARER/DATE

R. D. Baker 6/9/83

REVIEWER/CHECKER/DATE

R. Sulzberger 6-13-83

INDEPENDENT REVIEWER/DATE

Arnold Wadsworthy 7/7/83

SUBJECT/TITLE

Load Drop Analysis for SFHT-7

QA CATEGORY/CODE CLASS

I NSR

Momentum @ Impact = .121 * 50.3 = 6.09 'k-sec.
with water drag

Effective Moment of Inertia.


$$I_g = \frac{1}{12} 12(60)^3 = 216000 \text{ in}^4 = 10.42 \text{ ft}^4$$

Solve for x

$$\frac{12x^2}{2} - 17.1(56-x) = 0$$

$$6x^2 + 17.1x - 957 = 0$$

$$x = 11.28 \text{ in}$$



As = 9(1.185) = 17.1
 $\frac{E_s}{E_c} = 9$

$$I_{cr} = \frac{1}{3} 12(11.28)^3 + 17.1(56 - 11.28)^2 = 39940 \text{ in}^4$$

$$I_{e,fc} = \frac{1}{2} (I_{cr} + I_g) = 127170 \text{ in}^4 = 6.17 \text{ ft}^4$$

Peak Resistance of slab 'R'

$$R = 47 (M_b) = 47(313) \text{ k/ft} = 3933$$

w/ Dyn Incr. Fact = 1.1 $R = 4326$

Yield Displacement

$$\chi_e = C \frac{R a^2}{D}$$

$$\chi = \frac{.00721 (4326) (12)^2}{(449571) 6.17} (1 - .25^2) = .0015 \text{ ft}$$

$$D = \frac{E h^3}{12(1 - \nu^2)}$$

Let: $C = .00721$ $f_n \frac{b}{a} = \frac{2.5}{12} = 1.91$
 $a = 12 \text{ ft}$
 $h^3 = I_{eff}$

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

AS010 61

J.O./W.O./CALCULATION NO. *FPC*
14235.17 - C - 01

REVISION
0

PAGE 74

PREPARED/DATE
R.D. Salter 6/9/83

REVIEWER/CHECKER/DATE
R. Salter 6-13-83

INDEPENDENT REVIEWER/DATE
Kenneth Wislocky 7/6/83

SUBJECT/TITLE
Load Drop Analysis for SFHT-7

QA CATEGORY / CODE CLASS
I NSR

Deflection Due to Dead Load

Consider slab area above support walls

11' x 23'

Dead wt of water

assume water height = 162 - 118.33 = 43.67'

$$62.4 \text{ lb/ft}^2 \times 43.67 \text{ ft} = 2.725 \text{ } \frac{\text{lb}}{\text{ft}^2}$$

a = 23' b = 11'

a/b = 2.09

$\alpha = .0277$

$$k_{\text{eff}} = \sqrt[3]{\frac{I_{\text{eff}}}{12}} = \sqrt[3]{\frac{127970}{12}} = 4.2$$

$$y_{\text{max}} = \frac{\alpha q b^4}{E k_{\text{eff}}^3} = \frac{.0277 (2.725) 11^4}{449568 (4.2)^3} = .00003 \text{ ft.}$$

Some additional load & deflection should be included to account for the spent fuel & race. Even with these additional loads the deflection from the total Dead load on the slab is small when compared to the calculated yield deflection of .0014 ft. \therefore Neglect deflection due to dead load.

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

45010.61

J.O./W.O./CALCULATION NO. FDC
14235.17-C-01

REVISION
0

PAGE
75

PREPARED/DATE
R J. Butler 6/9/83

REVIEWER/CHECKER/DATE
R. Sulzberger 6-13-83

INDEPENDENT REVIEWER/DATE
Kenneth W. Schock 7/6/83

SUBJECT/TITLE
Load Drop Analysis for - SFHT-7

QA CATEGORY/CODE CLASS
I NSR

Summary of Results

refer: Attach #6

Drop #1 - Gate of wall

Ductility Ratio 2.06
Max. Deflection 0.0216

Drop #2 - Gate on Slab

	with water	No water
Ductility Ratio =	$\frac{\text{Drag}}{6.04}$	$\frac{\text{Drag}}{6.91}$
Maximum Barrier Deflection =	0.0085	.0104

CALCULATION SHEET

STONE & WEBSTER ENGINEERING CORPORATION

A501061

J.O./W.O./CALCULATION NO. <i>FPC</i> <i>14235.17-C-01</i>		REVISION <i>0</i>	PAGE <i>76</i>
PREPARER/DATE <i>R.D. Salkin 6/9/83</i>	REVIEWER/CHECKER/DATE <i>R. Kuehns 6-13-83</i>	INDEPENDENT REVIEWER/DATE <i>W. J. ... 7/6/83</i>	
SUBJECT/TITLE <i>Load Drop Analysis for SFHT-7</i>		QA CATEGORY/CODE CLASS <i>I NSR</i>	

Penetration & Scabbing NDRC (page 337) (refer #12)

$$X = \sqrt{4KNWd \left(\frac{V_0}{1000d} \right)^{1.8}}$$

$$d_c = \sqrt{\frac{4A}{\pi}} = \sqrt{\frac{4(.271)}{\pi}} = 7.05$$

$$K = \frac{180}{\sqrt{F_c}} = 3.28$$

$$N = .72$$

$$W = 3900$$

$$d = 7.05$$

$$V_0 = 6.78 \text{ ft/sec.}$$

$$\frac{x}{d} = .093$$

$$X = \sqrt{4(3.28)(.72)(3900)(7.05) \left(\frac{56.03}{1000(7.05)} \right)^{1.8}} = 6.57$$

$$s/d = 3.91 \left(\frac{x}{d} \right) - .718 \left(\frac{x}{d} \right)^2$$

$$s = 3.91(.93) - .718(.93)^2 = 3.0$$

$$s = 3.0(7.05) = 21" \quad \text{in}^2 < 60" \quad \text{OK}$$

CALCULATION SHEET		J.O./W.O./CALCULATION NO.	FPC	REVISION	PAGE
45010 61		14235.17-C-01		0	70.1
PREPARED/DATE	6/9/83	REVIEWER/CHECKER/DATE	6-13-83	INDEPENDENT REVIEWER/DATE	7/7/83
SUBJECT/TITLE		QA CATEGORY		CODE CLASS	
Lead Drop Analysis for SFHT-7		I		NSR	

Check Liner on bottom of pool. for Penetration.

Penetration of Steel

$$T = \frac{\left(\frac{MV^2}{2}\right)^{2/3}}{672 D} \quad (\text{refer } \# 16 \text{ page } 2-3) \\ \text{equation } 2-7$$

V = Velocity of Missile = 56.03 (no wave drag)

M: Mass of Missile = 121 lb-sec²/ft (wt. 39^{lb})

D = Diameter (equivalent) = $\sqrt{\frac{(1" \times 39")}{\pi}} = 7.05$

$$T = \frac{\left(\frac{56.03^2 (121)}{2}\right)^{2/3}}{672 (7.05)} = .697$$

required $t_p = 1.25 (.697) = .871"$

Penetration of Concrete (if no steel is present.)

$$X = 12 k_p A_p \text{Log}_{10} \left(1 + \frac{V_s^2}{215000}\right) \quad (\text{refer } \# 16 \text{ page } 2-1)$$

$f_c = 2000$
 $k_p = .0036$

$$A_p = \frac{3900 \text{ lb}}{.271 \text{ sq ft}} = 14391 \text{ sq ft} \quad X = 12 (.0036) 14391 \text{Log}_{10} \left(1 + \frac{56.03^2}{215000}\right)$$

$V_s = 56.03 \text{ ft/sec}$

$X = 3.9"$

$$\chi_i = [1 + e^{-4(\frac{X}{2} - 2)}] \chi = 3.9$$

J.O./W.O./CALCULATION NO. FPC		14235.17-C01	
REVISION		REVISOR	R.Z.
PREPARED/DATE		6/9/83	
REVIEWER/CHECKER/DATE		K. Anderson 6/9/83	
INDEPENDENT REVIEWER/DATE		G. Smith 9/7/83	
SUBJECT/TITLE		Drop Analysis for SHT-7	
QA CATEGORY/CODE CLASS		I/NSR	

Conclusion for Steel Liner

The actual thickness of the stainless steel liner is 3/16" (refer FPC. drawing "S21-110 to 112") This will below the value required by calculation, 0.0871". The concrete penetration calculation shows that that the gate would penetrate 3.9 inch of concrete if the liner was not present. From the combination of the concrete penetration and the thin steel liner it can be judged that the steel liner is not adequate for the impact of the gate.

IN	ECHO	1	2	3	4	5	6	7	8
1234567890123456789012345678901234567890123456789012345678901234567890									
LOAD DROP # 1 ANALYSIS FOR SFHT7--ON HALL								...	1
0.									2
1.0	3855.	0.0105	3855.	0.105	3855.	0.50	4.425		3
0.	0.0	0.	0.0						4
0.0	0.0	0.0	5.67	3.9					5
LOAD DROP # 2 ANALYSIS FOR SFHT7--ON SLAB WITHOUT WATER DRAG								...	6
0.									7
1.0	4326.	0.0015	4326.	0.015	4326.	0.200	14.137		8
0.	0.0	0.	0.0						9
0.0	0.0	0.0	6.78	3.9					10
LOAD DROP # 2 ANALYSIS FOR SFHT7--ON SLAB WITH WATER DRAG								...	11
0.									12
1.0	4326.	0.0014	4326.	0.0144	4326.	0.200	14.137		13
0.	0.0	0.	0.0						14
0.0	0.0	0.0	6.09	3.9					15
STOP									16

ATTACHMENT 6
 CALC. NO. C-01
 JO 14235.17
 PAGE 1 OF 4
 Prep: R J Sather 6/13/83
 Rev: P. Blumens 6/13/83
 I.R. Rishchay 7/10/83

77

LOAD DROP & 1 ANALYSIS FOR SFHT7--ON MALL

DATA ON MISSILE, BARRIER, AND LOAD COMBINATION EQUATION

BARRIER FORCE DISPLACEMENT RELATIONSHIP

KIPS	FEET
3855.0	0.0105
3855.0	0.1050
3855.0	0.5000

0.0 KIPS EQUIVALENT STATIC FORCE ** LOAD 1
 0.0 KIPS EQUIVALENT CONSTANT DYNAMIC FORCE ** LOAD 2
 0.0 KIP-SEC MISSILE IMPULSE RESISTED BY FORCE AT BARRIER SUPPORT PLUS BARRIER INERTIA DURING MOMENTUM TRANSFER ** LOAD 3
 5.670 KIP-SEC MISSILE IMPULSE RESISTED ONLY BY BARRIER INERTIA DURING MOMENTUM TRANSFER ** LOAD 4
 21.9 FPS BARRIER INITIAL VELOCITY DUE TO LOAD 4

BARRIER EQUIVALENT WEIGHT	MISSILE WEIGHT LOAD 3	MISSILE WEIGHT LOAD 4	BARRIER PLASTIC FORCE	BARRIER YIELD DEFLECTION	BARRIER PERIOD
KIPS	KIPS	KIPS	KIPS	FT	SEC
4.825	0.000	3.900	3855.0	0.0105	0.0030

RESULTS OF TIME HISTORY ANALYSIS FOR MISSILE IMPACT WITH OTHER LOADS

1	2	3	4	5	6	7	8	9
TIME HISTORY NUMBER	DURATION OF LOAD 3	MISSILE FORCE LOAD 3	FORCE AT BARRIER SUPPORT	TIME OF MAX BARRIER DEFLECTION	MAXIMUM BARRIER DEFLECTION	MAXIMUM BARRIER DUCTILITY	MAXIMUM BARRIER VELOCITY	FINAL BARRIER RESISTING MECHANISM
	SEC	KIPS	KIPS	SEC	FT	FT	FT/SEC	
0	0.0	0.0	3855.0	0.001720	0.0216	2.06	21.93	SPECIAL BARRIER SPRING

ATTACHMENT 6
 CALC. NO. C-01
 JO 14235.17
 PAGE 2 OF 4
 R.P. S. 6/13/83
 Rev R. S. 6/13/83

LOAD DROP # 2 ANALYSIS FOR SFHT7--ON SLAB WITHOUT WATER DRAG

DATA ON MISSILE, BARRIER, AND LOAD COMBINATION EQUATION

BARRIER FORCE DISPLACEMENT RELATIONSHIP

KIPS	FEET
4326.0	0.0015
4326.0	0.0150
4326.0	0.2000

0.0 KIPS EQUIVALENT STATIC FORCE ** LOAD 1
 0.0 KIPS EQUIVALENT CONSTANT DYNAMIC FORCE ** LOAD 2
 0.0 KIP-SEC MISSILE IMPULSE RESISTED BY FORCE AT BARRIER SUPPORT PLUS BARRIER INERTIA DURING MOMENTUM TRANSFER ** LOAD 3
 6.780 KIP-SEC MISSILE IMPULSE RESISTED ONLY BY BARRIER INERTIA DURING MOMENTUM TRANSFER ** LOAD 4
 12.1 FPS BARRIER INITIAL VELOCITY DUE TO LOAD 4

BARRIER EQUIVALENT HEIGHT	MISSILE WEIGHT LOAD 3	MISSILE WEIGHT LOAD 4	BARRIER PLASTIC FORCE	BARRIER YIELD DEFLECTION	BARRIER PERIOD
KIPS	KIPS	KIPS	FT	SEC	SEC
19.137	0.000	3.900	4326.0	0.0015	0.0025

RESULTS OF TIME HISTORY ANALYSIS FOR MISSILE IMPACT WITH OTHER LOADS

1 TIME HISTORY NUMBER	2 DURATION OF LOAD 3	3 MISSILE FORCE LOAD 3	4 FORCE AT BARRIER SUPPORT	5 TIME OF MAX BARRIER DEFLECTION	6 MAXIMUM BARRIER DEFLECTION	7 MAXIMUM BARRIER DUCTILITY	8 MAXIMUM BARRIER VELOCITY	9 FINAL BARRIER RESISTING MECHANISM
	SEC	KIPS	KIPS	SEC	FT		FT/SEC	
0	0.0	0.0	4326.0	0.001420	0.0104	6.91	12.10	SPECIAL BARRIER SPRING

Prop: R. D. S. *6/13/83*
 Rev: *6/13/83*
 I.R. *7/17/83*
 ATTACHMENT 6
 CALC. NO. C-01
 JO 14235.17
 PAGE 3 OF 4

LOAD DROP # 2 ANALYSIS FOR SFHT7--ON SLAB WITH WATER DRAG

DATA ON MISSILE, BARRIER, AND LOAD COMBINATION EQUATION

BARRIER FORCE DISPLACEMENT RELATIONSHIP

KIPS	FEET
4326.0	0.0014
4326.0	0.0144
4326.0	0.2000

0.0 KIPS EQUIVALENT STATIC FORCE ** LOAD 1
 0.0 KIPS EQUIVALENT CONSTANT DYNAMIC FORCE ** LOAD 2
 0.0 KIP-SEC MISSILE IMPULSE RESISTED BY FORCE AT BARRIER SUPPORT PLUS BARRIER INERTIA DURING MOMENTUM TRANSFER ** LOAD 3
 6.090 KIP-SEC MISSILE IMPULSE RESISTED ONLY BY BARRIER INERTIA DURING MOMENTUM TRANSFER ** LOAD 4
 10.9 FPS BARRIER INITIAL VELOCITY DUE TO LOAD 4

BARRIER EQUIVALENT WEIGHT	MISSILE WEIGHT LOAD 3	MISSILE WEIGHT LOAD 4	BARRIER PLASTIC FORCE	BARRIER YIELD EFFEC. DEFLECTION	BARRIER PERIOD
KIPS	KIPS	KIPS	KIPS	FT	SEC
14.137	0.000	3.900	4326.0	0.0014	0.0024

RESULTS OF YI... HISTORY ANALYSIS FOR MISSILE IMPACT WITH OTHER LOADS

1	2	3	4	5	6	7	8	9
TIME HISTORY NUMBER	DURATION OF LOAD 3	MISSILE FORCE LOAD 3	FORCE AT BARRIER SUPPORT	TIME OF MAX BARRIER DEFLECTION	MAXIMUM BARRIER DEFLECTION	MAXIMUM BARRIER DUCTILITY	MAXIMUM BARRIER VELOCITY	FINAL BARRIER RESISTING MECHANISM
SEC	SEC	KIPS	KIPS	SEC	FT	FT	FT/SEC	
0	0.0	0.0	4326.0	0.001480	0.0065	6.04	10.07	SPECIAL BARRIER SPRING

Prep: R.D. Bunker
 6/13/83
 Rev: K. Kuehner
 6/13/83
 I.R. Stubbely
 7/6/83

ATTACHMENT 6
 CALC. NO. C-01
 JO 14235,17
 PAGE 4 OF 4

ENCLOSURE 4

POSTULATED SPENT FUEL POOL GATE
DROP INTO FUEL POOL

STONE & WEBSTER ENGINEERING CORPORATION

CALCULATION TITLE PAGE

*SEE INSTRUCTIONS ON REVERSE SIDE

A 5010.64 (FRONT)

CLIENT & PROJECT				PAGE 1 OF 43		
CALCULATION TITLE (Indicative of the Objective): POSTULATED SPENT FUEL POOL GATE DROP INTO FUEL POOL				QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER		
CALCULATION IDENTIFICATION NUMBER						
J. O. OR W.O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	OPTIONAL WORK PACKAGE NO.		
14235-17	NM (C)	M-06				
* APPROVALS - SIGNATURE & DATE <i>John Lee 7-12-83</i>			REV. NO. OR NEW CALC NO.	SUPERSEDES * CALC. NO. OR REV. NO.	CONFIRMATION * REQUIRED (✓)	
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)			YES	NO
M. DURKOE 7/5/83	H.H. KUO 7/6/83	S.A. FELDMAN 7-12-83	0	-		✓

DISTRIBUTION*

GROUP	NAME & LOCATION	COPY SENT	GROUP	NAME & LOCATION	COPY SENT
RECORDS MGT. FILES (OR FIRE FILE IF NONE)	JOB BOOK	✓ Kuo			✓
	BOSTON FIRE FILE	✓			
EMD	S. LIU 6/30	✓			
EMD	H. KUO 36	✓			
EMA	S. FELDMAN 36	✓			
POWER	E. MICHAELS 6/28	✓			

14235.17 M05

STATEMENT OF REVIEW
CALCULATION NUMBER

This calculation has been reviewed in accordance with EMTP-12.8.22-0 and was found to be adequate. The method of review was:

- a. Review of Calculation
- b. Comparison with a similar previous calculation

1.	<u>John Kim Kw</u>	<u>7/6/83</u>	<u>a</u>	<u>0</u>
	REVIEWER	DATE	METHOD	REV.
2.	_____	_____	_____	_____
	REVIEWER	DATE	METHOD	REV.
3.	_____	_____	_____	_____
	REVIEWER	DATE	METHOD	REV.

The statement below applies to Nuclear Safety Related QA Category I calculations only.

This calculation has been INDEPENDENTLY reviewed in accordance with EMTP-12.8.22-0 and was found to be adequate. The method of review was: (list appropriate items)

- a. Comparison with prequalified methods and assumptions _____
(prequalified document number(s))

- b. Addressing the key questions appearing in EAP-5.3, and EAP-3.1

1.	<u>John Fedman</u>	<u>7-12-83</u>	<u>b</u>	<u>0</u>
	INDEPENDENT REVIEWER	DATE	METHOD	REV.
2.	_____	_____	_____	_____
	INDEPENDENT REVIEWER	DATE	METHOD	REV.
3.	_____	_____	_____	_____
	INDEPENDENT REVIEWER	DATE	METHOD	REV.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO.	DIVISION & GROUP NM(C)	CALCULATION NO. M06	OPTIONAL TASK CODE	
14235-17				

TABLE OF CONTENTS

PAGE

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

TITLE PAGE	1
REVIEW STATEMENT	2
TABLE OF CONTENTS	3
STATUS TABLE OF REVISIONS	4
OBJECTIVE	5
ASSUMPTIONS	6
METHOD	7
DESIGN INPUT	8
REFERENCES	9
MATERIALS	10
CONCLUSIONS	11
RESULTS SUMMARY	12-13
ANALYSIS	14
WEIGHT OF CANAL GATE	15-16
GATE DROP ONTO 1 ST SET OF RACKS	17-25
GATE DROP ONTO HIGH DENSITY FUEL RACKS	26-31
GATE SWING	32-33
LIFTING HOOKS ON GATE	34-41

REVISION STATUS TABLE

14235.17 - M06

PAGE NO. 7
CALCULATION NO. 14235.17-M06
JOB ORDER NO. 1423517

7736

REV NO.	PAGE NO.	REASON	REVISION/DATE	NON-INDEPENDENT REVIEWER/DATE	INDEPENDENT REVIEWER/DATE	APPROVAL/DATE

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>5</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
74235.17	MM(C)	M06		

OBJECTIVE

THE OBJECTIVES OF THIS CALCULATION ARE AS FOLLOWS:

- TO DETERMINE WHETHER THE SPENT FUEL STORAGE RACKS (BOTH STANDARD AND HIGH DENSITY CONFIGURATIONS) ARE CAPABLE OF PROTECTING THE FUEL BUNDLES FROM DAMAGE IN THE EVENT THE FUEL CANAL GATE IS DROPPED ON TOP OF THE RACKS
- IN THE EVENT THE RACKS ARE INCAPABLE OF WITHSTANDING THE DROP, DETERMINING HOW MANY FUEL BUNDLES COULD BE DAMAGED.
- DETERMINING THE FEASIBILITY OF A DUAL 3-TON HOIST LIFTING ARRANGEMENT FOR THE PURPOSE OF ELIMINATING THE POSTULATED GATE DROP.

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>6</u>
PROJECT W.O. NO. 14235.17	DIVISION & GROUP NM(C)	CALCULATION NO. M06	OPTIONAL TASK CODE	

ASSUMPTIONSFOR SPENT FUEL RACKS

- 1) MATERIAL PROPERTIES USED ARE THOSE FOR TYPE 304 STAINLESS STEEL @ 150°F.
- 2) WIDE FLANGE SECTION IS TAKEN TO BE W8X15.
- 3) MODE OF FAILURE IS DUE TO EXCESSIVE PLASTIC DEFORMATION.
- 4) BUCKLING IS NOT CONSIDERED.
- 5) EFFECTS OF FUEL BUNDLES ON DROP ARE IGNORED.

FOR HIGH DENSITY FUEL RACKS

- 1) POISON SHEETS, LAMINATED INTO STORAGE CELL WALLS, ARE NEGLECTED IN THE ANALYSIS.
- 2) EFFECTS OF FUEL BUNDLES ON DROP ARE IGNORED.

FOR GATE DROP

- 1) BOUNCY AND DRAG EFFECTS ARE NEGLECTED.
- 2) DROP HEIGHT IS TAKEN TO BE 3 FEET ABOVE THE 162' ELEVATION, FOR A TOTAL DROP DISTANCE OF 33 FEET. (SEE PG. 18)

ALLOWABLE STRESS FOR THE DESIGN OF THE LIFTING HOOR

OF THE GATE IS 0.6 σ_y (REF. 8)

CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>7</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
Q#235.17	NM(L)	M06		

METHOD

AN ENERGY BALANCE APPROACH IS UTILIZED IN THE ANALYSIS OF THE TWO TYPES OF FUEL STORAGE RACKS. THIS METHOD EQUATES THE STRAIN ENERGY OF SPECIFIED SECTIONS OF THE RACKS TO THE KINETIC ENERGY OF THE GATE AT IMPACT. IN THIS WAY THE MAXIMUM DEFORMATIONS OF THE ANALYZED RACK SECTIONS CAN BE DETERMINED. BY NEGLECTING LOCALIZED EFFECTS, THE USE OF AN ENERGY BALANCE WILL GIVE A LOWER BOUND DEFORMATION OF THE SECTIONS ANALYZED.

FOR THE ANALYSIS OF THE DUAL HOIST, ONE OF THE TWO CABLES IS ASSUMED TO SNAP. THE RESULTING MAXIMUM FORCE IN THE REMAINING CABLE IS THEN DETERMINED. THE LIFTING HOOKS OF THE GATE ARE ALSO TO BE ANALYZED TO INSURE THAT THEY ARE CAPABLE OF WITHSTANDING THE MAXIMUM RESULTANT FORCE

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>8</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM(c)	M06		

DESIGN INPUT

1) HEIGHT OF GATE DROP : 33 FEET (SEE PG. 18)

2) WEIGHT OF GATE : 1200 lb. (SEE PAGE 16)

3) CAPACITY OF HOIST : 3 TONS (REF. 9)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 86

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE
14235.17	NM(L)	MO6	

REFERENCES

- (1) ENTR 400-A, "MATERIAL PROPERTIES FOR PIPE RUPTURE ANALYSIS", APPR. A.L. VAUSICKEL, 19 NOV 1974, ENGINEERING MECHANICS DIVISION, STONE & WEBSTER ENGINEERING CORP.
- (2) VENDOR DRAWING # PR2859, REVISION C, "CANAL GATE", THE PRESLEY CORP.
- (3) FPC DRAWING # S-521-114, REVISION C, "AUXILIARY BUILDING SPENT FUEL RACKS", FLORIDA POWER CORPORATION
- (4) VENDOR DRAWING # 80 E 1490, REV 3, "STORAGE CELL TYPE 1", AUTOMATION INDUSTRIES INC.
- (5) VENDOR DRAWING # 80 E 1489, REV 2, "FUEL STORAGE RACK ARRAYS", AUTOMATION INDUSTRIES INC.
- (6) DRAWING # 136031 E, REV A, "MARK B2 FUEL ASSEMBLY DIMENSIONS FOR HANDLING & SHIPPING", BABCOCK & WILCOX COMPANY.
- (7) BLAKE, ALEXANDER; "PRACTICAL STRESS ANALYSIS IN ENGINEERING DESIGN", PP. 355-356, MARCEL DEKKER, INC., N.Y., 1982.
- (8) "MANUAL OF STEEL CONSTRUCTION - 7TH EDITION", AMERICAN INSTITUTE OF STEEL CONSTRUCTION, 1973.
- (9) VENDOR DRAWING, REF # M2871, "3 TON HOIST", EATON CORPORATION.
- (10) FPC DRAWING # L-002-003, REV II, "LAYOUT LONGITUDINAL SECTION THROUGH REACTOR BLDG. & SPENT FUEL PIT", FLORIDA POWER CORPORATION.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

A 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>10</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
□4235.17	NA(L)	M06		

MATERIALS & ALLOWABLES

RACKS & GATE: TYPE 304 STAINLESS STEEL,

$$\sigma_y = 27.5 \text{ ksi @ } 150^\circ\text{F. (REF 1)}$$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

A 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>11</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(L)	CALCULATION NO. MOG	OPTIONAL TASK CODE	
1	<u>CONCLUSIONS</u>			
2	(A) <u>IN THE EVENT OF A GATE DROP</u>			
3	1) NEITHER OF THE RACK DESIGNS ARE CAPABLE OF			
4	WITHSTANDING THE POSTULATED GATE DROP. THUS, THE			
5	GATE DROP WOULD POTENTIALLY RESULT IN DAMAGE			
6	TO THE FUEL BUNDLES.			
7	(B) <u>IF A DUAL HOIST ARRANGEMENT IS USED</u>			
8	1) A SINGLE HOIST IS CAPABLE OF TAKING THE MAXIMUM			
9	LOAD SHOULD THE SECOND HOIST'S CABLE SNAP. (THIS			
10	IS ASSUMING THE DUAL HOIST ARRANGEMENT IS			
11	USED). (DETAILED EXPLANATION ON P. 36)			
12	2) THE LIFTING HOOKS ON THE GATE WOULD HAVE TO			
13	BE CHANGED TO 1.25" DIAMETER ROD IF THE			
14	DUAL HOIST ARRANGEMENT IS USED. (DETAILED			
15	SKETCH ON P. 41)			
16	(C) <u>POTENTIAL FUEL DAMAGE IN THE EVENT OF A GATE DROP</u>			
17	1) 64 FUEL BUNDLES COULD BE SHOWN UP AGAINST			
18	OTHER FUEL BUNDLES. THIS SITUATION SHOULD BE INVESTIGATED			
19	TO DETERMINE WHETHER CRITICALITY OF THE FUEL IS			
20	REACHED.			
21	2) FOR THE CASE WHERE THE GATE LIES FLAT ON TOP OF			
22	THE RACK, IT COVERS 128 FUEL CELLS. THIS CASE SHOULD			
23	BE ANALYZED TO DETERMINE IF ANY THERMAL PROBLEMS			
24	EXIST.			
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>12</u>
J.O. OR W.O. NO. <u>14235.17</u>	DIVISION & GROUP NM(C)	CALCULATION NO. <u>1105</u>	OPTIONAL TASK CODE	

RESULTS SUMMARY

GATE SWING (DUAL HOIST ARRANGEMENT ASSUMING A CABLE SNAP)

1) FOR DUAL HOIST ARRANGEMENT: MAX. LOAD
 TO SECOND HOIST SHOULD ONE CABLE SNAP
 IS 6300 LB. (DETAILED ANALYSIS AND
 EXPLANATION ON PP 35-36).

2) GATE HOOK DIAMETER REQUIRED TO TAKE
 THE 6300 LB LOAD IS 1.25 INCHES

GATE DROP

SPENT FUEL RACKS

1) MAXIMUM DEFORMATIONS OF TWO SECTIONS
 ANALYZED: 233 INCHES AND 73 INCHES

HIGH DENSITY FUEL RACKS

1) LOWER BOUND DEFORMATION OF EDGE IMPACT
 (SMALLEST DIMENSION OF GATE IMPACTING):
22.1 INCHES

2) LOWER BOUND DEFORMATION OF EDGE IMPACT

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

A 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>13</u>
J.O. OR W.O. NO. 14235-17	DIVISION & GROUP NM (C)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

RESULTS SUMMARY (CONTINUED)

(LONGEST DIMENSION OF GATE IMPACTING) =

2.05 INCHES

3) NUMBER OF CELLS THAT COULD BE PUSHED UP AGAINST OTHER CELLS FROM IMPACT OF GATE.

a) FOR EDGE ON IMPACT, SMALLEST

DIMENSION OF GATE : 8 CELLS

b) FOR EDGE ON IMPACT, LONGEST

DIMENSION OF GATE : 69 CELLS

4) NUMBER OF CELLS THAT COULD BE COVERED SHOULD THE GATE LAND FLAT ON TOP OF THE RACK :

128 CELLS

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>14</u>
FIG. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17 14235.17	NM (C)	M06		

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46



ANALYSIS

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>15</u>
J.O. OR W.O. NO. 14235-17	DIVISION & GROUP NMCC)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

WEIGHT OF CANAL GATE



(SEE REF #2 FOR DETAILS)
 (CONCERNING DIMENSIONS)

DETERMINE WEIGHT OF GATE (NOTE: USING MAXIMUM CLEARANCES ON ALL DIMENSIONS)

SECTION ①: $332.5 \times 35.625 \times 1 = 11895.3$ $\gamma_{STEEL} = 0.283 \text{ } \frac{\text{lb}}{\text{in}^3}$
 $11895.3 (0.283) = \boxed{3352 \frac{1}{2}}$

SECTION ②: $24.375 \times 5.625 \times 1 = 137.1$ $137.1 (0.283) = \boxed{38 \frac{1}{2}}$

SECTION ③: $2 \left(\frac{\pi (5.625)^2}{4} \right) = 49.7$ $49.7 (0.283) = \boxed{14 \frac{1}{2}}$

SECTION ④: $1 [332.5 (1.5) 0.25] = 122.1$ $122.1 (0.283) = \boxed{34 \frac{1}{2}}$

SECTION ⑤: $1 \left[\frac{\pi (7.125^2 - 5.625^2)}{4} \right] 0.25 = 15$ $15 (0.283) = \boxed{4 \frac{1}{2}}$

SECTION ⑥: $2 (24.375 \times 0.25 \times 1.5) = 18.3$ $18.3 (0.283) = \boxed{5 \frac{1}{2}}$

SECTION ⑦: $2 \left(\frac{3}{4} \times 1 \times 332.5 \right) = 1335$ $1335 (0.283) = \boxed{569 \frac{1}{2}}$

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>16</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	MM (C)	MO6		

SECTION ①: $29.25 \times 0.75 \times 4 = 72.75$ $72.75(0.287) = \boxed{20.16}$

SECTION ②: $2 \left[\pi (6.375^2 - 5.625^2) / 4 \times 4 \right] =$ $56.5(0.283) = \boxed{16.16}$

TOTAL WEIGHT OF GATE IS EQUAL TO THE SUM OF THE WEIGHTS
 OF SECTIONS ① THROUGH ③

* TOTAL WEIGHT OF GATE = 91.51 lb

$\approx 1200 \text{ lb}$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46


STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010.65


CALCULATION IDENTIFICATION NUMBER				PAGE <u>17</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(C)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

GATE DROP ONTO 1ST SET OF FUEL RACKS

GATE TO BE DROPPED ON SECTIONS OF RACK
 INDICATED BELOW (SEE REF.#3 FOR RACK DETAILS)



RACK "C" (TOP) (FIGURE I)



AS THE WIDTH OF THE GATE, NEGLECTING THE $1\frac{1}{2} \times \frac{1}{4}$ SECTIONS AROUND
 THE PERIMETER, IS 37" AND THE BOTTOM CORNERS ARE
 ROUNDED, IT CAN BE ASSUMED THAT THE FULL IMPACT WILL BE
 TAKEN BY THE TWO ANGLES SHOWN ABOVE. THE GATE IS ASSUMED
 TO LIE IN THE Y-Z PLANE AND IMPACT THE MID-SPAN OF THE
 ANGLES.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 9010 85

CALCULATION IDENTIFICATION NUMBER				PAGE 19
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
4235.17	NM (L)	MO5		




FIGURE II

DROP HEIGHT

FROM REFERENCES (3 & 10) THE HEIGHT FROM THE TOP OF THE FUEL RACKS TO THE TOP OF THE POOL IS FOUND TO BE 30 FEET. AS THE GATE WILL ONLY BE LIFTED OUT OF THE CANAL JUST HIGH ENOUGH TO ALLOW IT TO BE MOVED (6"), 3 FEET IS ADDED TO THE DROP HEIGHT FOR CONSERVATISM. THIS BRINGS THE TOTAL DROP HEIGHT TO 33 FEET.


STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

A 5010 85


CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(C)	CALCULATION NO. MOE	OPTIONAL TASK CODE PAGE 19

SECTION OF RACK "C" (TOP) WHERE GATE COULD HIT.

MODELED AS A SIMPLY-SUPPORTED BEAM



$l = 15.25''$ (REF # 3)



DROP HEIGHT : 33'

WEIGHT OF GATE : 4200 lb.

(NEGLECT DRAG & BUOYANCY
 EFFECTS OF WATER)

POTENTIAL ENERGY @ ① = KINETIC ENERGY @ ②

$PE_{①} = mgh = 4200 (33) = \underline{138\ 600\ FT\cdot lb}$

VELOCITY @ IMPACT = $\sqrt{2gh} = \sqrt{2(32.2)33}$
 $= \underline{46\ FT/SEC}$ (31 mph)


$PE_{②} = \underline{1.663 \times 10^6\ IN\cdot lb}$

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>20</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP N/M (C)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46




$$k_1 = \frac{F}{\delta} \quad \delta = \frac{FL^3}{18EI}$$

$$\therefore k_1 = \frac{18EI}{L^3}$$

$$\begin{cases} D_p = F_p/k_1 \\ F_p = 4M_p/L \quad (\text{SIMPLY SUPPORTED BEAM}) \end{cases}$$

(FOR A SIMPLY-SUPPORTED BEAM, $M_{max} = \frac{FL}{4}$. LET $M_{max} = M_p$, $F = F_p = 4M_p/L$)

$$M_p = \sigma_y \int y dA = \sigma_y (\text{MOMENT OF AREA ABOUT NEUTRAL AXIS})$$




MOMENTS OF AREA

SECTION ① : $(0.592 - 0.125)(0.25(2)) = 0.233 \text{ in}^3$

SECTION ② : $(0.704)(0.25(1.908)) = 0.247 \text{ in}^3$

SECTION ③ : $(0.171)(0.312 - 0.125) = 0.019 \text{ in}^3$

$$\Sigma (\text{SECTION 1} + \text{SECTION 2}) = 0.233 + 0.247 = 0.480$$



ACTUAL BEAM CROSS-SECT.

THE ACTUAL BEAM CROSS-SECTION IS MADE UP OF TWO ANGLES, AS SHOWN AT THE LEFT, THEREFORE THE MOMENT OF THE AREA IS TWICE THE ABOVE VALUE.

$$\text{i.e. } 2(0.480) = \underline{0.960 \text{ in}^3}$$

$$M_p = \sigma_y (0.960) \quad (\text{IN-10})$$

$$F_p = 4\sigma_y (0.960) / 15.25 = 0.259 \sigma_y \quad (\text{LB})$$

(ASSUME 304 S.S. \rightarrow 27.5 KSI @ 150°F)

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 66

CALCULATION IDENTIFICATION NUMBER				PAGE <u>21</u>
J.O. OR W.O. NO. DA235.17	DIVISION & GROUP NAM (C)	CALCULATION NO. MO6 MO5	OPTIONAL TASK CODE	

THEN

$$M_p = (27.5 \times 10^3) \cdot 0.888 = \underline{27,170 \text{ in-lb.}}$$

$$F_p = 0.25(27.5 \times 10^3) = \underline{7122 \text{ lb.}}$$

$$K_1 = \frac{48EI}{L^3}$$

$$E = 27.9 \times 10^6 \text{ -Psi } (309 @ 152^\circ\text{F})$$

$$I = 2(0.384) = 0.768 \text{ in}^4$$

$$\therefore K_1 = \frac{48(27.9 \times 10^6) \cdot 0.768}{15.25^3} = \underline{290,000 \frac{\text{lb}}{\text{in}}}$$

$$D_p = \frac{F_p}{K_1} = \underline{0.024 \text{ INCHES}}$$

FOR ENERGY BALANCE:

$$\frac{1}{2} D_p F_p + F_p (\delta_{\max} - D_p) = 1.663 \times 10^6 \text{ in-lb}$$

SOLVING FOR δ_{\max}

$$\delta_{\max} = \frac{1.663 \times 10^6 - \frac{1}{2}(0.024)(7122)}{7122} + 0.02$$

$$= \underline{.253 \text{ INCHES}}$$



BECAUSE OF THE EXTREMELY LARGE δ_{\max} , A COMPLETE FAILURE
 OF THE SECTION IN QUESTION CAN BE ASSUMED.

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 65


CALCULATION IDENTIFICATION NUMBER			
I.O. OR W.O. NO. 14235-17	DIVISION & GROUP NA(C)	CALCULATION NO. M06	OPTIONAL TASK CODE PAGE 22

SECTION 2 OF FIGURE I



SECTION 2 IS ANALYZED AS A CANTILEVER BEAM DUE TO THE SUPPORT COLUMN LOCATED AT POINT A IN FIGURE I. LOCAL BUCKLING OF THE BEAM AND BUCKLING OF THE SUPPORT COLUMN ARE IGNORED. ANGLES WELDED TO THE END OF THE BEAM IN THE Z-Y DIRECTION ARE GUARDED

FIND CENTROID OF COMPOSITE SHAPE



$$C = \frac{1.06(4.43) + 2(7.152)(0.938)}{1.93 + 2(0.938)}$$

$$= \underline{4.986}$$

CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. DR235.17	DIVISION & GROUP N/M(C)	CALCULATION NO. MO6	OPTIONAL TASK CODE
			PAGE 23

CALCULATE I


$$I_{\text{NEUTRAL AXIS}} = 18.1 + 4.43 (0.92)^2 + 2 [0.348 + 0.938 (2.173)^2]$$

$$= \underline{61.1 \text{ in}^4}$$

MOMENT OF AREA ABOUT NEUTRAL AXIS

$$2 [2.173 (0.938)] + (0.3125 (4.015) 2.983) + (2.827) (0.245) (1.913) +$$

$$4.667 (0.245) 2.334 + (0.3125 (4.015) 4.823) = \underline{17.518 \text{ in}^3}$$



$$\delta = \frac{Fl^3}{3EI} \quad l = 21.1875 \text{''}$$

$$M_p = \sigma_y (\text{M.I. OF AREA ABOUT NEUT. AXIS}) = 27.5 \times 10^3 (17.518) = \underline{481,745 \text{ in} \cdot \text{lb}}$$

FOR A CANTILEVER BEAM, THE

MAXIMUM MOMENT $M_{\text{max}} = Fl$ LET $M_{\text{max}} = M_p$ FOR $F = F_p$ WE HAVE $F_p = \frac{M_p}{l}$

$$F_p = \frac{M_p}{l} \quad (\text{CANTILEVER BEAM})$$


$$= \frac{481,745}{21.1875}$$

$$= \underline{22,737 \text{ lb.}}$$

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 9010.85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 04235.17	DIVISION & GROUP NM(C)	CALCULATION NO. MO6	OPTIONAL TASK CODE
			PAGE 29



$$K_1 = \frac{F}{\delta} = \frac{3EI}{L^3}$$

$$= \frac{3(27.5 \times 10^6)(61.4)}{211875^3}$$

$$= \underline{540329 \frac{lb}{in}}$$

$$D_p = \frac{F_p}{K_1} = \frac{22737}{540329}$$

$$= \underline{0.042 \text{ in}}$$

FOR ENERGY BALANCE:

$$\frac{1}{2} D_p F_p + F_p (\delta_{max} - D_p) = 1.663 \times 10^6 \text{ in-lb.}$$

SOLVING FOR δ_{max} :

$$\delta_{max} = \frac{1.663 \times 10^6 - \frac{1}{2} (0.042)(22737)}{22737} + 0.042$$

$$= \underline{73.2''}$$

AGAIN, DUE TO THE EXTREMELY LARGE δ_{max} CALCULATED A COMPLETE FAILURE OF THE BEAM IS ASSUMED

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>45</u>
J.O. OR W.O. NO. 14235.17.	DIVISION & GROUP NM(C)	CALCULATION NO. MOT	OPTIONAL TASK CODE	

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46

ANALYSIS AT THIS POINT SHOWS THAT THE
FUEL STORAGE RACKS CANNOT WITHSTAND A DRO.
FROM THE CANAL GATE. THE TWO SECTIONS OF THE
RACK THAT WERE ANALYZED WERE SHOWN TO BE
INCAPABLE OF ABSORBING THE IMPACT ENERGY. THESE
SECTIONS WOULD EITHER TEAR OUT OR BEND OUT OF THE
WAY ; ALLOWING THE GATE TO CONTINUE DOWN THROUGH
THE RACK.

CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO.	DIVISION & GROUP NM(c)	CALCULATION NO. M06	OPTIONAL TASK CODE	
14235.17				
<u>TABLE OF CONTENTS</u>				<u>PAGE</u>
1	TITLE PAGE			1
2				
3				
4				
5	REVIEW STATEMENT			2
6				
7	TABLE OF CONTENTS			3
8				
9	STATUS TABLE OF REVISIONS			4
10				
11	OBJECTIVE			5
12				
13	ASSUMPTIONS			6
14				
15	METHOD			7
16				
17	DESIGN INPUT			8
18				
19	REFERENCES			9
20				
21	MATERIALS			10
22				
23	CONCLUSIONS			11
24				
25	RESULTS SUMMARY			12-13
26				
27	ANALYSIS			14
28				
29	WEIGHT OF CANAL GATE			15-16
30				
31	GATE DROP ONTO 1 ST SET OF RACKS			17-25
32				
33	GATE DROP ONTO HIGH DENSITY FUEL RACKS			26-31
34				
35	GATE SWING			32-33
36				
37	LIFTING HOOKS ON GATE			34-41
38				
39				
40				
41				
42				
43				
44				
45				
46				

REVISION STATUS TABLE

14235.17 - M06

PAGE NO. 7
CALCULATION NO. 14235.17-M06
JOB ORDER NO. 14235.17

7730

REV NO.	PAGE NO.	REASON	REVISION/DATE	NON-INDEPENDENT REVIEWER/DATE	INDEPENDENT REVIEWER/DATE	APPROVAL/DATE

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>5</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NH(C)	M06		

1
2 OBJECTIVE

3
4 THE OBJECTIVES OF THIS CALCULATION ARE AS FOLLOWS:

- 5
6
7
- 8 • TO DETERMINE WHETHER THE SPENT FUEL
9 STORAGE RACKS (BOTH STANDARD AND HIGH
10 DENSITY CONFIGURATIONS) ARE CAPABLE OF
11 PROTECTING THE FUEL BUNDLES FROM DAMAGE
12 IN THE EVENT THE FUEL CANAL GATE IS
13 DROPPED ON TOP OF THE RACKS
14
15
16
17
18
 - 19 • IN THE EVENT THE RACKS ARE INCAPABLE
20 OF WITHSTANDING THE DROP, DETERMINING
21 HOW MANY FUEL BUNDLES COULD BE DAMAGED.
22
23
24
25
26
 - 27 • DETERMINE THE FEASIBILITY OF A DUAL
28 3-TON HOIST LIFTING ARRANGEMENT FOR
29 THE PURPOSE OF ELIMINATING THE POSTULATED
30 GATE DROP.
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>6</u>
W.O. NO. 14235.17	DIVISION & GROUP NM(C)	CALCULATION NO. M06	OPTIONAL TASK CODE	

ASSUMPTIONS

FOR SPENT FUEL RACKS

- 1) MATERIAL PROPERTIES USED ARE THOSE FOR TYPE 304 STAINLESS STEEL @ 150°F.
- 2) WIDE FLANGE SECTION IS TAKEN TO BE W8x15.
- 3) MODE OF FAILURE IS DUE TO EXCESSIVE PLASTIC DEFORMATION.
- 4) BUCKLING IS NOT CONSIDERED
- 5) EFFECTS OF FUEL BUNDLES ON DROP ARE IGNORED.

FOR HIGH DENSITY FUEL RACKS

- 1) POISON SHEETS, LAMINATED INTO STORAGE CELL WALLS, ARE NEGLECTED IN THE ANALYSIS.
- 2) EFFECTS OF FUEL BUNDLES ON DROP ARE IGNORED

FOR GATE DROP

- 1) BOUNCY AND DRAG EFFECTS ARE NEGLECTED
- 2) DROP HEIGHT IS TAKEN TO BE 3 FEET ABOVE THE 162' ELEVATION, FOR A TOTAL DROP DISTANCE OF 33 FEET. (SEE PG. 18)

ALLOWABLE STRESS FOR THE DESIGN OF THE LIFTING HOOR

OF THE GATE IS 0.6 σ_y (REF. 8)

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>7</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM(L)	MO6		
1	<u>METHOD</u>			
2				
3				
4	AN ENERGY BALANCE APPROACH IS UTILIZED IN			
5	THE ANALYSIS OF THE TWO TYPES OF FUEL STORAGE			
6	RACKS. THIS METHOD EQUATES THE STRAIN ENERGY OF			
7	SPECIFIED SECTIONS OF THE RACKS TO THE KINETIC			
8	ENERGY OF THE GATE AT IMPACT. IN THIS WAY THE			
9	MAXIMUM DEFORMATIONS OF THE ANALYZED RACK			
10	SECTIONS CAN BE DETERMINED. BY NEGLECTING LOCALIZED			
11	EFFECTS, THE USE OF AN ENERGY BALANCE WILL GIVE			
12	A LOWER BOUND DEFORMATION OF THE SECTIONS ANALYZED.			
13				
14				
15				
16				
17				
18				
19				
20	FOR THE ANALYSIS OF THE DUAL HOIST, ONE OF			
21	THE TWO CABLES IS ASSUMED TO SNAP. THE RESULTING			
22	MAXIMUM FORCE IN THE REMAINING CABLE IS THEN			
23	DETERMINED. THE LIFTING HOOKS OF THE GATE ARE			
24	ALSO TO BE ANALYZED TO INSURE THAT THEY ARE			
25	CAPABLE OF WITHSTANDING THE MAXIMUM RESULTANT FORCE			
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				

CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>8</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(c)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

DESIGN INPUT

1) HEIGHT OF GATE DROP : 33 FEET (SEE PG. 18)

2) WEIGHT OF GATE : 1200 LB. (SEE PAGE. 16)

3) CAPACITY OF HOIST : 3 TONS (REF. 9)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 66

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE
14235.17	NM(C)	MO6	

PAGE 9

REFERENCES

- (1) ENTR 400-A, "MATERIAL PROPERTIES FOR PIPE RUPTURE ANALYSIS", APPR. A.L. VAN SICKEL, 13 NOV 1976, ENGINEERING-MECHANICS DIVISION, STONE & WEBSTER ENGINEERING CORP.
- (2) VENDOR DRAWING # PR2859, REVISION C, "CANAL GATE", THE PRESRAY CORP.
- (3) FPC DRAWING # S-521-114, REVISION C, "AUXILIARY BUILDING SPENT FUEL RACKS", FLORIDA POWER CORPORATION
- (4) VENDOR DRAWING # 80 E1490, REV 3, "STORAGE CELL TYPE 1", AUTOMATION INDUSTRIES INC.
- (5) VENDOR DRAWING # 80 E1489, REV 2, "FUEL STORAGE RACK ARRAYS", AUTOMATION INDUSTRIES INC.
- (6) DRAWING # 136031 E, REV A, "MARK BZ FUEL ASSEMBLY DIMENSIONS FOR HANDLING & SHIPPING", BABCOCK & WILCOX COMPANY.
- (7) BLAKE, ALEXANDER; "PRACTICAL STRESS ANALYSIS IN ENGINEERING DESIGN", PP. 355-356, MARCEL DEKKER, INC., N.Y., 1982.
- (8) "MANUAL OF STEEL CONSTRUCTION - 7TH EDITION", AMERICAN INSTITUTE OF STEEL CONSTRUCTION, 1973.
- (9) VENDOR DRAWING, REF # M2871, "3 TON HOIST", EATON CORPORATION.
- (10) FPC DRAWING # L-002-003, REV II, "LAYOUT LONGITUDINAL SECTION THROUGH REACTOR BLDG. & SPENT FUEL PIT", FLORIDA POWER CORPORATION.

CALCULATION SHEET

4 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>10</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM(L)	M06		

MATERIALS & ALLOWABLES

RACKS & GATE: TYPE 304 STAINLESS STEEL,

$$\sigma_y = 27.5 \text{ ksi @ } 150^\circ\text{F. (REF 1)}$$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>11</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(L)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

CONCLUSIONS(A) IN THE EVENT OF A GATE DROP

- 1) NEITHER OF THE RACK DESIGNS ARE CAPABLE OF WITHSTANDING THE POSTULATED GATE DROP. THUS, THE GATE DROP WOULD POTENTIALLY RESULT IN DAMAGE TO THE FUEL BUNDLES.

(B) IF A DUAL HOIST ARRANGEMENT IS USED

- 1) A SINGLE HOIST IS CAPABLE OF TAKING THE MAXIMUM LOAD SHOULD THE SECOND HOIST'S CABLE SNAP. (THIS IS ASSUMING THE DUAL HOIST ARRANGEMENT IS USED). (DETAILED EXPLANATION ON P. 36)
- 2) THE LIFTING HOOKS ON THE GATE WOULD HAVE TO BE CHANGED TO 1.25" DIAMETER ROD IF THE DUAL HOIST ARRANGEMENT IS USED. (DETAILED SKETCH ON P. 41)

(C) POTENTIAL FUEL DAMAGE IN THE EVENT OF A GATE DROP

- 1) 64 FUEL BUNDLES COULD BE SHOWN UP AGAINST OTHER FUEL BUNDLES. THIS SITUATION SHOULD BE INVESTIGATED TO DETERMINE WHETHER CRITICALITY OF THE FUEL IS REACHED.
- 2) FOR THE CASE WHERE THE GATE LIES FLAT ON TOP OF THE RACK, IT COVERS 128 FUEL CELLS. THIS CASE SHOULD BE ANALYZED TO DETERMINE IF ANY THERMAL PROBLEMS EXIST.

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>12</u>
J.O. OR W.O. NO. <u>14235.17</u>	DIVISION & GROUP <u>NM(C)</u>	CALCULATION NO. <u>106</u>	OPTIONAL TASK CODE	

RESULTS SUMMARY

GATE SWING (DUAL HOIST ARRANGEMENT ASSUMING A CABLE SNAP)

1) FOR DUAL HOIST ARRANGEMENT: MAX. LOAD TO SECOND HOIST SHOULD ONE CABLE SNAP IS 6300 LB. (DETAILED ANALYSIS AND EXPLANATION ON PP 35-36).

2) GATE HOOK DIAMETER REQUIRED TO TAKE THE 6300 LB. LOAD IS 1.25 INCHES

GATE DROP

SPENT FUEL RACKS

1) MAXIMUM DEFORMATIONS OF TWO SECTIONS ANALYZED: 233 INCHES AND 73 INCHES

HIGH DENSITY FUEL RACKS

1) LOWER BOUND DEFORMATION OF EDGE IMPACT (SMALLEST DIMENSION OF GATE IMPACTING):
22.1 INCHES

2) LOWER BOUND DEFORMATION OF EDGE IMPACT

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>13</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM (C)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

1
2
3 RESULTS SUMMARY (CONTINUED)

4
5 (LONGEST DIMENSION OF GATE IMPACTING) =

6 2.05 INCHES

7
8
9
10 3) NUMBER OF CELLS THAT COULD BE PUSHED
11 UP AGAINST OTHER CELLS FROM IMPACT
12 OF GATE.

13
14
15 a) FOR EDGE ON IMPACT, SMALLEST

16 DIMENSION OF GATE : 8 CELLS

17
18 b) FOR EDGE ON IMPACT, LONGEST

19 DIMENSION OF GATE : 64 CELLS

20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
NUMBER OF CELLS THAT COULD BE
COVERED SHOULD THE GATE LAND
FLAT ON TOP OF THE RACK :

128 CELLS

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 55

CALCULATION IDENTIFICATION NUMBER				PAGE <u>14</u>
PROJECT OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235 17 14235 17	NM (C)	M06		

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46



ANALYSIS

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET


▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>15</u>
J.O. OR W.O. NO. <u>14235.17</u>	DIVISION & GROUP <u>NMCC</u>	CALCULATION NO. <u>M06</u>	OPTIONAL TASK CODE	

WEIGHT OF CANAL GATE -----



SECTION A-A



(SEE REF #2 FOR DETAILS)
 (CONCERNING DIMENSIONS)

DETERMINE WEIGHT OF GATE (NOTE: USING MAXIMUM DIMENSIONS ON ALL DIMENSIONS)

SECTION ①: $332.5 \times 35.625 \times 1 = 11895.3$ $\gamma_{STEEL} = 0.283 \text{ } \frac{\text{lb}}{\text{in}^3}$

$11895.3 (0.283) = \boxed{3352 \frac{1}{2}}$

SECTION ②: $24.375 \times 5.625 \times 1 = 137.1$ $137.1 (0.283) = \boxed{38 \frac{1}{2}}$

SECTION ③: $2 \left(\frac{\pi (8.625)^2}{4} \right) \times 1 = 45.7$ $45.7 (0.283) = \boxed{12 \frac{1}{2}}$

SECTION ④: $4 \left[332.5 (1.5) (0.25) \right] = 498.7$ $498.7 (0.283) = \boxed{141 \frac{1}{2}}$

SECTION ⑤: $4 \left[\frac{\pi (7.125^2 - 5.625^2)}{4} \right] (0.25) = 15$ $15 (0.283) = \boxed{4 \frac{1}{2}}$

SECTION ⑥: $2 (24.375 \times 0.25 \times 1.5) = 18.3$ $18.3 (0.283) = \boxed{5 \frac{1}{2}}$

SECTION ⑦: $2 \left(\frac{3}{4} \times 4 \times 332.5 \right) = 1995$ $1995 (0.283) = \boxed{564 \frac{1}{2}}$

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>16</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM (C)	M06		

SECTION ⑧: $29.25 \times 0.75 \times 4 = 72.75$ $72.75(0.287) = \boxed{20.16}$

SECTION ⑨: $2 \left[\pi (6.375^2 - 5.625^2) / 4 \times 4 \right] =$ $56.5(0.283) = \boxed{16.16}$

TOTAL WEIGHT OF GATE IS EQUAL TO THE SUM OF THE WEIGHTS
 OF SECTIONS ① THROUGH ⑤

* TOTAL WEIGHT OF GATE = 4151.16

$\approx 1200 \text{ lb.}$

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46


STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 66

CALCULATION IDENTIFICATION NUMBER				PAGE 17
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP MM(c)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

GATE DROP ONTO 1ST SET OF FUEL RACKS

GATE TO BE DROPPED ON SECTIONS OF RACK
 INDICATED BELOW (SEE REF.#3 FOR RACK DETAILS)



AS THE WIDTH OF THE GATE, NEGLECTING THE $1\frac{1}{2} \times \frac{1}{4}$ SECTIONS AROUND
 THE PERIMETER, IS 37" AND THE BOTTOM CORNERS ARE
 ROUNDED, IT CAN BE ASSUMED THAT THE FULL IMPACT WILL BE
 TAKEN BY THE TWO ANGLES SHOWN ABOVE. THE GATE IS ASSUMED
 TO LIE IN THE Y-Z PLANE AND IMPACT THE MID-SPAN OF THE
 ANGLES.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE 19
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
4235.17	N/M (L)	1105		




FIGURE II

DROP HEIGHT

FROM REFERENCES (3 & 10) THE HEIGHT FROM THE TOP OF THE FUEL RACKS TO THE TOP OF THE POOL IS FOUND TO BE 30 FEET. AS THE GATE WILL ONLY BE LIFTED OUT OF THE CANAL JUST HIGH ENOUGH TO ALLOW IT TO BE MOVED (26"), 3 FEET IS ADDED TO THE DROP HEIGHT FOR CONSERVATISM. THIS BRINGS THE TOTAL DROP HEIGHT TO 33 FEET.


STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85


CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 4235.17	DIVISION & GROUP NM(C)	CALCULATION NO. MOE	OPTIONAL TASK CODE
			PAGE 19

SECTION OF RACK "C" (TOP) WHERE GATE COULD HIT.

MODELED AS A SIMPLY-SUPPORTED BEAM



$l = 15.25''$ (REF # 3)



DROP HEIGHT : 33'

WEIGHT OF GATE : 4200 lb.

(NEGLECT DRAG & BOUNCY EFFECTS OF WATER)

POTENTIAL ENERGY @ ① = KINETIC ENERGY @ ②

$P.E. @ ① = mgh = 4200 (33) = 138600 \text{ FT}\cdot\text{lb}$

VELOCITY @ IMPACT = $\sqrt{2gh} = \sqrt{2(32.2)33}$


= 46 FT/SEC (31 mph)

$P.E. @ ② = 1.663 \times 10^6 \text{ IN}\cdot\text{lb}$

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

45010 05

CALCULATION IDENTIFICATION NUMBER				PAGE <u>20</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP N/M (C)	CALCULATION NO. MO6	OPTIONAL TASK CODE	




$$K_1 = \frac{F}{\delta} \quad \delta = \frac{FL^3}{18EI}$$

$$\therefore K_1 = \frac{18EI}{L^3}$$

$$\begin{cases} D_p = F_p / K_1 \\ F_p = 1 M_p / L \quad (\text{SIMPLY SUPPORTED BEAM}) \end{cases}$$

(FOR A SIMPLY-SUPPORTED BEAM, $M_{max} = \frac{FL}{4}$. LET $M_{max} = M_p$, $F = F_p = 4M_p/L$)

$$M_p = \sigma_y \int y dA = \sigma_y (\text{MOMENT OF AREA ABOUT NEUTRAL AXIS})$$



MOMENTS OF AREA

SECTION ① :


$$(0.592 - 0.125) (0.25 (2)) = 0.233 \text{ in}^2$$

SECTION ② :

$$(0.704) (0.25 (1.908)) = 0.247 \text{ in}^2$$

$$\text{SECTION ③ : } (0.171) (0.25 (2)) = 0.019 \text{ in}^2$$

$$\Sigma I_{NA} = 0.231 + 0.247 + 0.011 = \underline{0.489}$$



ACTUAL BEAM CROSS-SECT.

THE ACTUAL BEAM CROSS-SECTION IS MADE UP OF TWO ANGLES, AS SHOWN AT THE LEFT, THEREFORE THE MOMENT OF THE AREA IS TWICE THE ABOVE VALUE.

$$i.e. \quad 2(0.489) = \underline{0.978 \text{ in}^2}$$

$$M_p = \sigma_y (0.978) \quad (\text{IN-10})$$

$$F_p = 1 \sigma_y (0.978) / 15.25 = 0.259 \sigma_y \quad (\text{LB})$$

(ASSUME 304 S.S. \rightarrow 27.5 KSI @ 150°F)

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. D#235.17	DIVISION & GROUP NAA (C)	CALCULATION NO. MOC MO5	OPTIONAL TASK CODE
			PAGE 21

THEN

$$M_p = (27.5 \times 10^3) \cdot 0.808 = \underline{27,170 \text{ in-lb}}$$

$$F_p = 0.253(27.5 \times 10^3) = \underline{7122 \text{ lb}}$$

$$K_1 = \frac{18 E I}{L^3}$$

$$E = 27.9 \times 10^6 \text{ -Psi} \quad (309 @ 150^\circ\text{F})$$

$$I = 2(0.304) = 0.768 \text{ in}^4$$

$$\therefore K_1 = \frac{18(27.9 \times 10^6) \cdot 0.768}{15.25^3} = \underline{290,000 \frac{\text{lb}}{\text{in}}}$$

$$D_p = \frac{F_p}{K_1} = \underline{0.024 \text{ INCHES}}$$

FOR ENERGY BALANCE:

$$\frac{1}{2} D_p F_p + F_p (\delta_{\max} - D_p) = 1.663 \times 10^6 \text{ in-lb}$$

SOLVING FOR δ_{\max}

$$\delta_{\max} = \frac{1.663 \times 10^6 - \frac{1}{2}(0.024)(7122)}{7122} + 0.024$$

$$= \underline{.233 \text{ INCHES}}$$



BECAUSE OF THE EXTREMELY LARGE δ_{\max} , A COMPLETE FAILURE
 OF THE SECTION IN QUESTION CAN BE ASSUMED.

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010.65


CALCULATION IDENTIFICATION NUMBER			
10. DR. W. O. NO. 14235.17	DIVISION & GROUP NA(C)	CALCULATION NO. MO6	OPTIONAL TASK CODE
			PAGE 22

SECTION 2 OF FIGURE I



SECTION 2 IS ANALYZED AS A CANTILEVER BEAM DUE TO THE SUPPORT COLUMN LOCATED AT POINT A IN FIGURE I. LOCAL BUCKLING OF THE BEAM AND BUCKLING OF THE SUPPORT COLUMN ARE IGNORED. ANGLES WELDED TO THE END OF THE BEAM, IN THE ±Y DIRECTION ARE IGNORED

FIND CENTROID OF COMPOSITE SHAPE



$$C = \frac{4.06(4.43) + 2(7.153)(0.938)}{7.93 + 2(0.938)}$$

$$= \underline{4.980}$$

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>23</u>
J.O. OR W.O. NO. D235.17.	DIVISION & GROUP NAM(C)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

CALCULATE I


$$I_{\text{NEUTRAL AXIS}} = 18.1 + 4.13 (0.92)^2 + 2 [0.348 + 0.938 (2.173)^2]$$

$$= \underline{61.4 \text{ in}^4}$$

MOMENT OF AREA ABOUT NEUTRAL AXIS

$$Z [2.173 (0.938)] + (0.3125 (4.015) 2.983) + (2.827) (0.245) (1.913) +$$

$$4.667 (0.245) 2.334 + (0.3125 (4.015) 4.823) = \underline{17.518 \text{ in}^3}$$



$$\delta = \frac{Fl^3}{3EI} \quad l = 21.1875 \text{ ''}$$

$$M_p = S_y (\text{MOM. OF AREA ABOUT NEUT. AXIS}) = 27.5 \times 10^3 (17.518) = \underline{481,745 \text{ in}\cdot\text{lb}}$$

FOR A CANTILEVER BEAM, THE

MAXIMUM MOMENT $M_{\text{max}} = Fl$ LET $M_{\text{max}} = M_p$ FOR $F = F_p$ WE HAVE $F_p = \frac{M_p}{l}$

$$F_p = \frac{M_p}{l} \quad (\text{CANTILEVER BEAM})$$


$$= \frac{481,745}{21.1875}$$

$$= \underline{22,737 \text{ lb.}}$$

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(C)	CALCULATION NO. M06	OPTIONAL TASK CODE
			PAGE 29



$$K_1 = \frac{F}{\delta} = \frac{3EI}{L^3}$$

$$= 3(27.9 \times 10^6)(61.4) / 211875^3$$

$$= \underline{540\,329 \frac{lb}{in}}$$

$$D_p = \frac{F_p}{K_1} = \frac{22\,737}{540\,329}$$

$$= \underline{0.042 \text{ in}}$$

FOR ENERGY BALANCE:

$$\frac{1}{2} D_p F_p + F_p (\delta_{max} - D_p) = 1.663 \times 10^6 \text{ in-lb.}$$

SOLVING FOR δ_{max} :

$$\delta_{max} = \frac{1.663 \times 10^6 - \frac{1}{2}(0.042)(22\,737)}{22\,737} + 0.042$$

$$= \underline{73.2''}$$

AGAIN, DUE TO THE EXTREMELY LARGE δ_{max} CALCULATED A COMPLETE FAILURE OF THE BEAM IS ASSUMED

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>25</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NAC(L)	CALCULATION NO. MOC	OPTIONAL TASK CODE	
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				

ANALYSIS AT THIS POINT SHOWS THAT THE FUEL STORAGE RACKS CANNOT WITHSTAND A DROP FROM THE CANAL GATE. THE TWO SECTIONS OF THE RACK THAT WERE ANALYZED WERE SHOWN TO BE INCAPABLE OF ABSORBING THE IMPACT ENERGY. THESE SECTIONS WOULD EITHER TEAR OUT OR BEND OUT OF THE WAY ; ALLOWING THE GATE TO CONTINUE DOWN THROUGH THE RACK.

CALCULATION SHEET

▲ 9010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>26</u>
J.O. OR W.O. NO. <u>14235.1Z</u>	DIVISION & GROUP <u>NM(C)</u>	CALCULATION NO. <u>M06</u>	OPTIONAL TASK CODE	

GATE DROP ONTO HIGH DENSITY FUEL RACKS

THE HIGH DENSITY FUEL RACKS ARE MADE UP OF INDIVIDUAL CELLS, WITH EACH CELL MODELED AS A LONG, THIN-WALLED SQUARE TUBE. BECAUSE OF THE THIN WALL'S AND THE TACK WELD CONSTRUCTION (SEE REF'S #4 & #5), IT IS NOT EXPECTED THAT THE RACKS WILL BE ABLE TO WITHSTAND THE IMPACT BY THE GATE. FOR THIS REASON AN ENERGY BALANCE IS USED TO CALCULATE THE TOTAL DEFORMATION OF THE RACKS WITH THE ASSUMPTION ^{THAT} NO LOCAL BUCKLING OR TEARING OCCURS. BY NEGLECTING LOCAL CRUSH AND TEARING, AND ONLY CONSIDERING UNIAxIAL DEFORMATION OF THE THIN WALLED SECTIONS, THE DEFORMATION ARRIVED AT THROUGH THE ENERGY BALANCE APPROACH WILL REPRESENT A LOWER BOUND ON THE ACTUAL DEFORMATION.

BY CONSIDERING THE GEOMETRY OF THE GATE (REF. 2) AND THE GEOMETRY OF THE RACK (REF. 5) IT CAN BE SHOWN THAT AN END ON IMPACT, AS SHOWN IN FIGURE (II), WILL AFFECT 4 FUEL CELLS (SEE FIGURE (II)). AS CAN BE SEEN IN FIG (II), 6 WALL SECTIONS OF THE 4 TUBES ARE HIT. WITH THIS INFORMATION WE PROCEED AS FOLLOWS:

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 86

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE
84235 17	NM (C)	MOE	
			PAGE 27




FIGURE (III)




FIGURE (II)

OF THE SIX SIDES AFFECTED WE ONLY CONSIDER THE MATERIAL DIRECTLY UNDER THE GATE, I.E. THE THICKNESS OF THE GATE (GATE WIDTH = 4" (REF #2)).

THICKNESS OF WALL = 0.12"

TOTAL # OF WALLS AFFECTED = 6

WIDTH OF AFFECTED WALL UNDER CONSIDERATION = 4"

LENGTH OF TUBE = 163"

AREA = $0.12 (6) 4 = \underline{2.88 \text{ in}^2}$

∴ EQUIVALENT MODEL FOR IMPACT ANALYSIS IS A ROD OF CROSS-SECTIONAL AREA 2.88 in², 163" LONG.

CALCULATE THE YIELD FORCE

$F_y = \sigma_y A = 27.5 (2.88) = \underline{79.2 \text{ KIPS}}$

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. D4235.17	DIVISION & GROUP NAM (C)	CALCULATION NO. MOB	OPTIONAL TASK CODE PAGE 28

CALCULATE DEFLECTION AT F_y . (δ_y)


$$\delta_y = F_y l / AE$$

l = LENGTH OF EQUIVALENT ROD

$$= 79.2(163) / 2.08(30 \times 10^3)$$

$$= 163''$$

$$= \underline{0.15 \text{ INCHES}}$$



SETTING UP THE ENERGY BALANCE EXPRESSION AND SOLVING FOR δ_{max} YIELDS

$$\begin{aligned} \delta_{max} &= \frac{K.E. + \frac{1}{2} \delta_y F_y}{F_y - 4200} \\ &= \frac{1.663 \times 10^6 + \frac{1}{2} (0.15) 79200}{79200 - 4200} \\ &= \underline{22.1 \text{ INCHES}} \end{aligned}$$

SIMILARLY, FOR AN EDGE IMPACT LENGTHWISE (WHERE THE LONG EDGE IMPACTS) IT CAN BE DETERMINED FROM THE GEOMETRY OF THE GATE AND RACK (REFS (2) & (5)) THAT 32 CELLS COULD BE DIRECTLY HIT. FOLLOWING THE SAME

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>29</u>
J.O. OR W.O. NO. <u>14235.17</u>	DIVISION & GROUP <u>NM(C)</u>	CALCULATION NO. <u>MO6</u>	OPTIONAL TASK CODE	

PROCEDURE AS BEFORE :

THICKNESS OF WALL = 0.12 "

TOTAL # OF WALLS AFFECTED = 32(2) = 64

WIDTH OF AFFECTED WALL = 1 "

TOTAL LENGTH OF TUBE = 163 "

AREA = $0.12(64) \times 1 = 30.7 \text{ IN}^2$

∴ EQUIVALENT MODEL FOR IMPACT ANALYSIS IS A ROD OF
 CROSS-SECTIONAL AREA 30.7 IN^2 , 163 IN. LONG

YIELD FORCE


$F_y = \sigma_y A = 27.5(30.7) = 844.8 \text{ KIP}$

DEFLECTION AT F_y (δ_y)

$$\delta_y = \frac{F_y L}{AE}$$

$$= \frac{844.8(163)}{30.7(30 \times 10^3)}$$

$$= 0.15 \text{ INCHES}$$



STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>30</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(L)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

SETTING UP THE ENERGY BALANCE EXPRESSION AND SOLVING

FOR δ_{max} YIELDS:

$$\begin{aligned} \delta_{max} &= \frac{K.E. + \frac{1}{2} \delta_y F_y}{F_y - 4200} \\ &= \frac{1.663 \times 10^6 + \frac{1}{2} (0.15) 844 800}{844 800 - 4200} \\ &= \underline{2.05"} \end{aligned}$$

AS STATED EARLIER, BOTH OF THE DEFORMATIONS REPRESENT LOWER BOUNDS FOR THE ACTUAL DEFORMATIONS AS ALL LOCALIZED EFFECTS HAVE BEEN IGNORED. IN ACTUALITY, THE MODE OF FAILURE WOULD PROBABLY BE LOCAL BUCKLING OF THE TUBE SECTION WHICH WOULD RESULT IN MUCH LESS ENERGY DISSIPATION AND FAR GREATER DEFORMATIONS.

THE POSSIBILITY ALSO EXISTS THAT THE GATE COULD IMPACT BETWEEN THE FUEL CELLS, RATHER THAN DIRECTLY ON TOP OF THEM. THE GATE WEDGING ITSELF BETWEEN THE FUEL CELLS WOULD FORCE THE ADJACENT CELLS UP AGAINST OTHER CELLS. THIS COULD POSSIBLY PRESENT A CRITICALITY PROBLEM. FOR THE SMALL END IMPACT DESCRIBED FIRST, 8 CELLS COULD BE DISPLACED AND FORCED UP AGAINST OTHER CELLS. FOR THE LONG EDGE IMPACT, 69 CELLS WOULD BE DISPLACED.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>31</u>
J.O. OR W.O. NO. <u>14235.17</u>	DIVISION & GROUP <u>HMCC</u>	CALCULATION NO. <u>MOB</u>	OPTIONAL TASK CODE	

1
2
3 A THIRD POSSIBILITY EXISTS AS WELL. THAT IS THAT
4
5 THE GATE COULD LAND FLAT ON TOP OF THE RACK
6
7 AND BLOCK THE CIRCULATION THROUGH 128 (4x32)
8
9 CELLS.

10
11
12 AS A FURTHER NOTE, A COMPARISON OF THE FUEL
13
14 BUNDLE LENGTH WITH THE HEIGHT OF THE RACK
15
16 (SEE REF'S (5) & (6)) SHOWS THAT THE FUEL
17
18 BUNDLE STICKS OUT OF THE TOP OF THE RACK BY 2".

19
20
21 LENGTH OF FUEL BUNDLE = $165 \frac{5}{8}$ "

22
23 LENGTH OF FUEL CELL = $163 \frac{5}{8}$ "

24 THIS FURTHER INCREASES THE LIKELIHOOD OF FUEL BUNDLE
25
26 DAMAGE DUE TO A DROP, AS THERE IS A HIGH PROBABILITY
27
28 ANYTHING DROPPED ON THE RACK WILL IMPACT THE
29
30 FUEL BUNDLES FIRST.

31
32
33 THE ABOVE INFORMATION ON THE GATE IMPACTING THE
34
35 HIGH DENSITY RACKS WAS TRANSMITTED TO POWER
36
37 FOR THE PURPOSE OF DETERMINING WHETHER OR NOT
38
39 THE POSTULATED DAMAGE TO THE FUEL IS ACCEPTABLE.
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET


A 5010 88

CALCULATION IDENTIFICATION NUMBER				PAGE <u>32</u>
J.O. OR W.O. NO. A235.17	DIVISION & GROUP NMLC	CALCULATION NO. MO6	OPTIONAL TASK CODE	

GATE SWING

POSTULATED ACCIDENT: ONE OF THE TWO HOIST CABLES SNAP

OBJECTIVE: TO FIND THE MAXIMUM FORCE IN THE REMAINING CABLE.



INITIAL CONDITION

SINCE $\lambda \ll R$ AND THE MOTION OF A BODY IS RELATIVELY SMALL,
 WE ASSUME THE x AND θ MOTIONS CAN BE DECOUPLED.

(1) FOR θ MOTION,

- $W = 4200 \text{ lbs}$
- $a = 13.5 \text{ INCHES}$ *
- $d = 168.5 \text{ INCHES}$ *

$$I \ddot{\theta} + W d \theta = 0$$

THE INITIAL CONDITIONS ARE

$$\theta(t=0) = \theta_0 \approx a/d$$

$$\dot{\theta}(t=0) = 0$$

* ALL GATE DIMENSIONS ARE FROM REF. 2

WHICH IS A PENDULUM EQUATION. THE MAXIMUM CABLE'S TENSION OCCURS WHEN THE PENDULUM ATTAINS ITS MAXIMUM VELOCITY, i.e.

$$\frac{1}{2} I \dot{\theta}^2 = W a = W d (1 - \cos \theta_0) \rightarrow \dot{\theta}^2 = 2 W d (1 - \cos \theta_0) / I$$

AND THE MAXIMUM TENSION IN THE CABLE DUE TO CENTRIFUGAL FORCE IS


$$\Delta T = \frac{W}{g} d \dot{\theta}^2 = \frac{2 W^2 d^2}{g I} (1 - \cos \theta_0). \text{ DETAILED CALCULATION FOLLOWS.}$$

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.05

CALCULATION IDENTIFICATION NUMBER				PAGE <u>33</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(C)	CALCULATION NO. MO5	OPTIONAL TASK CODE	

GATE SWING



WEIGHT = 4200 lb.

$$d = \sqrt{13.5^2 + 168^2} = 168.5''$$

MASS MOMENT OF INERTIA ABOUT POINT OF ROTATION

$$I_o = I_{CG} + m d^2$$

$$I_{CG} = \frac{1}{12} m (b^2 + a^2)$$

$$= \frac{1}{12} \left[\frac{4200}{32.2(1.25)} \right] (336^2 + 29^2)$$

$$= 103\ 638 \text{ in} \cdot \text{lb} \cdot \text{s}^2$$

$$I_o = 103\ 638 + \left(\frac{4200}{32.2(1.25)} \right) (168.5)^2$$

$$= 912\ 901 \text{ in} \cdot \text{lb} \cdot \text{s}^2$$

KINETIC ENERGY = TRANSLATIONAL (K.E.) + ROTATIONAL (K.E.)


$$K.E. = \frac{1}{2} m (d\dot{\theta})^2 + \frac{1}{2} I_o (\dot{\theta})^2$$

$$= \frac{1}{2} (\dot{\theta})^2 (I_o + m d^2)$$

WHERE
 $I = I_o + m d^2$

$$K.E. = P.E. = W h$$

$$\therefore \frac{1}{2} (\dot{\theta})^2 I = W h$$



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE 74
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NMCC1	CALCULATION NO. MO6	OPTIONAL TASK CODE	

1
2
3
4
5
6
7
8
9

$$\therefore \theta = \sqrt{2Wh/I} = \sqrt{2(4200)0.5/412401}$$
$$= 0.1 \text{ RAD/S}$$

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

FORCE DUE TO ROTATION

$$\Delta T = m d \omega^2$$
$$= \left(\frac{4200}{386.4}\right) 168.5 (0.1)^2$$
$$= \underline{18.31 \text{ lbs}} \approx 0$$

WHICH IS NEGLIGIBLE.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>35</u>
J.O. OR W.O. NO. 2235.17	DIVISION & GROUP N.M (C)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

(3) FOR X MOTION

$$M \ddot{x} + K_1 x = W$$

THE INITIAL CONDITIONS ARE

$$x(t=0) = \frac{W}{2K_1}$$

$$\dot{x}(t=0) = 0$$

THE SOLUTION TO THE ABOVE EQUATION IS

$$x = A \cos \omega t + B \sin \omega t + \frac{W}{K_1} \quad \omega = \sqrt{\frac{K_1}{M}}$$

FROM $x(t=0) = \frac{W}{2K_1}$

$$\frac{W}{2K_1} = A + \frac{W}{K_1} \quad \rightarrow \quad A = -\frac{W}{2K_1}$$

FROM $\dot{x}(t=0) = 0 \quad B = 0$

$$\therefore x = \frac{W}{K_1} - \frac{W}{2K_1} \cos \omega t$$

THE MAXIMUM X IS

$$(x)_{\max} = \frac{W}{K_1} - \frac{W}{2K_1} (-1) = \frac{3W}{2K_1}$$

THEREFORE, THE MAXIMUM ^(CABLE FORCE) DUE TO TRANSLATIONAL MOTION IS

$$R = K_1 (x)_{\max} = \frac{3W}{2}$$

$$\therefore R = \frac{3(4200)}{2} = 6300 \text{ lb.}$$

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 1A235.17	DIVISION & GROUP NM(L)	CALCULATION NO. 705	OPTIONAL TASK CODE


PAGE 36

1
2
3
4 THE MAXIMUM FORCE, 6300 LB., IS 300 LB. GREATER
5 THAN THE RATED CAPACITY OF THE HOIST, 6000 LB. BUT,
6 AS HOISTS ARE DESIGNED WITH FACTORS OF SAFETY
7 OF 5 OR 6, AND THAT THE POSTULATED EVENT IS
8 A ONE-TIME OCCURANCE, IT CAN BE CONCLUDED
9 THAT A SINGLE HOIST CAN SUFFICIENTLY HANDLE THE
10 MAXIMUM LOAD.
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>37</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(C)	CALCULATION NO. MO6	OPTIONAL TASK CODE	

LIFTING HOOKS ON GATE



$$M_{\theta} = M_0 - \frac{WR}{2} \sin \theta + HR(1 - \cos \theta) \quad (1)$$

$$M_x = M_0 - \frac{WR}{2} + H(R+x) \quad (2)$$

WHERE:

$$M_0 = \frac{WRC_1}{2} \quad (3)$$

$$H = \frac{WC_2}{2} \quad (4)$$

$$C_1 = \frac{(k+2)[k^3 + 6k^2 + 12k(4-\pi) + 98(\pi-3)]}{k^4 + 4\pi k^3 + 48k^2 + 24\pi k + 24(\pi^2-8)} \quad (5)$$

$$C_2 = \frac{12(k+2)[(\pi-2)k + 2(4-\pi)]}{k^4 + 4\pi k^3 + 48k^2 + 24\pi k + 24(\pi^2-8)} \quad (6)$$

$$k = L/R \quad (7)$$

$$W = 6300 \text{ lb.}$$

[EXPRESSIONS (1)-(7)
 FROM REF #7]

FIRST WE CHECK THE ADEQUACY OF THE EXISTING LIFT

HOOKS. (REF. 2)

$$R = 1.75''$$

$$L = 2''$$

$$\text{DIAMETER} = 0.5''$$

$$k = \frac{L}{R} = \frac{2}{1.75} = 1.143$$

$$C_1 = \frac{(1.143 + 2)[1.143^3 + 6(1.143)^2 + 12(1.143)(4-\pi) + 98(\pi-3)]}{1.143^4 + 4\pi(1.143)^3 + 48(1.143)^2 + 24\pi(1.143) + 24(\pi^2-8)}$$

$$= \frac{87.67}{219.18} = \underline{0.405}$$

$$C_2 = \frac{12(1.143 + 2)[(\pi-2)1.143 + 2(4-\pi)]}{219.18} = \underline{0.580}$$

CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>18</u>
J.O. OR W.O. NO. <u>14235.17</u>	DIVISION & GROUP <u>NM(C)</u>	CALCULATION NO. <u>MDE</u>	OPTIONAL TASK CODE	

THEN

$$M_0 = \left(\frac{6300}{2} \right) 1.75 (0.103) = \underline{2254 \text{ IN-LB.}}$$

$$H = \left(\frac{6300}{2} \right) 0.580 = \underline{1827 \text{ LB}}$$

THE MAXIMUM STRESS AT $\theta = 0$ OCCURS AT THE INSIDE FIBER,

FROM REF (#7 pg. 333) WE GET

$$\sigma_{\theta=0} = \left(\frac{M_0 C}{I} + \frac{H}{A} \right) \phi_0$$

WHERE: ϕ_0 IS THE
CORRECTION FACTOR
FOR THE INSIDE FIBER
OF A CURVED BEAM.

$$\text{FROM REF (#7 pg. 334)} : \phi_0 = \underline{1.19}$$

THEN:

$$\sigma_{\theta=0} = \left(\frac{2254 (0.25)}{\left(\frac{\pi}{4}\right) (0.25)^3} + \frac{1827}{\pi (0.25)^2} \right) 1.19$$

$$= (95930 + 9304) 1.19 = \underline{62967 \text{ PSI}}$$

THE OTHER POINT OF CONCERN IS POINT A ($x=1$). FOR

THIS CASE WE HAVE:

$$M_{x=1} = M_0 - \frac{WR}{2} + H(R+1)$$

$$= 2254 - \frac{6300(1.75)}{2} + 1827(2.75)$$

$$= \underline{1766 \text{ IN-LB}}$$

$$\sigma_{x=1} = \left(\frac{M_{x=1} C}{I} + \frac{(P/2)}{A} \right)$$

$$= \left(\frac{1827 (0.5)}{\left(\frac{\pi}{4}\right) (0.5)^3} + \frac{6300}{2(\pi) (0.5)^2} \right) = \underline{13314 \text{ PSI}}$$

CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>39</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
142-5.17	NM(C)	FE		

USING THE CRITERIA THAT $\tau_{MAX} < 0.6 \sigma_y$ (16,500 PSI)
 WE CAN SEE THAT $\tau_{B=0} >> 16.5$ KSI. THEREFORE WE
 MUST RESIZE THE HOOKS.

WE WANT TO MAINTAIN A $1\frac{1}{2}$ " INSIDE DIAMETER OF THE
 HOOK. WE THEN TRY A 1" DIAMETER ROD.

THEN

$$L = 2" \quad , \quad R = 2"$$

$$k = \frac{L}{R} = 1$$

$$\begin{aligned}
 C_1 &= \frac{(1+2) [1+6 + 12(4-\pi) + 48(\pi-3)]}{1+4\pi + 48 + 24\pi + 24(\pi^2-8)} \\
 &= \frac{72.292}{181.835} = \underline{0.397}
 \end{aligned}$$

$$\begin{aligned}
 C_2 &= \frac{12(1+2) [(\pi-2) + 2(4-\pi)]}{181.835} \\
 &= \frac{102.902}{181.835} = \underline{0.566}
 \end{aligned}$$

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>10</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM(6)	M06		

$$M_0 = \left(\frac{6300}{2} \right) 2 (0.397) = \underline{2501 \text{ IN-LB}}$$

$$H = \left(\frac{6300}{2} \right) (0.566) = \underline{1782 \text{ IN-LB}}$$

THE EXPRESSION FOR THE STRESS AT $\theta = 0^\circ$ IS GIVEN BY (AS BEFORE)

$$\sigma_{\theta=0^\circ} = \left(\frac{M_0 C}{I} + \frac{H}{A} \right) \phi_{\text{INSIDE CURVE}}$$

WHERE: $\phi_{\text{INSIDE CURVE}}$ IS
THE CORRECTION FACTOR FOR
THE INSIDE RADIUS OF A
CURVED BEAM

THEREFORE, FOR A CIRCULAR CROSS SECTION OF 1" DIAMETER,

$$R = 2" \text{ WE HAVE: } \phi_0 = \underline{1.23} \text{ (REF #7, PG. 334)}$$

THEN,

$$\begin{aligned} \sigma_{\theta=0} &= \left(\frac{2501 (0.5)}{\left(\frac{\pi}{4} \right) (0.5)^4} + \frac{1782}{\pi (0.5)^2} \right) 1.23 \\ &= (12737 + 2269) 1.23 = \underline{18450 \text{ PSI}} \end{aligned}$$

THE STRESS AT $X = 1"$ IS GIVEN BY:

$$\sigma_{X=1"} = \left(\frac{M_x C}{I} + \frac{W}{A} \right)$$

$$\begin{aligned} M_x &= M_0 - \frac{W R}{2} + H(R+x) \\ &= 2501 - \frac{6300(2)}{2} + 2375(3) \\ &= \underline{3326 \text{ IN-LB.}} \end{aligned}$$

CALCULATION SHEET

▲ 9010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>41</u>
J.O. OR W.O. NO. 142-5.17	DIVISION & GROUP M&M (C)	CALCULATION NO. MOL	OPTIONAL TASK CODE	

THEN, THE STRESS AT $x=1$ " IS:

$$\sigma_{x=1} = \left(\frac{3320 (0.5)}{\pi/4 (0.5)^3} + \frac{6300}{2\pi (0.5)^2} \right)$$

$$= 16,939 + 4010 = \underline{\underline{20,949 \text{ PSI}}}$$

BASED ON THE CRITERION THAT THE MAXIMUM STRESS MUST BE LESS $0.6 \sigma_y$ WE HAVE:

$$\sigma_{\max} \neq \sigma_{x=1} > 16,500 \text{ PSI}$$

THEREFORE, FOR $R=2$ " & $D=1$ " WE HAVE NOT SATISFIED THE $0.6 \sigma_y$ CRITERIA.

WE NEXT TRY $D=1.25$ ". WE ALSO WISH TO MAINTAIN AN INSIDE RADIUS OF 1.5 " $\therefore R=2.125$ "

$$\frac{L}{R} = \frac{2}{2.125} = 0.9411 = k \quad f_0 = 1.33 \text{ (REF #7, PG. 334)}$$

THEN

$$C_1 = \frac{(0.9411+2) [0.9411^3 + 6(0.9411)^2 + 12(0.9411)(4-\pi) + 48(\pi-2)]}{0.9411^4 + 4\pi(0.9411)^3 + 48(0.9411)^2 + 24\pi(0.9411) + 24(\pi^2-8)}$$

$$= \frac{56.739}{165.613} = \underline{\underline{0.339}}$$

$$C_2 = \frac{2(0.9411+2) [(\pi-2)0.9411 + 2(4-\pi)]}{165.613}$$

$$= \frac{38.511}{165.613} = 0.580$$

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>42</u>
J.D. OR W.O. NO. <u>14-2-11</u>	DIVISION & GROUP <u>NM (C)</u>	CALCULATION NO. <u>M06</u>	OPTIONAL TASK CODE	

THEN, AS BEFORE

$$M_0 = \left(\frac{6300}{2} \right) 2.125 (0.393) = \underline{2630} \text{ IN-LB.}$$

$$H = \left(\frac{6300}{2} \right) 0.580 = \underline{1827} \text{ LB.}$$

THE STRESS AT $\theta = 0^\circ$ IS:

$$\begin{aligned} \sigma_{\theta=0} &= \left(\frac{2630 (0.625)}{\frac{\pi}{4} (0.625)^3} + \frac{1827}{\pi (0.625)^2} \right) 1.33 \\ &= (8572 + 1488) 1.33 \\ &= \underline{13380} \text{ PSI} \end{aligned}$$

THE STRESS AT $x = 1''$ IS:

$$\sigma_{x=1''} = \left(\frac{M_x C}{I} + \frac{(W/2)}{A} \right)$$

$$\begin{aligned} M_x &= 2630 - \frac{6300 (2.125)}{2} + 1827 (3.125) \\ &= \underline{1675} \text{ IN-LB} \end{aligned}$$

$$\begin{aligned} \sigma_{x=1''} &= \left(\frac{1675 (0.625)}{\frac{\pi}{4} (0.625)^3} + \frac{(1.500/2)}{\pi (0.625)^2} \right) \\ &= (5363 + 2566) \\ &= \underline{7929} \text{ PSI} \end{aligned}$$

THE STRESSES ARE BELOW 16.5 KSI \therefore $d = 1.25''$ & $R = 2.125''$



ARE ADEQUATE.

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>43</u>
J.O. OR W.O. NO. <u>4235.17</u>	DIVISION & GROUP <u>NM (C)</u>	CALCULATION NO. <u>MO6</u>	OPTIONAL TASK CODE	

CHECK THE WELDS



* (FROM REF. 2)

FOR 2 FILLET WELDS

$$A = [0.707 W (1)] 2 = 5.65 W$$

$$I = \frac{1}{12} (0.707)(2) W (1)^3 + 2 (0.707 W) (1) (0.625)^2$$

$$= 7.54 + 2.2 = 9.54 W$$

$$f_1 = \frac{3150}{5.65 W} + \frac{(1645 + 1827(2)) 0.625}{9.54 W} = \frac{557.5}{W} + \frac{347.1}{W}$$

$$= \frac{904.6}{W}$$

$$f_2 = \frac{1827}{5.65 W} + \frac{(1645 + 1827(2)) 2}{9.54 W} = \frac{323}{W} + \frac{1110}{W}$$

$$= \frac{1433}{W}$$

$$\sqrt{f_1^2 + f_2^2} = \frac{1694}{W}, \text{ SET THIS EQUAL TO } 18 \times 10^3 \text{ PSI (REF B, PG. 5-21)}$$

THEN : $W = 0.034$ INCHES

USE $W = \frac{1}{4}$ INCHES


CALCULATION SHEET

▲ 5010 86

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 2235.17	DIVISION & GROUP N.M.C.	CALCULATION NO. MO6	OPTIONAL TASK CODE
			PAGE 43

THEREFORE, THE FINAL CONFIGURATION FOR THE HOOK IS AS

FOLLOWS:



SECTION A-A

USE 1/4" FILLET WELDS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

ENCLOSURE 5

POSTULATED DROP OF 7,000-lb JACK
ONTO SPENT FUEL POOL MISSILE SHIELDS

CALCULATION TITLE PAGE

*SEE INSTRUCTIONS ON REVERSE SIDE

▲ 5010 64 (FRONT)

CLIENT & PROJECT FLORIDA POWER / CRYSTAL RIVER - UNIT 3				PAGE 1 OF 33	
CALCULATION TITLE (Indicative of the Objective): POSTULATED DROP OF 7000 POUND JACK ONTO SPENT FUEL POOL MISSILE SHIELDS				QA CATEGORY (✓) <input checked="" type="checkbox"/> I - NUCLEAR SAFETY RELATED <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> OTHER	
CALCULATION IDENTIFICATION NUMBER					
J.O. OR W.O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIONAL TASK CODE	OPTIONAL WORK PACKAGE NO.	
M235.17	NM (C)	14235.17-M-07	-	-	
* APPROVALS - SIGNATURE & DAT. <i>Shan Liu 7/21/83</i>			REV. NO. OR NEW CALC NO.	SUPERSEDES * CALC. NO. OR REV. NO.	CONFIRMATION * REQUIRED (✓)
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)			YES NO
M. BURKEE 7/13/83	H. H. KUD 7/15/83	S. M. FELDMAN 7-20-83	5	14235.17-M-05	-
DISTRIBUTION*					
GROUP	NAME & LOCATION	COPY SENT (✓)	GROUP	NAME & LOCATION	COPY SENT (✓)
RECORDS MGT. FILES (OR FIRE FILE IF NONE)	JOB BOOK				
	BOSTON FIRE FILE				
EMD	S. LIU 6/3RD				
EMD	H. H. KUD 3G				
EMD	S. FELDMAN 3G				
	E. MICHAELIS 6/3R				
	J. POSUSNEY 50				
	FPC				

This calculation has been reviewed in accordance with (EMAG-CH-41-2) and was found to be adequate. The method of review was: (List appropriate items)

- a. Review of calculations
- b. Comparison with similar calculation (number _____.)
- c. Number by number check

26. Stein Kuo / 7-15-83 / 0 / C
NONINDEPENDENT REVIEWER/DATE/REV./METHOD

NONINDEPENDENT REVIEWER/DATE/REV./METHOD

NONINDEPENDENT REVIEWER/DATE/REV./METHOD

NONINDEPENDENT REVIEWER/DATE/REV./METHOD

NONINDEPENDENT REVIEWER/DATE/REV./METHOD

NONINDEPENDENT REVIEWER/DATE/REV./METHOD

The statement below applies to Nuclear Safety Related QA Category I calculations only.

This calculation has been INDEPENDENTLY reviewed in accordance with EMAG-CH-41-2 and was found to be adequate. The method of review was: (List appropriate items)

- a. Comparison with prequalified methods and assumptions

prequalified document number(s)

- b. Addressing the key questions appearing in Attachment 13.11 of EMAG-CH-41-2

S.M. Feldman / 7-20-83 / 0 / 6
INDEPENDENT REVIEWER/DATE/REV./METHOD

INDEPENDENT REVIEWER/DATE/REV./METHOD

INDEPENDENT REVIEWER/DATE/REV./METHOD

INDEPENDENT REVIEWER/DATE/REV./METHOD

INDEPENDENT REVIEWER/DATE/REV./METHOD

INDEPENDENT REVIEWER/DATE/REV./METHOD

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO. 4235:17	DIVISION & GROUP VM (C)	CALCULATION NO. 4235:17-M-0>	OPTIONAL TASK CODE	

TABLE OF CONTENTS

	<u>PAGE</u>
TITLE PAGE	1
REVIEW STATEMENT	2
TABLE OF CONTENTS	3
STATUS TABLE OF REVISIONS	4
OBJECTIVE	5
ASSUMPTIONS	6
METHOD OF ANALYSIS	7
DESIGN INPUT	8
REFERENCES	9-10
MATERIALS	11
CONCLUSIONS	12
RESULTS SUMMARY	13
ANALYSIS	14
ENERGY BALANCE APPROACH	14-23
USE OF LIMITAZ TO MODEL BEAM IMPACT	24-31
COMPUTER LOG	32
MICROFICHE	33

REVISION STATUS TABLE

CALCULATION NO. 14235:17-M-D 7
JOB ORDER NO. 14235:17

7730

REV NO.	PAGE NO.	REASON	REVISOR / DATE	NON-INDEPENDENT REVIEWER / DATE	INDEPENDENT REVIEWER / DATE	APPROVAL / DATE

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 14235;17	DIVISION & GROUP NM (C)	PROJECT NUMBER 14235;17-M-07	OPTIONAL TASK CODE
			PAGE <u>5</u>

1
2
3 OBJECTIVE

4 THE OBJECTIVE OF THIS CALCULATION IS TO ANALYZE
5
6 A POSTULATED DROP OF A 7,000 LB. HYDRAULIC JACK
7
8 , FROM THE MECHANICAL SCAFFOLDING ON TOP OF THE CONTAINMENT
9
10 BUILDING, ONTO THE SPENT FUEL POOL MISSILE SHIELDS.
11
12 IT IS DESIRED TO DETERMINE THE ENERGY AT IMPACT, THE
13
14 POTENTIAL FOR JACK TO DEFORM SHIELD AND FALL INTO THE POOL,
15
16 AND CONCRATE EMBEDMENT LOADS FOR STRUCTURAL EVALUATION.
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.D. NO. 14235:17	DIVISION & GROUP NM(C)	14235:17-M-07 14235:17-M-07	OPTIONAL TASK CODE
			PAGE 6

ASSUMPTIONS

- 1) MISSILE SHIELD IS MODELED AS A SIMPLY SUPPORTED BEAM,
FOR ENERGY BALANCE APPROACH,
- 2) A BEAM RESPONSE IS ELASTIC-PERFECTLY PLASTIC.
- 3) THE EFFECTS OF LOCAL BUCKLING ARE NOT CONSIDERED
- 4) JACK IS MODELED AS A 26" DIAMETER, 5 FOOT LONG
CYLINDER.
- 5) THE JACK IS TAKEN TO IMPACT, ON END, IN THE CENTER
OF A SINGLE MISSILE SHIELD.
- 6) THE ENERGY DISSIPATED BY THE JACK PASSING
THROUGH THE ROOF OF THE FUEL BUILDING IS NEGLECTED

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 19235.17	DIVISION & GROUP NM(L)	CALCULATION NO. 19235.17-M-07	OPTIONAL TASK CODE
			PAGE <u>7</u>

1
2
3 METHOD

4
5 AS A FIRST APPROACH,
6 AN ENERGY BALANCE METHOD, IS UTILIZED FOR THE
7 MISSILE SHIELD ANALYSIS AS IT IS A SIMPLER, AND MORE
8 CONSERVATIVE APPROACH THAN USING NON-LINEAR
9 LARGE DEFLECTION ANALYSIS. THE ENERGY BALANCE
10 METHOD INVOLVES SETTING THE KINETIC ENERGY AT
11 IMPACT EQUAL TO THE STRAIN ENERGY OF THE
12 TARGET. IN THIS WAY THE MAXIMUM DEFLECTION OF
13 THE MISSILE SHIELD CAN BE DETERMINED. A SLIGHTLY
14 MODIFIED APPROACH IS ALSO UTILIZED WHICH TAKES INTO
15 ACCOUNT STRAIN-RATE EFFECTS AND THE EFFECTIVE
16 MASS OF THE SHIELD.
17
18
19
20
21
22
23
24
25
26

27 A NON-LINEAR DYNAMIC ANALYSIS COMPUTER CODE
28 (LIMITA 2) IS THEN UTILIZED TO ELIMINATE CONSERVATISM
29 INHERENT IN THE ENERGY BALANCE APPROACH, FOR THE
30 PURPOSE OF MINIMIZING THE MAXIMUM DEFORMATION OF
31 THE SHIELD.
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>6</u>
J.O. OR W.O. NO. 14235-17	DIVISION & GROUP NM(C)	CALCULATION NO. 14235.17-M-07	OPTIONAL TASK CODE	

DESIGN INPUT

- 1) DROP HEIGHT : ELEVATION 280' (REF. 5)
- 2) IMPACT HEIGHT : ELEVATION 162' (REF'S. 3 & 4)
- 3) HYDRAULIC JACK :

LENGTH - 5'	}	PER TELECON WITH FLORIDA POWER
DIAMETER - 26"		
WEIGHT - 7000 lb		
- 4) MISSILE SHIELD :

LENGTH - 29'	}	(REF. 3)
WIDTH - 30"		
DEPTH - 25"		
MATERIAL - A36 STRUCTURAL STEEL		

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>9</u>
J.O. OR W.O. NO. 14235:17.	DIVISION & GROUP NM(C)	CALCULATION NO. 14235:17-M-07	OPTIONAL TASK CODE	

REFERENCES

- (1) "TOPICAL REPORT - DESIGN OF STRUCTURES FOR MISSILE IMPACT" - SC-TOP-9 REV. 2, BECHTEL POWER CORP., SEPT. 1974.
- (2) "THE CONTROL OF HEAVY LOADS AT CRYSTAL RIVER UNIT NO. 3, NUREG-0612 SIX MONTH REPORT," NUS REPORT 3874; AUGUST 29, 1981.
- (3) FPC DRAWING NUMBER S-521-116, REV. 1, "AUXILIARY BUILDING SPENT FUEL PIT MISSILE SHIELDING", FLORIDA POWER CORPORATION
- (4) FPC DRAWING NUMBER L-002-003, "LAYOUT LONGITUDINAL SECTION THRU REACTOR BLDG. & SPENT FUEL PIT", FLORIDA POWER CORPORATION
- (5) VENDOR DRAWING # 3138-1 (FPC REFERENCE # S 01B3, SHEET 1, 2, & 3.)
- (6) SALMON, C. B., JOHNSON, J. E., "STEEL STRUCTURES - DESIGN AND BEHAVIOR", INTERT EDUCATIONAL PUBLISHERS, 1971.
- (7) EMTR-900A, "MATERIAL PROPERTIES FOR PIPE RUPTURE ANALYSIS", NOV. 19, 1976, STONE & WEBSTER ENGINEERING CORPORATION.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>10</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM(C)	14235.17-M-07		

1
2
3 (8) "NON LINEAR DYNAMIC ANALYSIS OF PLANE FRAMES
4 (LIMIT 2) : USERS MANUAL", REVISED SEPTEMBER 1980,
5
6 STONE & WEBSTER ENGINEERING CORPORATION, ST-223.
7
8

9
10 (9) ROLFE, D.K., BARSON, J.M., " FRACTURE AND FATIGUE CONTROL
11 IN STRUCTURES : APPLICATIONS OF FRACTURE MECHANICS",
12 PRENTICE - HALL , 1977.
13
14

15
16 (10) NUREG - 0800, STANDARD REVIEW PLAN, SECTION 3.5.3,"
17 BARRIER DESIGN PROCEDURES", U.S. NUCLEAR REGULATORY
18 COMMISSION, JULY 1981.
19
20

21
22 (11) NUREG - 0800, STANDARD REVIEW PLAN, SECTION 3.6.2,
23 DETERMINATION OF RUPTURE LOCATIONS AND DYNAMIC
24 EFFECTS ASSOCIATED WITH THE POSTULATED RUPTURE
25 OF PIPING, REV. 1, JULY 1981.
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>11</u>
J.O. OR W.O. NO. T4235:17	DIVISION & GROUP NM(L)	CALCULATION NO. T4235:17-M-07	OPTIONAL TASK CODE	

1
2
3 MATERIALS
4

5 1) MISSILE SHIELDS - TYPE = A36 STRUCTURAL STEEL
6

7 $\sigma_y = 36 \text{ KSI}$
8

9 $E = 30 \times 10^3 \text{ KSI}$
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>12</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM(C)	14235.17-M-07		

CONCLUSIONS

RESULTS OF THE ANALYSIS SHOWS THAT THE DUCTILITY RATIO IS 13.5, WHICH EXCEEDS THE VALUE OF 10 SPECIFIED (REF 10) IN SRP 3.5.3. HOWEVER, BASED ON THE FACT THAT THE SHIELD HAS NOT FAILED AND ALLOWED THE JACK TO FALL INTO THE POOL, AND BASED ON OTHER ARGUMENTS PRESENTED ON PP. 29-31, IT IS RECOMMENDED THAT THE ABOVE DUCTILITY RATIO OF 13.5 IS ACCEPTABLE AND REDESIGN OF MISSILE SHIELD IS NOT REQUIRED.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
I.O. OR W.O. NO. 14235:17	DIVISION & GROUP NM(C)	CALCULATION NO 14235:17-M-07	OPTIONAL TASK CODE
			PAGE <u>13</u>


RESULTS SUMMARY

(A) FROM ENERGY BALANCE APPROACH -- A SIMPLIFIED METHOD

- 1) KINETIC ENERGY OF JACK AT IMPACT = 812,000 FT-10
- 2) VELOCITY OF JACK AT IMPACT = 86 FT/SEC
- 3) DEFLECTION OF SHIELD WHICH WOULD ALLOW THE JACK TO FALL THROUGH = 51 INCHES

(B) FROM A DETAILED NONLINEAR DYNAMIC ANALYSIS

- 1) MAXIMUM DEFLECTION OF SHIELD:
 - a.) 16.375" (BASED ON THE USE OF THE LIMITA 2 COMPUTER CODE)
- 2) DUE TO THE HIGH LOADS DEVELOPED AT THE EMBEDMENTS THEY ARE ASSUMED TO PULL OUT. THE LOADS THEN DEVELOPED ON THE FLOOR ARE:



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 14235:17	DIVISION & GROUP M(C)	CALCULATION NO. 14235:17-M-07	OPTIONAL TASK CODE
			PAGE 19

1
2
3 ANALYSIS

4 (A) ENERGY BALANCE APPROACH

5 TWO ENERGY BALANCE APPROXIMATES WERE USED TO
6 CALCULATE THE MAXIMUM DEFLECTION OF THE MISSILE
7 SHIELD. THE FIRST METHOD DOES NOT CONSIDER
8 THE EFFECTIVE MASS OF THE BEAM OR STRAIN
9 RATE EFFECTS. THE SECOND METHOD DOES CONSIDER
10 THESE IN THE ANALYSIS. THIS SECOND METHOD
11 FOLLOWS THE PROCEDURE OUTLINED IN REFERENCE 1.
12
13
14
15
16
17
18

19
20 (B) NONLINEAR DYNAMIC ANALYSIS

21 THE MISSILE SHIELD IS MODELED AS A LUMPED-MASS
22 BEAM-ELEMENT SYSTEM, AND A BILINEAR STRESS-STRAIN
23 CURVE IS USED TO SIMULATE THE NON-LINEAR BEHAVIOR
24 OF THE MATERIAL. THE VELOCITY OF THE JACK AT IMPACT
25 AND THE GRAVITATIONAL FORCE OF THE JACK IS APPLIED
26 AT THE MID-SPAN OF THE BEAM THROUGH THE USE
27 OF THE LIMITA COMPUTER CODE (REF B) TO DETERMINE
28 THE STRUCTURAL RESPONSE.
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46


STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 14235:17	DIVISION & GROUP VM (L)	CALCULATION NO. 14235:17-M-07	OPTIONAL TASK CODE
			PAGE 15

(A) ENERGY-BALANCE APPROACH

POSTULATED DROP SITUATION



$280 - 169 = 116'$ → HEIGHT THROUGH WHICH THE JACK FALLS BEFORE IMPACTING THE MISSILE SHIELDS

K.E. - P.E. = 0

$P.E. = mgh = 7000 (116) = 812,000 \text{ Ft.-lb}$


$\frac{1}{2} m v^2 - mgh = 0 \rightarrow v = \sqrt{2gh} = \sqrt{2(32.2)(116)}$
 $= 86 \text{ Ft./sec}$
 $= 1032 \text{ in./sec}$

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET


▲ 5010 85

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 14235:17	DIVISION & GROUP NM (C)	CALCULATION NO. 14235:17-M-07	OPTIONAL TASK CODE
			PAGE 16

MISSILE SHIELD IMPACT



$l = 27'-8" = 332"$




MATERIAL: A36,
 $\sigma_y = 36$ KSI
 (REF. 3)

CROSS-SECTION OF
 MISSILE SHIELD (REF. 3)
 $A_x = 60 \text{ in}^2$

$M_p = \sigma_y \int y dA$

$= \sigma_y (\text{MOMENT OF AREA ABOUT NEUT. AXIS})$



MOMENT OF THE AREA

$8 (12 \times \frac{3}{8}) 6 + 2 (\frac{1}{2} \times 30) 12.25 = 547.5 \text{ in}^3$

PLASTIC MOMENT & YIELD FORCE

$M_p = \sigma_y (547.5) = 36 \times 10^3 (547.5) = 19.71 \times 10^6 \text{ in-lb.}$

$F_p = 4 M_p / l = 4 (19.71 \times 10^6) / 332 = 237,470 \text{ lb.}$

(FOR A SIMPLY-SUPPORTED BEAM LOADED AT MIDSPAN,

CALCULATE I

THE MAX $M = \frac{F l}{4}$. LET $M_{max} = M_p$, $F = F_p = \frac{4 M_p}{l}$)

$I = 2 \left(\frac{30 (0.3)^3}{12} + 12.25 (15)^2 \right) + 8 \left(\frac{5/16 (12)^3}{3} \right)$

$= 5542 \text{ in}^4$

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>17</u>
J.O. OR W.O. NO. 1A235:17	DIVISION & GROUP NM (C)	CALCULATION NO. 1A235:17-M-07	OPTIONAL TASK CODE	


WEIGHT OF JACK = 7000 lb.

DROP HEIGHT = 136'

∴ ENERGY AT IMPACT = 136 (7000) 12 = 9.79×10^6 IN-16

{ ASSUME AN ELASTIC - PERFECTLY PLASTIC RESPONSE OF THE
 BEAM. ASSUME BUCKLING DOES NOT OCCUR.

METHOD I



$$K_1 = \frac{F}{\delta} = \frac{48EI}{l^3} = \frac{48(30 \times 10^6) 5342}{(332)^3}$$

$$= \underline{233\ 819 \text{ lb/in}}$$

$$D_p = \frac{F_p}{K_1} = \frac{237\ 470}{233\ 819} = \underline{1.015 \text{ INCHES}}$$

FOR ENERGY BALANCE:

$$\frac{1}{2} D_p F_p + F_p (S_{max} - D_p) = 9.79 \times 10^6 \text{ IN-16} + 7000 S_{max}$$


SOLVING FOR S_{max} :

$$S_{max} = \frac{9.79 \times 10^6 + \frac{1}{2} (1.015) 237\ 470}{237\ 470 - 7000} = \underline{42.8 \text{ ''}}$$


STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 E

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 14235:17	DIVISION & GROUP NM (C)	CALCULATION NO. 14235:17-M-07	OPTIONAL TASK CODE
			PAGE 18



WILL SHIELD FALL INTO POOL?



$$\frac{\sin 90}{166} = \frac{\sin \alpha}{43}$$

$$\alpha = 15^\circ$$

$$\beta = 180 - (90 + 15)$$

$$= 75^\circ$$

$$\text{THEN } \sin 90 / 166 = \sin 75 / x \quad x \approx 160.3''$$

BECAUSE THE 2-DIMENSION HAS ONLY SHORTENED BY 26" AND THE DISTANCE FROM THE END OF THE SHIELD TO THE POOL WALL IS 204", IT CAN BE CONCLUDED THAT THE MISSILE SHIELD WILL NOT FALL INTO THE POOL.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>19</u>
J.O. OR W.O. NO. <u>14235:17</u>	DIVISION & GROUP <u>NM (C)</u>	CALCULATION NO. <u>14235:17-M-07</u>	OPTIONAL TASK CODE	

METHOD II:PROCEDURE AS OUTLINED IN BECHTELS REPORT (REFERENCE 1)EFFECTIVE MASS OF THE STEEL BEAM

$$M_e = (D_x + 2d) M_x$$

WHERE:

D_x = MAX. MISSILE CONTACT
DIMENSION IN THE X-
DIRECTION (LONGITUDINAL
AXIS FOR BEAM)

d = DEPTH OF BEAM

M_x = MASS/UNIT LENGTH OF BEAM

$$M_e = (26 + 2(25)) 0.0938$$

LET:

$$= \underline{\underline{3.328}} \cdot \frac{10.5^2}{12}$$

$$D_x = 26''$$

$$d = 25''$$

$$M_x = \left(\frac{20316}{\text{FT}} \right) / 32.2 = 6.32 \frac{10.5^2}{\text{FT}^2}$$

$$= 0.0938 \frac{10.5^2}{12}$$

TARGET STRAIN ENERGY REQUIRED TO ABSORB THEIMPACT ENERGY

$$E_s = \frac{M_m^2 V_s^2}{2(M_m + M_e)}$$

WHERE:

M_m = MASS OF MISSILE

V_s = STRIKING VELOCITY OF
MISSILE

$$E_s = \frac{(18.083)^2 (1050)^2}{2(18.083 + 3.328)}$$

LET:

$$M_m = \frac{7000}{32.2} = 217 \frac{10.5^2}{\text{FT}}$$

$$= \underline{\underline{8132.674}} \text{ IN-16}$$

$$= 18.083 \frac{10.5^2}{12}$$

(18 "63)

$$(677722 \text{ ft} \cdot \text{in})$$

$$V_s = 86 \text{ FT/S} = 1032 \frac{10.5}{5}$$

$$= \sqrt{gh} = \sqrt{2 \times 32.2 \times 116}$$

CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>20</u>
J.O. OR W.O. NO. <u>14235-17</u>	DIVISION & GROUP <u>NM(C)</u>	CALCULATION NO. <u>14235.17-M-07</u>	OPTIONAL TASK CODE	

CALCULATE M_p

$$M_p = DIF (\sigma_y) (\text{MOMENT OF THE AREA})$$

WHERE:

DIF = DYNAMIC INCREASE
FACTOR (FOR A36 = 1.2)

(TABLE 4-1, REF. 1)

σ_y = YIELD STRENGTH (36 KSI)

$$M_p = 1.2 (36,000) 517.5$$

$$= \underline{23.652 \times 10^6 \text{ IN-IB}}$$

CALCULATE F_p

$$F_p = 4M_p/L = 4(23.652 \times 10^6) / 332 = \underline{289,638 \text{ LB}}$$

CALCULATE DISPLACEMENT AT F_p

$$D_p = \frac{F_p L^3}{48EI} = \frac{289,638 (332)^3}{48(5942)(30 \times 10^6)}$$

$$= \underline{1.217 \text{ INCHES}}$$

MAXIMUM STRAIN ENERGY FOR PURELY ELASTIC RESPONSE:

$$E_e = \frac{1}{2} F_p D_p = \frac{1}{2} (289,638) 1.217 = \underline{173,202 \text{ IN-IB}}$$

$E_e < E_s \therefore$ RESPONSE IS ELASTIC-PLASTIC


STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

• 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>21</u>
J.O. OR W.O. NO. <u>14235-17</u>	DIVISION & GROUP <u>NM (C)</u>	CALCULATION NO. <u>14235-17-M-07</u>	OPTIONAL TASK CODE	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATE δ_{max} BASED ON F_p , D_p , AND E_s CALCULATED
FOR THIS SECTION (METHOD II)



$F_p = 284\,638 \text{ lb.}$

$D_p = 1.217 \text{ INCHES}$

$E_s = 8857\,783 \text{ in.-lb.}$

$\frac{1}{2} D_p F_p + F_p (\delta_{max} - D_p) = E_s + 7000 \delta_{max}$

$\delta_{max} = \frac{8\,732\,674 + \frac{1}{2}(1.218)(284\,638)}{284\,638 - 7000}$


$= \underline{29.9 \text{ INCHES}}$

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.85


CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO. 14235-17	DIVISION & GROUP NM(L)	CALCULATION NO. 14235-17-M-07	OPTIONAL TASK CODE
			PAGE <u>22</u>

EMBEDMENT LOADINGS FOR TRANSMITTAL TO STRUCTURE



$F = 284 \text{ KIP (LARGEST } F)$

$d = 43 \text{ INCHES (LARGEST } d)$




$R_1 = \frac{(284/2)}{\sin 15^\circ} = 548 \text{ KIP}$

$R_x = 529 \text{ KIP}$

DUE TO THE LARGE R_x VALUE (529 KIPS), IT IS ASSUMED THAT THE ANCHOR WILL PULL OUT. THE MISSILE SHIELD WILL THEN BE IN CONTACT WITH THE CONCRETE.

THUS:



$R_y = (N \cos 15^\circ + \mu N \sin 15^\circ) = \frac{F}{2} = \frac{284}{2} = 142 \text{ KIPS}$


$R_x = (\mu N \cos 15^\circ - N \sin 15^\circ)$

$\mu = 0.7 \text{ (STEEL ON CONCRETE)}$

$\therefore N = \frac{142}{\cos 15^\circ + \mu \sin 15^\circ} = 124 \text{ KIPS}$

$R_y = 142 \text{ KIPS}$

$R_x = (0.7 \times 0.966 - 0.259) \times 124 = 51.8 \text{ KIPS}$



CALCULATION SHEET

A 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>23</u>
J.O. OR W.O. NO. 14235-17	DIVISION & GROUP NMLC	CALCULATION NO. 14235-17-M-07	OPTIONAL TASK CODE	

(B) NON-LINEAR DYNAMIC ANALYSIS

THE NRC'S STANDARD REVIEW PLAN 3.5.3, REF. 10, (BARRIER DESIGN PROCEDURES) STIPULATES THAT THE MAXIMUM DUCTILITY RATIO SHOULD NOT BE GREATER THAN 10. BASED ON THE DEFLECTIONS AT YIELD OF THE PREVIOUS TWO ENERGY BALANCE APPROACHES, THIS WOULD ALLOW A MAXIMUM DEFLECTION OF THE SHIELD OF 10.15 TO 12.18 INCHES. AS THE ACTUAL CALCULATED DEFLECTIONS, BASED ON THESE TWO APPROACHES, RANGE FROM 30" TO 43", A MORE ACCURATE

APPROACH WILL BE UTILIZED TO REDUCE THE DEFLECTIONS.

A NON-LINEAR DYNAMIC ANALYSIS COMPUTER CODE (LIMITA 2) WILL BE UTILIZED FOR THE ANALYSIS. STRAIN-RATE EFFECTS, WORK HARDENING, AND THE ADJUSTED VELOCITY OF THE MISSILE/CARRIER EFFECTIVE MASS WILL BE ACCOUNTED FOR IN THE ANALYSIS.

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>24</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM(L)	14235.17 - M-87		

LIMITA ANALYSIS OF MISSILE SHIELD IMPACT

CALCULATE M_p

M_p IS CALCULATED AS BEFORE. HOWEVER, THIS TIME
 M_p IS MULTIPLIED BY A FACTOR OF 1.2 (REF 1, PG. 4-4)
 TO ACCOUNT FOR STRAIN RATE EFFECTS. THUS:

$$\begin{aligned} M_p &= 1.2 \sigma_y (\text{MOMENT OF AREA}) \\ &= 1.2 (36 \times 10^3) 597.5 \\ &= \underline{23.652 \times 10^6 \text{ IN-LB}} \end{aligned}$$

CALCULATE F_p

FOR THE LIMITA CODE, F_p IS THE AXIAL YIELD FORCE
 AND IS INCREASED BY THE FACTOR OF 1.2 AS WELL. THUS,

$$\begin{aligned} F_p &= 1.2 \sigma_y A_x & A_x &= 60 \text{ IN}^2 \text{ (SEE PG. 16)} \\ &= 1.2 (36 \times 10^3) 60 \\ &= \underline{2.592 \times 10^6 \text{ LB.}} \end{aligned}$$

EQUIVALENT VELOCITY OF MISSILE/SHIELD EFFECTIVE MASS JUST AFTER IMPACT

(FROM REF 1, PG. 3-3) FOR A PLASTIC COLLISION, THE VELOCITY

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>25</u>
J.O. OR W.C. NO. 14235-17	DIVISION & GROUP UM(C)	CALCULATION NO. 14235-17-M-07	OPTIONAL TASK CODE	

OF THE JACK / SHIELD COMBINATION IS GIVEN BY :

$$V_{EQUIVALENT} = \left(\frac{M_M}{M_M + M_C} \right) V_I$$

WHERE :

M_M = MASS OF MISSILE (JACK)

M_C = EFFECTIVE MASS OF SHIELD (IE PG. 19)


V_I = IMPACT VELOCITY BEFORE CONTACT. (P. 15)

THEN

$$V_{EQUIVALENT} = \left(\frac{10.083}{18.083 + 3.328} \right) 1032$$

$$= \underline{871.6 \frac{IN}{SEC}}$$

CALCULATE E_p



FOR A36 STEEL @ 70°F (REF. 6, pg. 32)

$$E = 29 \times 10^6 \text{ PSI}$$

$$\sigma_y = 36 \times 10^3 \text{ PSI}$$

$$\sigma_u = 58 \times 10^3 \text{ PSI}$$

$$\epsilon_y = 0.002 + \frac{\sigma_y}{E} = 0.003$$

$$\epsilon_u = 0.19$$

FOLLOWING THE PROCEDURE OF EMTR - 900A (REF. 7) :

$$E_p = (\sigma_i - \sigma_y) / (0.5 \epsilon_u - \epsilon_y)$$

$$\sigma_i = \sigma_0 (0.5 \epsilon_u)^n$$

$$n = \frac{\ln(\sigma_u / \sigma_y)}{\ln(\epsilon_u / \epsilon_y)}$$

$$= \underline{0.115}$$

$$\sigma_0 = \frac{\sigma_u}{\epsilon_u^n} = \underline{70.2 \times 10^3 \text{ PSI}}$$

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 66

CALCULATION IDENTIFICATION NUMBER				PAGE <u>26</u>
J.O. OR W.O. NO. 14235-17	DIVISION & GROUP PM(C)	CALCULATION NO. 14235-17-M-07	OPTIONAL TASK CODE	

$$\sigma_1 = 70.2 \times 10^3 [0.5(0.19)]^{0.15}$$

$$= \underline{53\ 551\ \text{PSI}}$$

THEN:

$$E_p = (53\ 551 - 36\ 000) / (0.5(0.19) - 0.003)$$

$$= \underline{190.8 \times 10^3\ \text{PSI}}$$

ROTATIONAL STRAIN HARDENING PARAMETER (HD)

FROM (REF. B, PG. 19) WE GET:

$$HD = [4 I_z / A_x]^{1/2}$$

$$= [4 (5492) / 60]^{1/2}$$

$$= \underline{19.134\ \text{IN}}$$


1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>27</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM (C)	CALCULATION NO. 14235.17-M-07	OPTIONAL TASK CODE	

MEMBER AND JOINT WEIGHTS



MEMBER	(lb) WEIGHT	ROT. WEIGHT (in.)	NODE	WEIGHT (lb)	ROT. WEIGHT (in.)	NODE COORDINATES (INCHES) (X, Y)
			1	254.7	44326.3	(0, 0)
①	509.4	88652.6	2	509.4	88652.6	(30, 0)
②	509.4	88652.6	3	509.4	88652.6	(60, 0)
③	509.4	88652.6	4	509.4	88652.6	(90, 0)
④	509.4	88652.6	5	509.4	88652.6	(120, 0)
⑤	509.4	88652.6	6	390.6	53952.6	(150, 0)
⑥	271.7	21252.6	7	7271.7	31252.6	(166, 0)
⑦	271.7	31252.6	8	390.6	53952.6	(182, 0)
⑧	509.4	88652.6	9	509.4	88652.6	(212, 0)
⑨	509.4	88652.6	10	509.4	88652.6	(242, 0)
⑩	509.4	88652.6	11	509.4	88652.6	(272, 0)
⑪	509.4	88652.6	12	509.4	88652.6	(302, 0)
⑫	509.4	88652.6	13	254.7	88652.6	(332, 0)

$A_x = 60 \text{ IN}^2$
 $I_z = 5432 \text{ IN}^4$

} SEE PG. (16)

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>28</u>
J.O. OR W.O. NO. 14235.17	DIVISION & GROUP NM(C)	CALCULATION NO. 14235.17-M-07	OPTIONAL TASK CODE	

RESULTS OF COMPUTER ANALYSIS

RESULTS SHOW THAT A MAXIMUM DEFLECTION OF 16.920"
OCCURS AT NODE 7 (THE CENTER OF THE MISSILE SHIELD)


REACTION FORCES FOR THE
BEAM MODELED ARE:

$$F_y = \underline{261 \text{ KIPS}}$$

$$F_x = \mu F_y = 0.7 (261)$$

$$= \underline{182.7 \text{ KIPS}}$$

$\mu = 0.7$ (SEE PG. 22)



STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

4 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE 29
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NM (L)	14235.17-M07		

1
2
3 DISCUSSION OF RESULTS

4 AS THE DEFLECTION AT YIELD IS 1.218" AND THE
5
6 MAXIMUM DEFLECTION IS 16.375", THIS GIVES US A
7
8 DUCTILITY RATIO OF $16.375 / 1.218 = 13.5$. THIS VALUE
9
10 IS GREATER THAN 10, THE ALLOWABLE SPECIFIED IN
11
12 SRP 3.5.3. HOWEVER, THE FOLLOWING ARGUMENTS ARE
13
14 PRESENTED TO JUSTIFY THE ACCEPTABILITY OF THE 16.375"
15
16 DEFORMATION.
17

18
19 A) THE GUIDELINES OF THE LATEST SRP ARE BEING
20
21 USED TO QUALIFY THE SHIELDS(DUCTILITY RATIO
22
23 = 10). (REF. 10) HOWEVER, AT
24
25 THE TIME OF THIS PLANTS CONSTRUCTION, THERE
26
27 WERE NO GUIDELINES ON ALLOWABLE DUCTILITY
28
29 FOR SUCH DEVICES.
30

31 ALSO, IT SHOULD BE EMPHASIZED THAT WE
32
33 ARE MERELY TRYING TO SHOW THAT THE SHIELDS
34
35 WILL PREVENT THE JACK FROM FALLING INTO THE
36
37 FUEL POOL; WE ARE NOT TRYING TO DESIGN A
38
39 NEW SHIELD.
40

41
42 B) REF (1), PG. 4-7, STIPULATES A MAXIMUM
43
44 DUCTILITY RATIO, FOR STEEL MEMBERS SUBJECT
45
46

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>30</u>
J.O. OR W.O. NO. 19235.17	DIVISION & GROUP NM(4)	CALCULATION NO. 19235.17-M-07	OPTIONAL TASK CODE	

1
2
3 TO FLEXURE, COMPRESSION, AND SHEAR, OF 20.
4
5 THIS VALUE IS TWICE THAT PRESENTED IN SRA 3.5.3.
6

7
8 C) CONSERVATISM STILL EXISTS, IN THAT THE ENERGY
9
10 DISSIPATION DUE TO THE JACK GOING THROUGH THE
11
12 ROOF OF THE AUXILIARY BUILDING IS NOT CONSIDERED.
13
14 ALSO, ANY CONSTRAINT DUE TO THE EMBEDMENTS HAS
15
16 NOT BEEN CONSIDERED.

17
18 D) LATERAL BUCKLING OF THE SHIELD IS PREVENTED DUE TO
19
20 THE CONSTRAINT IMPOSED BY THE REMAINING SHIELDS. THIS WOULD
21
22 PRECLUDE PREMATURE FAILURE OF THE SHIELD AND ALLOW
IT TO FAIL BY A HIGHER STRAIN.

23
24 E) A MULTIPLIER OF 1.2 WAS USED TO INCREASE σ_y
25
26 DUE TO THE STRAIN RATE EFFECT. THIS AMOUNTS TO
27
28 AN INCREASE IN σ_y BY 13.2 KSI. HOWEVER, IT HAS
29
30 BEEN CITED IN THE LITERATURE (REF. 9, PG. 103) THAT
31
32 A GOOD APPROXIMATION FOR DYNAMIC TENSILE
33
34 YIELD STRENGTH IS GIVEN BY $\sigma_{yD} = \sigma_y + (20 \text{ TO } 30 \text{ KSI})$
35
36 THE USE OF THIS HIGHER DYNAMIC YIELD STRENGTH
37
38 WOULD FURTHER REDUCE THE MINIMUM DEFORMATION.
39

40
41 F) THE PROBABILITY OF THE EVENT OCCURRING IS
42
43 VERY SMALL AS THE SCAFFOLDING, WHICH CONTAINS
44
45 THE JACK, IS ONLY IN A POSITION OVER THE POOL
46
ONCE EVERY FIVE YEARS

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.05

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3/</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
14235.17	NMCC)	14235.17-4-07		

1
2
3 G. MISSILE SHIELD IS DESIGNED FOR THE PROTECTION OF
4 OTHER SAFETY-RELATED SYSTEMS FOR A POSTULATED
5 ACCIDENT, IN THIS CASE, ^{FOR} A POSTULATED HEAVY WEIGHT
6 DROP ACCIDENT. THE FUNCTIONAL REQUIREMENTS OF
7 A MISSILE SHIELD ARE THEREFORE COMPARABLE TO THAT
8 OF A PIPE RUPTURE RESTRAINT OR A JET IMPINGEMENT SHIELD,
9 WHICH ARE STRUCTURED DESIGNED FOR THE PROTECTION OF
10 OTHER SAFETY-RELATED SYSTEMS IN A POSTULATED PIPE FAILURE.
11
12
13
14
15
16
17

18 A 50% OF THE ULTIMATE UNIFORM STRAIN
19 IS ALLOWED FOR THE DESIGN OF THESE PIPE FAILURE
20 PROTECTIVE STRUCTURES ACCORDING TO SRP 3.6.2 (REF. 11).
21
22 IF THIS SAME CRITERION IS APPLIED TO THE MISSILE SHIELD,
23 THE ALLOWABLE DUCTILITY RATIO WOULD BE AROUND 30~50.
24
25
26
27

28 H. ALTHOUGH THE DEFORMATION IS IN EXCESS OF THAT SPECIFIED
29 IN SRP 3.5.3, THE BOTTOM LINE IS THAT THE SHIELD HAS NOT
30 FAILED AND ALLOWED THE JOCK TO FALL INTO THE POOL.
31
32
33
34

35 THEREFORE, BASED ON THE ABOVE ARGUMENTS IT IS RECOMMENDED
36 THAT EVEN THOUGH THE DUCTILITY RATIO REQUIREMENTS OF SRP 3.5.3
37 ARE EXCEEDED THE MISSILE SHIELDS ARE ACCEPTABLE AND NO
38 REDESIGN OF SHIELDS IS REQUIRED.
39
40
41
42
43
44
45
46

COMPUTER LOG

7729

S & W AUTH. NO. 7189
 CDC CHARGE NO.

CALCULATOR NO. 14235.17.M.07
 JOB ORDER NO. 14235.17

RUN NO.	JOB NO. *	FICHE LOC.		PREPARED BY		REVIEWED BY		COMP **	COMMENTS
		PAGE	SECT	SIGNATURE	DATE	SIGNATURE	DATE		
052	1235		A	M. D. Steel	7/13/82	H. H. Kuo	7/15/83	spw	LIMITA 2A - ROLLER/ROLLER SUPPORT

* COMPUTER GENERATED JOB NUMBER

** COMPUTER USED (S & W OR CDC)