



GPU Nuclear Corporation
 Post Office Box 388
 Route 9 South
 Forked River, New Jersey 08731-0388
 609 971-4000
 Writer's Direct Dial Number:

C321-92-2035
 January 29, 1992

U.S. Nuclear Regulatory Commission
 Attention: Document Control Desk
 Washington, D.C. 20555

Gentlemen:


Subject: Oyster Creek Nuclear Generating Station (OCNGS)
 Docket No. 50-219
 Response to Generic Letter 91-11
 Resolution of Generic Issues 48 and 49

GPU Nuclear Corporation (GPUN) has reviewed the guidance attached to Generic Letter 91-11 and evaluated its requirements using a multi-disciplinary review process. Equipment, procedures, and other design documents were reviewed and evaluated in accordance with the recommended actions of the Generic Letter.

As a result, several procedures were revised to include time limitations for normal and/or alternate power supplies to 120V 1E vital instrument buses to be out of service. [Generic Issue No. 48] Additionally, review of the existing station procedures for control of interlocks to Class 1E Tie Breakers found that the administrative controls, currently in place, conform to the GL 91-11 guidelines. [Generic Issue No. 49]


Therefore, GPUN does hereby certify that the Oyster Creek Nuclear Generating Station has implemented procedures which conform to the guidance contained in the Enclosure to Generic Letter 91-11.

Sincerely,


 for J. J. Barton
 Vice President and Director
 Oyster Creek

JRB/GMG
 cc: Director, Project Directorate I-4
 Region I, Administrator
 NRC Project Manager
 Senior NRC Resident Inspector, OCNGS

Sworn to and subscribed before me this 29th day of January, 1992.



JUDITH M. CROWE
 Notary Public of New Jersey
 My Commission Expires 11/25/95

9202050149 920129
 PDR ADOCK 05000219
 P PDR

Handwritten: A027 1/0