

Pilgrim Nuclear Power Station Rocky Hill Road Plymouth, Massachusetts 02360 10 CFR 50.36a(a)(2) PNPS TS Section 6.9.C.1 Reg. Guide 1.21

August 28 , 1995 BECo Ltr. 95- 086

L. J. Olivier
Vice President Nuclear Operations
and Station Director

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D.C. 20555

> Docket No. 50-293 License No. DPR-35

Subject:

SEMI-ANNUAL RADIOACTIVE EFFLUENT AND WASTE DISPOSAL REPORT

FOR THE PERIOD JULY 1, 1994 THROUGH DECEMBER 31, 1995

In accordance with the requirements of 10 CFR 50.36a(a)(2), Pilgrim Nuclear Power Station Technical Specification Section 6.9.C.1, and Regulatory Guide 1.21, the Boston Edison Company submits the Semi-Annual Radioactive Effluent and Waste Disposal Report Including Meteorological Data for the period of January 1 through June 30, 1995.

Please do not hesitate to contact me if there are any questions regarding this report.

L.J. Olivier

WJM/lam/Waste

cc: Mr. Thomas T. Martin

Regional Administrator, Region I U.S. Nuclear Regulatory Commission

475 Allendale Road

King of Prussia, PA 19406

Sr. NRC Resident Inspector - Pilgrim Station

000000

9509060219 951231 PDR ADDCK 05000293 R PDR 1548

PILGRIM NUCLEAR POWER STATION

Radioactive Effluent and Waste Disposal Report Including Meteorological Data

January 1 through June 30, 1995



PILGRIM NUCLEAR POWER STATION

RADIOACTIVE EFFLUENT AND WASTE DISPOSAL REPORT
INCLUDING METEOROLOGICAL DATA

JANUARY 1 THROUGH JUNE 30, 1995

Prepared by: Hemseld

K J Seikor

Senior Environmental Radiochemist

Approved by

C. S. Goddard

Nuclear Services Department Manager

TABLE OF CONTENTS

Secti	<u>on</u>	Page
1.	Introduction	5
2.	Radioactive Effluent Data	6
3.	Radioactive Waste Disposal Data	13
4.	Meteorological Data	16
5.	Off-Site Dose Calculation Manual Revisions	49
6.	References	50
	LIST OF TABLES	
Table		Page
	Supplemental Information	7
1A	Gaseous Effluents - Summation of All Releases	8
1B	Gaseous Effluents - Elevated Release	9
1C	Gaseous Effluents - Ground Level Release	10
2A	Liquid Effluents - Summation of All Releases	11
2B	Liquid Effluents	12
3	Solid Waste and Irradiated Fuel Shipments	14
4A-1	Distribution of Wind Directions and Speeds for the 33 ft. Level of the 220 ft. Tower	17

4A-2 Distribution of Wind Directions and Speeds for the 220 ft. Level of the 220 ft. Tower

33

EXECUTIVE SUMMARY

BOSTON EDISON COMPANY
Pilgrim Nuclear Power Station
Radioactive Effluent and Waste Disposal Report
including Meteorological Data
January 1 to June 30, 1995

INTRODUCTION

This report quantifies the radioactive gaseous, liquid, and radwaste releases, and summarizes the local meteorological data for the period from January 1 to June 30, 1995. This document has been prepared in accordance with the requirements set forth in the Pilgrim Nuclear Power Station (PNPS) Technical Specifications and Revision 1 of Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light Water Cooled Nuclear Power Plants."

The quantity of radioactive material released from Pilgrim Station was determined from sample analyses of gaseous releases from the main stack, reactor building vent, and turbine building, and liquid releases into the discharge canal. The quantity and volume of radioactive waste which was shipped off-site from Pilgrim Station for burial was determined from data contained on the radwaste shipping documentation. The meteorological data were obtained from instrumentation measurements from the 220 foot meteorological tower located at Pilgrim Station.

GASEOUS EFFLUENTS

The gaseous radioactive releases for the reporting period are quantified in Tables 1A, 1B and 1C. Radioactive noble gases released during the period totalled 1743 curies. Releases of radioactive particulates and iodines from the main stack, reactor building vent, and turbine building, totalled 0.005 curies, and tritium releases totalled 16.3 curies. No gross alpha radioactivity was detected in gaseous effluents.

LIQUID EFFLUENTS

The liquid radioactive releases for the reporting period are quantified in Tables 2A and 2B. Liquid effluents into the discharge canal resulted in a total release to the environment (Cape Cod Bay) of 0.069 curies of fission and activation products and 7.71 curies of tritium. Dissolved and entrained gases were not detected. No gross alpha radioactivity was detected.

SOLID WASTE

Boston Edison's radioactive waste burial allocation in Barnwell, South Carolina was suspended in early 1994. Although some shipments of radioactive waste materials were made off-site for volume reduction and/or salvage, no <u>disposal</u> of radioactive waste took place during the reporting period. Any radioactive residue arising from the processing of the waste will be returned to Boston Edison for interim storage at Pilgrim Station.

METEOROLOGICAL DATA

The meteorological data joint frequency distributions are listed in Tables 4A-1 and 4A-2. The percent data recovery for the reporting period was 96% on the 33 foot and 97% on the 220 foot elevations of the 220 foot meteorological tower at Pilgrim Station.

The predominant wind direction was from the south-southwest, which occurred approximately 13% of the time during this period. The predominant wind speed range at the 220 foot sensor was 13 to 18 mph, which occurred 31% of the time during this period. The predominant wind speed range at the 33 foot sensor was 4 to 7 mph, which occurred approximately 45% of the time. The predominant stability class was stability class D, which occurred about 36% of the time during this period.

CONCLUSION

The PNPS Technical Specifications contain limiting conditions for operations and operational objectives regarding radiological environmental releases. None of the limiting conditions for operation or operational objectives associated with liquid or gaseous effluents were exceeded during this reporting period, as confirmed by conservative dose assessments performed on a monthly basis during this period. Official dose assessments will be published in a supplement to this report due 90 days following January 1, 1996. Conformance to these PNPS Technical Specification operational objectives ensures that the releases of radioactive materials in gaseous and liquid effluents were kept as low as is reasonably achievable in accordance with the Nuclear Regulatory Commission's regulation 10CFR50, Appendix I. Furthermore, compliance with PNPS Technical Specifications demonstrates compliance with the Environmental Protection Agency's (EPA) federal environmental regulation 40CFR190.10, Subpart B.

1. INTRODUCTION

This report is issued for the period January 1 to June 30, 1995 in accordance with the Boston Edison Company's PNPS Technical Specifications and NRC Regulatory Guide 1.21, "Measuring, Evaluating and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light Water Cooled Nuclear Power Plants," Revision 1 (Reference 1).

Regulatory Guide 1.21 requires an assessment of the radiological impact on man resulting from radioactivity released in liquid and gaseous effluents. This assessment is to be performed using effluent and meteorological data collected during the semiannual period covered by the report. Due to the complexity of calculations involved with performing such an assessment, it was impractical to complete the assessment within the 60 day issuance requirement for the report. Therefore, PNPS Technical Specifications were modified in May 1988 (Amendment #116) to allow for submission of a supplemental report containing the radiological impact assessments. This report is to be issued by April 1, and is to contain impact assessments for both semiannual periods (January-June, July-December) for the previous year. Since Technical Specification limits for gaseous effluents listed in Table 1A are based on calculated dose, these values are not presented in the semiannual effluent release report. These "percent of technical specification limit" values will be presented in the supplemental report issued prior to April 1, 1996.

2. RADIOACTIVE EFFLUENT DATA

Radioactive liquid and gaseous releases (Reference 2) for the period January 1 to June 30, 1995 are given in the standard NRC Regulatory Guide 1.21 format in Tables 1A, 1B, 1C, 2A, 2B, and the supplemental information form.

2.1 Gaseous Effluents

Gaseous radioactivity is released from Pilgrim Station to the atmosphere from the main stack and the reactor building exhaust vent. These gaseous effluent releases for the reporting period are summarized in Table 1A. Noble gases released during the period totalled 1743 curies, for an average release rate of 111 μ Ci/sec. A total of 0.005 curies of radioactive iodines and particulates with half-lives greater than 8 days was released at an average release rate of 0.00032 μ Ci/sec. No alpha radioactivity was detected on particulate filters during this reporting period. A total of 16.3 curies of tritium was released at an average release rate of 1.03 μ Ci/sec.

The main stack is an elevated release point with a height of approximately 400 feet above mean sea level. The main stack is located about 700 feet west-northwest of the reactor building. The elevated releases for the reporting period are shown in Table 1B.

The majority of ground-level releases during the period occurred from the reactor building vent, but low levels of radionuclides were also detected in air exhausted from the turbine building. The reactor building exhaust vent is considered a mixed-mode/ground-level release point with a height of approximately 182 feet above mean sea level. The exhaust vent is located on the west corner of the reactor building. Combined ground level releases from both the reactor building vent and turbine building for the reporting period are shown in Table 1C.

2.2 Liquid Effluents

Liquid radioactivity is released from Pilgrim Station to the Cape Cod Bay via the circulating water discharge canal. These effluent releases enter the Cape Cod Bay at the outfall of the canal which is located about 1100 feet north from the reactor building.

The liquid releases for the reporting period are summarized in Table 2A. A total of approximately 1.6 million liters of radioactive liquid waste (prior to dilution) containing 0.069 curies of fission and activation products (excluding tritium, gases, and alpha-emitting nuclides) was discharged with a total dilution volume of approximately 5.2 billion liters of water. The liquid effluents were released at an average concentration of fission and activation products of 1.35E-08 μ Ci/ml. A total of 7.71 curies of tritium was released, resulting in an average concentration of 1.50E-06 μ Ci/ml. No dissolved and entrained gases were detected in liquid effluents during the period. Alpha radioactivity was not detected during this reporting period. Quarterly release estimates and principal radionuclides in the liquid effluents are given in Table 2B.

Pilgrim Nuclear Power Station Effluent and Waste Disposal Report Supplemental Information January-June 1995

FACILITY: PILGRIM NUCLEAR POWER STATION LICENSE: DPR-35

1. REGULATORY LIMITS

a. Fission and activation gases: 500 mrem/yr total body and 3000 mrem/yr for

skin at site boundary

b,c. lodines, particulates with half-life: 150

>8 days, tritium

1500 mrem/yr to any organ at site boundary

d. Liquid effluents: 0.06 mrem/month for whole body and

0.2 mrem/month for any organ (without radwaste treatment)

2. EFFLUENT CONCENTRATION LIMITS

a. Fission and activation gases: 10CFR20 Appendix B Table II b. Iodines: 10CFR20 Appendix B Table II

c. Particulates with half-life > 8 days: 10CFR20 Appendix B Table II

d. Liquid effluents: 2E-04 μCi/mL for entrained noble gases;
 10CFR20 Appendix B Table II values for all

other radionuclides

3. AVERAGE ENERGY Not Applicable

4. MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

A Process of the Control of the Cont

a. Fission and activation gases:b. lodines:

b. lodines.

c. Particulates:

d. Liquid effluents:

High purity germanium gamma spectroscopy for all gamma emitters; radiochemistry analysis for H-3, Fe-55 (liquid effluents), Sr-89, and Sr-90

5. BATCH RELEASES

a. Liquid Effluents

1. Total number of releases:

2. Total time period (minutes):

3. Maximum time period (minutes):

4. Average time period (minutes):

5. Minimum time period (minutes):

Average stream flow (Liters/min): during periods of release of effluents

into a flowing stream

b. Gaseous Effluents

6. ABNORMAL RELEASES

a. Liquid Effluents

b. Gaseous Effluents

Jan-Mar 1995	Apr-Jun 1995
3.40E+01	6.30E+01
2.51E+03	3.37E+03
3.49E+02	1.80E+02
7.38E+01	5.35E+01
2.50E+01	1.30E+01
1.11E+06	6.95E+05
None	None
None	None
None	None

Table 1A Pilgrim Nuclear Power Station Effluent and Waste Disposal Report Gaseous Effluents - Summation of All Releases January-June 1995

	Period: Jan-Mar 1995	Period: Apr-Jun 1995	Estimated Total Error
A. FISSION AND ACTIVATION GASES			
	1.58E+03	1.67E+02	22%
Average Release Rate During Period: µCi/sec	2.00E+02	2.12E+01	
Percent of Technical Specification Limit	*	*	
B. IODINES			
Total lodine-131 Release: Ci	3.29E-03	5.10E-04	20%
Average Release Rate During Period: µCi/sec	4.17E-04	6.47E-05	
Percent of Technical Specification Limit	*		
C. PARTICULATES			
Total Release: Ci	8.54E-04	3.82E-04	21%
Average Release Rate During Period: µCi/sec	1.08E-04	4.85E-05	
Percent of Technical Specification Limit	*	*	
Gross Alpha Radioactivity: Ci	NDA	NDA	
D. TRITIUM			
Total Release: Ci	1.28E+01	3.46E+00	20%
Average Release Rate During Period: µCi/sec	1.62E+00	4.39E-01	
Percent of Technical Specification Limit	*	* *	
	The second secon	ALTERNATION OF STREET SHARE SHARE SHARE STREET SHARE S	of the same of the

Notes for Table 1A:

- * Percent of Technical Specification limit values in above sections are based on dose assessments not performed as part of this report. These will be provided in the annual supplemental dose assessment report to be issued prior to April 1, 1996.
- 1. NDA stands for No Detectable Activity.
- 2. LLD for airborne gross alpha activity listed as NDA is 1E-11 μCi/cc.

Table 1B Pilgrim Nuclear Power Station Effluent and Waste Disposal Report Gaseous Effluents - Elevated Release January-June 1995

	Continuous	Mode	Batch	Mode
Nuclide Released	Jan-Mar 1995	Apr-Jun 1995	Jan-Mar 1995	Apr-Jun 1995
1. FISSION AND AC	CTIVATION GASES	S - Ci		
N-13	NDA	NDA	N/A	N/A
Kr-85m	2.07E+02	4.33E+01	N/A	N/A
Kr-87	2.55E+02	2.45E+01	N/A	N/A
Kr-88	5.16E+02	8.77E+01	N/A	N/A
Xe-133	1.51E+02	9.77E+00	N/A	N/A
Xe-135	2.87E+02	1.67E+00	N/A	N/A
Xe-135m	NDA	NDA	N/A	N/A
Xe-138	2.10E+01	NDA	N/A	N/A
Total for period	1.44E+03	1.67E+02	N/A	N/A
2. IODINES - CI	1.78E-03	3.57E-04	N/A	N/A
I-133	5.92E-03	4.54E-03	N/A	N/A
Total for period	7.70E-03	4.90E-03	N/A	N/A
3. PARTICULATES	- Ci			
Sr-89	3.83E-05	4.72E-05	N/A	N/A
Sr-90	NDA	NDA	N/A	N/A
Cs-134	NDA	NDA	N/A	N/A
Cs-137	4.79E-06	2.73E-06	N/A	N/A
Ba/La-140	1.31E-04	1.32E-04	N/A	N/A
Total for period	1.74E-04	1.82E-04	N/A	N/A
4. TRITIUM - Ci				
H-3	4.59E-01	3.42E-01	N/A	N/A
AND DESCRIPTION OF THE PERSON NAMED IN COLUMN TWO PERSONS NAMED IN COLUMN TRANSPORT NAMED IN COLUMN TWO PERSONS NAMED IN COLUMN TRANSPORT NAMED IN COLUMN TRANSP	CHANGE AND DESCRIPTION OF THE PROPERTY AND ADDRESS OF THE PARTY ADDRESS OF THE PARTY ADDRESS OF	A RESIDENCE OF THE RESIDENCE OF THE PARTY OF	Account to the second s	the second secon

Notes for Table 1B:

1. N/A stands for not applicable.

2. NDA stands for No Detectable Activity.

3. LLD for airborne radionuclides listed as NDA are as follows:

Fission Gases: 1E-04 μ Ci/cc lodines: 1E-12 μ Ci/cc Particulates: 1E-11 μ Ci/cc

Table 1C Pilgrim Nuclear Power Station Effluent and Waste Disposal Report Gaseous Effluents - Ground Level Release January-June 1995

	Continuous	Mode	Batch	Mode
Nuclide Released	Jan-Mar 1995	Apr-Jun 1995	Jan-Mar 1995	Apr-Jun 1995
1. FISSION AND AC	CTIVATION GASES	S - Ci		
N-13	NDA	NDA	N/A	N/A
Kr-85m	NDA	NDA	N/A	N/A
Kr-87	NDA	NDA	N/A	N/A
Kr-88	NDA	NDA	N/A	N/A
Xe-133	NDA	NDA	N/A	N/A
Xe-135	1.16E+02	NDA	N/A	N/A
Xe-135m	NDA	NDA	N/A	N/A
Xe-138	1.96E+01	NDA	N/A	N/A
Total for period	1.36E+02	NDA	N/A	N/A
2. IODINES - Ci I-131 I-133	1.51E-03 5.94E-03	1.53E-04 8.10E-05	N/A N/A	N/A N/A
1-133	5.94⊏-03	6.10E-05	N/A	N/A
Total for period	7.45E-03	2.34E-04	N/A	N/A
3. PARTICULATES	- Ci			
Co-60	NDA	8.67E-05	N/A	N/A
Sr-89	3.58E-04	7.99E-05	N/A	N/A
Sr-90	NDA	NDA	N/A	N/A
Cs-134	NDA	NDA	N/A	N/A
Cs-137	NDA	7.26E-06	N/A	N/A
Ba/La-140	3.22E-04	2.64E-05	N/A	N/A
Total for period	6.80E-04	2.00E-04	N/A	N/A
4. TRITIUM - Ci				
H-3	1.23E+01	3.12E+00	N/A	N/A

Notes for Table 1C:

- 1. N/A stands for not applicable.
- 2. NDA stands for No Detectable Activity.
- 3. LLD for airborne radionuclides listed as NDA are as follows:

Fission Gases: 1E-04 μ Ci/cc lodines: 1E-12 μ Ci/cc Particulates: 1E-11 μ Ci/cc

Table 2A Pilgrim Nuclear Power Station Effluent and Waste Disposal Report Liquid Effluents - Summation of All Releases January-June 1995

	Period: Jan-Mar 1995	Period: Apr-Jun 1995	Estimated Total Erro
A. FISSION AND ACTIVATION PRODUCTS			
Total Release (not including H-3, noble gas, or alpha): Ci	2.71E-04	6.89E-02	12%
Average Diluted Concentration During Period: µCi/mL	9.71E-11	2.94E-08	
Percent of Effluent Concentration Limit*	4.08E-03	1.18E+00	
B. TRITIUM			
Total Release: Ci	5.99E-02	7.65E+00	9.4%
Average Diluted Concentration During Period: µCi/mL	2.15E-08	3.26E-06	
Percent of Effluent Concentration Limit*	2.15E-03	3.26E-01	
C. DISSOLVED AND ENTRAINED GASES Total Release: Ci	NDA	NDA	16%
Average Diluted Concentration During Period: µCi/mL	NDA	NDA	
Percent of Effluent Concentration Limit*	NDA	NDA	
D. GROSS ALPHA RADIOACTIVITY			
Total Release: Ci	NDA	NDA	34%
E. VOLUME OF WASTE RELEASED PRIOR TO DILUTI	ON	Alleman	
Waste Volume: Liters	3.56E+05	1.22E+06	5.7%
	NOD		
F. VOLUME OF DILUTION WATER USED DURING PER	(IOD		

Notes for Table 2A:

- 1. NDA stands for No Detectable Activity.
- 2. LLD for dissolved and entrained gases listed as NDA is 1E-05 μCi/mL.
- 2. LLD for liquid gross alpha activity listed as NDA is 1E-07 μCi/mL.

^{*} Additional percent of Technical Specification limit values based on dose assessments will be provided in the annual supplemental dose assessment report to be issued prior to April 1, 1996.

Table 2B Pilgrim Nuclear Power Station Effluent and Waste Disposal Report Liquid Effluents January-June 1995

	Continuous	Mode	Batch	Mode
Nuclide Released	Jan-Mar 1995	Apr-Jun 1995	Jan-Mar 1995	Apr-Jun 1995
1. FISSION AND A	CTIVATION PROD	UCTS - Ci		
Cr-51	N/A	N/A	NDA	7.97E-04
Mn-54	N/A	N/A	1.58E-05	9.64E-03
Fe-55	N/A	N/A	6.66E-05	4.93E-04
Fe-59	N/A	N/A	NDA	6.71E-04
Co-58	N/A	N/A	NDA NDA	3.02E-03
Co-60	N/A	N/A	1.09E-04	4.02E-02
Zn-65	N/A	N/A	NDA	5.19E-04
Sr-89	N/A	N/A	7.11E-06	7.80E-06
Sr-90	N/A	N/A	2.81E-06	4.91E-06
Zr/Nb-95	N/A	N/A	NDA	NDA
Mo-99/Tc-99m	N/A	N/A	NDA	NDA
Ag-110m	N/A	N/A	NDA	6.40E-05
Sb-124	N/A	N/A	NDA	9.78E-07
1-131	N/A	N/A	NDA	2.17E-07
1-133	N/A	N/A	NDA	NDA
Cs-134	N/A	N/A	NDA	3.15E-04
Cs-137	N/A	N/A	6.97E-05	1.32E-02
Ba/La-140	N/A	N/A	NDA	NDA
Ce-141	N/A	N/A	NDA	1.37E-05
Total for period	N/A	N/A	2.71E-04	6.89E-02
2. DISSOLVED AN	D ENTRAINED GA	SES - Ci		
Xe-133	N/A	N/A	NDA	NDA
Xe-135	N/A	N/A	NDA	NDA
THE R. P. LEWIS CO., LANSING, MICH. LANSING, MICH. 49-14039-1-120-1-1-120-1-120-1-1-120-1-1-120-1-1-120-1-1-1-1	CONTRACT AND ADDRESS OF THE PARTY OF THE PAR	PROPERTY AND ADDRESS OF THE PROPERTY ADDRESS OF THE PROPERTY AND ADDRESS OF THE PROPERTY ADDRESS OF TH	THE R. LEWIS CO., LANSING MICHIGAN PRINTED AND PRINTED AND PARTY OF THE PARTY OF TH	The second secon

N/A

NDA

NDA

Notes for Table 2B:

Total for period

1. N/A stands for not applicable.

2. NDA stands for No Detectable Activity.

3. LLD for liquid radionuclides listed as NDA are as follows:

N/A

 $\begin{array}{lll} Strontium: & 5E-08 \; \mu \text{Ci/mL} \\ Iodines: & 1E-06 \; \mu \text{Ci/mL} \\ Noble \; Gases: & 1E-05 \; \mu \text{Ci/mL} \\ Ali \; Others: & 5E-07 \; \mu \text{Ci/mL} \\ \end{array}$

3. RADIOACTIVE WASTE DISPOSAL DATA

In early 1994, Boston Edison's radioactive waste burial allocation with Chem Nuclear Systems, Inc. in Barnwell, South Carolina was suspended. Since Massachusetts is not a member of Southeast Compact, it is no longer allowed to bury its radioactive wastes at facilities within the compact. Until a disposal location is agreed upon, PNPS's radioactive wastes will be held in an interim storage facility at Pilgrim Station.

Some shipments of radioactive wastes were made off-site during the reporting period for purposes of volume reduction and/or salvage. However, none of the radioactivity was disposed of via burial. Any radioactive residue recovered from the processing of the wastes is to be returned to Pilgrim Station for interim storage.

Table 3 Pilgrim Nuclear Power Station Effluent and Waste Disposal Report Solid Waste and Irradiated Fuel Shipments January-June 1995

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not Irradiated Fuel)

		Jan-Jun 1995	
1. Type of Waste	Volume m ³	Activity Ci	Est. Total Error
Spent resins, filter sludges, evaporator bottoms, etc.	0.00E+00	0.00E+00	0%
 b. Dry compressible waste, contaminated equipment, etc. 	0.00E+00	0.00E+00	0%
c. Irradiated components, control rods, etc.	0.00E+00	0.00E+00	0%
d. Other (describe)	0.00E+00	0.00E+00	0%
Total Combined Waste	0.00E+00	0.00E+00	0%

2. Estimate of major composition (By type of waste)

a. Spent resin, filter sludges, evaporator bottoms, etc.

No shipments of radioactive wastes or components for disposal were made during the reporting period.

b. Dry compressible waste, contaminated equipment etc.

No shipments of radioactive wastes or components for disposal were made during the reporting period.

Irradiated components, control rods, etc.

No shipments of radioactive wastes or components for disposal were made during the reporting period.

d. Other (describe miscellaneous low level waste).

No shipments of radioactive wastes or components for disposal were made during the reporting period.

3. Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
2	Tractor-trailer	Alaron Corp., Wampum, PA*
6	Tractor-trailer	Scientific Ecology Group. Oak Ridge, TN*
2	Tractor-trailer	American Ecology Recycle Center, Oak Ridge, TN*

^{*} Contaminated wastes are shipped to these vendors for volume reduction and/or salvage. After processing, the remaining wastes will be returned to Boston Edison for interim storage at Pilgrim Station.

B. IRRADIATED FUEL SHIPMENTS (DISPOSITION)

No shipments of radioactive wastes or components for disposal were made during the reporting period.

4. METEOROLOGICAL DATA

Meteorological data (Reference 3) for the period January 1 to June 30, 1995 is given in Tables 4A-1 and 4A-2 in the standard joint frequency distribution format as given in NRC Regulatory Guide 1.21.

The predominant wind direction was from the south-southwest, which occurred about 13% of the time during this period. The predominant wind speed range at the 220 foot sensor was 13 to 18 mph, which occurred with a frequency of 31% during this period. The predominant wind speed range at the 33 foot sensor was 4 to 7 mph, which occurred approximately 45% of the time. The predominant stability class was stability class D, which occurred about 36% of the time during this period.

There were instances where the data recorded by the 220 foot tower were not continuous. Typically, data losses were due to loss of power, malfunction of the sensors, and/or malfunction of the digital dataloggers. On May 16, 1995, the elevator system for meteorological sensors on the 220 foot tower failed when the transport cable broke. Meteorological data collected from both levels of the tower was inoperable until June 26, when the system was repaired and returned to operation. Due to the extensive loss of data during this period, meteorological data from the backup 160 foot tower were scaled to 220 foot values, and were subsequently substituted for the missing data. Without the replacement information, data recovery for the second quarter would have been 52%. When the replacement data was incorporated, the net result is that the data recovery for the period was 96% on the 33 foot elevation and 97% on the 220 foot elevation of the meteorological tower at Pilgrim Station.

Table 4A-1 Distributions of Wind Directions and Speeds for the 33-ft Level of the 220-ft Tower

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA

STABILITY CLASS A

CLASS FREQUENCY (PERCENT) = 11.27

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	s	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0		0	0	0	0	0	0	0	0	0			0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	-00
(2)	.00	-00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	. 0	. 1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	,44	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00	.00	.44
(2)	.00	.05	.00	.00	.00	.00	.00	,00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.05
4-7	14	17	7	14	0	1	1	0	0	4	0			15	4	13	0	103
(1)	6.11	7.42	3.06	6.11	.00	.44	. 46	.00	.00	1.75	.00		2.62	6.55	1.75	5.68	.00	44.98
(2)	.69	.84	.34	.69	.00	.05	.05	.00	.00	.20	,00	.34	.30	.74	.20	.64	.00	5.07
8-12	20	12	4	3	1	0	0	2	8	3	4	13	13	14	8	8	0	113
(1)	8.73	5.24	1.75	1.31	44	.00	.00	.87	3.49	1.31	1.75	5.68	5.68	6.11	3.49	3.49	.00	49.34
(2)	.98	.59	.20	.15	.05	.00	.00	.10	.39	. 15	.20	.64	.64	.69	.39	.39	.00	5.56
13-18	0	0	1	0	0	0	0	0	0	0	0	3	7	- 1	0	0	0	12
(1)	.00	.00	-44	.00	.00	.00	.00	.00	.00	.00	.00	1.31	3.06	.46	.00	.00	.00	5.24
(2)	.00	.00	.05	.00	.00	.00	.00	.00	.00	.00	.00	.15	.34	.05	.00	.00	.00	.59
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	34	30	12	17	1	1	1	2	8	7	4	23	26	30	12	21	0	229
(1)	14.85	13.10	5.24	7.42	.44	. 44	.44	.87	3.49	3.06	1.75	10.04	11.35	13.10	5.24	9.17	.00	100.00
(2)	1.67	1.48	.59	.84	. 05	. 05	- 05	.10	.39	.34	.20	1.13	1.28	1.48	.59	1.03	.00	11.27

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA STABILITY CLASS B

CLASS FREQUENCY (PERCENT) = 3.40

		1																	
SPE	ED(MPH)	N	SINE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	CALM	0	0	0	0	0	. 0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
												200							
	C-3	0	0	. 0	0	0	0	0	. 0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
														4.00.00					
	4-7	3	1	- 1	2	2	0	. 1	0	0	- 1	2	2	0	5	- 4	1	0	25
	(1)	4.35	1.45	1.45	2.90	2.90	.00	1.45	.00	.00	1.45	2.90	2.90	.00	7.25	5.80	1.45	.00	36.23
	(2)	. 15	. 05	. 05	.10	.10	.00	.05	.00	.00	.05	.10	.10	.00	.25	.20	.05	.00	1.23
																			-
	8-12	2	1	10	0	0	0	. 1	0	3	4	1	5	6	2	1	2	0	38
	(1)	2.90	1.45	14.49	.00	.00	.00	1.45	.00	4.35	5.80	1.45	7.25	8.70		1.45	2.90	.00	55.07
	(2)	.10	.05	.49	.00	.00	.00	.05	.00	.15	.20	.05	.25	.30	.10	.05	.10	.00	1.87
																			1.01
	13-18	0	0	4	0	0	0	0	0	0	0	0	1	1	0	0	0	0	6
	(1)	.00	.00	5.80	.00	.00	.00	.00	.00	.00	.00	.00	1.45	1.45	.00	.00	.00	.00	8.70
	(2)	.00	.00	.20	.00	.00	.00	.00	.00	.00	.00	.00	.05	. 05	.00	.00	.00	.00	.30
																10,000			
	19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	-00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	3.00							-				1000							.00
	GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
				1000					-			-	,						100
ALL	SPEEDS	5	- 2	15	2	2	0	2	. 0	3	5	3	8	7	7	5	3	0	69
	(1)	7.25	2.90	21.74	2.90	2.90	.00	2.90	.00	4.35	7.25	4.35	11.59	10.14	10.14	7.25	4.35	.00	100.00
	(2)	. 25	.10	.74	.10	.10	.00	.10	.00	. 15	.25	.15			.34	. 25	. 15	.00	3.40
											100				-			-	

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA

STABILITY CLASS C

CLASS FREQUENCY (PERCENT) = 3.54

SPE	ED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	CALM	0	0	0	. 0	0	. 0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	-00	.00	.00		.00	.00	.00	.00	.00
	(2)	.00	.00		.00	.00	.00	.00	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00
	147		* 25.00	100	100	.00	.00	2.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	C-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	(3)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	-00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	4-7	4	1	3	1	0	2	0	0	0	1	2	5	6	3	3	3	0	34
	(1)	5.56	1.39		1.39	.00	2.78	.00	.00	.00	1.39	2.78			4.17	4.17	4.17	.00	47.22
	(2)	.20	.05	. 15	.05	.00	.10	.00	.00	.00	.05	.10	. 25	.30	.15	.15	.15		
	167		-02	. 12	.03	.00	.10	.00	.00	.00	,03	.10	. 63	. 20	- 13	, 12	- 10	.00	1.67
	8-12	2	0	8	1	0	0	0	0	3	5	3	4	4	2	2		0	35
	(1)	2.78	.00	11,11	1.39	.00	.00	.00	.00	4.17	6.94	4.17	5.56	5.56	2.78	2.78	1.39	.00	48.61
	(2)	-10	.00	.39	. 05	,00	.00	.00	.00	. 15	. 25	. 15	.20	.20	.10	.10	.05	.00	1.72
	13-18	. 0	2	1	0	0	0	0	0	0	0	0	0	0	0	0	n	0	3
	(1)	.00	2.78	1.39	.00	.00	.00	.00	.00	.00	.00	-00	.00		.00	.00	.00	.00	4.17
	(2)	.00	.10		.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	. 15
	100		4.156	143	.00	.00	-00	.00	,00	.00	.00	.00	.00	.00	.00	.00	.00	.00	. 12
	19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	-00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	-00	.00	.00	.00	-00	.00	.00	.00	.00	.00	.00	.00		.00	.00	-00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	-00	.00	.00
	(2)	.00	200	.00	-00	,00	.00	.00	.00	200	,00	.00	.00	-00	.00	.00	.00	.00	.00
ALL	SPEEDS	6	3	1.00	2	0	2	0	0	3	6	5	9		5	5	4	0	72
	(1)	8.33		16.67	2.78	.00	2.78	.00	.00	4.17	8.33	6.94	12.50	13.89	6.94	6.94	5.56	.00	100.00
	(2)	.30	. 15	.59	.10	.00	.10	.00	.00	. 15	.30	. 25	- 44	.49	. 25	. 25	.20	.00	3.54

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA

STABILITY CLASS D

CLASS FREQUENCY (PERCENT) = 42.32

SPEED (MPH)	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	CALM	0	0	0	0	0	0	0	0	0	0	0	D	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	-00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	2007	100		.50			.00	.00	.00	.00	,00	.00	.00	.00	.00	.00	.00	.00	.00
	C-3	7	. 0	. 2	2	2	1	2	5	7	3	9	2	6	6	2	. 4	0	60
	(1)	.81	.00	.23	23	-23	.12	. 23	.58	.81	.35	1.05	.23	.70	.70	.23	.47	.00	6.98
	(2)	.34	.00	.10	-10	.10	. 05	-10	. 25	.34	. 15	. 66	.10	.30	.30	.10	.20	.00	2.95
						-			-						1.20		160		6100
	4-7	31	21	25	14	- 5	. 6	8	14	24	29	25	31	29	22	26	19	0	329
	(1)	3.60	2.44	2.91	1.63	.58	.70	. 93	1.63	2.79	3.37	2.91	3.60	3.37	2.56	3.02	2.21	.00	38.26
	(2)	1.53	1.03	1.23	.69	- 25	.30	.39	.69	1.18	1.43	1.23	1.53	1,43	1.08	1.28	.94	.00	16.19
																	1000		
	8-12	33	27	19	19	8	2	3	3	33	28	29	38	66	30	30	25	- 0	393
	(1)	3.84	3.14	2.21	2.21	.93	.23	.35	.35	3.84	3.26	3.37	4.42		3.49	3.49	2.91	.00	45.70
	(2)	1.62	1.33	.94	.94	.39	.10	.15	.15	1.62	1.38	1.43	1.87			1.48	1.23	.00	19.34
		1177	11.000		7.07		-		3.15	1100		1177			11.46		1.15.00	100	17.50
13	3-18	2	7	0	1	0	0	0	1	17	12	- 1	5	18	6	4	0	0	74
	(1)	. 23	.81	.00	.12	.00	.00	.00	.12	1.98	1.40	.12	.58	2.09	.70	.47	.00	.00	8.60
	(2)	.10	.34	.00	. 05	.00	.00	-00	.05	.84	,59	.05	. 25	.89	.30	.20	.00	, P.d	3.64
								4.650	100		4.00		3,36,00			1.50	.00		3.04
11	9-24	0	0	0	0	0	0	0	1	2	1	0	0	0	0	0	0	0	4
	(1)	.00	.00	.00	.00	.00	.00	-00	.12	.23	-12	.00	.00	.00	.00	.00	.00	.00	.47
	(2)	.00	.00	.00	.00	.00	.00	.00	. 05	.10	. 05	.00	.00	.00	.00	-00	.00	.00	.20
																			16.0
G G	1 24	. 0	0	0	. 0	. 0	0	0	0	0	0	0	0	0	0	- 0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	-00	.00	-00	.00	.00	.00	.00	.00	.00
										1.00	1.46			1.00	130				
ALL SPI	EEDS	73	55	46	36	15	9	13	24	83	73	64	76	119	64	62	48	0	860
	(1)	8.49	6.40	5.35	4.19	1.74	1.05	1.51	2.79	9.65	8.49	7.44	8.84	13.84	7.44	7.21	5.58	.00	100.00
	(2)	3.59	2.71	2.26	1.77	.74	. 44	.64	1.18					5.85	3.15	3.05	2.36	.00	42.32
				-			1 557			-		2000						4.00	The same in

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA STABILITY CLASS E

CLASS FREQUENCY (PERCENT) = 32.92

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	MNM	NW	NNW	VRBL	TOTAL
(1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3 (1) (2)	7 1.05 .34	.60 .20	.45 .15	.15 .05	.00	.00	9 1.35 .44	16 2.39 .79	18 2.69 .89	11 1.64 .54	8 1.20 .39	1.20 .39	.60	10 1.49 .49	11 1.64 .54	11 1.64 54	.00	121 18.09 5.95
4-7 (1) (2)	23 3.44 1.13	15 2.24 .74	7 1.05 .34	.75 .25	. 15 . 05	7 1.05 .34	23 3.44 1.13	25 3.74 1.23	46 6.88 2.26	42 6.28 2.07	39 5.83 1.92	53 7.92 2.61	20 2.99 .98	24 3.59 1.18	29 4.33 1.43	22 3.29 1.08	.00	381 56.95 18.75
8-12 (1) (2)	7 1.05 .34	9 1.35 .44	.75 .25	.00	.30 .10	.60 .20	.60 .20	.90 .30	19 2.84 .94	42 6.28 2.07	16 2.39 .79	15 2.24 .74	.90 .30	.60 .20	.90 .30	.30 .10	.00	147 21.97 7.23
13-18 (1) (2)	.00	.00	00.00	.00	.00	.00	.00	.15	7 1.05 .34	.60 .20	.00	.00	. 15 . 05	.00	.00	.00	.00	13 1.94 .64
19-24 (1) (2)	.00 .00	0 .00 .00	.00	.00	.00	.00	.00	. 15 . 05	.60 .20	.30	.00	.00	.00	.00	.00	.00	.00	7 1.05 .34
GT 24 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS (1) (2)	37 5.53 1.82	28 4.19 1.38	15 2.24 .74	.90 .30	.45 .15	11 1.64 .54	36 5.38 1.77		94 14.05 4.63		63 9.42 3.10		31 4.63 1.53	38 5.68 1.87	46 6.88 2.26	35 5.23 1.72	.00	669 100.00 32.92

⁽¹⁾⁼PERCENT OF ALL GOOD ORSERVATIONS FOR THIS PAGE

⁽²⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERICD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA

STABILITY CLASS F

CLASS FREQUENCY (PERCENT) = 5.12

SPEE	ED (MPH)	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	(1) (2)	.00	.00	.00	.00	0 .00 .00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	C-3 (1) (2)	.00	.00	.00	.00	.96 .05	.00	1.92 .10	.00	4.81 .25		2.88 .15		6.73 .34	3 2.88 .15	.96 .05	.96 .05	.00	28 26.92 1.38
	4-7 (1) (2)	.00	.00	.96 .05	.00	.00	,00 ,00	, 96 , 05	1.92	5 4.81 .25	15 14.42 .74	20 19.23 .98		1.92	3 2.88 .15	1.92	.00	.00	57.69 2.95
	8-12 (1) (2)	.00	.00	.00	.00	00, 00.	.00	00.00	.00	3.85 .20	2.88 .15	5.77 .30		.00	.00	.00	00.00	.00	15 14.42 .74
	13-18 (1) (2)	00. 00.	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.60	.96 .05	.00	00.00	.00	.00 .00	1 - 96 - 05
	19-24 (1) (2)	00.00	.00	.00	.00	.00	.00	.00	00.00	.00.	.00.	.00	.00	.00	.00	.00	.00	.00	.00
	GT 24 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00,00	.00	.00	.00	.00	.00
ALL	SPEEDS (1) (2)	.00	.00 .00	.96 .05	.00	.96 .05	.00	3 2,88 .15	1.92		21 20.19 1.03		10-20-00-00-00-	10 9.62 .49	5.77 .30	3 2.88 .15	.96 .05	.00	104 100.00 5.12

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA STABILITY CLASS G

CLASS FREQUENCY (PERCENT) = 1.43

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	. 0	0	0	. 0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00	.00	.00
147	1.00	.00	.00	.00	.00	.00		,00	.00	200	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	0	0	0	0	0	1	1	0	2	- 1	0	1	0	C	0	6
(1)	.00	.00	.00	.00	.00	.00	.00	3.45	3.45	.00	6.90	3.45	.00	3.45	.00	.00	.00	20.69
(2)	.00	.00	.00	.00	.00	.00	.00	.05	. 05	.00	.10	.05	.00	.05	.00	.00	.00	.30
4-7	0	1	1	0	0	0	0	0	1	2	3	1	0	0	0	0	0	9
(1)	-00	3.45	3.45	.00	.00	.00	.00	.00	3.45		10.34	3.45	.00	.00	.00	.00	.00	31.03
(2)	-00	.05	.05	.00	.00	.00	.00	.00	.05	.10		.05	.00	.00	.00	-00	.00	.44
167	-90	100	.02	.00	100	-00	.00	.00	.43	. 10	. 12	.03	.00	.00	.00	.00	.00	. 44
8-12	0	0	0	0	0	0	- 1	0	0	4	3	0	0	0	0	0	0	8
(1)	.00	.00	.00	.00	.00	.00	3.45	.00	.00	13.79	10.34	-00	.00	.00	.00	.00	.00	27.59
(2)	.00	.00	.00	.00	.00	.00	. 05	.00	.00	.20	.15	.00	.00	.00	.00	.00	.00	.39
13-18	3	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	4
(1)	10.34	.00	.00	.00	3.45	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00	.00	13.79
(2)	- 15	.00	.00	.00	.05	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00		
(2)	+12	100	.00	.00	.05	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.20
19-24	. 1	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	2
(1)	3.45	.00	.00	.00	3.45	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	6.90
(2)	.05	.00	.00	.00	.05	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.10
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
(1)	.00	-00	.00	.00	-00	-00	.00	.00	.00	.00		.00	.00					0
														.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	4	1	1	0	2	0	1	1	2	6	8	2	0	- 1	0	0	0	29
(1)	13.79	3.45	3.45	.00	6.90	.00	3,45	3.45	6.90	20.69	27.59	6.90	.00	3.45	.00	.00	.00	100.00
(2)	.20	. 05	. 05	.00	.10	.00	.05	.05	.10			.10	.00	.05	.00	.00	.00	1.43

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

⁽²⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA

STABILITY CLASS ALL

CLASS FREQUENCY (PERCENT) = 100.00

SPEED	(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	:/SW	W	WNW	NW	NNW	VRBL	TOTAL
	(1) (2)	.00	00.00	.00	.00	.00	.00	,00	.00	.00	.00	.00	.00	.00	00,00	.00	.00	.00	.00
	C-3 (1) (2)	14 .69 .69	.25 .25	. 25 . 25	3 .15 .15	.15 .15	.05 .05	13 .64 .64	22 1.08 1.08	31 1.53 1.53	17 .84 .84	22 1.08 1.08	13 .64 .64	17 .84 .84	20 .98 .98	.69 .69	16 .79 .79	00.00	216 10.63 10.63
	4-7 (1) (2)	75 3.69 3.69	56 2.76 2.76	45 2.21 2.21	36 1.77 1.77	.39 .39	16 .79 .79	34 1.67 1.67	41 2.02 2.02	76 3.74 3.74	94 4.63 4.63	91 4.48 4.48	108 5.31 5.31	63 3.10 3.10	72 3.54 3.54	68 3.35 3.35	58 2.85 2.85	.00	941 46.31 46.31
	8-12 (1) (2)	64 3.15 3.15	49 2.41 2.41	46 2.26 2.26	23 1.13 1.13	.54 .54	.30 .30	.44 .44	.54 .54	70 3.44 3.44	89 4.38 4.38	62 3.05 3.05	77 3.79 3.79	95 4.68 4.68	52 2.56 2.56	47 2.31 2.31	38 1.87 1.87	.00	749 36.86 36.86
	13-18 (1) (2)	5 .25 .25	.44 .44	.30 .30	.05 .05	.05	.00	.00	.10	24 1.18 1.18	16 .79 .79	1 .05 .05	. 44 . 46	28 1.38 1.38	7 .34 .34	.20 .20	.00	.00	113 5.56 5.56
	19-24 (1) (2)	.05	.00	.00	.00	.05 .05	.00	.00	.10	.30 .30	. 15 . 15	.00	.00	00.00	00,00	.00	.00	.00	13 .64 .64
	GT 24 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00.00	.00	.00
ALL S	SPEEDS (1) (2)	159 7.82 7.82	119 5.86 5.86	102 5.02 5.02	63 3.10 3.10	24 1.18 1.18	23 1.13 1.13	56 2.76 2.76		10.19			207 10.19 10.19	203 9.99 9.99	151 7.43 7.43	133 6.55 6.55	112 5.51 5.51	.00	2032 100.00 100.00

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA

STABILITY CLASS A

CLASS FREQUENCY (PERCENT) = 24.87

CDEE	D(MPH)	N	NNE	NE	ENE	Ε	ESE	SE	SSE	s	SSW	SW	WSW	V	UNW	NW	NNW	VRBL	TOTAL
31.55	DAME 11.2		NA.	1930	2772		200				u o m				344645				
	CALM	0	0	0	- 1	0	0	0	0	0	0	0	0	0	0	0	0	0	1
	(1)	.00	.00	.00	.19	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	. 19
	(2)	.00	.00	.00	.05	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	. 05
	C-3	0	7	9	14	10	3	1	- 1	3	- 0	1	2	2	0	- 0	6	0	59
	(1)	.00	1.32	1.70	2.65	1.89	.57	.19	.19	.57	.00	.19	.38	.38	.00	.00	1.13	.00	11.15
	(2)	.00	.33	.42	.66	,47	.14	.05	.05	.14	.00	.05	.09	.09	.00	.00	.28	.00	2.77
	4-7	18	23	25	12	22	33	12	4	6	9	9	11	21	12	8	17	0	242
	(1)	3.40	4.35	4.73	2.27	4.16	6.24	2.27	.76	1.13	1.70	1.70	2.08	3.97	2.27	1.51	3.21	.00	45.75
	(5)	.85	1.08	1.18	.56	1.03	1.55	.56	.19	.28	.42	.42	.52	.99	.56	.38	.80	.00	11.38
	8-12	13	7	7	7	7	6	5	3	16	33	22	22	21	12	4	6	0	191
	(1)	2.46	1.32	1.32	1.32	1.32	1.13	.95	.57	3.02	6.24	4.16	4.16	3.97	2.27	.76	1.13	.00	36.11
	(2)	.61	.33	.33	.33	.33	.28	.24	. 14	.75	1.55	1.03	1.03	.99	.56	. 19	.28	.00	8.98
	13-18	1	1	0	0	0	0	0	0	6	14	3	0	5	2	. 1	- 1	0	34
	(1)	.19	.19	.00	.00	.00	.00	.00	.00	1.13	2,65	.57	.00	. 95	.38	.19	.19	.00	6.43
	(2)	.05	.05	.00	.00	.00	.00	.00	.00	.28	.66	.14	.00	.24	.09	.05	. 05	.00	1.60
	19-24	0	0	0	0	0	0	0	0	0	0	0	0	- 1	1	0	0	0	2
	(1)	.00	.00	.00	.00	.00	.00	, GO	.00	.00	.00	.00	.00	.19	.19	.00	.00	.00	. 38
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.05	.05	.00	.00	.00	.09
	GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL	SPEEDS	32	30	41	34	39	42	18	8	31	56	35	35	50	27	13	30	0	529
	(1)	6.05	7.18	7.75	6.43	7.37	7.94	3.40	1.51	5.86	10.59	6.62	6.62	9.45	5.10	2.46	5.67	.00	100.00
	(2)	1.50	1.79	1.93	1.60	1.83	1.97	.85	.38	1.46	2.63	1.65	1.65	2.35	1.27	.61	1.41	.00	24.87

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA STABILITY CLASS B

CLASS FREQUENCY (PERCENT) = 2.73

SPEED (M	(HPH)	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	(1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	C-3 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	1 1.72 .05	.00	1 1.72 .05	.00	.00	.00	.00	.00	.00	3.45 .09
	4-7 (1) (2)	3.45 .09	1 1.72 .05	5.17 .14	10.34 .28	.00	1 1.72 .05	3.45 .09	.00	3 5.17 .14	8.62 .24	1 1.72 .05	3.45 .09	3 5.17 .14	1 1.72 .05	3.45 .09	6.90 .19	.00	36 62.07 1.69
	3-12 (1) (2)	3.45 .09	.00	.00	1 1.72 .05	.00	.00	.00	1 1.72 .05	1 1.72 .05	8 13.79 .38	3.45 .09	1 1.72 .05	.00	.00	.00	.00	.00	16 27.59 .75
	(1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	1 1.72 .05	.00	1 1.72 .05	1 1.72 .05	1 1.72 .05	.00	.00	6.90 .19
	(1) (2)	.00	0 .00 .00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(1) (2)	.00	.00	.00	.00	.00 .00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00.00	.00
	(1) (2)	6.90 .19	1 1.72 .05	5.17 .14	7 12.07 .33	.00	1 1.72 .05	2 3.45 .09	1 1.72 .05	8.62 .24	13 22.41 .61	5 8.62 .24	3 5.17 .14	6.90 .19	3.45 .09	3 5.17 .14	6.90 .19	.00	58 100.00 2.73

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA

STABILITY CLASS C

CLASS FREQUENCY (PERCENT) = 3.06

SPEED (MPH) N	NNE	NE	ENE	Ε	ESE	SE	SSE	\$	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALI	4 0	0	0	0	0	0	0	. 0	0	0	0	0	0	0	0	0	0	0
(1	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2			.00	.00	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00	.00	.00	.00
C-	3 0	0	. 1	0	0	0	0	0	0	0	0	0	0	0	0	1	0	2
(1	.00	.00	1.54	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	1.54	.00	3.08
(2	,00	.00	.05	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.05	.00	.09
4-	7 1	2	5	2	1	3	2	0	1	7	3	2	2	3	4	3	0	41
(1	1.54	3.08	7.69	3.08	1.54	4.62	3.08	.00	1.54	10.77	4.62	3.08	3.08	4.62	6.15	4.62	.00	63.08
(2	.05	-09	.24	.09	. 05	.14	.09	.00	.05	.33	.14	.09	.09	.14	.19	.14	.00	1.93
8-1	1	1	0	1	- 1	1	0	0	2	7	2	0	2	1	0	0	0	19
(1	1.54	1.54	.00	1.54	1.54	1.54	.00	.00	3.08	10.77	3.08	.00	3.08	1.54	.00	.00	.00	29.23
(2	. 05	.05	.00	.05	. 05	.05	.00	.00	.09	.33	.09	.00	.09	. 05	.00	.00	.00	.89
13-11	3 0	1	0	0	0	0	0	0	0	1	0	0	0	0	1	0	0	3
(1	.00	1.54	.00	.00	.00	.00	.00	.00	.00	1.54	.00	.00	.00	.00	1.54	.00	.00	4.62
(2	.00	.05	.00	.00	.00	.00	.00	.00	.00	.05	.00	.00	.00	.00	.05	.00	.00	.14
19-2	. 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 2	. 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2	.00	.00	.00	.00	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	2	4	6	3	2	4	2	0	3	15	5	2	4	4	5	4	0	65
(1	3.08	6.15	9.23	4.62	3.08	6.15	3.08	.00	4.62	23.08	7.69	3.08	6.15	6.15	7.69	6.15	.00	100.00
(2	.09	.19	.28	.14	.09	.19	.09	.00		.71	.24	.09	.19	.19	.24	.19	-00	3.06

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA STABILITY CLASS D

CLASS FREQUENCY (PERCENT) = 28.07

SPEED (MPH)	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
(1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.34 .09	.00	.00	.00	.34 .09
C-3 (1) (2)	1.01 .28	9 1.51 .42	.34	.67 .19	. 84 . 24	8 1.34 .38	8 1.34 .38	.67 .19	10 1.68 .47	9 1.51 .42	.67 .19	.67 .19	.67 .19	8 1.34 .38	9 1.51 .42	1.68 .47	.00	104 17.42 4.89
4-7 (1) (2)	24 4.02 1.13	1.51 .42	17 2.85 .80	16 2.68 .75	16 2.68 .75	10 1.68 .47	28 4.69 1.32	18 3.02 .85	26 4.36 1.22	24 4.02 1.13	8 1.34 .38	10 1.68 .47	15 2.51 .71	2.35 .66	14 2.35 .66	17 2.85 .80	.00.	266 44.56 12.51
8-12 (1) (2)	16 2.68 .75	10 1.68 .47	6 1.01 .28	.34	10 1.68 .47	.50 .14	8 1.34 .38		29 4.86 1.36	42 7.04 1.97	7 1.17 .33	7 1.17 .33	16 2.68 .75	7 1.17 .33	11 1.84 .52	16 2.68 .75	.00	196 32.83 9.21
13-18 (1) (2)	.00	.67 .19	.17 .05	.00	.00	.00	.00	1 .17 .05	.50 .14	2 .34 .09	.00	.17 .05	8 1.34 .38	.34 .09	6 1.01 .28	.17 .05	.00	29 4.86 1.36
19-24 (1) (2)	.00	,00 ,00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00. 00.	.00	.00
GT 24 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00.00	.00	.00 .00
ALL SPEEDS (1) (2)	46 7.71 2.16	32 5.36 1.50	26 4.36 1.22	22 3.69 1.03	31 5.19 1.46	21 3.52 .99	7.37 2.07		68 11.39 3.20		19 3.18 .89	22 3.69 1.03	43 7.20 2.02	33 5.53 1.55	40 6.70 1.88	44 7.37 2.07	.00	597 100.00 28.07

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA STABILITY CLASS E

CLASS FREQUENCY (PERCENT) = 28.91

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
(1) (2)	.00	.00	.00	.00	.00	.16 .05	.16 .05	.00	1 . 16 . 05	.00	.00	.00	.00	.00	.00	.00	.00	.49 .14
C-3 (1) (2)	.33 .09	.81 .24	.33	3 -49 -14	11 1.79 .52	1.63 .47	12 1.95 .56	9 1.46 .42	6 .98 .28	1.30 .38	.81 .24	.81 .24	6 .98 .28	11 1.79 .52	12 1.95 .56	.65	.00	111 18.05 5.22
4-7 (1) (2)	19 3.09 .89	.81 .24	.98 .28	.65 .19	.49 .14	9 1.46 .42	10 1.63 .47	29 4.72 1.36	27 4.39 1.27	26 4.23 1.22	12 1.95 .56	26 4.23 1.22	24 3.90 1.13	23 3.74 1.08	18 2.93 .85	12 1.95 .56	.00	253 41.14 11.89
8-12 (1) (2)	.65 .19	9 1.46 .42	.49 .14	.16 .05	7 1.14 .33	.00	.00	.98 .28	18 2.93 .85	103 16.75 4.84	25 4.07 1.18	6 .98 .28	.65 .19	8 1.30 .38	9 1.46 .42	15 2.44 .71	.00	218 35.45 10.25
13-18 (1) (2)	.00	0 .00 .00	.00	.00	.00	.00	.00	.00	.81 .24	6 .98 .28	.65 .19	.00	.33	1 .16 .05	.65 .19	3 .49 .14	00.00	25 4.07 1.18
19-24 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.16	.00	.00	.00	0 .00	00.00	.00	.65	.00	.81 .24
GT 24 (1) (2)	00.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00.00	.00	.00	.00	.00	.00	00.00	.00
ALL SPEEDS (1) (2)	25 4.07 1.18	19 3.09 .89	11 1.79 .52	8 1.30 .38	21 3.41 .99	20 3.25 .94	23 3.74 1.08	44 7.15 2.07		143 23.25 6.72	46 7.48 2.16	37 6.02 1.74	36 5.85 1.69	43 6.99 2.02	6. 02 2.02	38 6.18 1.79	.00	615 100.00 28.91

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

⁽²⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA STABILITY CLASS F

CLASS FREQUENCY (PERCENT) = 8.84

SPEED (MP	НЭ	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL	
CA	LM	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1	
(1)	.00	.00	.00	.00	.00	.00	.53	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.53	
(2)	.00	.00	.00	.00	.00	.00	.05	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.05	
C	-3	1	0	1	1	1	4	4	5	3	3	2	7	7	2	0	4	0	42	
	1)	.53	.00	.53	.53	.53	2.13	2.13	2.66	1.60	1.60	1.06	3.72		- 75		6.7		1000	
	2)	.05	.00	.05	.05										1.06	.00	.53	.00	22.34	
	c)	.02	.00	.05	.03	. 05	. 19	.19	.24	.14	. 14	.09	.33	.33	.09	-00	. 05	.00	1.97	
	-7	0	0	0	0	2	2	1	3	6	3	12	16	19	7	0	1	0	72	
(1)	.00	.00	.00	.00	1.06	1.06	.53	1.60	3.19	1.60	6.38	8.51	10.11	3.72	.00	.53	.00	38.30	
(2)	.00	.00	.00	.00	.09	.09	. 05	.14	-28	. 14	.56	. 75	.89	.33	.00	. 05	.00	3.39	
8-	12	0	0	0	0	0	0	0	1	0	19	24	1	1	1	1	0	0	48	
(1)	.00	.00	.00	.00	.00	.00	.00	.53			12.77	-53	.53	.53	.53	.00	.00	25.53	
	2)	.00	.00	.00	.00	.00	.00	.00	.05	.00		1.13	.05	.05	.05	.05	.00	.00	2.26	
					2.3650	****	100		100	200	.07	1 . 1.0	.00	,0,7	*113	.03	.00	.00	2.20	
13-	18	0	0	0	0	- 0	0	0	0	0	9	15	0	0	0	1	. 0	0	25	
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	4.79	7.98	.00	.00	.00	.53	.00	.00	13.30	
(2).	.00	.00	.00	.00	.00	.00	.00	.00	.00	.42	.71	.00	.00	.00	. 05	.00	.00	1.18	
19-	24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
(13	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
(.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00		
				.00		.00	.00	.00	200	.00	.00	.00	.00	.00	.00	.00	,00	.00	.00	
GT	24	0	0	- 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
ALL SPEE	DS	1	0	- 1	1	3	6	6	9	9	34	53	24	27	10	2	2	0	188	
	1)	.53	.00	.53	.53	1,60	3.19		4.79					14,36	5.32	1.06	1.06	.00	100.00	
	2)	.05	.00	.05	.05	.14	.21	.28	.42			2.49			.47	.09	.09			
		2.00.01	100	1500	100	1.14	11 Ac. 1	. 60	.46	.42	1.00	2.49	1.13	1.21	.41	.09	.09	.00	8.84	

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA STABILITY CLASS G

CLASS FREQUENCY (PERCENT) = 3.53

SPEED(MPH)	N	NNE	NE	ENE	Ε	ESÉ	SE	SSE	S	SSW	SW	WSW	W	WKA	NW	NNW	VRBL	TOTAL
	(1) (2)	00.00	.00	.00	00.00	.00	00.00	.00	1 1.33 .05	1 1.33 .05	.00	.00	.00	.00	.00	.00	.00	.00	2 2.67 .09
	C-3 (1) (2)	.00	.00	.00	.00	.00	1 1.33 .05	.00	12.00	2.67 .09	8.00 .28	11 14.67 .52	3 4.00 .14	1 1.33 .05	.00	.00	00.00	.00	33 44.00 1.55
	4-7 (1) (2)	.00	0 .00 .00	.00	1 1.33 .05	.00	.00	.00	10 13.33 .47	5 6.67 .24	.00	5.33 .19	5 6.67 .24	2 2.67 .09	.00	.00	.00	.00.	27 36.00 1.27
	8-12 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	00.00	2 2.67 .09	10.67 .38	.00	1 1.33 .05	.00	.00	.00	.00	11 14.67 .52
	3-18 (1) (2)	.00	.00	.00	00.00	.00	.00	.00	.00	.00	.00	1 1.33 .05	.00	.00	.00	00.00	.00	.00	1 1.33 .05
	9-24 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	1 1.33 .05	.00	.00	.00	.00	00.00	.00	1 1.33 .05
G	(1) (2)	.00	.00	.00	.00	.00	.00	00.00	.00	.00	.00	.00	.00	.00	.00	00.00	.00	.00 .00	.00
ALL SP	(1) (2)	.00	.00	.00	1 1.33 .05	.00	1 1.33 .05	.00	26.67	8 10.67 .38		25 33.33 1.18		5.33 .19	.00	.00	0.00.	.00	75 100.00 3.53

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

⁽²⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

33.0 FT WIND DATA

STABILITY CLASS ALL

CLASS FREQUENCY (PERCENT) = 100.00

SPEED (MP	0	N NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL.	TOTAL
CAI	0.		.00	.05	.00	.05	.09	.05 .05	.09	.00	.00	.00	.00	.09	.00	.00	.00	9 .42 .42
C) .4	. 99	.71	1.03 1.03	27 1.27 1.27	26 1.22 1.22	25 1.18 1.18	28 1.32 1.32	25 1.18 1.18	26 1.22 1.22	24 1.13 1.13	21 .99 .99	20 .94 .94	21 .99 .99	21 .99 .99	22 1.03 1.03	.00	353 16.60 16.60
(3.0	1 1.88	2.63		2.07 2.07	58 2.73 2.73	2.59			74 3.48 3.48	49 2.30 2.30	72 3.39 3.39	86 4.04 4.04	60 2.82 2.82	46 2.16 2.16	54 2.54 2.54	.00	937 44.05 44.05
8- (1	1.6	1.27	.75	12 .56 .56	25 1.18 1.18	10 .47 .47	13 .61 .61	17 .80 .80	3.10	214 10.06 10.06	90 4.23 4.23	37 1.74 1.74	45 2.12 2.12	29 1.36 1.36	25 1.18 1.18	37 1.74 1.74	.00	699 32.86 32.86
13-	.0	. 28	.05	.00	.00	.00	.00	.05	14 .66	32 1.50 1.50	24 1.13 1.13	.05 .05	16 .75 .75	.28 .28	14 .66 .66	.24 .24	.00	121 5.69 5.69
19-2 (1	0.	00.	.00	.00	.00	.00	.00	.00	.05	.00	.05 .05	.00	.05 .05	.05	.00	.19 .19	00.00	.38 .38
GT (.0	.00	.00	.00	.00	.00	.00	.00	.00	00.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEED) 5.1	7 4.42					95 4.47 4.47			346 16.27 16.27	188 8.84 8.84	131 6.16 6.16	168 7.90 7.90	119 5.59 5.59		122 5.74 5.74	.00	2127 100.00 100.00

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS .* THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

Table 4A-2
Distributions of Wind Directions and Speeds for the 220-ft Level of the 220-ft Tower

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA

STABILITY CLASS A

CLASS FREQUENCY (PERCENT) = 10.99

SPEED(MPH)	. N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
(1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3 (1) (2)	.00	.00	0,00	.00	00.00	.00	.00	.00	.00	.00	00.00	.00	0	.00	.00	0.00	0.00	0.00
4-7 (1) (2)	.43 .05	.87 .10	1.74	1 .43 .05	1 .43 .05	.00	.00	.43 .05	.00	00.00	0.00	.00	.00	.00	00.00	.87 .10	0,00	12 5.22 .57
8-12 (1) (2)	13 5.65 .62	5 2.17 .24	1.74	5 2.17 .24	8 3.48 .38	.87 .10	.43 .05	1 .43 .05	.87 .10	1 .43 .05	0.00	5 2.17 .24		.43 .05	.87 .10	3 1.30 .14	.00	58 25.22 2.77
13-18 (1) (2)	5.22 .57	9 3.91 .43	.00	.00	.87 .10	00.00	.87 .10	00.00	3 1.30 .14	5 2.17 .24	6 2.61 .29	2.61 .29	3.04		1.74	11 4.78 .53	00.00	82 35.65 3.92
19-24 (1) (2)	6 2.61 .29	1.74 .19	.43 .05	.00	.00	.00	.00	.00	1 .43 .05	.00	.00	.43 .05	14 6.09 .67	10 4.35 .48	6 2.61 .29	15 6.52 .72	00.00	58 25.22 2.77
GT 24 (1) (2)	.00	,00 ,00	.00	.00	.00	.00	.00	.00	00.00	.00	00.00	.43 .05	4.78 .53	1.74	3 1.30 .14	1 .43 .05	00.00	20 8.70 .96
ALL SPEEDS (1) (2)	32 13.91 1.53	8.70 .96	9 3.91 .43	6 2.61 .29	11 4.78 .53	.87 .10	3 1.30 .14			6 2.61 .29	6 2.61 .29		37 16.09 1.77		15 6.52 ,72	32 13.91 1.53	.00	230 100.00 10.99

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS B

CLASS FREQUENCY (PERCENT) = 3.39

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	s	SSW	SW	WSW	W	WNW	NW	NNW	VRBL.	TOTAL
CALM (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00	.00
C-3 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00.00	.00	.00	.00
4-7 (1) (2)	.00	.00	.00	1 1.41 .05	.00	.00	.00	.00	.00	.00	.00	.00	.00	1.41	2.82	.00	.00	5.63 .19
8-12 (1) (2)	1 1.41 .05	.00	2 2.82 .10	.00	2.82	.00	.00	.00	.00	.00	1 1.41 .05	5.63 .19		2 2.82 .10	.00	1 1.41 .05	00.00	13 18.31 .62
13-18 (1) (2)	2 2.82 .10	2 2.82 .10	5.63 .19	.00	.00	.00	2.82	.00	4.23 .14	1 1.41 .05	5.63 .19				1.41 .05	1 1.41 .05	.00	30 42.25 1.43
19-24 (1) (2)	1 1.41 .05	6 8.45 .29	.00	.00	.00	.00	.00	.00	.00	.00	.00				.00	2.82	.00	17 23.94 .81
GT 24 (1) (2)	.00	4.23 .14	.00	.00	.00	.00	.00	.00	.00	.00	.00			1 1.41 .05	.00	.00	00.00	7 9.86 .33
ALL SPEEDS (1) (2)	5.63 .19	11 15.49 .53	8.45 .29	1 1.41 .05	2.82	00.00	2 2.82 .10	00.00	3 4.23 .14	1 1.41 .05	7.04 .24	14.08	11.27	15.49	3 4.23 .14	5.63 .19	.00	71 100.00 3.39

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS C

CLASS FREQUENCY (PERCENT) = 3.63

SPEED (MPH)	N	NNE	NE	ENE	Ε	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
(1) (2)	.00	.00	.00	.00	.00	.00	.00.	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	0 .00 .00
C-3 (1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00.	.00	.00	.00	.00	.00	.00	.00
4-7 (1) (2)	2 2.63 .10	1 1.32 .05	.00	.00	.00	00.00	.00	.00	.00	.00 .G0	.00		1 1.32 .05	2.63 .10	.00	1 1.32 .05	.00	7 9.21 .33
8-12 (1) (2)	1 1.32 .05	.00	1 1.32 .05	.00	1 1.32 .05	2.63 .10	.00	.00	.00	2.63 .10	1.32	.00	2 2.63 .10	2 2.63 .10	.00	.00	.00	12 15.79 .57
13-18 (1) (2)	.00	1 1.32 .05	6 7.89 .29	1 1.32 .05	1 1.32 .05	1 1.32 .05	.00	.00	1 1.32 .05	2 2.63 .10	3.95 .14	11.84	5.26 .19	2 2.63 .10	1 1.32 .05	1 1.32 .05	.00	33 43.42 1.58
19-24 (1) (2)	2 2.63 .10	2 2.63 .10	.00	.00	.00	.00	.00	.00	1 1.32 .05	2 2.63 .10	.00		1 1.32 .05	3 3.95 .14	2 2.63 .10	3 3.95 .14	.00	16 21.05 .76
GT 24 (1) (2)	1 1.32 .05	3.95 .14	.00	.00	.00	.00	.no	.00	.00	.00	.00		1.32	.00	1 1.32 .05	2 2.63 .10	.00	10.53 .38
ALL SPEEDS (1) (2)	6 7.89 .29	9.21 .33	7 9.21 .33	1.32	2 2.63 .10	3 3.95 .14	.00	.00	2 2.63 .10	6 7.89 .29	5.26 .19		9 11.84 .43		5.26 .19	7 9.21 .33	.00	76 100.00 3.63

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

ATAD DATA 0.055

STABILITY CLASS D

CLASS FREQUENCY (PERCENT) = 43.57

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
(1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	00.00	.00	.00
C-3 (1) (2)	.11 .05	.11	.11	.00	.00	.00	0.00.	.11	.11 .05	.00	.00	.00.	.22	.11	.00	.00	.00	.88 .38
4-7 (1) (2)	.44	.11 .05	.44	.22	.66 .29	3 .33 .14	.44	5 .55 .24	.22 .10	.22	5 .55 .24	3 .33 .14	.33	.55 .24	.22	.44	.00	55 6.03 2.63
8-12 (1) (2)	.88 .38	.99 .43	1.10 1.10 .48	.77 .33	.77 .33	1.75 .76	.77 .33	1.21	21 2.30 1.00		17 1.86 .81	27 2.96 1.29	1.54	5 .55 .24	.44 .19	.55 .24	00.00	196 21.49 9.36
13-18 (1) (2)	23 2.52 1.10	11 1.21 .53	1.10 1.10 .48	17 1.86 .81	.33 .14	.77 .33	6 .66 .29	.22	25 2.74 1.19	19 2.08 .91	27 2.96 1.29			15 1.64 .72	21 2.30 1.00	13 1.43 .62	.00	237 25.99 11.32
19-24 (1) (2)	23 2.52 1.10	.88 .38	.99 .43	.22	.77 .33	.55 .24	.33 .14	.11 .05	12 1.32 .57	11 1.21 .53	15 1.64 .72	16 1.75 .76	5.37	16 1.75 .76	6.47	35 3.84 1.67	.00	271 29.71 12.95
GT 24 (1) (2)	.77 .33	8 .88 .38	.00	.22	.22	.33 .14	.00	.11	15 1.64 .72	5 .55 .24	.11	3 .33 .14	5.37	18 1.97 .86	20 2.19 .96	11 1.21 .53	00.00	145 15.90 6.93
ALL SPEEDS (1) (2)	66 7.24 3.15		34 3.73 1.62	30 3.29 1.43	25 2.74 1.19	34 3.73 1.62	20 2.19 .96	21 2.30 1.00		65 7.13 3.11	65 7.13 3.11		130 14.25 6.21		11.62	68 7,46 3,25	.00	912 100.00 43.57

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA

STABILITY CLASS E

CLASS FPEQUENCY (PERCENT) = 32.06

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	(1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	C-3 (1) (2)	.30	.45 .14	.00	.00	.00	.00	.00	.00	.00	.00	.00	1 .15 .05	.00	.00	.15 .05	.30 .10	.00	9 1.34 .43
	4-7 (1) (2)	.75 .24	8 1.19 .38	.75 .24	.00	.60 .19	.45 .14	.30 .10	3 .45 .14	.30	5 .75 .24	.30 .10	1 .15 .05	.30 .10	.30	.45 .14	.89 .29	.00	53 7.90 2.53
	8-12 (1) (2)	.75 .24	.60	3 .45 .14	.60 .19	.60	7 1.04 .33	18 2.68 .86	16 2.38 .76		22 3.28 1.05	8 1.19 .38	11 1.64 .53	10 1.49 .48	17 2.53 .81	10 1.49 .48	.30	.00	161 23.99 7.69
	3-18 (1) (2)	14 2.09 .67	7 1.04 .33	.60 .19	.30 .10	.75 .24	9 1.34 .43	17 2.53 .81	8 1.19 .38	30 4.47 1.43		36 5.37 1.72	35 5.22 1.67	25 3.73 1.19	20 2.98 .96	26 3.87 1.24	20 2.98 .96	.00	292 43.52 13.95
	9-24 (1) (2)	10 1.49 .48	.45 .14	.60 .19	.00	.15	3 .45 .14	.60 .19	.30 .10		24 3.58 1.15	11 1.64 .53	10 1.49 .48	7 1.04 .33	.45 .14	5 .75 .24	18 2.68 .86	.00	117 17.44 5.59
	(1) (2)	.45 .14	.00	00.00	0.00.	.00	.00	.00	.60 .19	13 1.94 .62	10 1.49 .48	.15 .05	.00	.4. .14	.15	.30 .10	.30 .10	.00	39 5.81 1.86
	(1) (2)	39 5.81 1.86	25 3.73 1.19	16 2.38 .76	.89 .29	14 2.09 .67	22 3.28 1.05	41 6.11 1.96			95 14.16 4.54	58 8.64 2.77	58 8.64 2.77	47 7.00 2.25	43 6.41 2.05	47 7.00 2.25	50 7.45 2.39	.00	671 100.00 32.06

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

⁽²⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS F

CLASS FREQUENCY (PERCENT) = 4.97

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	s	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
(1) (2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3 (1) (2)	.00	.00	.96 .05	.00	.00	.00	.00	.00	.00	.00	,00	.00	.00	.96	.00	.96 .05	.00	3 2.88 .14
4-7 (1) (2)	.96 .05	.96 .05	.96 .05	.00	.00	.96 .05	.00	.96 .05	.00	3 2.88 .14	3.85 .19	3 2.88 .14	.00	.96 .05	.96 .05	3 2.88 .14	.00	20 19.23 .96
8-12 (1) (2)	.00	00,00	.00	.00	.00	.96 .05	.00		1.92	3 2.88 .14		3 2.88 .14	5 4.81 .24	5 4.81 .24	.96 .05	00.00	.00	27 25.96 1.29
13-18 (1) (2)	.00	.00	.00	.00	.00	.00	.00	5.77 .29	3 2.88 .14	5.77 .29		10 9.62 .48	3.85 .19	.96 .05	. 96 . 05	.00	.00	38 36.54 1.82
19 24 (1) (2)	.00	.00	.00	.00	.00	.00	.00	1 .96 .05	1.92 .10	1.92 .10		3 2.88 .14	.96 .05	.00	.00	1.92 .10	.00	15 14.42 .72
GT 24 (1) (2)	.00	.00	.00	.00	.96 .05	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.96 .05
ALL SPEEDS (1) (2)	.96 .05	.96 .05	1.92	.00	.96 .05	1.92	.00	11.54	7 6.73 .33	14 13.46 .67	17.31	19 18.27 .91	10 9.62 .48	8 7.69 .38	3 2.88 .14	5.77 .29	.00	104 100.00 4.97

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA

STABILITY CLASS G

CLASS FREQUENCY (PERCENT) = 1.39

SPEED (MP	H)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	IOTAL
CA	LM	0	0	0	- 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	2)	.00	.00	.00	.00		.00	.00	.00	.00	.00			.00	.00	.00	.00	.00	.00
C	- 3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	-00	.00	.00	.00	.00	.00	.00	.00	0	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00			.00	.00	.00	.00	.00	.00
4	-7	0	0	0	0	0	0	0	0	1	0	1	1	0	0	2	0	0	5
(10	-00	.00	.00	.00	.00	.00	.00	.00	3.45	.00	3.45	3.45	.00	.00	6.90	.00	.00	17.24
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.05	.00	.05	.05	.00	.00	.10	.00	.00	.24
8-	12	0	0	0	0	0	0	1	0	3	0	0	0	0	1	0	0	0	5
(10	.00	.00	.00	.00	.00	.00	3.45	.00	10.34	.00	.00	.00	.00	3.45	.00	.00	.00	17.24
(2)	.00	.00	.00	.00	.00	.00	.05	.00	.14	.00	.00	.00	.00	. 05	.00	.00	.00	.24
13-		0	0	0	0	0	0	0	0	0	0	1	3	2	0	0	0	0	6
(13	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	3.45	10.34	6.90	.00	.00	.00	.00	20.69
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	. 05	. 14	.10	.00	.00	.00	.00	.29
19-	24	0	0	0	0	0	0	- 1	0	0	0	5	0	0	0	0	0	0	6
(1)	.00	.00	.00	.00	.00	.00	3.45	.00	.00	.00	17.24	.00	.00	.00	.00	.00	.00	20.69
(2)	.00	.00	.00	.00	.00	.00	.05	.00	.00	.00	.24	.00	.00	.00	.00	.00	.00	.29
GT	24	0	0	0	- 1	5	1	0	0	0	0	0	0	0	0	0	0	0	7
(1)	.00	.00	.00	3.45	17.24	3.45	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	24.14
(2)	.00	.00	.00	.05	.24	.05	.00	.00	.00	-00	.00	.00	.00	.00	.00	.00	.00	.33
ALL SPEE		0	0	0	. 1	5	1	2	0	4	0	7	4	2	1	2	0	0	29
(1)	.00	.00	.00	3.45	17.24	3.45	6.90	.00	13.79	.00	24.14	13.79	6.90	3.45	6.90	.00	.00	100.00
(2)	.00	.00	.00	.05	.24	.05	.10	.00	.19	.00	.33	.19	.10	.05	.10	.00	.00	1.39

^{(1) =} PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

⁽²⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM JAN95-MAR95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS ALL

CLASS FREQUENCY (PERCENT) = 100.00

SPEED (MPH)	N	NNE	NE	ENE	Е	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)		.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00
									.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	3	4	2	0	0	0	0	- 1	1	0	0	1	2	2	1	3	. 0	20
(1)	. 14	.19	.10	.00	.00	.00	.00	.05	.05	.00	.00	.05	.10	.10	.05	.14	.00	.96
(2)	.14	.19	.10	.00	.00	.00	.00	.05	.05	.00	.00	.05	.10	.10	.05	.14	.00	.96
						-		1.90				100	. 10	. 10	.02	2.17	.00	. 70
4-7	13	13	14	4	11	7	6	10	5	10	12	8	6	11	10	16	0	156
(1)	.62	.62	.67	.19	.53	.33	.29	.48	. 24	.48	.57	.38	.29	.53	.48	.76	.00	7.45
(2)	.62	.62	.67	.19	.53	.33	.29	.48	.24	.48	.57	.38	.29	.53	.48	.76	.00	7.45
															1.436			
8-12	28	18	20	16	22	28	27	32	48	56	30	50	36	33	17	11	0	472
(1)	1.34	.86	.96	.76	1.05	1.34	1.29	1.53	2.29	2.68	1.43	2.39	1.72	1.58	.81	.53	.00	22.55
(2)	1.34	-86	.96	.76	1.05	1.34	1.29	1.53			1.43			1.58	.81	.53	.00	22.55
								1.000		2.00	1 4 7 4	61.07	1.1.4	1120				66.33
13-18	51	30	24	20	11	17	27	16	65	67	84	91	59	56	54	46	0	718
(1)	2.44	1.43	1.15	.96	.53	. 91	1.29	.76	3.11	3.20	4.01	4.35	2.82	2.68	2.58	2.20	.00	34.30
(2)	2.44	1.43	1.15	-96	.53	.81	1.29	.76	3.11	3.20		4.35		2.68	2.58	2.20	.00	34.30
					- 11					2160	4.01	4.33	C.OL	2.00	2.20	2.20	.00	34.30
19-24	42	23	14	2	8	8	8	4	28	39	35	32	74	36	72	75	0	500
(1)	2.01	1.10	.67	.10	.38	.38	.38	.19	1.34	1.86	1.67	1.53	3.54	1.72	3.44	3.58	.00	23.89
(2)	2.01	1.10	.67	.10	.38	.38	.38	.19	1.34	1.86		1.53		1.72	3.44	3.58	.00	23.89
										1100	1201	1.00	3.34	1116	2,44	2.20	.00	647.07
GT 24	1.1	14	0	3	8	4	0	5	28	15	2	5	66	24	26	16	0	227
(1)	.53	.67	.00	.14	.38	.19	.00	.24	1.34	.72	.10	.24	3.15	1.15	1.24	.76	.00	10.85
(2)	.53	.67	.00	.14	.38	.19	.00	.24	1.34	.72	.10	.24		1.15	1.24	.76	.00	10.85
													2112		1 + 5.79	110	.00	10103
ALL SPEEDS	148	102	74	45	60	64	68	68	175	187	163	187	243	162	180	167	0	2093
(1)	7.07	4.87	3.54	2.15	2.87	3.06	3.25	3.25	8.36	8.93	7.79	8.93	11.61	7.74	8.60	7.98	.00	100.00
(2)	7.07	4.87	3.54	2.15	2.87	3.06	3.25	3.25	8.36				11.61			7.98	.00	100.00
				100000	-	-	- ande			-	2000				40 × 100 10	1. 1. 1.40	4 10.00	100100

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA

STABILITY CLASS A

CLASS FREQUENCY (PERCENT) = 24.87

SPE	ED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL.	TOTAL
	CALM	0	0	1	. 0	0	0	0	.0	0	0	0	0	0	0	0	0	0	1
	(1)	.00	.00	.19	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.19
	(5)	.00	.00	.05	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	. 05
	C-3	0	2	4	6	2	0	- 1	0	1	0	0	0	1	0	0	0	0	17
	(1)	.00	.38	.76	1.13	.38	.00	.19	.00	.19	.00	.00	.00	.19	.00	.00	.00	.00	3.21
	(2)	.00	.09	. 19	.28	.09	.00	.05	.00	.05	.00	.00	.00	. 05	.00	.00	.00	.00	.80
	4-7	6	11	6	12	16	8	1	1	2	0	1	4	0	1	2	4	0	75
	(1)	1.13	2.08	1.13	2.27	3.02	1,51	.19	.19	.38	.00	.19	.76	.00	.19	.38	.76	.00	14.18
	(2)	.28	.52	.28	.56	.75	.38	.05	. 05	.09	.00	.05	.19	.00	.05	.09	.19	.00	3.53
	€-12	12	11	12	13	12	25	14	4	6	7	4	9	12	7	2	6	0	156
	(1)	2.27	2.08	2.27	2.46	2.27	4.73	2.65	.76	1.13	1.32	.76	1.70	2.27	1.32	.38	1.13	.00	29.49
	(2)	.56	.52	.56	.61	.56	1.18	.66	. 19	.28	.33	.19	.42	.56	.33	.09	.28	.00	7.33
	13-18	11	. 7	1	2	1	14	14	5	12	19	14	21	26	9	3	11	0	170
	(1)	2.08	1.32	.19	.38	.19	2.65	2.65	.95	2.27	3.59	2.65	3.97	4.91	1.70	.57	2.08	.00	32.14
	(2)	.52	.33	.05	.09	.05	.66	.66	.24	.56	.89	.66	.99	1.22	.42	.14	.52	.00	7.99
	19-24	2	1	5	3	0	0	0	3	5	15	6	9	6	6	0	4	0	65
	(1)	.38	.19	. 95	.57	.00	.00	.00	.57	.95	2.84	1.13	1.70	1.13	1,13	.00	.76	.00	12.29
	(2)	.09	.05	.24	.14	.00	.00	.00	.14	.24	.71	.28	.42	.28	.28	.00	.19	.00	3.06
	GT 24	1	0	0	1	0	0	0	0	5	12	2	1	7	7	1	8	0	45
	(1)	.19	.00	.00	.19	.00	.00	.00	.00	.95	2.27	.38	.19	1.32	1.32	.19	1.51	.00	8.51
	(2)	.05	.00	.00	. 05	.00	.00	.00	.00	.24	-56	.09	.05	.33	.33	.05	.38	.00	2.12
ALL	SPEEDS	32	32	29	37	31	47	30	13	31	53	27	44	52	30	8	33	0	529
	(1)	6.05	6.05	5.48	6.99	5.86	8.88	5.67	2.46	5.86	10.02	5.10	8.32	9.83	5.67	1.51	6.24	.00	100.00
	(2)	1.50	1.50	1.36	1.74	1.46	2.21	1.41	-61	1.46	2.49	1.27	2.07	2.44	1.41	.38	1.55	.00	24.87

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS B

CLASS FREQUENCY (PERCENT) = 2.73

SPEED(MPH) N NNE NE ENE E ESE SE SSE S SSW SW WSW W WNW NW NNW VR	L TOTAL
	0 0
CALM 0 0 0 0 0 0 0 0 0 0 0 0 0	
. 00. 00. 00. 00. 00. 00. 00. 00. 00. 0	0 .00
	0 .00
C-3 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0
. 00, 00, 00, 00, 00, 00, 00, 00, 00, 00	0 .00
	00.00
4-7 1 1 0 1 1 0 0 0 0 0 0 0 0 1 1	0 6
(1) 1.72 1.72 .00 1.72 1.72 .00 .00 .00 .00 .00 .00 .00 .00 .00 1.72 1.72 .	0 10.34
(2) .05 .05 .00 .05 .05 .00 .00 .00 .00 .00	0 .28
8-12 1 2 1 5 1 5 0 0 2 1 2 1 1 2 0 0	0 24
(1) 1.72 3.45 1.72 8.62 1.72 8.62 .00 .00 3.45 1.72 3.45 1.72 1.72 3.45 .00 .00 .	0 41.38
(2) .05 .09 .05 .24 .05 .24 .00 .00 .09 .05 .09 .05 .09 .00 .00 .	
13-18 0 0 0 0 1 1 1 0 4 2 1 1 0 0 1 2	0 14
(1) .00 .00 .00 .00 1.72 1.72 1.72 .00 6.90 3.45 1.72 1.72 .00 .00 1.72 3.45 .	0 24.14
(2) .00 .00 .00 .05 .05 .05 .00 .19 .09 .05 .05 .00 .00 .05 .09 .	
19-24 0 0 0 0 0 0 0 2 1 4 0 1 0 0 0	0 8
(1) .00 .00 .00 .00 .00 .00 .00 3.45 1.72 6.90 .00 1.72 .00 .00 .00 .00 .	0 13.79
	0 .38
GT 24 1 0 0 0 0 0 0 0 0 1 1 0 1 1 1 0	0 6
(1) 1.72 .00 .00 .00 .00 .00 .00 .00 1.72 1.72 .00 1.72 1.72 .00 .	0 10.34
	0 .28
ALL SPEEDS 3 3 1 6 3 6 1 2 7 8 4 3 2 3 3 3	0 58
(1) 5.17 5.17 1.72 10.34 5.17 10.34 1.72 3.45 12.07 13.79 6.90 5.17 3.45 5.17 5.17 5.17	
	0 2.73

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2) = PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

Table 4A-2 (continued)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS C CLASS FREQUENCY (PERCENT) = 3.06

SPE	ED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	CALM	. 0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00		.00	.00	.00	.00	.00	.00	.00
	C-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	(5)	,00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
	4-7	0	1	4	2	0	0	3	0	0	0	0	0	0	2	2	2	0	16
	(1)	.00	1.54	6.15	3.08	.00	.00	4.62	.00	.00	.00	.00	.00	.00	3.08	3.08	3.08	.00	24.62
	(2)	.00	.05	.19	.09	.00	.00	.14	.00	.00	.00	.00	.00	.00	.09	.09	.09	.00	.75
	8-12	0	0	0	2	2	4	2	- 1	1	1	2	- 1	2	1	1	1	0	21
	(1)	.00	.00	.00	3.08	3.08	6.15	3.08	1.54	1.54	1.54	3.08	1.54	3.08	1.54	1.54	1.54	.00	32.31
	(2)	.00	.00	.00	.09	.09	.19	.09	.05	.05	.05	.09	.05	.09	.05	.05	.05	.00	.99
	13-18	. 1	0	0	0	0	0	0	0	2	3	4	1	2	0	1	0	0	14
	(1)	1.54	.00	.00	.00	.00	.00	.00	.00	3.08	4.62	6.15	1.54	3.08	.00	1.54	.00	.00	21.54
	(5)	.05	.00	.00	.00	.00	.00	.00	.00	.09	-14	.19	.05	.09	.00	.05	.00	.00	.66
	19-24	0	0	0	0	0	0	0	0	0	6	0	0	0	1	1	0	0	8
	(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	9.23	.00	.00	.00	1.54	1.54	.00	.00	12.31
	(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	. 28	.00	.00	.00	.05	.05	.00	.00	.38
	GT 24	3	0	0	0	0	0	0	0	0	1	1	0	0	0	0	1	0	6
	(1)	4.62	.00	.00	.00	.00	.00	.00	.00	.00	1.54	1.54	.00	.00	.00	.00	1.54	.00	9.23
	(2)	. 14	.00	.00	.00	.00	.00	.00	.00	.00	.05	*L.	.00	.00	.00	.00	. 05	.00	.28
ALL	SPEEDS	4	1	4	4	2	4	5	1	3	11	7	2	4	4	5	4	0	65
	(1)	6.15	1.54	6.15	6.15	3.08	6.15	7.69	1.54	4.62	16.92	10.77	3.08	6.15	6.15	7.69	6.15	.00	100.00
	(2)	.19	.05	.19	.19	.09	.19	.24	.05	.14	.52	.33	.09	.19	.19	.24	.19	.00	3.06

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA

* 60 4

STABILITY CLASS D

CLASS FREQUENCY (PERCENT) = 28.07

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.17	.00	.00	.00	.00	.00	.00	.17
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.05	.00	.00	.00	.00	.00	.00	.05
															1000			
C-3	- 1	2	5	0	0	0	1	0	3	2	. 2	2	. 2	2	1	2	. 0	22
(1)	.17	.34	.34	.00	.00	.00	.17	.00	.50	.34	.34	.34	.34	.34	.17	.34	.00	3.69
(2)	. 05	.09	.09	.00	.00	.00	.05	.00	.14	.09	.09	-09	.09	.09	. 05	.09	.00	1.03
4-7	- 4	3	8		10		**											
				6	2.00	6	10	4		-	1	3	1	2	6	8	0	87
(1)	.67	.50	1.34	1.01	1.68	1.01	1.68	.67	1.51		.17	.50	.17	.34	1.01	1.34	.00	14.57
(2)	.19	. 14	.38	.28	.47	.28	.47	.19	.42	.28	.05	.14	.05	.09	.28	.38	.00	4.09
8-12	3	. 8	11	3	12	20	28	8	18	13	9	7	4	4	9	5	0	162
(1)	.50	1.34	1.84	.50	2.01	3.35	4.69	1.34		2.18	1.51	1.17	.67	.67	1.51	.84	.00	27.14
(2)	.14	.38	.52	.14	.56	.94	1.32	.38	. 85	.61	.42	.33	.19	.19	.42	.24	.00	7.62
								100										7.00
13-18	7	4	5	4	15	10	14	6	13	22	6	6	7	4	6	14	0	143
(1)	1.17	.67	.84	.67	2.51	1.68	2.35	1.01	2.18	3.69	1.01	1.01	1.17	.67	1.01	2.35	.00	23,95
(2)	.33	.19	.24	.19	.71	.47	.66	.28	.61	1.03	.28	.28	.33	.19	.28	.66	.00	6.72
10.07																		
19-24	5	7	1	3	11	2	5	3	10	30	2	2	5	1	13	13	0	113
(1)	.84	1.17	. 17	.50	1.84	.34	-84	.50	1.68		.34	.34	.84	.17	2.18	2.18	.00	18.93
(2)	.24	.33	. 05	. 14	.52	.09	.24	.14	.47	1.41	.09	.09	.24	.05	.61	.61	.00	5.31
GT 24	3	2	2	2	0	0	0	1	3	8	0	0	13	15	13	7	0	69
(1)	.50	.34	.34	.34	.00	.00	.00	.17	.50		.00	.00	2.18	2.51	2.18	1.17	.00	11.56
(2)	.14	.09	.09	.09	.00	.00	.00	.05	.14	.38	.00	.00	.61	.71	.61	.33	7 (7)	
****		100		.03	.00	.00	.00	.00	. 1.99	, 30	.00	.00	.01	-/1	-01	. 33	.00	3.24
ALL SPEEDS	23	26	29	18	48	38	58	22	56	81	21	20	32	28	48	49	0	597
(1)	3.85	4.36	4.86	3.02	8.04	6.37	9.72	3.69	9.38	13.57	3.52	3.35	5.36	4.69	8.04	8.21	.00	100.00
(2)	1.08	1.22	1.36	. 85	2.26	1.79		1.03	2.63	3.81	.99	.94	1.50	1.32		2.30	.00	28.07

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS E

. ...

CLASS FREQUENCY (PERCENT) = 28.91

SPEED (MPH)	N	NNE	NE	ENE	3	ESE	SE	SSE	s	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
(1) (2)	.00	.00	.00	.00	0 .00	.00	.16 .05	.33	3 .49 .14		.00	. 16 . 05	.00	.00	.00	.00	.00	7 1.14 .33
C-3 (1) (2)	00.00	1 .16 .05	.00	.33	.33	.33	.00	3 .49 .14	.33	.00	.16 .05	.16 .05	00.00	.00	00.00	.33	.00	16 2.60 .75
4-7 (1) (2)	.65 .19	.33	1 .16 .05	.65 .19	.98 .28	3 .49 .14	3 .49 .14	.65	.33	.33	3 .49 .14	1 .16 .05	3 .49 .14	3 .49 .14	6 .98 .28	.81 .24	.00	52 8.46 2.44
8-12 (1) (2)	1.46	.33	.33 .09	.81 .24	3 .49 .14	6 .98 .28	1.46	13 2.11 .61	2.28	2.28		3 .49 .14	.81 .24	10 1.63 .47	9 1.46 .42	10 1.63 .47	.00	116 18.86 5.45
13-18 (1) (2)	6 .98 .28	7 1.14 .33	.81 .24	.81 .24	.65	5 .81 .24	8 1.30 .38	15 2.44 .71		2.93	15 2.44 .71	.65 .19	24 3.90 1.13	16 2.60 .75	18 2.93 .85	8 1.30 .38	.00	178 28.94 8.37
19-24 (1) (2)	6 .98 .28	.81 .24	.33	.49 .14	.00	.00	2 .33 .09	3 .49 .14			19 3.09 .89	1 .16 .05	9 1.46 .42	.65	7 1.14 .33	.81 .24	0 ,00	132 21.46 6.21
GT 24 (1) (2)	.00	.00	.00	.65 .19	.00	.00	.00	.00	6 .98 .28	6.18	28 4.55 1.32	.49 .14	.33 .09	6 .98 .28	21 3.41 .99	6 .98 .28	.00	114 18.54 5.36
ALL SPEEDS (1) (2)	25 4.07 1.18	17 2.76 .80	10 1.63 .47	23 3.74 1.08	15 2.44 .71	16 2.60 .75	23 3.74 1.08		10.08	123 20.00 5.78		14 2.28 .66	43 6.99 2.02	39 6.34 1.83	61 9.92 2.87	36 5.85 1.69	.00	615 100.00 28.91

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

⁽²⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA

STABILITY CLASS F

CLASS FREQUENCY (PERCENT) = 8.84

SPEED (MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM (1) (2)	.00	00,00	.00	.00	.00	.00	.53 .05	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.53 .05
C-3 (1) (2)	.00	.00	.00	.00	1.06	00.00	1 .53 .05	.00	00.00	00.00	.00	.00	.00	.53 .05	1 .53 .05	0.00.00	0.00	5 2.66 .24
4-7 (1) (2)	.00	.00	.00	.00	3 1.60 .14	.00	.00	.53 .05	1.06	.53 .05	2.13 .19	.53 .05	00.00	.00	3 1.60 .14	1.06	.00	17 9.04 .83
8-12 (1) (2)	.53 .05	.53 .05	.00	1.06 .09	1.06 .09	.00	.53 .05	2.13 .19	3 1.60 .14	1.06	2.13		1.06	9 4.79 .42	3 1.60 .14	3 1.60 .14	.00	40 21.28 1.88
13-18 (1) (2)	.00	.00	00.00	.00	.53 .05	1.06	.00	7 3.72 .33	1.06	.53	8 4.26 .38	5 2.66 .24	8 4.26 .38	8 4.26 .38	6 3.19 .28	1.06	.00	50 26.60 2.35
19-24 (1) (2)	.00	.00	.00	00.00	.00	.00	00.00	.53 .05	.00 .00	7 3.72 .33	5.32	4.26	.53 .05	3 1.60 .14	.53 .05	.53 .05	00,00	32 17.02 1.50
GT 24 (1) (2)	.00	.00	.00	.00	.00	.00	00.00	00.00	00.00		26 13.83 1.22		.00	.00	.53 .05	.00	.00	43 22.87 2.02
ALL SPEEDS (1) (2)	.53 .05	.53 .05	.00	1.06	8 4.26 .38	2 1.06 .09	1.60 .14	13 6.91 .61			27.66	22 11.70 1.03	11 5.85 .52	21 11.17 .99	15 7.98 .71	8 4,26 .38	.00	188 100.00 8.84

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95 JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS G CLASS FREQUENCY (PERCENT) = 3.53

SPEED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM (1) (2)	.00	.00	.00	1 1.33 .05	1 1.33 .05	1 1.33 .05	.00	1.33	.00	.00		.00	.00	.00	.00	.00	0.00.	5 6.67 .24
C-3 (1) (2)	.00	1 1.33 .05	.00	.00	.00	.00	.00		.00	.00	4.00	.00	.00	.00	2 2.67 .09	.00	.00	8.00 .28
4-7 (1) (2)	.00	.00	1.33 .05	.00	2 2.67 .09	1 1.33 .05	1.33	2.67 .09	1.33 .05	.00			.00	.00	.00	2 2.67 .09	.00	15 20.00 .71
8-12 (1) (2)	.00	1 1.33 .05	.00	.00	.00	.00	5.33 .19	2.67	3 4.00 .14	1.33	1.33 .05	1 1.33 .05	1 1.33 .05	1 1.33 .05	1 1.33 .05	.00	.00	16. 21.33 .75
13-18 (1) (2)	.00	.00	.00	.00	.00	.00	.00		9 12.00 .42	.00		4.00	2 2.67 .09	1 1.33 .05	1 1.33 .05	.00	.00	20 26.67 .94
19-24 (1) (2)	.00	.00	.00	.00	.00	.00	.00	1.33	.00	.00	2.67	1 1.33 .05	2 2.67 .09	1 1.33 .05	.00	.00	.00	7 9.33 .33
GT 24 (1) (2)	.00	.00	.00	.00	.00	.00	.00		.00	.00	1 1.33 .05	6.67 .24	.00	.00	.00	.00	.00	8.00 .28
ALL SPEEDS (1) (2)	.00	2 2.67 .09	1 1.33 .05	1 1,33 .05	3 4.00 .14	2 2.67 .09	6.67	10.67	13 17.33 .61			12 16.00 .56	5 6.67 .24	3 4.00 .14	5.33 .19	2 2.67 .09	.00	75 100.00 3.53

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

PILGRIM APR95-JUN95 MET DATA JOINT FREQUENCY DISTRIBUTION (220-FOOT TOWER)

220.0 FT WIND DATA STABILITY CLASS ALL

CLASS FREQUENCY (PERCENT) = 100.00

SPEE	ED(MPH)	N	NNE	NE	ENE	E	ESE	SE	SSE	\$	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
	CALM	0	0		1	1	1	2	3	3	0	2	1	0	0	0	0	. 0	15
	(1)	.00	.00	,1/5	.05	.05	.05	.09	.14	.14	.00	.09	.05	.00	-00	.00	.00	.00	.71
	(2)	.00	-00	.05	. 05	. 05	.05	.09	.14	.14	.00	.09	.05	.00	.00	.00	.00	.00	.71
	****						142	100	4 179	2.179	200	107	.00	.00	.00	,00	.00	.00	* (.1
	C-3	1	6	6	8	6	2	3	3	6	2	6	3	3	3	4	- 4	0	66
	(1)	. 05	.28	.28	.38	.28	.09	.14	.14	.28		.28	.14	.14	.14	.19	.19	.00	3.10
	(2)	.05	.25.	-28	.38	.28	.09	.14	.14	-28		.28	-14	.14	-14	.19	.19	.00	3.10
												160			1.77	. 12	. 13	.00	3.10
	4-7	15	18	20	25	38	18	18	12	16	9	12	11	4	8	20	24	0	268
	(1)	.71	.85	.94	1.18	1.79	.85	.85	.56	.75	.42	.56	.52	.19	.38	.94	1.13	.00	12.60
	(2)	.71	.85	.94	1.18	1.79	.85	.85	.56	. 75	.42	.56	.52	.19	.38	.94	1.13	.00	12.60
											2.75	130	3.17.60		130	2.2.19	1.12	.00	16.00
	8-12	26	25	26	30	32	60	58	32	47	39	24	25	27	34	25	25	0	535
	(1)	1.72	1.18	1.22	1.41	1.50	2.82				1.83	1.13	1.18	1.27	1.60	1.18	1.18	.00	25.15
	(2)	1.22	1.18			1.50	2.82				1.83		1.18	1.27	1.60		1.18	.00	25.15
					1000		N. F. Series.		2.00.00		1.00		1.10	1.267	1.00	1.10	1.10	.00	23,12
	13-18	25	18	11	11	22	32	37	35	62	65	50	41	69	38	36	37	0	589
	(1)	1.18	.85	.52	.52	1.03	1.50	1.74	1.65		3.06		1.93		70.00	1.69	1.74	.00	27.69
	(2)	1.18	.85	.52	.52	1.03	1.50				3.06					1.69	1.74	.00	27.69
											3100	2.22		2.57		1.07	1 2	.00	21.07
	19.24	13	13	8	9	11	2	7	13	31	113	39	22	23	16	22	23	0	365
	(1)	.61	-61	.38	.42	.52	.09	.33	.61	1.46	5.31	1.83	1.03	1.08	.75	1.03	1.08	.00	17.16
	(2)	.61	-61	.38	.42	.52	.09	.33	.61		5.31	1.83	1.03	1.08	.75	1.03	1.08	.00	17.16
									101	1140		1 1 100	1.00	1.00	112	1.00	1,00	200	17.10
	GT 24	8	2	2	7	0	0	.0	1	14	71	59	14	23	29	37	22	0	289
	(1)	.38	.09	.09	.33	.00	.00	.00	- 05	.66	3.34	2.77	.66	1.08	1.36	1.74	1.03	.00	13.59
	(2)	.38	.09	.09	.33	.00	.00	.00	. 05	.66		2.77	.66	1.08	1.36	1.74	1.03	.00	13.59
													1 400	1,100	1100	7.0.7.99	1.000	100	12.27
ALL	SPEEDS	88	82	74	91	110			99		299	192	117	149	128	144	135	C	2127
	(1)	4.14	3.86			5.17							5.50	7.01	6.02	6.77	6.35	.00	100.00
	(2)	4.14	3.86	3.48	4.28	5.17	5.41	5.88	4.65	8.42	14.06	9.03	5.50	7.01	6.02	6.77	6.35	.00	100,00
													1			Carlot Alexander	17.195		

⁽¹⁾⁼PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF AL' GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

5. OFF-SITE DOSE CALCULATION MANUAL REVISIONS

. .. .

The PNPS Off-site Dose Calculation Manual (ODCM) was not revised during the reporting period.

6. REFERENCES

- U. S. Nuclear Regulatory Commission, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants", Regulatory Guide 1.21, Revision 1, June 1974.
- T. Messier memorandum to K. J. Sejkora, "PNPS Meteorological Data Joint Frequency Distribution Tables January - June 1995", dated August 17, 1995.

KJS/gml