

UNITED STATES NUCLEAR REGULATORY COMMISSIONDUQUESNE LIGHT COMPANYOHIO EDISON COMPANYPENNSYLVANIA POWER COMPANYBEAVER VALLEY POWER STATION, UNIT NO. 1DOCKET NO. 50-334NOTICE OF WITHDRAWAL OF APPLICATION FOR
AMENDMENT TO FACILITY OPERATING LICENSE

The United States Nuclear Regulatory Commission (the Commission) has granted the request of Duquesne Light Company (the licensee) to withdraw its September 4, 1990, application for proposed amendment to Facility Operating License No. DPR-66 for the Beaver Valley Power Station, Unit No. 1.

The proposed amendment would have revised the Appendix A Technical Specifications by changing the required number of operable incore-detector thimbles. Specifically, the change would have reduced the required number of operable incore-detector thimbles to 50% from 75%, and modified the Surveillance Requirements to provide for increased uncertainty allowances to account for the reduced minimum operability requirement.


The Commission has previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on January 10, 1991 (56 FR 1033). However, by letter dated December 23, 1991, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated September 4, 1990, and the licensee's letter dated December 23, 1991, which withdrew the application for license amendment. The

above documents are available for public inspection at the Commission's Public Document Room, 2120 L Street, NW., Washington, DC 20555 and at the local public document room located at the B. F. Jones Memorial Library, 663 Franklin Avenue, Aliquippa, Pennsylvania 15001.

Dated at Rockville, Maryland this 24th day of January 1992.

FOR THE NUCLEAR REGULATORY COMMISSION



Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation