BUCKET NO. 56-266

UATE June 6, 1984

COMPLETED BY C. W. FAY

OPERATING STATUS

1. UNIT NAME: FOINT BEACH NUCLEAR PLANT UNIT 1 . NOTES 2. REPORTING PERIOD: MAY 1984 3. LICENSED THERAL POWER (BUT): 1518. 4. NAMEPLATE RATING (GROSS MAE): 523.8 5. DESIGN ELECTRICAL RATING (NET MUE): 497. 6. MAXIMUM DEPENDABLE CAPACITY (NET MUE): 485. 7. NAXIMUM DEPENDABLE CAPACITY (NET MUE): 485. 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:							*******************	ST REFORT. GIVE REASONS:
POINT PERTUD: HERNAL RATING CIRICAL PENDABL PENDABL								DUGH 7) SINCE LA
POINT PERTUD: HERNAL RATING CIRICAL PENDABL PENDABL	 . NOTES							ER 3 THRE
- 44446	PUINT		LICENSED THERMAL POWER (MUT): 1518.	Page 1	_	DEPENDABLE	8	
	-	C.	3	47	כע	0	1	8

MOI APPLICABLE POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET RUE): REASONS FOR RESTRICTIONS, (IF ANY): NOT APPLICABLE . 0

HOURS IN REPORTING PERIOD NUMBER OF HOURS REACTOR WAS CRITICAL REACTOR RESERVE SHUTDOUN HOURS HOURS GENERATOR ON LINE UNIT RESERVE SHUTDOUN HOURS GROSS THERMAL ENERGY GENERATED (MUH) SASZ,640 SASZ,64	CUMULATIVE	118.943	95,376.9	629.3	92,872.0	799.3	125,329,392	42,017,630	39,949,584	78.1	78.8	. 299	67.6	2.6	
HOURS IN REPORTING NUMBER OF HOURS REA REACTOR RESERVE SHUTDO GROSS THERMAL ENERGINGS ELECTRICAL ENERGONT SERVICE LACTOR UNIT CAPACITY FACTOUNIT CAPACITY FACTOUNIT FORCED OUTAGE SHUTDOWN SCHEDULED	IR TO DATE	3.647	1,298.4	3.9	1,264.5	8.0	1,794,080	621,650	587,150	34.7	34.8	33.2	32.4	0.0	DN OF EACH):
HOURS IN REPORTING NUMBER OF HOURS REA REACTOR RESERVE SHUTDO GROSS THERMAL ENERGINGS ELECTRICAL ENERGONT SERVICE LACTOR UNIT CAPACITY FACTOUNIT CAPACITY FACTOUNIT FORCED OUTAGE SHUTDOWN SCHEDULED	THIS MONTH	744	744.0	0.0	744.0	0.0	1,101,621	382,640	366,399	100.0	100.0	101.5	1.66	0.0	PE. DATE, AND DUNALI
222.25.20.00.00.00.00.00.00.00.00.00.00.00.00.		IING	BER OF HOURS REA	EACTOR RESERVE SHU	UURS GERERATOR O	IT RESERVE SHUTDO	S THERMAL ENER	ROSS ELECTRICAL EN	LECTRICAL ENER	IT SERVICE FACTOR	IT AVAILABILITY F	IT CAPACITY FACTO	UNIT CAPACITY FACTO	IT FORCED DUTAGE	HUTBOWNS SCHEDULED

NUTURE TOWN SIAKLUP: REPORT PERIOD, ESTIMATED DATE OF END OF SHUTDOWN AT 4.1 25.

DOCKET NO. 50-266

UNIT NAME Point Beach Unit 1

DATE June 6. 1984

COMPLETED BY C. W. Krause

TELEPHONE 414/277-2001

AVERAGE DAILY UNIT POWER LEVEL

		MONTH	May, 1984		
DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWE NET	DAY	AVERAGE DAILY POWER LEVEL MWE NET
1	500	11	499	21	498
2	501	12	483	22	496
3	501	13	480	23	501
4	501	14	465	24	500
5	501	15	480	25	501
6	474	16	491	26	499
7	487	17	492	27	496
8	446	18	500	28	500
9	500	19	494	29	499
10	490	20	493	30	498
				31	501

TELEPHONE	COMPLETED BY		UNIT NAME	DOCKET NO.
	D BY C	DATE J		
414/277-2001	. W. Krause	une 4, 1984	oint Beach	0-200
			Unit	

COMP

No.
Date
Type ¹
Duration (Hours)
Reason ²
Method of Shitting Down Leactor
Licencie Event Report No.
System Code 4
Component Code
Cause and Corrective Action To Prevent Recurrence

AD-28B (01-78)

E-D-

Operational Error (explain)

Administrative

Operator Training & License Exam

Regulatory Restriction

4- Other (explain) 3- Automatic Scram 2- Manual Scram

Sheets for LER File

(NUREG-0161)

ation of Data Entry tions for Prepar-Exhibit G-Instruc-

Source

Exhibit I- Same

S: Scheduled F: Forced

A- Equipment Failure (explain)

Method:

1- Manual

Maintenance or Test

Refueling

Reason:

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

Docket No. 50-266

Unit Name Point Beach Unit 1

Date
Completed By
Telephone

June 6, 1984
C. W. Krause
414/277-2001

Unit 1 operated at approximately 496 MWe net throughout the period with no significant load reductions. On May 30, 1984, Unit 1 achieved 42 billion kilowatt hours of generation.

A Licensee Event Report was submitted regarding the control rod insertion limit described in last month's report.

Safety-related maintenance included completion of the 3D emergency Diesel generator annual outage and modifications to the steam-driven auxiliary feedwater pumps' bearing cooler.

BOCKET NO. 50-301

DATE June 6, 1984

COMPLETED BY C. W. FAY

TELEPHONE 414 277 2811

OPERATING STATUS

1.	UNIT NAME: POINT BEACH NUCLEAR PLANT UNIT 2 . NOTES .
2.	REPORTING PERIOD: MAY 1984 .
3.	LICENSED THERMAL POWER (MWT): 1518.
4.	NAMEPLATE RATING (GROSS MWE): 523.8 .
5.	DESIGN E'ECTRICAL RATING (NET MWE): 497.
6.	MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509
7.	MAXIMUM DEPENDABLE CAPACITY (NET MWE): 485
0	TE CHANCES OFFID IN PARAPITY DATINGS (TIENS WINDED 7 THROUGH 7) SINCE LAST DEDRET GIVE DEAGING.

- 9. POWER LEVEL TO WHICH RESTRICTED. IF ANY (NET MWE): NOT APPLICABLE
- 10. REASONS FOR RESTRICTIONS. (IF ANY): NOT APPLICABLE

	THIS MONTH	YR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	744	3,647	103,728
12. NUMBER OF HOURS REACTOR WAS CRITICAL	718.6	3.621.6	92.049.8
13. REACTOR RESERVE SHUTDOWN HOURS	8.8	8.8	207.1
14. HOURS GENERATOR ON LINE	654.9	3,557.9	90,460.7
15. UNIT RESERVE SHUTDOWN HOURS	15.4	15.4	198.1
16. GROSS THERMAL ENERGY GENERATED (MUH)	934.923	5,292,015	126,186,792
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	315,470	1./84.080	42,743.910
18. NET ELECTRICAL ENERGY GENERATED (MUH)	299.688	1,704,842	40,705,442
19. UNIT SERVICE FACTOR	88.0	97.6	87.2
20. UNIT AVAILABILITY FACTOR	90.1	98.0	87.4
21. UNIT CAPACITY FACTOR (USING MDC NET)	83.1	95.4	79.8
22. UNIT CAPACITY FACTOR (USING DER NET)	81.0	94.1	79.0
23. UNIT FORCED OUTAGE RATE	0.0	0.0	1.4
	a transfer of the property	The same of the sa	

24. SHUIDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): Five-week refueling outage scheduled to begin on September 28, 1984.

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NOT SHUTDOWN

DOCKET NO. 50-301

UNIT NAME Point Beach Unit 2

DATE June 6, 1984

COMPLETED BY C. W. Krause

TELEPHONE 414/277-2001

AVERAGE DAILY UNIT POWER LEVEL

		MONTII	May, 1984		
DAY	AVERAGE DAILY POWER LEVEL MWE NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWE NET
1	488	11	482	21	
2	487	12	488	22	37
3	488	13	486	23	142
4	488	14	477	24	298
5	487	15	482	25	494
6	487	16	487	26	494
7	487	17	487	27	496
8	487	18	322	28	494
9	487	19	-13	29	495
10	487	20	-11	30	494
				31	496

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH May, 1984

DOCKET NO. 50-301

UNIT NAME Point Beach Unit 2

DATE June 4, 1984

C. W. Krause

TELEPHONE 414/277-2001

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor	Licensee Event Report No.	System Code4	Component Code	Cause and Corrective Action To Prevent Recurrence
1	840518	S	89.1	В	1	N/A	ZZ	ZZZZZZ	Conducted corrective maintenance on moisture separator reheater, condenser waterboxes and incore flux thimble plugs.

F: Forced S: Scheduled

Reason:

A- Equipment Failure (explain)

B- Maintenance or Test

C- Refueling

D- Regulatory Restriction

E- Operator Training & License Exam

F- Administrative

G- Operational Error (explain)

3 Method:

1- Manual

2- Manual Scram

3- Automatic Scram

4- Other (explain)

Exhibit G-Instructions for Preparation of Data Entr Sheets for LER Fil (NUREG-0161)

Exhibit I- Same Source

AD-28B (01-78)

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

Docket No. 50-301

. . . .

Unit Name Point Beach Unit 2

Date
Completed By
Telephone

June 6, 1984
C. W. Krause
414/277-2001

Unit 2 operated at approximately 487 MWe net for the entire period with one significant load reduction. At 1400 hours on May 18, 1984, load was reduced at 1/2% per minute in preparation for a scheduled weekend outage. At 2108 hours the same day, Unit 2 turbine generator was taken off line.

At 0200 hours on May 19, 1984, a reactor shutdown was commenced. This ended 220 days of continuous operation. During the shutdown at 0341 hours on May 19, 1984, an inadvertent safety injection (SI) actuation occurred while decreasing reactor coolant system pressure. The operator failed to block SI prior to the actuation setpoint. This event is considered reportable and a Licensee Event Report will be submitted. The NRC was also informed via a red phone report.

At 1704 hours on May 21, 1984, the reactor was taken critical and at 1406 hours on May 22, 1984, Unit 2 turbine generator was put back on line. The unit operated at 150 MWe for 2½ days due to high conductivity in the steam generator. Full power was achieved on May 24, 1984, at 2100 hours.

The purpose of the weekend outage was three-fold; clean flux thimble, plug failed moisture separator reheater tubes, and conduct preventive plugging of condenser tubes.

Seven out of 26 flux thimbles were cleaned. This still leaves at least 3 thimbles per quadrant operable. It is hoped that further cleaning will not be necessary until the regularly scheduled Unit 2 outage.

A Licensee Event Report was submitted regarding the control rod insertion limit described in last month's report.

Safety-related maintenance performed includ I testing of "B" atmospheric steam dump valve, replacement of source range detection Channel 32, cleaning of the crankcase filter on the 4D Diesel generator and repair of an oil leak on charging pump 2P2A.



June 8, 1984

Director of Regulatory Operations U. S. NUCLEAR REGULATORY COMMISSION Washington, D.C. 20555

Gentlemen:

MONTHLY OPERATING REPORTS POINT BEACH NUCLEAR PLANT

Attached are monthly operating reports for Units 1 and 2, Point Beach Nuclear Plant, for the calendar month of May 1984.

Very truly yours,

(

C. W. Fay

Attachments

Copies to J. G. Keppler - NRC, Region III NRC Resident Inspector C. F. Reiderer - PSCW Vice President - Nuclear Power

50-361

IE24