

The Light company

Houston Lighting & Power

South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

August 31, 1995
ST-HL-AE-5161
File No.: G26
10CFR50.73


U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

South Texas Project
Unit 2
Docket No. STN 50-499
Revision 5 to Licensee Event Report 94-005
Inadvertent Test-Mode Starts of
Standby Diesel Generators Attributed to Electronic Noise

Pursuant to 10CFR50.73, Houston Lighting & Power submits the attached revision to Unit 2 Licensee Event Report 94-005 regarding inadvertent test-mode starts of Standby Diesel Generators attributed to electronic noise which is sensed by the fiber optic board test circuits to be start signals. This revision includes the details from a recent inadvertent test-mode start, and the corrective actions in progress to address the root cause.

The test-mode starts described in this Licensee Event Report do not have an adverse effect on the health and safety of the public. Inadvertent test-mode starts would not prevent any of the Standby Diesel Generators from performing their safety function. Should another test-mode start occur on any of the South Texas Project Standby Diesel Generators, a revision to this Licensee Event Report will be submitted.

If you should have any questions on this matter, please contact S. M. Head at (512) 972-7136 or me at (512) 972-7988.



R. E. Masse
Unit 2,
Plant Manager


Attachment: Revision 5 to LER 94-005 (South Texas, Unit 2)

060038

Project Manager on Behalf of the Participants in the South Texas Project

LER-95/5161

9509070005 950831
PDR ADDCK 05000499
S PDR



c:

Leonard J. Callan
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Thomas W. Alexion
Project Manager
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001 13H15

David P. Loveless
Sr. Resident Inspector
c/o U. S. Nuclear Regulatory Comm.
P. O. Box 910
Bay City, TX 77404-0910

J. R. Newman, Esquire
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

K. J. Fiedler/M. T. Hardt
City Public Service
P. O. Box 1771
San Antonio, TX 78296

J. C. Lanier/M. B. Lee
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

C. A. Johnson
Central Power and Light Company
P. O. Box 289, Mail Code: N5012
Wadsworth, TX 77483

Rufus S. Scott
Associate General Counsel
Houston Lighting & Power Company
P. O. Box 61067
Houston, TX 77208

Institute of Nuclear Power
Operations - Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Dr. Joseph M. Hendrie
50 Bellport Lane
Bellport, NY 11713

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

U. S. Nuclear Regulatory Comm.
Attn: Document Control Desk
Washington, D. C. 20555-0001

J. R. Egan, Esquire
Egan & Associates, P.C.
2300 N Street, N.W.
Washington, D.C. 20037

J. W. Beck
Little Harbor Consultants, Inc.
44 Nichols Road
Cohasset, MA 02025-1166