

# Duquesne Light Company

Beaver Valley Power Station  
P.O. Box 4  
Shippingport, PA 15077-0004  
(412) 393-5255

JOHN D. SIEBER  
Vice President - Nuclear Group

January 21, 1992

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

**Subject: Beaver Valley Power Station, Unit No. 2  
Docket No. 50-412, License No. NPP-73  
Proposed Operating License Change Request No. 61  
(TAC No. MB2306)**


Enclosed are the following:

1. An application for amendment to the above license to delete the associated process flow rate monitor operability requirements, as specified in Tables 3.3-13 and 4.3-13, for the gaseous effluent monitors 2RMQ-RQ-301, 2RMQ-RQ-303, and 2HVL-RQ-112.
2. Documents designated Attachment A, B, and C which set forth, respectively, the change in the technical specifications, the safety analysis (including the no significant hazards evaluation), and the typed replacement technical specification pages.

This change has been reviewed by the Onsite Safety Committee and Offsite Review Committee and was determined to be safe based on the attached safety analysis.

The requested target date for approval of this proposed change is April 30, 1992.

Sincerely,

  
J. D. Sieber

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. DeAgazio, Project Manager  
Mr. T. M. Gerusky, Director BRP/DER  
Mr. R. Janati, BRP/DER  
Mr. M. L. Bowling (VEPCO)

9202060054 920121  
PDR ADDCK 05000412  
P PDR

A001  
111

