

NOTICE OF DEVIATION

Duke Power Company
Catawba Units 1 and 2

Docket Nos. 50-413, 50-414
License Nos. NPF-35, NPF-52

During an NRC inspection conducted on July 9 - August 5, 1995, a deviation from Commitments in Section 1.7.1.1, Regulatory Guides, of the Final Safety Analysis Report was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," (Enforcement Policy) (60 FR 34381, June 30, 1995) the deviation is listed below:

Final Safety Analysis Report Section 1.7.1.1, Regulatory Guides, specifies conformance to Regulatory Guide 1.95, Protection of Nuclear Plant Control Room Operators Against an Accidental Chlorine Release (Revision 1, 1/77).

- Regulatory Guide 1.95, paragraph C.4.c specifies the rehearsal of chlorine release emergency plan provisions to ensure donning of full face self-contained pressure demand type breathing apparatus on detection of high chlorine concentrations.
- Regulatory Guide 1.95, paragraph C.4.c specifies storage provisions and procedures for breathing apparatus such that operators can begin using the apparatus within two minutes after an alarm.
- Regulatory Guide 1.95, paragraph C.4.d specifies, in part, that air supply apparatus should meet the single failure criterion.

Contrary to the above, on August 2, 1995, it was identified that:

- rehearsals using the Control Room Habitability System to ensure the donning of full face breathing apparatus on detection of high chlorine concentrations have not been conducted,
- storage provisions and procedures such that the operators can begin using the Control Room Habitability System within two minutes after an alarm were not implemented, and
- the Control Room Habitability System does not meet the single failure criterion in that a single pressure regulating valve supplies the entire system.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, in writing within 30 days of the date of this Notice, (1) the reason for the deviation, or if contested, the basis for disputing the deviation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further deviations, and (4) the date when your corrective action will be

Notice of Deviation

2

completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 31st day of August, 1995

Enclosure 1