

NOTICE OF VIOLATION

Commonwealth Edison Company
Braidwood Station, Unit 2

Docket No. 50-457
License No. NPF-77

During an NRC inspection conducted on December 14, 1991 through January 17, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1991), the following violation is listed below:

Braidwood Unit 1 and 2 Technical Specification 6.8.1 requires that written procedures shall be established, implemented, and maintained covering the following activities:


- The applicable procedures recommended in appendix A of Regulatory Guide 1.33, Revision 2, February 1978, which includes administrative procedures.

Contrary to the above on January 10, 1992, the licensee failed to comply with Administrative Procedure BwAP 300-1, Step C.5, which requires that shift operators be made aware of changes in plant status. Personnel inadvertently removed 2A containment spray pump, rather than the 2A residual heat removal pump, from service for preventive maintenance, and failed to inform the shift operators of the error.

This is a Severity Level IV violation (Supplement 1) (50-457/91026-01(DRP)).

Pursuant to the provisions of 10 CFR 2.201, Commonwealth Edison is required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington D.C. 20555 with a copy to the U.S. Nuclear Regulatory Commission Region III, 799 Roosevelt Road, Glen Ellyn, Illinois, 60137, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within thirty days of the date of the letter transmitting this Notice of Violation. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or if contested, the basis for disputing the violation, (2) the corrective steps that will be taken and the results achieved; (3) the corrective steps that will be taken to avoid further violations; and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Glen Ellyn, Illinois
this 3rd day of February, 1992



Brent Clayton, Chief
Reactor Projects Branch 1