



**North Anna Power Station Units 1 and 2  
Emergency Diesel Generator  
Preventive Maintenance Inspection Outage**

**PROBABILISTIC SAFETY ASSESSMENT**

**August 1995**

**VIRGINIA ELECTRIC AND POWER COMPANY**

## TABLE OF CONTENTS

<b>1.0 INTRODUCTION</b> .....	<b>4</b>
<b>2.0 BACKGROUND INFORMATION</b> .....	<b>4</b>
2.1 Emergency Diesel Generator .....	5
2.2 Emergency Electrical Power System .....	7
2.3 Alternate A.C. Diesel .....	8
<b>3.0 PSA ANALYSIS</b> .....	<b>13</b>
3.1 Comparison to IPE model .....	13
3.2 Revised EDG Unavailability Data .....	16
3.3 AAC DG TM .....	17
3.4 AAC DG Base Case .....	17
3.5 Extended EDG Unavailability .....	19
3.6 BOUNDING Model .....	19
3.7 Results .....	19
<b>4.0 ACCEPTABLE RISK INCREASES</b> .....	<b>26</b>
<b>5.0 IMPLEMENTATION REQUIREMENTS</b> .....	<b>27</b>
<b>6.0 CONCLUSIONS</b> .....	<b>31</b>

**APPENDIX A:** Fault Trees

**APPENDIX B:** Event Trees

## **1.0 INTRODUCTION**

This report was prepared to document the feasibility of a 14-day outage on-line (Modes 1, 2, 3 and 4) for preventive maintenance and inspection of each emergency diesel generator (EDG) once every 18 months. The alternate A.C. diesel generator (AAC DG) recently installed at North Anna is assumed to be operable during the performance of this EDG preventive maintenance and inspection. It has been determined that the increase in risk associated with performance of the 18-month diesel preventive maintenance and inspection on-line is acceptably small. Based on this conclusion, a request for revised North Anna Power Station Technical Specifications associated with EDG outage time is being proposed. This report is being prepared to serve as an attachment to the licensing package.

Section 2 presents background information on the reason for the request and a summary description of the relevant systems including a description of the AAC DG. Section 3 contains a discussion of the PSA analysis performed. Section 4 presents a discussion of acceptable risk increases. Implementation requirements are provided in Section 5. Section 6 contains conclusions. References are provided as footnotes.

## **2.0 BACKGROUND INFORMATION**

The EDGs installed at North Anna Power Station were manufactured by Fairbanks-Morse. The manufacturer recommends that an extensive inspection of these diesels be performed every 18 months. Currently, this maintenance is performed during shutdown conditions as required by Technical Specifications. Because the inspections require at least ten days to complete, a significant burden is placed on the maintenance crews to perform this work along with the many other tasks that must be performed during an outage.

Virginia Power has determined that the substantial benefits of performing this maintenance on-line justify the negligible increase in risk for at-power conditions because of the decrease in risk achieved due:

- ▶ to installation of the AAC DG,
- ▶ to improved maintenance quality resulting from focused resources on the EDG maintenance, and
- ▶ to less EDG unavailability during shutdown (i.e., Modes 5 and 6) which lowers shutdown risk.

The following sections provide a description of the generators and the power distribution system. This background information is important because it provides an understanding of the various sources of A.C. power and of the path to the emergency bus.

## 2.1 Emergency Diesel Generator

The Emergency Generator (EG) System provides a reliable source of emergency electric power to Engineered Safeguards Features(ESFs) and other essential loads in the event of a Loss of Off-site Power (LOOP)<sup>1</sup>. The EG System consists of two 100-percent capacity Emergency Diesel Generator (EDG) sets in each unit. Each EDG independently powers a train of safety-related equipment, thereby providing redundancy in the event of loss of an EDG. Each EDG in a unit will automatically start when a safety injection signal from its associated train is present. Each EDG in a unit will automatically start with a pre-set time delay upon sensing either undervoltage or degraded voltage on its associated 4kV bus or an improper 4kV supply breaker lineup. Then, an EDG output breaker closes, and loads connect sequentially to the emergency bus if the residual voltage on the bus is less than 30 percent, a degraded or undervoltage exists, the 4kV buses are aligned properly, the EDG volts are greater than 95 percent, and the EDG output breaker lock-out and EDG differential breaker relay are reset. Each EDG is initiated automatically or manually and consists of a diesel engine, governor, generator with excitation system, controls, battery and charger, and the following subsystems: starting air, fuel oil, scavenging air and exhaust, lubricating oil, jacket cooling, and air cooling.

The diesel engine provides sufficient mechanical power to drive a generator with a 2,000 hr/yr rating of not less than 3,000kW, both mounted on a sub-base. The governor is furnished with an adjustable speed droop, load limit, and remote speed control for 125V dc operation

The EG System may be operated from the Main Control Room or from the Diesel Generator Rooms. Control circuits are provided for local and remote operation of the engine, generator and generator output breakers. The engine initiation signals are provided from the Emergency Electrical Power (EE) System (under/degraded voltage) and the Reactor Protection System (RPS) safety injection signal.

The generator and exciter provide a 2000 hr/yr capacity of 3,000 Kw at 4160V, 60 cycles. The generator uses a brushless exciter and rectifier assembly to provide excitation to the main generator field. Space heaters are provided for insulation protection.

The EDG battery and battery charger provide power for flashing the generator field, powering the dc fuel oil pump, powering the speed control motor, operating the air starting solenoids, and providing power for EDG control circuits voltage regulation and protective relays.

---

<sup>1</sup>The information in this section is taken from the SDBD document "Emergency Diesel Generator System, North Anna Power Station," SDBD-NAPS-EG, Rev. 1, Section 3.1, 12/31/93

The starting air subsystem for each EDG consists of two independent, separate trains of equipment and piping that deliver compressed air to the diesel engine. Either train is capable of starting the engine without outside electric power.

Each starting air train has an air receiver (tank) that stores a sufficient volume of compressed air to provide five diesel engine starts without recharge. Each air receiver is kept charged by an electric motor-driven air compressor powered from the Emergency Electrical Power (EE) System. Each compressor has a small diesel engine backup drive that can be manually connected in the event of loss of electric power.

The fuel oil (FO) subsystem consists of underground fuel storage tanks, fuel transfer pumps, and engine delivery and injection components. The fuel oil is stored in two safety-related underground fuel oil storage tanks (one per unit) which contain sufficient capacity to provide continuous operation of one EDG in each unit at full load for 7 days. The underground fuel oil storage tanks are filled from the aboveground non-safety-related FO System which provides fuel oil for all site needs. For each EDG, one ready fuel oil transfer pump takes suction from one of the two underground fuel oil storage tanks, and one standby fuel oil transfer pump takes suction from the other tank. Either transfer pump fills and maintains the proper level of the day tank required for diesel generator operation. The day tank has sufficient capacity to support a fully loaded engine for at least 3 hours.

The scavenging air and exhaust subsystem provides pressurized air to the diesel engine cylinders for combustion, and aids in exhausting the combustion gases.

The lubricating oil (LO) subsystem consists of an engine-driven pump, full-flow filter, cooler, strainer, immersion heater, motor-driven prelube pump, and a standby circulating pump. This subsystem provides cleaned and cooled lube oil to the diesel engine and its components during operation.

The air-cooling subsystem consists of an engine-driven pump, a three-way mixing valve, radiators, and aircoolers (aftercooler). This subsystem removes heat from the combustion air in the scavenging air and exhaust subsystem. A three-way mixing valve controls the flow through the radiators. During EDG operation, an engine-driven air cooling pump circulates cooling water through the radiators for cooling and then to the aftercoolers in the scavenging air and exhaust subsystem. Cooling water is also circulated through the radiator fan gear box cooler. The radiator fan assembly provides forced air flow over the radiators in both the jacket cooling and air cooling subsystems by drawing ambient air into the Diesel Generator Room, over the radiator fins, and exhausting through the roof.

## 2.2 Emergency Electrical Power System

The Emergency Electrical Power (EE) System provides a highly reliable power source to Class 1E loads and certain non-Class 1E loads during all plant conditions<sup>2</sup>. Figures 1 and 2 show one line diagrams of the emergency buses for Unit 1 and Unit 2 respectively. The EE System consists of two redundant power distribution systems. One system is referred to as the train A (orange; H) system. The other system is referred to as the train B (purple; J) system. Each EE System train consists of a 4160V switchgear, two 480V load centers, and 480V MCCs, which supply power to motors, motor-operated valves (MOVs), heaters, lighting, and other loads, which are required to be powered during normal and design basis event plant operating conditions.

Each train is normally energized continuously from the switchyard external grid system. This preferred power supply is available from the reserve station service transformers (RSSTs) via the transfer buses. Upon loss of the switchyard "preferred power supply," each EE System train is supplied by a "standby power supply," which consists of an on-site EDG. There are a total of four EDGs at North Anna, two per unit. Each 100-percent capacity EDG is connected to its assigned train and is available to pick up load within 10 seconds after receipt of a start signal. The Class 1E loads are loaded onto the EDGs sequentially.

An additional supply source for the Unit 1H bus is the connection from the 1H bus to the 1B bus. The 1B bus may be energized in the startup or shutdown mode from RSST B (Figure 1). In addition, if the main generator breaker is open, the 1H bus may be supplied through the main transformer, the unit station service transformer, and the 1B bus tie. In a similar manner, the 1J bus may be supplied from the 2B bus. However, the only source of supply to the 2B bus, except for when Unit 2 is operating, is from RSST B.

An additional off-site source of Unit 2 normal station service power can be made available in 8 hours by removing the isolated bus duct disconnect links, backfeeding through the main transformers, and utilizing the normal station service transformers. The 2B bus then can serve as an alternative power source to power the emergency bus 1J for Unit 1. To minimize low-voltage effects on equipment during an EE System emergency bus transfer from the off-site source to the diesel generators, the 4.16kV Class 1E bus is divided into two sections: the normal Class 1E bus section and the stub bus section, which are connected via the stub bus tie breaker. The stub bus section supplies the component cooling and residual heat removal loads, which are not immediately required during an accident condition. These loads on the stub

---

<sup>2</sup>The information in this section is taken from the SDBD document "Emergency Power System, North Anna Power Station," SDBD-NAPS-EP, Rev. 1, Section 3.1, 12/31/93

bus are disconnected due to undervoltage on the bus, i.e., during transfer from the off-site to the on-site source, and may be reconnected either manually or automatically. In addition, when a containment depressurization actuation (CDA) signal occurs, the stub bus tie breaker is tripped and locked out.

For Unit 2, either 4160V emergency bus may be connected to the emergency bus of the opposite train, by an administratively controlled bus tie breaker. This connection permits Class 1E equipment of one train to be powered by its opposite train emergency bus, which can get its power from either the RSST or EDG. Unit 1 does not have this emergency bus tie breaker installed.

### 2.3 Alternate A.C. Diesel

The AAC DG is a Caterpillar 3612, four cycle, turbocharged, after-cooled, diesel engine. The AAC DG engine will operate at 900 RPM, 4640 horsepower, to produce 3300 electrical kilowatts on a continuous basis. In addition, the engine will be capable of a "2000" hour rating of 3640 kilowatts.

The fuel oil system consists of a day tank sized to allow diesel operation for up to four hours without replenishment. The fill system for the diesel engine day tank utilizes the auxiliary boiler fuel transfer pump with a supply line routed from the Auxiliary Boiler Building to the Alternate A.C. (AAC) Building. Filling of the day tank is an automatic process with pump and valve activation based on tank level. Additionally, a gravity fed bypass of the pump is available.

The AAC DG can be started by local operator action or by receiving an auto start signal following the simultaneous loss of the D or E and F transfer buses. This logic will prevent unnecessary diesel starts when a single emergency bus is lost (one RSST) on a unit, while providing a diesel start when the potential exists for a station blackout (i.e., loss of both emergency buses on a unit). After it has started, the diesel will be available for manual loading onto the desired transfer bus and subsequent emergency bus as shown in Figure 1 and Figure 2 for Unit 1 and Unit 2 respectively.

Based on the train specific (loads powered from H buses only or J buses only) nature of some common systems, especially instrument air, it is desirable to power a H and a J bus in order to deal with a station blackout. Therefore, if the H EDG is providing power to the non-blacked out unit, then the AAC DG will, if possible, power the J bus on the blacked out unit. It is possible that an operator can power a J bus on both the blacked out and non-blacked out unit. Then the operator will have to take appropriate actions to restore power to an air compressor or to perform necessary actions without compressed air.




Figure 1 - Power Supply to 1H and 1J Emergency Buses




Figure 2 - Power Supply to the 2H and 2J Emergency Buses

Before Station Blackout (SBO) modifications were made the normal off-site feeder breakers from the transfer buses to the emergency buses (15D3, 15E3, 15F3 and 15F4) were tripped and blocked from closing following a loss of off-site power, a RSST differential trip, a pilot wire trip or a trip of their associated main transfer bus breaker (15D1, 15E1 or 15F1). These non-safety related breakers, however, must be closed during a SBO with any or all of the mentioned conditions present. This has been accomplished by adding a "NORMAL/AAC" switch on the AAC breaker control panel for each breaker (15D3, 15E3, 15F3, 15F4). In the "AAC" position, this switch will bypass/defeat the trip and close interlocks stated above. Once the transfer bus breaker is closed, the associated emergency bus breaker may be closed and the desired emergency bus energized. The ability to close these breakers with 15D1, 15E1, and 15F1 open has been proven during start up testing.

The existing electrical separation requirements which pertain to circuits related to the D and E versus the F transfer bus system and its feeders have been maintained. The new switchgear provides isolation of the AAC source from the normally energized transfer buses. This arrangement also minimizes the increase in exposure of the energized transfer buses during normal operation by maintaining them in their associated Switchgear Room.

Diesel control panels are provided in the AAC Building. Three panels are provided by the diesel manufacturer and contain the controls required for manual diesel operation, and the operation of its support equipment as well as recording parameter variation with time. General annunciation is provided remotely in the Control Room to indicate diesel trouble/diesel tripped/diesel running/RSST A paralleled with RSST B/bus OL and breaker 15F5 alarms. Specific problem annunciation is provided locally to enhance troubleshooting efforts.

A bus relaying panel is located adjacent to the diesel generator monitoring panel. This panel is supplied by the switchgear manufacturer. The panel contains the generator protection relaying. There is also a control panel installed adjacent to the diesel generator control panels which provides remote control of the new AAC system breakers. These breakers were added to provide the electrical connection between the transfer bus and the AAC DG.

## **2.4 Description of EDG Preventive Maintenance Inspection**

Once every 18 months each of the EDG undergoes preventive maintenance and inspection appropriate for diesels used for this class of standby service. This maintenance involves disassembly of the major subsystems in order to clean and inspect components. A list of the components which are included follows:

Inspection Covers and Exhaust Manifold  
Crankshaft Coupler Pointer Check  
Crank Leak Check  
Fuel Injection Timing Check  
Inspection of Fuel Oil Pump Shaft Seal  
Inspection of Governor and Fuel Pump Drive  
Inspection of Lube Oil Pump and Coolant Pump Drive Gears  
Inspection of Upper Torsional Dampers  
Inspection of Lower Torsional Dampers  
Inspection of Lube Oil Internal Piping  
Inspection of Pistons, Rings, and Cylinder Liners  
Inspection of Blower Flexible Drive, Timing Gears and Spring Packs  
Inspection of Timing Chain, Sprocket and Sprocket Bearing  
Measuring Lower Crankshaft Strain on Cylinders No. 11 and 12  
Upper and Lower Main and Connecting Rod Bearing Inspection  
Inspection of Vertical Drive Shaft Gears and Coupling  
Checking Crankshaft Thrust Bearing Clearance  
Checking Torque of Crankshaft Coupling Bolts  
Fuel Injection Nozzle Opening Pressure Check and Seal Leakage Check  
Air-Start Check Valve and Distributor Inspection  
Inspection of Cooling Water Side of Lube Oil Cooler  
Engine Block Coolant Hydrostatic Test  
Cleaning and Inspection of Crankcase Assembly and Cleaning Oil separator/Breather  
Lube Oil System Maintenance  
Fuel Oil Day Tank Foot Valve Strainer Maintenance  
Changing Oil in Woodward EG-B10 Governor  
Blower Lobe and Housing Clearances  
Blower Inlet Air Filter Inspection  
Installing Exhaust Manifold and Engine Inspection Covers  
Cleaning Standby Lube Oil Heater  
Refilling Engine Sump (If Drained)

Historically, this maintenance has been performed during refueling outages (i.e., Modes 5 and 6) when Technical Specifications require only one EDG to be operable. A review of the maintenance records, by station personnel, shows that the above list of activities requires about fourteen days to complete in the worst case. On average it takes about ten days to perform this work (i.e., with no unplanned additional activities).

Two crews work to support the EDG maintenance. Obviously, this represents a cost that will be incurred regardless of when the diesel is maintained. However, if the EDG inspection can be performed when the unit is on-line, the crews doing this

maintenance can work on other outage activities during refueling operations. So, more of the outage work can be performed by Virginia Power personnel. This action represents a cost savings because there are fewer contractor personnel required. In addition it is estimated that one day of critical outage time can be realized using this approach.

### 3.0 PSA ANALYSIS

The PSA analysis was performed with a model of North Anna that represents the current operation of the station. The IPEEE model was upgraded and enhanced, including use of the newest version of NUPRA<sup>3</sup>. Each stage of the development is summarized below.

- ▶ Upgrade, enhance and solve the IPEEE model using the latest version of NUPRA.(EDG-TM)
- ▶ Update the plant specific EDG unavailability data used in the IPE to account for operating practices during the last five years. (NO-AAC)
- ▶ Add the AAC DG to the current model with the updated data. (95JUNE)
- ▶ Increase the maintenance unavailability of the EDG to represent the single 14-day outage per 18 months for each EDG. (EDG-AOT)
- ▶ Run a sensitivity case with EDG unavailability extended beyond the 14-day window. (BOUNDING)

#### 3.1 Comparison to IPE model

The North Anna IPE model was submitted to NRC in December 1992<sup>4</sup>. A request for additional information (RAI) was received and the response was submitted on April 28, 1995<sup>5</sup>. The IPEEE model, submitted in June 1994<sup>6</sup>, is similar to the IPE model but

---

<sup>3</sup>"NUPRA 2.2 Users Manual," NUS Corporation, March 1994.

<sup>4</sup>"North Anna Power Station Units 1 and 2 Response to Generic Letter 88-20 and Supplement 1, Individual Plant Examination (IPE) for Severe Accident vulnerabilities," Letter from W.L.Stewart to USNRC, Serial No. 92-774, December 1992 with Final Report as Enclosure.

<sup>5</sup>"North Anna Power Station Units 1 and 2 Individual Plant Examination (IPE), Request for Additional Information," Letter from M.L. Bowling to USNRC, Serial No. 94-740A with enclosure.

incorporates plant changes and model enhancements since the IPE model was completed. Two minor hardware modifications thought to have significance to prevention of core damage were added to the model. They were a tie-in to the bearing cooling system to create an alternate supply of cooling water to the emergency switchgear room chillers and the capability to use fire water as a backup supply to the charging pump lube oil heat exchangers. The PSA model was solved with these modifications included and the result was a slightly lower overall CDF.

Some model enhancements and event tree structure changes were also made to the IPE model. The model enhancements were made to take advantage of increased computing capability and reduce manual iterations. The primary event tree changes include developed fault trees for equipment from the unaffected unit. The trees affected by this change are loss of seal cooling (T4), loss of service water (T6), and loss of emergency room switchgear cooling, (T8). Table 3.1 summarizes the event trees used in each model.

There are significantly more event trees listed for the IPEEE than the IPE. The number of accident initiators remains the same in both models. The original event trees were split into smaller trees with less sequences to improve the utility of the two trees. For example, by splitting the large LOCA tree into two the number of sequences on each page is cut in half and therefore is much easier to read. The accident sequence structure did not change for most accident initiators. However, as mentioned above the structure of the T4, T6 and T8 trees were changed. Each of these trees is discussed below.

The T4 tree modification involves an alternate interpretation of the seal LOCA model. In the IPE, successful depressurization was assumed to avoid a seal LOCA. Following the IPE solution, it was evident that this depressurization assumption did not significantly affect overall CDF, and a more conservative approach could be adopted. Therefore, for the IPEEE, the depressurization function was assigned a value of 1.0. The impact of this change is that core damage can only be avoided if the loss of seal cooling is mitigated using the core cooling recovery strategy given in the emergency response guidelines. The T4 contribution to core damage frequency doubles, relative to the IPE, to ~2E-8/yr. Hence the change is not significant but represents consistent seal LOCA modeling among the event trees.

The loss of service water tree (T6) was changed more substantially. Given the loss of service water there is a loss of RC pump seal cooling and ESGR cooling. Either of these lead to core damage by causing a seal LOCA unless a different heat sink can be found. Fortunately, another heat sink is available for each component. The use of

---

<sup>6</sup>"Individual Plant Examination Of Non-Seismic External Events and Fires, North Anna Power Station, Units 1 and 2," Final Report Volumes 1 and 2, April 1994.

these alternate heat sinks was developed to support the large service water pipe restoration project at North Anna and are now part of the plant design. As a result, the revised loss of service water event tree does not consider the state of the seals but instead considers the probability of recovering the lost heat sink. The T6 contribution to core damage increases to ~5E-7/yr as compared to 4E-9/yr reported for the IPE. While the difference is about two orders of magnitude it should be noted that the absolute value is still quite small at about 0.9% of total core damage frequency.

The final tree with structural changes is the loss of emergency switchgear room cooling event tree (T8). Once the event occurs it is not an issue of depressurization as much as it is one of needing to provide alternate RC pump seal cooling before it is lost. Since the T8 initiating event affects only one unit, the equipment on the unaffected unit is available to mitigate the loss of seal cooling. Therefore, the tree has been structured to use HVAC from the unaffected unit to cool the affected unit. There are two ways to accomplish this goal: use fans to blow cool air into the affected ESGR or cross connect the seal cooling equipment from the unaffected unit. If the first action fails but the unaffected unit HVAC still functions, it is possible to use charging and component cooling from the unaffected unit to supply seal injection and seal cooling to the affected unit. As a result of these changes the loss of ESGR cooling initiating event contributes ~6E-7/yr to CDF as opposed to ~7E-6/yr using the IPE model.

The core damage frequency was nearly the same for both solutions. The IPE core damage frequency is 6.8E-5/yr while the IPEEE core damage frequency was 6.3E-5/yr. The differences in the results between the two solutions were reviewed and found to be non-significant based on a comparison of the cut sets for each function. Some of the IPEEE event trees were used in the analysis of fires as reported in the Non-Seismic IPEEE final report<sup>7</sup>.

The PSA software used by Virginia Power has evolved as PC hardware capabilities have improved. One significant advancement is that NUPRA now allows batch mode solution of the entire PSA model. Therefore, the first step in the analysis of extended allowed outage time was to convert the model to the most recent version of NUPRA. This conversion must show that the results with the new code version are the same as the previous results or that any differences are understood. The EDG-TM run served this purpose.

The differences between the IPEEE and the EDG-TM are attributable to several factors including: the function truncation limits were set at 1E-9 versus 1E-10; undeveloped

---

<sup>7</sup>"Individual Plant Examination Of Non-Seismic External Events and Fires, North Anna Power Station, Units 1 and 2," Final Report Volumes 1 and 2, April 1994.

transfers from the earlier models were deleted; and two new functions were added to the T1 event tree, providing status of the Unit 1 and Unit 2 EDGs, to facilitate development of the AAC model. The core damage frequency for the IPEEE model is 6.3E-5/yr while the EDG-TM model yields a core damage frequency of 5.7E-5/yr.

### 3.2 Revised EDG Unavailability Data

In addition to conversion to the latest version of NUPRA, the EDG test and maintenance unavailability is updated with recent plant specific data. Improvements in EDG preventive and corrective maintenance practices have lowered the EDG unavailability. A more accurate EDG unavailability is desirable not only to lower SBO and total CDF results, but also to provide faithful risk ranking for applications such as the 10 CFR 50.65 maintenance rule. The North Anna IPE data analysis methods were used to revise the EDG unavailability estimate. Plant records for the 1990 through 1994 interval indicate an average EDG unavailability of 97.30 hours per EDG per calendar year. This EDG unavailability applies to plant operation in Modes 1 to 4, and is felt to conservatively estimate at-power EDG unavailability (Modes 1 and 2 only). Critical-hours from NUREG-0020 were used to estimate EDG exposure for at-power operation. For the 1990 to 1994 interval, the average unit (or EDG) critical-hour exposure is 7601.66 cr-hrs per calendar year. Combining the 1990-1994 EDG unavailability with the EDG exposure yields an unavailability probability of 1.28E-2. This can be expressed in terms of hours as 112.2 hours/critical-year or in terms of days as 4.7 days/critical-year or 4.1 days per calendar year.

The PSA model includes components from Unit 2 systems that can be cross-connected to Unit 1 requiring consideration of opposite unit diesel unavailability. Furthermore, the opposite unit EDG unavailability must include all modes of operation since the unaffected unit may be down when the affected unit is at power. This is accomplished by determining how many hours of diesel unavailability there are when the unit is in Modes 3 to 6 and adding that to the diesel unavailability during Modes 1 and 2.

Based on a review of available data and discussions with plant personnel it was concluded that the total unavailability per diesel is conservatively estimated to have been 23 days per fuel cycle during 1990 to 1994. Converting 23 days of diesel unavailability every 18 months to a 12 month basis results in  $23 * (12/18) = 15.3$  days per calendar year. Adding this to the 4.7 days per critical year of unavailability during Modes 1 and 2 results in a total of 20 days per critical year or an unavailability of 5.48E-2. This is equivalent to 17.3 outage days per calendar year.

The use of this data bounds the expected conditions for the revised operating strategy. If the EDG maintenance is performed on-line there will be 14 days of opposite unit EDG preventive maintenance and inspection outage plus normal EDG

unavailability. However, the EDG unavailability during opposite unit shutdown will decrease to 3 or 4 days. Thus, the total days of EDG unavailability should be about the same for either operating strategy.

The impact of the changes in EDG unavailability models can be seen through the reduction in CDF from the EDG-TM model ( $5.7 \times 10^{-5}$ ) to the NO-AAC model ( $5.4 \times 10^{-5}$ ). (A summary of all of the results is shown in Table 3.2). Hence the increased availability of the diesels reduces core damage frequency  $\sim 3 \times 10^{-6}/\text{yr}$ .

### 3.3 AAC DG TM

The AAC DG manufacturer recommends a major tear down maintenance inspection, similar to the 18 month preventive maintenance and inspection of the EDG, but only once every ten years. The AAC DG is not required to be operable by Technical Specifications but is required to have a high availability to meet the SBO Rule Guidelines. There is no readily available operating history to use as a basis for the AAC DG test and maintenance unavailability. It is reasonable to estimate the AAC DG unavailability with that used for the Unit 2 EDG TM unavailability when Unit 1 is operating. This is conservative to the North Anna IPE generic industry data for EDG unavailability by a factor of two.

### 3.4 AAC DG Base Case

The AAC DG, recently installed to meet the requirements of the station blackout rule, is now fully operational. This diesel represents an independent source of emergency power that can feed any one of the four 4160V emergency buses at North Anna. Therefore, it is postulated that this AAC DG can serve as a replacement to the EDG during the preventive maintenance and inspection outage if it is performed on-line.

The 95JUNE model provides the positive impact of the AAC DG when it is available. In other words this model provides the estimated core damage frequency given that the AAC DG is available and the EDGs continue to experience the same number of hours of maintenance unavailability.

It should be noted that this diesel can not serve as a replacement for an EDG for all initiating events because the AAC DG is loaded manually. The need to load the diesel manually is a design feature which is intended to reduce common mode failures as required by the station blackout rule. It is assumed that it takes one hour to start and load the AAC DG. One hour is conservatively chosen since it is the longest time permitted by the station blackout rule.

A human factors viewpoint is used to evaluate the PSA initiating events to determine which events occur so rapidly that there is insufficient time to load the AAC DG. Several initiating events proceed to core damage in less than one hour without power available including: Large LOCA (A); Medium LOCA (S1); Reactor Vessel Rupture (Rx); Interfacing system LOCA; and ATWS (Th). The assumption that AAC DG cannot mitigate core damage for these initiating events is executed by special PSA model logic.

The AAC DG is potentially available for any emergency bus for the remaining initiating events. The PSA model is structured so that only one emergency bus can be powered from the AAC DG. Furthermore, if either of the Unit 2 diesels is failed the AAC DG is assumed to only provide power to Unit 2. This approach conservatively models electric power recovery at Unit 1.

The above restrictions are incorporated by revising certain aspects of the station and unit blackout models. Each of these are discussed below in some detail. The significant changes to the EDG-TM model include common cause modeling and the addition of the AAC DG system model.

The addition of the fifth diesel to the PSA model complicates the EDG common cause model. First, the criterion for the purchase and installation of the AAC DG was to minimize common cause failures between this fifth diesel and the other EDGs. Second, the PSA model considers only one unit, so the station impact of a five or four diesel common cause failure is not straightforward. Third, the IPE utilizes the multiple greek letter method for EDG common cause failures, and this 11 fault model could become unwieldy with an additional diesel. The 95JUNE PSA solution chose to simplify the EDG common cause model in a conservative manner, reducing the 11 fault model to a 3 fault model. Two faults are unchanged, the Unit 1 two EDG fault for 1H and 1J diesels, and the Unit 2 two EDG fault for the 2H and 2J diesels. The remaining two EDG common cause faults and all the three EDG common cause faults are combined with the four EDG common cause fault. This approach is conservative and allocates the common cause failures among the two units.

The system model for the AAC DG is similar to EDG model. It considers the typical electrical equipment failures that prevent the transfer of electrical energy to each of the three transfer buses. These failures include breaker failures, maintenance unavailability, AAC DG fail-to-start and fail-to-run. The fault tree resulting from the system model is shown in Appendix A.

The addition of the AAC DG reduces core damage by requiring three failures, instead of two, to fail both 4160 V electrical buses after a loss of off-site power. The 95JUNE model represents the current plant hardware configuration, and with the addition of the AAC DG, the core damage frequency is reduced by ~ 1.3E-5/yr to 4.1E-5/yr compared to the NO-AAC model shown in Table 3.2.

### **3.5 Extended EDG Unavailability**

For the EDG-AOT model, the EDG unavailability is increased to reflect the assumption of a single, fourteen day maintenance outage once every eighteen months for each EDG. Actually, the 95JUNE model data is applied to the EDG-AOT model, except for the Unit 1 EDG maintenance unavailability basic events. The 14 day preventive maintenance and inspection outage time is added to the existing unavailability to determine the impact of the proposed EDG Technical Specifications changes. A 14 day outage performed once every 18 months is equivalent to 9.3 outage days, or 224 hours, per calendar year. Adding this unavailability to the 97.30 hour plant data unavailability yields a total unavailability of about 321.3 hours. Combining this 321.3 hour unavailability with the 7601.66 cr-hrs per calendar year exposure produces a new unavailability probability of 4.23E-2.

The EDG-AOT model solution yields a core damage frequency of 4.2E-5/yr. The 95JUNE model CDF of 4.1E-5/yr is the base case against which the difference of 1E-6/yr from the EDG-AOT case represents an acceptably small increase.

### **3.6 BOUNDING Model**

A final model was created to study the effects of EDG unavailability on CDF. This model is named "BOUNDING", and represents a sensitivity study on EDG unavailability. The maintenance unavailability was set equal to 40 days per calendar year for all five diesels. The resulting CDF is 4.7E-5/yr.

### **3.7 Results**

Each of the five cases produced reasonable results. A summary of the cases is shown in Table 3.2. The CDF contribution from the each initiating event is shown in Table 3.3. Table 3.3 is a listing of core damage frequency sorted by accident group and accident type. The fault trees which have been changed since the IPEEE model was created are included in Appendix A. The event trees for the 95JUNE model are included in Attachment B. The results show that the electrical transient accident initiators are sensitive to the inclusion of the AAC DG and to varying the EDG unavailability. Other accident initiators are less sensitive to the AAC DG and EDG unavailability.

The LOCA transients shown in Table 3.3 contribute the same to core damage frequency with and without the AAC DG in operation as shown by the subtotal for the "NO-AAC", "95JUNE" and "EDG-AOT" cases. Also, the EDG unavailability does not impact the contribution of this initiating event group. The same conclusion can be drawn for the general transient group of initiating events. The electrical transients are

impacted by both the AAC DG and the increased EDG unavailability. The inclusion of the AAC DG results in a significant reduction in CDF of ~1.3E-5/yr (i.e., "NO-AAC" - "95JUNE"). This reduction is entirely from the electrical transients subgroup.

Thus, the initiating event groups with the largest contribution are those involving loss of electrical power and include the T1 and T1EE trees. These trees have in common the loss of off-site power as an initiating event. This fact makes the diesel generator arrangement important. In the other trees, a coincident loss of off-site power must occur before any diesel dependencies are realized. Unless the initiating event involves a loss of off-site power there is only a small impact from the extended EDG unavailability on the contribution of that initiating event group to core damage frequency.

The T1EE event tree represents the loss of off-site power and failure of the EDGs on Unit 1; or in other words a unit blackout. This event tree is the largest contributor to core damage until the AAC DG is added to the model. The AAC DG decreases the contribution of this initiating event group from about 22% to about 14%. When the extended diesel generator unavailability is added the contribution increases only slightly to about 16%. The change in core damage frequency is ~1E-6/yr due to this extended EDG unavailability. This represents an average annual increase but, it actually occurs over two separate fourteen day intervals; one for the 1H diesel and one for the 1J diesel. Thus, it is concluded that the AAC DG is an adequate source of replacement power for an EDG for the limited outage required to perform the 18-month inspection.

The PSA models assume that other risk significant equipment is unavailable on an average annual basis. However, it is important that on-line maintenance be performed in an integrated fashion so that all risk significant components are considered. This important consideration is ensured by the administrative controls in place for performing on-line maintenance. These controls are based on a list of risk significant equipment which was developed from the North Anna PSA model. The controls involve scheduling of on-line maintenance. Scheduling of equipment for on-line maintenance is to be performed in a way that minimizes simultaneous outages of risk significant equipment. Special emphasis is given to limiting on-line maintenance when the electrical distribution system is at less than full capacity.

Table 3.1 - Comparison of Event Trees Between The IPE and the IPEEE

Event Tree	IPE	IPEEE
Large LOCA	A	A,AD2
Vessel Rupture	Rx	Rx
Medium LOCA	S1	S1,S1D1
Small LOCA	S2	S2,S2D1
Loss of Off-site Power	T1,T1Tr,T1A	T1,T1Q,T1QFW, T1Hv,T1EG, T1EGQ
Transient - Loss of MFW	T2,T2Tr	T2,T2HV
Transient - MFW Recoverable	T2A,T2ATr	T2A,T2AHv
Transient - MFW Available	T3,T3Tr	T3,T3Hv
Loss of RCP Seal Cooling	T4	T4
Loss of Emergency Power DC Bus 1-I	T5A	T5A,T5AQ
Loss of Emergency Power DC Bus 1-III	T5B	T5B,T5BQ
Loss of Service Water	T6	T6
Steam Generator Tube Rupture	T7	T7,T7D1
Loss of ESGR Cooling	T8	T8
Loss of Emergency Power - Bus 1H	T9A,T9ATr	T9A,T9AQ,T9AHv
Loss of Emergency Power - Bus 1J	T9B,T9BTr	T9B,T9AQ,T9RHv
ATWS	TH,TL	TH,THMFW,TL
Interfacing System LOCA	VX	VX

Table 3.2 - Summary Of Results

Model Name	AAC DG Yes/No	Outage Days Per Calendar Year			CDF /yr
		Unit 1 EDG	Unit 2 EDG	AAC DG	
IPE	No	5.5	31.7	N/A	6.8E-5
IPEEE	No	5.5	31.7	N/A	6.3E-5
EDG-TM	No	5.5	31.7	N/A	5.7E-5
NO-AAC	No	4.1	17.3	17.3	5.4E-5
95JUNE	Yes	4.1	17.3	17.3	4.1E-5
EDG-AOT	Yes	13.4	17.3	17.3	4.2E-5
BOUNDING	Yes	40.0	40.0	40.0	4.7E-5

Table 3.3  
Core Damage Frequency For Each Accident Group For Each North Anna PSA Model

Accident Group	Accident Type	BOUNDING	EDG-AOT	95JUNE	NO-AAC	EDG-TM	94 Jan (IPEEE)	92 Dec (IPE)
LOCA Transients	S2	9.87E-6	9.86E-6	9.86E-6	9.89E-6	9.90E-6	9.84E-6	1.01E-5
	T7	7.58E-6	7.57E-6	7.57E-6	7.59E-6	7.60E-6	7.34E-6	7.02E-6
	S1	6.76E-6	6.75E-6	6.75E-6	6.75E-6	6.75E-6	6.73E-6	6.64E-6
	A	4.06E-6	4.06E-6	4.06E-6	4.06E-6	4.06E-6	4.48E-6	4.09E-6
	Vx	1.60E-6	1.60E-6	1.60E-6	1.60E-6	1.60E-6	1.60E-6	1.60E-6
	Rx	2.67E-7	2.67E-7	2.67E-7	2.67E-7	2.67E-7	2.67E-7	2.68E-7
	T4	2.43E-8	2.43E-8	2.43E-8	2.43E-8	2.43E-8	2.43E-8	1.07E-8
	Subtotal	3.02E-5	3.01E-5	3.01E-5	3.02E-5	3.02E-5	3.03E-5	2.97E-5

**Table 3.3**  
**Core Damage Frequency For Each Accident Group For Each North Anna PSA Model**

Accident Group	Accident Type	BOUNDING	EDG-AOT	95JUNE	NO-AAC	EDG-TM	94 Jan (IPEEE)	92 Dec (IPE)
Electrical Transients	T1EE	8.83E-6	6.53E-6	5.85E-6	1.17E-5	1.32E-5	1.80E-5	7.98E-6
	T1	4.14E-6	2.19E-6	1.67E-6	7.82E-6	8.76E-6	9.89E-6	4.60E-6
	T9AHv	2.66E-7	2.13E-7	2.01E-7	3.87E-7	4.37E-7	2.26E-7	3.26E-6
	T9B	2.17E-7	1.62E-7	1.47E-7	3.25E-7	3.54E-7	3.38E-7	5.81E-7
	T9A	1.59E-7	1.17E-7	1.06E-7	2.40E-7	3.42E-7	2.50E-7	4.15E-7
	T1Hv	2.58E-7	1.04E-7	7.70E-8	7.53E-7	1.15E-6	1.50E-6	7.27E-6
	T9BHv	7.01E-8	7.01E-8	7.01E-8	7.03E-8	7.10E-8	7.48E-9	6.78E-8
	T5A	2.35E-8	2.04E-8	1.96E-8	2.95E-8	3.10E-8	2.95E-8	1.11E-7
	T5B	1.77E-8	1.77E-8	1.77E-8	1.81E-8	1.84E-8	3.52E-8	1.09E-7
	Sub-total	1.40E-5	9.42E-6	8.16E-6	2.13E-5	2.44E-5	3.03E-5	2.44E-5

Table 3.3  
Core Damage Frequency For Each Accident Group For Each North Anna PSA Model

Accident Group	Accident Type	BOUNDING	EDG-AOT	95JUNE	NO-AAC	EDG-TM	94 Jan (IPEEE)	92 Dec (IPE)
General Transients	T8	6.53E-7	6.17E-7	6.17E-7	7.04E-7	7.90E-7	5.67E-7	6.56E-6
	T6	5.39E-7	5.39E-7	5.39E-7	5.39E-7	5.39E-7	5.39E-7	4.52E-9
	TH	4.24E-7	4.24E-7	4.24E-7	4.24E-7	4.24E-7	4.25E-7	4.20E-7
	T3Hv	3.92E-7	3.92E-7	3.92E-7	3.97E-7	4.06E-7	1.19E-7	4.06E-6
	T2	3.45E-7	3.45E-7	3.45E-7	3.45E-7	3.45E-7	3.28E-7	8.86E-7
	T2AHv	1.57E-7	1.57E-7	1.57E-7	1.59E-7	1.61E-7	3.94E-8	1.65E-6
	T3	1.68E-8	1.59E-8	1.59E-8	1.96E-8	2.05E-8	2.09E-8	7.61E-8
	T2A	1.45E-8	1.42E-8	1.42E-8	1.54E-8	1.57E-8	1.51E-8	6.11E-8
	T2Hv	1.39E-8	1.39E-8	1.39E-8	1.39E-8	1.39E-8	2.80E-9	1.44E-7
	TL	4.23E-10	4.23E-10	4.23E-10	4.23E-10	4.23E-10	4.23E-10	0.0
Sub-total		2.54E-6	2.52E-6	2.52E-6	2.62E-6	2.72E-6	2.06E-6	1.39E-5
Grand Total		4.67E-5	4.21E-5	4.08E-5	5.42E-5	5.72E-5	6.27E-5	6.79E-5

#### 4.0 ACCEPTABLE RISK INCREASES

Virginia Power has determined what constitutes an acceptable risk increase for the proposed Technical Specifications changes. This determination was based on a review of existing documents and the selection of the guidelines most applicable to North Anna Power Station. The pertinent documents are summarized below.

The EPRI PSA applications guide discusses the concept of a permanent modification which is essentially what is proposed herein. The modification is to the Technical Specifications not the plant hardware. The EPRI document states that a permanent risk increase can be determined as a percentage of the base CDF. The calculation for North Anna follows assuming that the base case is the IPE model submitted previously for NRC review.

$$\log(\Delta_{CDF}) = -0.5 * \log(CDF_{baseline}) - 1$$

For North Anna the baseline core damage frequency ( $CDF_{baseline}$ ) is  $6.8E-5/yr$ . So, the acceptable risk increase ( $\Delta_{CDF}$ ) is given as

$$\log(\Delta_{CDF}) = -0.5 * \log(6.8E-5) - 1$$

Evaluating by reducing the right-hand-side and making both sides an exponent of base 10 gives

$$\Delta_{CDF} = 12.1$$

Hence based on the above formula, a 12.1% increase in core damage frequency could be justified for a permanent increase. This increase is comparable to the contribution from the largest initiating event categories. It is larger than the largest contribution from any sequence.

The Brookhaven NUREG/CR study of risk based technical specification development does not discuss risk increases in general but does treat the subject of Allowed Outage Time increases. The document discusses when a sensitivity analysis can be used in lieu of re-solving the model. One of the criteria it gives for the acceptability of sensitivity analysis is if the overall equation has minimal cut sets for the down component that have "a non-negligible contribution, i.e., have a contribution greater than 1%."<sup>8</sup> A complementary statement to this is that those cut sets which contribute less than 1.0% have a negligible contribution. Therefore, another possible

---

<sup>8</sup>"Handbook of Methods for Risk-Based Methods for Analyses of Technical Specifications," NUREG/CR-6141, page 3-8, December 1994.

acceptable risk increase criterion is 1.0% of the base core damage frequency which for North Anna would be 6.8E-7/yr using the IPE as the base model.

The use of 1.0% of core damage frequency as the cutoff value is similar to the types of cutoffs that have been chosen in other applications. For example, the reporting guidelines for the individual plant examination require core damage sequences greater than 1E-7 per year and within the upper 95 percent of the total core damage frequency to be reported. The NUMARC guidelines for the maintenance rule define risk significant components in several possible ways<sup>9</sup>. One way is the use of the core damage frequency contribution. Cut sets that account for about 90% of the overall core damage frequency, with appropriate eliminations, should be used as input to risk determination. Since a cut set can appear in only one sequence this is the same as a sequence requirement and is obviously less restrictive than the 1% number discussed above.

Finally, consider that the screening cutoff for the IPEEE, including FIVE, is 1E-6/yr<sup>10</sup>. This is comparable with the 6.8E-7/yr representing 1% of the core damage frequency as indicated by the North Anna IPE.

As a result of the above discussion it is clear that the use of something on the order of 1% as an acceptable risk increase is within the bounds used by NRC and its contractors for PSA applications. It is also clear that it is more conservative than some of the measures discussed. Based on this review of industry experience, 1E-6/yr has been adopted by Virginia Power as the figure of merit for use in the evaluation of the extended EDG outage.

## 5.0 IMPLEMENTATION REQUIREMENTS

An implementation plan is necessary to ensure that analysis assumptions are properly incorporated into station operating procedures. The plan presented below has two components: equipment required to be operable during the extended EDG maintenance outage and other safety related equipment potentially available for on-line maintenance.

The off-site power sources and other (i.e., both units) EDGs must be operable during the EDG extended outage when the inspection and maintenance is performed during

---

<sup>9</sup>"Industry Guidelines for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants," March 1993.

<sup>10</sup>"Procedural and Submittal Guidance for the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities - Final Report," NUREG-1407, page 4, June 1991.

operation in Modes 1,2,3 or 4. Additionally, the AAC DG must be operable as defined in the Technical Requirements Manual. Operability includes the EDG set and several subsystems, such as the fuel transfer system, in a manner similar to the EDGs. Surveillance requirements have been defined for these AAC DG subsystems and some specific components. The AAC DG operability items are listed in Table 5.1. In addition to these operability requirements in Table 5 the AAC DG must be tested within 14 prior to removal of an EDG for its preventive maintenance inspection outage. During this testing the AAC DG must be aligned to the transfer bus associated with the emergency bus powered by the EDG to be inspected.

A procedure must be written to address the use of the AAC DG for each of the EDGs. The procedure must address the controls for starting the diesel and individual breaker position for providing power to each bus. The procedure should include an equipment load list with priorities for the order in which equipment are loaded onto the bus.

Performance of additional on-line maintenance concurrent with EDG preventive maintenance during the fourteen day extended outage is governed by existing on-line maintenance administrative controls which rely on a list of risk significant equipment developed from the North Anna PSA model. The administrative controls currently require that only one functional equipment group, FEG, (i.e., all of the subcomponents which must function in order for a major piece of equipment to function) be unavailable for planned maintenance at the same time.

If two or more risk important FEGs for a unit are to be unavailable additional administrative controls may be required. However, during the extended EDG outage if two or more FEGs are to be unavailable at the same time, for any reason, a contingency plan outlining compensatory actions should be developed.

The performance of this inspection outage during modes 3 and 4 has not been specifically analyzed. The at-power PSA model is not appropriate for these conditions. NUREG/CR-5994<sup>11</sup> considered the effect of EDG maintenance on core damage frequency during various modes of operation. The study concludes that EDG maintenance in shutdown modes prior to an outage should be avoided because decay heat generation is highest and steam to power the turbine driven auxiliary feedwater pumps may not be available.

The administrative controls currently in place preclude on-line maintenance to FEGs on systems important to PSA safety and components important to plant reliability during planned transients. So, this type of maintenance would not be started during a planned evolution into Modes 3 or 4. However, if a unit is forced to enter into these

---

<sup>11</sup>"Emergency Diesel Generator: Maintenance and Failure Unavailability, and Their Risk Impacts," NUREG/CR-5994, Chapter 5, November 1994.

modes while the EDG maintenance is in progress, the increase in core damage frequency resulting solely from changing modes does not require continued cooldown as long as sufficient secondary heat removal capability exists. Sufficient secondary heat removal capability exists if there are at least two sources of feedwater available. The main feedwater system, the auxiliary feedwater system or a combination of the two could be used for this purpose. The operability assumptions related to the EDG outage (items 1,2 and 4 above) must also continue to be met. If at least two sources of feedwater cannot supply their respective steam generators the unit should be brought to cold shutdown.

**Table 5.1**  
**Alternate A.C. Diesel Operability Requirements**

1.	Verify that the volume of fuel oil in the day tank is greater than or equal to 850 gallons.
2.	Verify that the volume of fuel oil in the above ground fuel oil storage tank is greater than or equal to 45,000.
3.	Verify that a fuel oil transfer pump can be started and transfers fuel from the storage system to the day tank, or verify gravity feed flow to the day tank is > 4 gpm, or verify gravity feed flow is sufficient to maintain the day tank level while the AAC DG is loaded > 3250 kw.
4.	Verify that the AAC DG can start and accelerate to synchronous speed (900 rpm) with generator voltage and frequency at $4300 \pm 100$ volts and $60 \pm 1.2$ Hz. Subsequently, verifying the generator is synchronized, gradually loaded to an indicated 3250-3350 kw and operates for at least 60 minutes.
5.	Verify that the AAC DG total battery terminal voltage is greater than or equal to 126 volts on a float charge before initiating Surveillance Requirement 4.8.1.1.2.f when operating in Modes 1,2,3 or 4.
6.	Verify that the starting air tank is > 275 psig.
7.	Verifying that the following A.C. electrical buses are OPERABLE:
a.	4160 v bus OM
b.	4160 v bus OL
c.	480 v bus OM1
d.	480 v bus OM1-1

## 6.0 CONCLUSIONS

Virginia Power has performed an analysis of extended EDG outages. The analysis included an update of the existing PSA model in order to keep it current with the configuration of the plant. A base case was run with and without the AAC DG model activated assuming the current average annual unavailability for the EDGs. The core damage frequency for the case without the AAC DG is 5.4E-5/yr while the base case CDF with the AAC DG included is 4.1E-5/yr as reported in Table 3.2. When the unavailability of each EDG is increased to include a single 14-day outage once every 18 months the core damage frequency increases to 4.2E-5/yr. A sensitivity analysis performed with even larger assumed EDG unavailability shows that the increase in CDF is still much less than the decrease resulting from the addition of the AAC DG. The decrease in core damage frequency associated with adding the AAC DG is 1.3E-5/yr while the increase in CDF resulting from the increased EDG unavailability is 1E-6/yr. This increase in CDF is small and meets the criterion for acceptable risk increase identified for this project.

The PSA analysis found that the increase in CDF with the additional EDG unavailability is small. The analysis considered operation in Modes 1 and 2. Administrative procedures preclude performance of the EDG inspection outage coincident with a planned transient. Continued performance of the inspection outage during unplanned entrance into Modes 3 and 4 was evaluated and found to be acceptable as long as secondary heat removal capability could be demonstrated.

With the EDG maintenance performed on-line it is not expected to be necessary to have an EDG in extended maintenance during shutdown conditions. Hence, any increase in risk associated with the inspection performed on-line is partially offset by the reduced risk of core damage during shutdown. Thus, the overall CDF increase is less than the 1E-6/yr identified above because the units will typically have both diesels in operation for most of the outage. This means that both EDG's will have higher availability during loss of off-site power events at shutdown, which will improve residual heat removal system availability in these events. In the past, one diesel was declared inoperable for about half of an outage. Therefore, for half of the outage decay heat removal during loss of off-site power events is highly dependent upon a single RHR pump; the redundant RHR pump is available only if powered by the AAC DG.

A shutdown PSA has not been performed for North Anna. However, a shutdown PSA analysis was performed for Surry Power Station that is documented in NUREG/CR-6144<sup>12</sup>. The Surry shutdown PSA found only reduced inventory plant operational

---

<sup>12</sup>"Evaluation of Potential Severe Accidents During Low Power and Shutdown Operations at Surry, Unit 1 - Analysis of Core Damage Frequency from Internal Events During Mid-Loop Operations,"

states were significant contributors to core damage frequency. The study also found that "maintenance unavailability was the dominant cause of equipment unavailability" during the reduced inventory states. In this study the EDGs were defined to be part of the minimum equipment list for reduced inventory situations so they were assigned no maintenance unavailability.

The above shutdown PSA model was used along with a full power PSA model to look specifically at the impact of EDG maintenance at power and during shutdown. The results of the comparison are reported in NUREG/CR-5994<sup>13</sup> prepared by Brookhaven National Laboratory. This study shows that the change in CDF due to an EDG being in maintenance is the same as or more significant during most shutdown operational configurations than when the EDG maintenance is performed at power. While this conclusion indicates that EDG maintenance at power is risk beneficial it should be remembered that Surry has only three diesels and that the North Anna model presented herein takes credit for five diesels. The impact of the AAC DG at shutdown could change the results of the Brookhaven study. Nevertheless, this study confirms that some shutdown risk is averted by doing the maintenance at power.

Based on these results Virginia Power concludes that it is acceptable to conduct the 18 month EDG preventive maintenance and inspection during any mode, and during mode changes, as long as the inspection is performed in a single 14-day EDG outage once every eighteen months and the AAC DG is operable during this time. Restrictions on the operability of other equipment are also defined. The 1E-6/yr increase in CDF calculated as a result of the increased EDG unavailability meets the criterion for acceptable risk increase defined for this project.

---

NUREG/CR-6144, Executive Summary, pp xxxii-xxxiii, June 1994.


<sup>13</sup>"Emergency Diesel Generator: Maintenance and Failure Unavailability, and Their Risk Impacts," NUREG/CR-5994, Chapter 5, November 1994.


## APPENDIX A


### Fault Trees


The following fault trees are contained in this Appendix.

<u>ID</u>	<u>Name</u>	<u>Description</u>
1EG	1EG	Emergency Diesel Generators Unit 1 6/95 PSA, 1 p.
2EG	2EG	Emergency Diesel Generators Unit 2 6/95 PSA, 1 p.
AAC	0AAC	Alternate AC Power Units 1 & 2 6/95 PSA, 1 p.
DAM	DAM	Disallowed Maintenance Unit 1 6/95 PSA, 19 pp.
E1H	E1H00	1H Emergency Electric Power Unit 1 6/95 PSA, 15 pp.
E1J	E1J00	1J Emergency Electric Power Unit 1 6/95 PSA, 12 pp.
E2H	E2H00	2H Emergency Electric Power Unit 2 6/95 PSA, 13 pp.
E2J	E2J00	2J Emergency Electric Power Unit 2 6/95 PSA, 12 pp.
ESY	ESY00	Switchyard Buses Units 1 & 2 6/95 PSA, 14 pp.
FFT	FFT	Functional Fault Tree Unit 1 6/95 PSA, 6 pp.
LR1	LR100	Low Head Safety Recirculation Unit 1 6/95 PSA, 10 pp.
T9A	IET9A	T9A Loss of 1H 4160 Elect Pwr Unit 1 6/95 PSA, 1 p.
T9B	IET9A	T9A Loss of 1J 4160 Elect Pwr Unit 1 6/95 PSA, 1 p.









0 1 2 3 4 5

## Disallowed Maintenance

NAPS Unit 1

6/95 PSA

DAM 2

ANALYST: RST | CREATION DATE: 06-22-92

REVISION: 06-01-95

EMERGENCY DIESEL  
GENERATORS  
TS 3.B.1.1.B  
GDAM212

TPR TO  
1 20

2/5

1-EE-EG-1H  
Test & Maintenance  
Unavailability  
1EGEDG-TM-1H

1.20E-002

3

1-EE-EG-1J  
Test & Maintenance  
Unavailability  
1EGEDG-TM-1J

1.20E-002

3

2-EE-EG-2H  
Test & Maintenance  
Unavailability  
2EGEDG-TM-2H

5.40E-002

3

2-EE-EG-2J  
Test & Maintenance  
Unavailability  
2EGEDG-TM-2J

5.40E-002

3

0-AAC-0G-0M  
Test & Maintenance  
Unavailability  
AACEDG-TM-0M

5.47E-002

3

2

3

4

5

6

7


8


9

Disallowed Maintenance  
NAPS Unit 1 6/95 PSA

DAM 3

ANALYST: RST | CREATION DATE: 06-22-92 | REVISION: 06-01-95








0 1 2 3 4 5  
0 Disallowed Maintenance  
MAPS Unit 1 6/95 PSA

DAM 5

ANALYST: RST | CREATION DATE: 06-22-92 | REVISION: 06-01-95






Disallowable Maintenance  
MAPS Unit 1 6/95 PSA

DAM 7

ANALYST: RST CREATION DATE: 06-22-92

REVISION: 06-01-95



Disallowed Maintenance


NAPS Unit 1

6/95 PSA

DAM B

ANALYST: RST | CREATION DATE: 06-22-92


REVISION: 06-01-95




Disallowable Maintenance  
NAPS Unit 1 6/95 PSA

DAM 9

ANALYST: RST CREATION DATE: 06-22-95 REVISION: 06-01-95







Disallowanced Maintenance  
MAPS Unit 1

6/95 PSA

DAM 11


ANALYST: RST | CREATION DATE: 06-22-92 | REVISION: 06-01-95







0 1 2 3 4 5

Disallowed Maintenance NAPS Unit 1		6/95 PSA	DAM 13
ANALYST: RST	CREATION DATE: 06-22-92	REVISION: 06-01-95	








0 1 2 3 4 5


Disallowed Maintenance  
MAPS Unit 1


6/95 PSA


DAM 16


ANALYST: RST | CREATION DATE: 06-22-92 | REVISION: 06-01-95




















PAGE 1

0 1 2 3 4 5

1H Emergency Electric Power  
NAPS Unit 1  
6/95 PSA

E1H 5

ANALYST: RST | CREATION DATE: 04-30-1991 | REVISION: 06-01-95

0

1

2

3

4

5







6

7

8

9

0




PAGE 3


SH Emergency Electric Power  
MAPS Unit 1


6/95 PSA


E1H 6


ANALYST: RST | CREATION DATE: 04-30-1991 | REVISION: 06-01-95












1H Emergency Electric Power  
NAPS Unit 1 6/95 PSA

ANALYST: RGT | CREATION DATE: 04-30-1991 | REVISION: 06-01-96



NO ELECTRIC POWER  
480 V MCC SH1-A  
1-EP-MC-43  
GE JHB12

12  
PAGE 5

BREAKER D1L  
ON MCC 3H1-4  
SPURIOUSLY OPENS  
1EEBKR-50-N4-D1L

3.38E-005 24

TRANSFORMER 118  
SEM VITAL DIST 1A  
80-120/240V 15KVA  
SEE TFM-LP-118

TRANSFORMER 118  
SEMI VITAL DIST 1A  
80-120/240V 15KVA  
SEE TFM-LP-118


AKER 17 ON  
VITAL DIST 1A  
OUSLY OPENS

AKER 17 DM  
VITAL DIST 1A  
OUSLY OPENS  
R-SD-16A-17

.21E-005

卷之三

297 163




0 1 2 3 4 5

1H Emergency Electric Power  
MAPS Unit 1  
6/95 PSA

E1H 13


ANALYST: RST | CREATION DATE: 04-30-1991 | REVISION: 06-01-95




1  
2  
PAGE 3

0 1 2 3 4 5

1H Emergency Electric Power MAPS Unit 1	6/95 PSA	E1H 14
ANALYST: RST	CREATION DATE: 04-30-1991	REVISION: 06-01-95







0 1 2 3 4 5

1J Emergency Electric Power  
NAPS Unit 1 6/95 PSA

E1J 1

ANALYST: RST | CREATION DATE: 05-24-1991 | REVISION: 06-01-95






0 1 2 3 4 5

1J Emergency Electric Power  
NAPS Unit 1 6/95 PSA

E1J 3

ANALYST: RST | CREATION DATE: 05-24-1991 | REVISION: 06-01-95




PAGE 1

1J Emergency Electric Power  
NAPS Unit 1

6/95 PSA

E1J 4

ANALYST: RST | CREATION DATE: 05-24-1991 | REVISION: 06-01-95





0 1 2 3 4 5

1J Emergency Electric Power  
NAPS Unit 1  
6/95 PSA

E1J 5

ANALYST: RST | CREATION DATE: 05-24-1991 | REVISION: 06-01-95







E1J60 LGC NAPS 2.2 VAPR0


1J Emergency Electric Power  
NAPS Unit 1 6/95 PSA


E1J 7

ANALYST: RST | CREATION DATE: 05-24-1991 | REVISION: 06-01-95










0 1 2 3 4 5

1J Emergency Electric Power  
MAPS Unit 1 6/95 PSA

E1J 11

ANALYST: RST CREATION DATE: 05-24-1991 REVISION: 06-01-95





PAGE 3

SIJ Emergency Electric Power  
NAPS Unit 1

6/95 PSA

E1J 12

ANALYST: RST | CREATION DATE: 05-24-1991 | REVISION: 06-01-95




0 1 2 3 4 5

2H Emergency Electric Power  
MAPS Unit 2  
6/95 PSA

E2H 1

ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95




2H Emergency Electric Power  
NAPS Unit 2


6/95 PSA


E2H 2

ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95



12  
PAGE 1






0 1 2 3 4 5

2H Emergency Electric Power  
NAPS Unit 2  
6/95 PSA

E2H 5

ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95





0 1 2 3 4 5


2: Emergency Electric Power  
NAPS Unit 2  
6/95 PSA


E2H 6



ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95
















2H Emergency Electric Power  
NAPS Unit 2 6/95 PSA E2H 11  
ANALYST: PST CREATION DATE: 05-27-1991 REVISION: 06-01-95









PAGE 3





**2J Emergency Electric Power  
MAPS Unit 2**

ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95




0 1 2 3 4 5

2J Emergency Electric Power  
NAPS Unit 2  
6/95 PSA

E2J 4


ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95



2J Emergency Electric Power  
NAPS Unit 2      6/95 PSA

E2J 5

ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95





0 1 2 3 4 5


2J Emergency Electric Power  
MAPS Unit 2  
6/95 PSA


E2J 6

ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95












0 1 2 3 4 5  
0 1 2 3 4 5  
2J Emergency Electric Power  
NAPS Unit 2 6/95 PSA

E2J 10

ANALYST: RST CREATION DATE: 05-27-1991 REVISION: 06-01-95






2J Emergency Electric Power  
MAPS Unit 2

6/95 PSA

E2J 12


ANALYST: RST | CREATION DATE: 05-27-1991 | REVISION: 06-01-95





Switchyard Electrical Buses  
NAPS Units 1 & 2 6/95 PSA

ESY 1


ANALYST: RST | CREATION DATE: 03-10-1991 | REVISION: 06-01-95








PAGE 1






Switchyard Electrical Buses  
MAPS Units 1 & 2 6/95 PSA

ANALYST: RST CREATION DATE: 03-10-1991 REVISION: 06-01-95


**ESY 6**



Switchyard Electrical Buses  
NAPS Units 1 & 2 6/95 PSA

ESY 7

ANALYST: RST CREATION DATE: 03-10-1991 REVISION: 06-01-95





0 1 2 3 4 5


Switchyard Electrical Buses  
NAPS Units 1 & 2  
6/95 PSA


ESY 8


ANALYST: RST | CREATION DATE: 03-10-1991 | REVISION: 06-01-95














PAGE 8






12  
PAGE 9





Functional Fault Tree  
MAPS Unit 1 6/95 PSA

FFT 2

ANALYST: RST | CREATION DATE: 12-29-93 | REVISION: 06-01-95








Functional Fault Tree  
MAPS Unit 1 6/95 PSA

FFT 5

ANALYST: RST | CREATION DATE: 12-29-93 | REVISION: 06-01-95



## Functional Fault Tree


NAPS Unit 1


6/95 PSA

FFT 6

ANALYST: RST CREATION DATE: 12-29-93

REVISION: 06-01-95





0

1

2

3


4



5


Low Head Safety Recirculation  
NAPS Unit 1  
6/95 PSA



LR1 2


ANALYST: RST | CREATION DATE: 06-26-1991 | REVISION: 06-01-95



























T9B LOSS OF 1J 4160 ELECT PWR  
MAPS UNIT 1  
6/95 PSA

T9B 1

ANALYST: RST | CREATION DATE: 06-22-92 | REVISION: 06-01-95



**APPENDIX B**  
**Event Trees**

- A: Large Break Loss of Coolant Accident (LOCA)  
AD2: Large Break Loss of Coolant Accident (LOCA) & Accumulators Fail To Inject
- Rx: Reactor Vessel Rupture
- S1: Medium Break Loss Of Coolant Accident  
S1D1: Medium Break Loss Of Coolant Accident (LOCA) Without High Head Safety Injection
- S2: Small Break Loss Of Coolant Accident (LOCA)  
S2D1: Small Break Loss Of Coolant Accident (LOCA) Without High Head Safety Injection
- T1: Loss Of Off-site Power  
T1EE: Unit 1 Station Blackout Loss Of Off-site Power & Failure of Unit 1 Emergency Diesel Generators And Alternate AC Diesel  
T1EEQ: Station Blackout (Loss Of Off-site Power & Failure of Diesels to Supply Power) And Pressurizer PORV Fails Open  
T1Hv: Loss Of Off-site Power & Loss Of Emergency Switchgear Room Cooling  
T1Q: Loss Of Off-site Power & Pressurizer PORV Fails Open  
T1QAFW: Loss Of Off-site Power & Pressurizer PORV Fails Open & Auxiliary Feedwater Fails
- T2: Loss Of Main Feedwater  
T2A: Recoverable Loss Of Main Feedwater  
T2AHv: Recoverable Loss Of Main Feedwater & Loss Of Emergency Switchgear Room Cooling  
T2Hv: Loss Of Main Feedwater & Loss Of Emergency Switchgear Room Cooling  
T3: Transients With Main Feedwater  
T3Hv: Transients With Main Feedwater & Without Emergency Switchgear Room Cooling
- T4: Loss Of Reactor Coolant Pump Seal Cooling
- T5A: Loss Of Emergency Power DC Bus 1-I  
T5AQ: Loss Of Emergency Power DC Bus 1-I & Pressurizer PORV Fails Open  
T5B: Loss Of Emergency Power DC Bus 1-III

T5BQ: Loss Of Emergency Power DC Bus 1-III & Pressurizer PORV Fails Open

T6: Loss Of Service Water

T7: Steam Generator Tube Rupture

T7D1: Steam Generator Tube Rupture Without High Head Safety Injection

T8: Loss Of Emergency Switchgear Room Cooling

T9A: Loss Of Emergency Power 4160 V Bus 1H

T9AHv: Loss Of Emergency Power 4160 V Bus 1H & Loss Of Emergency Switchgear Room Cooling

T9AQ: Loss Of Emergency Power 4160 V Bus 1H & Pressurizer PORV Fails Open

T9B: Loss Of Emergency Power 4160 V Bus 1H

T9BHv: Loss Of Emergency Power 4160 V Bus 1H & Loss Of Emergency Switchgear Room Cooling


T9BQ: Loss Of Emergency Power 4160 V Bus 1H & Pressurizer PORV Fails Open

TH: Anticipated Transient Without a Scram (ATWS) When Greater Than 40% Reactor Power

THMFW: Anticipated Transient Without a Scram (ATWS) When Greater Than 40% Reactor Power & No Main Feedwater

TL: Anticipated Transient Without a Scram (ATWS) When Greater Than 40% Reactor Power


Vx: Interfacing System LOCA



D:\MARS\ASURANCE\ENTERPRISE\BAT\7\07\56500\6-14-95\TOTAL.DAT = 1.94E-006  
D:\MARS\ASURANCE\ENTERPRISE\BAT\7\07\56500\6-14-95\MURPA\2.2.VAPR

North Anne Probabilistic Safety Assessment  
June 1995


A: Large Break Loss of Coolant Accident (LOCA)



North Anne Probabilistic Safety Assessment June 1999

A A 02: Large Break Loss Of Coolant Accident (LOCA)  
6 Accumulators Fail to Inject  
During 1990


Q MAPS/SHADE/ETREES/A02.EVT    X 0E 50MM 8-14-93    X 0E 51MM 8-14-93    TOTAL OF = 2.2 VAPRA



D:\MAPS\GULANE\ETRME310\DET\7\093600\8-14-95\TOTAL.CDF = 2.67E-007  
 DOCUMENT NUMBER: DET-7-093600 8-14-95 MFDPA 2.3 VAPPA

North Anne Probabilistic Safety Assessment  
June 1995

RX: Reactor Vessel Rupture



North Anna Probabilistic Seismic Assessment


June 1997

### 5i: Medium Break Loss Of Coolant Accidents

D:\wang\192.168.1.105\ETHERES\101.EVT 7/11/2008 6-14-05 NAPRA 2.2. VAPPA Quantification Date: 6-14-05 7/11/2008 TOTAL. CDF = 4.0E-006


North Anna Probabilistic Safety Assessment  
June 1995

SI DI: Medium Break Loss Of Coolant Accident (LOCA)  
Without High Head Safety Injection



North Anna Probabilistic Safety Assessment  
June 1995


S2: Small Break Loss Of Coolant Accident (LOCA)




Quantitative Evaluation Date: 6-14-95 / 12/30/99 Total Dif = 7.17E-06  
Q:\MWS\GSA\NE\ETRSES\S201.EVT / 12/30/99 6-14-95 MWSA 2.2 VAPIN

North Anna Probabilistic Safety Assessment  
June 1995

S201: Small Break Loss Of Coolant Accident (LOCA)  
Without High Head Safety Injection




DE WILFRED GUTHRIE/ET PRESENT L'EVT 71-145385M 6-14-95 MURKIN 2.2 VAPOR  
DE QUENTIN GUTHRIE/ET PRESENT DREC 6-14-95 71-145385M TOTAL QTR = 1.66-006



C:\VAPPS\G5\NAME\TIEE\TIEE.TIEE 7/17/06 8:51-14-95 TOTAL CPU = 5.22E-008  
Quantitative Information Date: 6-14-95 7/17/06 8:51-14-95 MPP=2 VAPPS

North Anna Probabilistic Safety Assessment  
June 1995

TIEE: Unit 1 Station Blackout  
Loss of Offsite Power & Failure of Unit 1 Emergency Diesel Generators And Alternate AC Diesel




Q:\VAPPS\GSA\NCE\TEPRESENCE\TIEE0.GST 7/17/95 3:17:34AM TOTAL QST = 6.22E-007

June 1995

TIEE0: Station Blackout Loss of Off-site Power & Failure of Diesels to Supply Power  
And Pressurizer PWR Falls Open

North Anna Probabilistic Safety Assessment

Loss Of Offsite Power & Loss Of ESGR Cooling	Unit 1 Emergency Electrical Busses	Unit 2 Emergency Electrical Buses	Offsite AC Electric Power Recovered Before Core Recovery	Unit 2 HV System Used To Recover Cooling Power To Unit 1 ESGR Reaching 120F	Main Feedwater	Auxiliary Feedwater	Unit 2 Charging Water Recovery Unit 1 ESGR Cooling	Unit 2 Component Recovery Unit 1 ESGR Cooling	SEQUENCE DESCRIPTOR	P	FREQUENCY
TSWY	IEEE	2EE	EP	2HV	NFW	APW	2CH	RCP Seal Cooling	6	S	6



SEARCHED BY BUREAU OF INVESTIGATION, FBI, WASH., D.C. SERIALIZED BY BUREAU OF INVESTIGATION, FBI, WASH., D.C. INDEXED BY BUREAU OF INVESTIGATION, FBI, WASH., D.C. FILED BY BUREAU OF INVESTIGATION, FBI, WASH., D.C. 6-14-95 BY J.R. SAWYER TOTAL PAGE 7, 70E-008


North Anna Probabilistic Safety Assessment  
June 1995

T1 Q: Loss Of Offsite Power  
S Pressurizer Port Fails Open


Loss Of Offsite Power & PORV Falls Open & AFW Falls	Unit 1 Emergency Electrical Buses	Unit 2 Emergency Electrical Buses	Unit 1 Emergency Switchgear Room Cooling	Pressurizer PORVs For RCS Feed And Bleed	High Head Safety Injection	Quench Spray	Recirculation Spray	Containment Heat Removal (SN to RS Heat Exchangers)	Low Head Safety Injection Cold Leg Recirculation	S E G #	SEQUENCE DESCRIPTOR	P D S #	FREQUENCY
T1OFN	1EE	2EE	1Hy	P	D1	0s	Rs	Ch	H1				
										P01	T1OFN	20	0.00E+00 52
										P02	T1OFNHS	21	0.00E+00
										P03	T1OFNCH	22	0.00E+00
										P04	T1OFNPRs	23	0.00E+00
										P05	T1OFN01	OK	
										P06	T1OFN01Ch	21	0.00E+00
										P07	T1OFN01Rs	22	0.00E+00
										P08	T1OFN010s	23	0.00E+00
										P09	T1OFNP	20	0.00E+00
										P10	T1OFNPHs	21	0.00E+00
										P11	T1OFNCH	22	0.00E+00
										P12	T1OFNPRs	23	0.00E+00
										P13	T1OFNHy	TR	0.00E+00 T1HV
										P14	T1OFN2EE	TR	0.00E+00 2580
										P15	T1OFNIEE	TR	0.00E+00 T1EE

North Anna Probabilistic Safety Assessment  
 June 1995

T1 O AFM: Loss Of Offsite Power  
 & Pressurizer PORV Falls Open & Auxiliary Feedwater Falls





DE WADDESSAARNE/TERRENAUT-ZET 7.22.2826 8-14-95 URGENT 2.2 VARIOUS QUESTIONS/INFORMATION DESCR: 8-14-95 7.22.2826 TOTAL QRS = 3.48E-007



North Anne Probabilistic Safety Assessment  
June 1995

T2A: Recoverable Loss of Main Feedwater






North Anne Probabilistic Safety Assessment  
June 1995

T2 Hy: Loss Of Main Feedwater  
E Loss Of Emergency Switchgear Room Cooling

Transient With Main Feedwater	Emergency Switchgear Room Cooling	Auxiliary Feedwater	Main Feedwater	Pressurizer PDRVs For RCS Feed And Bleed	High Head Safety Injection	High Head Safety Injection Cold Leg Recirc.	Quench Spray	Containment Failure Becomes Energy Relief Path	Recirculation Spray	Containment Heat Removal (SW to RS Heat Exchangers)	Low Head Safety Injection Cold Leg Recirc.	S E Q #	SEQUENCE DESCRIPTOR	P D S #	FREQUENCY
T3	Hv	AFW	MFW	P	D1	H2	0s	C	Rs	Ch	H1				
												P01	T3		
												P02	T3AFW		
												P03	T3AFMFH		
												P04	T3AFMFHC		
												P05	T3AFMFHCH	1	0.00E+00
												P06	T3AFMFHCRs	2	0.00E+00
												P07	T3AFMFH2	21	0.00E+00
												P08	T3AFMFH2H1	21	0.00E+00
												P09	T3AFMFH2H2	22	0.00E+00
												P10	T3AFMFH2Rs	23	0.00E+00
												P11	T3AFMFHD1	20	1.38E-08
												P12	T3AFMFHD1H1	21	0.00E+00
												P13	T3AFMFHD1CH	22	0.00E+00
												P14	T3AFMFHD1Rs	23	0.00E+00
												P15	T3AFMFHD1Os	23	0.00E+00
												P16	T3AFMFHP	8	2.11E-09
												P17	T3AFMFHPH1	9	0.00E+00
												P18	T3AFMFHPCH	10	0.00E+00
												P19	T3AFMFHPRs	11	0.00E+00
												P20	T3AFMFHPOs	11	0.00E+00
												P21	T3hv	1R	3.31E-04 T3hv

North Anna Probabilistic Safety Assessment  
June 1995

T3: Transients With Main Feedwater




The fault tree diagram illustrates the sequence of events following a Loss of Reactor Coolant Pump Seal Cooling (T4). The tree structure is as follows:

- Initial Event:** T4 (Loss of Reactor Coolant Pump Seal Cooling)
- Intermediate Events:**
  - T4 leads to P01 (Containment Failure Between Energy Relief Path C and RS Ch).
  - P01 leads to P02 (Containment Spray), P03 (Containment Failure Between Energy Relief Path C and RS Ch), and P04 (Containment Spray).
  - P04 leads to P05 (Containment Spray), P06 (Containment Spray), and P07 (Containment Spray).
  - P05 leads to P08 (Containment Spray), P09 (Containment Spray), and P10 (Containment Spray).
  - P06 leads to P11 (Containment Spray), P12 (Containment Spray), and P13 (Containment Spray).
  - P07 leads to P14 (Containment Spray), P15 (Containment Spray), and P16 (Containment Spray).
  - P08 leads to P17 (Containment Spray), P18 (Containment Spray), and P19 (Containment Spray).
  - P09 leads to P20 (Containment Spray), P21 (Containment Spray), and P22 (Containment Spray).
  - P10 leads to P23 (Containment Spray), P24 (Containment Spray), and P25 (Containment Spray).
  - P11 leads to P26 (Containment Spray), P27 (Containment Spray), and P28 (Containment Spray).
  - P12 leads to P29 (Containment Spray), P30 (Containment Spray), and P31 (Containment Spray).
  - P13 leads to P32 (Containment Spray), P33 (Containment Spray), and P34 (Containment Spray).
  - P14 leads to P35 (Containment Spray), P36 (Containment Spray), and P37 (Containment Spray).
  - P15 leads to P38 (Containment Spray), P39 (Containment Spray), and P40 (Containment Spray).
  - P16 leads to P41 (Containment Spray), P42 (Containment Spray), and P43 (Containment Spray).
  - P17 leads to P44 (Containment Spray), P45 (Containment Spray), and P46 (Containment Spray).
  - P18 leads to P47 (Containment Spray), P48 (Containment Spray), and P49 (Containment Spray).
  - P19 leads to P50 (Containment Spray), P51 (Containment Spray), and P52 (Containment Spray).
  - P20 leads to P53 (Containment Spray), P54 (Containment Spray), and P55 (Containment Spray).
  - P21 leads to P56 (Containment Spray), P57 (Containment Spray), and P58 (Containment Spray).
  - P22 leads to P59 (Containment Spray), P60 (Containment Spray), and P61 (Containment Spray).
  - P23 leads to P62 (Containment Spray), P63 (Containment Spray), and P64 (Containment Spray).
  - P24 leads to P65 (Containment Spray), P66 (Containment Spray), and P67 (Containment Spray).
  - P25 leads to P68 (Containment Spray), P69 (Containment Spray), and P70 (Containment Spray).
  - P26 leads to P71 (Containment Spray), P72 (Containment Spray), and P73 (Containment Spray).
  - P27 leads to P74 (Containment Spray), P75 (Containment Spray), and P76 (Containment Spray).- Final Outcomes:**
  - P01 T4
  - P02 T4NH1
  - P03 T4C
  - P04 T4CH
  - P05 T4CDH1
  - P06 T4CDH2
  - P07 T4CH2
  - P08 T4CHN1
  - P09 T4D3
  - P10 T4D3H
  - P11 T4D3H1
  - P12 T4D3H2
  - P13 T4D2
  - P14 T4D2H1
  - P15 T4D2H2
  - P16 T4D2H3
  - P17 T4D2H5
  - P18 T4Y
  - P19 T4NH1
  - P20 T4CH
  - P21 T4CH2
  - P22 T4CH2
  - P23 T4AFN
  - P24 T4AFNHC
  - P25 T4AFNHC1
  - P26 T4AFNHC2
  - P27 T4AFNHC3
  - P28 T4AFNHC4

North Anne Probabilistic Safety Assessment

ЕБР 1961


74: Loss of Reactor Coolant Pump Seal Cooling



Quantitative Information Date: 6-14-95 7-27-2664 8-14-95 HPPA 2.3 VAPPA  
T5A

North Anna Probabilistic Safety Assessment  
June 1995


T5A: Loss Of Emergency Power DC Bus I-1



© WAPPS/SCANNER/TESTES/TEAD/EVT X-27-3868 8-14-95 HUMLA 2.2 ADAMS  
Quadratic/Elastication Order: 8-14-95 7-27-3868 TOTAL DR = 2.2E-009

North Anne Probabilistic Safety Assessment  
June 1995

TSAQ: Loss Of Emergency Power DC Bus 1-1  
6 Pressurizer Pump Fails Open




0005 S-18E-03  
P08 T5B0  
TR 5 SEC-06  
P10 T5B  
TR 5 SEC-06  
P11 T5B  
TR 5 SEC-06  
P12 T5B AFN  
TR 5 SEC-06  
P01 T5B AFN  
TR 5 SEC-06  
P02 T5B AFN NF N  
TR 5 SEC-06  
P03 T5B AFN NF N  
TR 5 SEC-06  
P04 T5B AFN NF N  
TR 5 SEC-06  
P05 T5B AFN NF N  
TR 5 SEC-06  
P06 T5B AFN NF N  
TR 5 SEC-06  
P07 T5B AFN NF N  
TR 5 SEC-06  
P08 T5B  
TR 5 SEC-06  
P10 T5B  
TR 5 SEC-06  
P11 T5B  
TR 5 SEC-06  
P12 T5B AFN  
TR 5 SEC-06

North Anna Probabilistic Safety Assessment  
June 1995

T5B: Loss Of Emergency Power DC Bus I-III


Z-WS5/525MVE/ETRREGAT580-EVT 7-27148888 5-14-95 MFGPA 2.2 VAPPA  
Z-WS5/525MVE/ETRREGAT580-DET 7-2714955 5-14-95 MFGPA 2.2 VAPPA  
TOTAL QTY = 1120E-009




Q:\W95\ASURANCE\ETREES\TS.EST 7:27:30AM 6-14-95 Mspaq 2.2 VAPM  
Quench injection doses: 6-14-95 7:27:31AM TOTAL Dose = 3.38E-007

North Anna Probabilistic Safety Assessment  
June 1995

16: Loss Of Service Water




DC-N95-95/UNIV-E/ETR003177.EFT 7/28 00hrs 5-14-95 7/28 01am TOTAL CHF = 6,75E-006



01-N95\35SUMMERTEES\1701.EVT 5-14-95 7-28-06AM TOTAL CPU = 8.19E-007  
Quantitative Evaluation Date: 5-14-95 7-28-06AM TOTAL CPU = 8.19E-007


North Anna Probabilistic Safety Assessment  
June 1995

17 D1: Steam Generator Tube Rupture  
Without High Head Safety Injection



Line Number	Component	Description	Flow Direction	Valve / Valve Status
P01	Pump	Emergency Power 4160 V Bus 1H	From P01 to CH10	
P02	Pressurizer	Hy	From CH13 to P02	
CH10	Heat Exchanger	Hy	From P01 to CH10	Open
CH11	Heat Exchanger	Hy	From CH10 to CH11	Open
CH12	Heat Exchanger	Hy	From CH11 to CH12	Open
CH13	Heat Exchanger	Hy	From CH12 to CH13	Open
PS10	Pressure Sensor	Hy	On line between CH10 and CH11	Open
PS11	Pressure Sensor	Hy	On line between CH11 and CH12	Open
PS12	Pressure Sensor	Hy	On line between CH12 and CH13	Open
PS13	Pressure Sensor	Hy	On line between CH10 and CH13	Open
PS14	Pressure Sensor	Hy	On line between CH10 and CH11	Open
Spray Header	Header	Hy	From CH13 to Spray Header	Open
P03	Pump	Hy	From Spray Header to P03	Open
P04	Pump	Hy	From Spray Header to P04	Open
P05	Pump	Hy	From Spray Header to P05	Open
P06	Pump	Hy	From Spray Header to P06	Open
P07	Pump	Hy	From Spray Header to P07	Open
P08	Pump	Hy	From Spray Header to P08	Open
P09	Pump	Hy	From Spray Header to P09	Open

NSA/LG/USAGM/NS/Unit/creg/TGA/EVT # 32 2000 6-19-95 MSG# 2.2 VAPR  
SUSPENDED/IFICATION DATE: 6-19-95 # 31-0700 TOTAL CPE = 1 21Z-008




Document ID: 1B-PSA-NAPS-931June-1989; TIAHNE GET 931204 931204 931204 2.2 VAPM  
Document Creation Date: 6-19-95 9:33:19AM TOTAL CFS = 2.01E-007

F:\MSAL\B\PMG\WAVES\95\June\surveys\1980.EYT S: 34: 0608 8-19-95 HUFRRA 2.2 YAPHR  
Quantification Date: 8-19-95 S: 34: 0708 TOTAL CEF = 9.35E-008

LOSS OF 4160 V Bus JH 6 Pressurizer PORV Fails Open	Auxiliary Feedwater	Main Feedwater	High Head Safety Injection	High Head Safety Injection Cold Leg Recirculation	Quench Spray	Containment Failure Becomes Energy Relief Path	Recirculation Spray	Containment Heat Removal (SW to RS Heat Exchangers)	Low Head Safety Injection Cold Leg Recirculation	S E 0 #	SEQUENCE DESCRIPTR	P D S #	FREQUENCY
TSAQ	AFN	MFN	D1	H2	0s	C	RS	CH	H3				
						C-C01 9.80E-01				P01	T9AQ	TR	8.45E-07
						C-H205 9.07E-01				P02	T9ADC	TR	1.67E-08
						C01 2.00E-02		CH11 9.70E-03		P03	T9AQCH	I	0.00E+00
						RS11 1.05E-03				P04	T9ADCRs	2	0.00E+00
										P05	T9ADH2	21	5.13E-08
										P06	T9ADH2CH	22	0.00E+00
										P07	T9ADH2Rs	23	0.00E+00
								C-H105 9.39E-01	H105 5.12E-02	P08	T9A001	20	4.02E-08
								CH10 1.40E-02		P09	T9A001H1	21	4.38E-10
								RS10 7.14E-03		P10	T9A001CH	22	3.75E-10
										P11	T9A001Rs	23	0.00E+00
										P12	T9A001Rs	23	1.15E-09
										P13	T9AGAFN	TR	4.79E-10
										P14	T9AGAFNC	TR	0.00E+00
										P15	T9AGAFNCH	I	0.00E+00
										P16	T9AGAFNCRs	2	0.00E+00
										P17	T9AGAFNH2	21	0.00E+00
										P18	T9AGAFNH2CH	22	0.00E+00
										P19	T9AGAFNH2Rs	23	0.00E+00
									C-H105 9.39E-01	P20	T9QAFHD1	20	0.00E+00
									H105 5.12E-02	P21	T9QAFHD1H1	21	0.00E+00
									CH10 1.40E-02	P22	T9QAFHD1CH	22	0.00E+00
								RS10 7.14E-03		P23	T9QAFHD1Rs	23	0.00E+00
										P24	T9QAFHD1Os	23	0.00E+00
									C-H105 9.39E-01	P25	T9QAFHNFM	20	0.00E+00
								H105 5.12E-02	P26	T9QAFHNFMH1	21	0.00E+00	
								CH10 1.40E-02	P27	T9QAFHNFMCH	22	0.00E+00	
								RS10 7.14E-03	P28	T9QAFHNFMRs	23	0.00E+00	
										P29	T9QAFHNFMWs	23	0.00E+00


North Anna Probabilistic Safety Assessment  
June 1995

T9A Q: Loss Of Emergency Power 4160 V Bus jH  
6 Pressurizer PORV Fails Open



North Anna Probabilistic Safety Assessment  
June 1995

198: Loss Of Emergency Power 4160 V Bus 1J



Model Anne Probabilistic Society Assessment June 1995

566 I 2010

T9B Rev: Loss Of Emergency Power 4150 V Bus 1J  
6 Loss Of Emergency Switchgear Room Cooling

Loss Of 4160 V Bus 1J & Pressurizer PORV Falls Open	Auxiliary Feedwater	Main Feedwater	High Head Safety Injection	High Head Safety Injection Cold Leg Recirculation	Quench Spray	Containment Failure Becomes Energy Relief Path	Recirculation Spray	Containment Heat Removal (SN to RS Heat Exchangers)	Low Head Safety Injection Cold Leg Recirculation	S E G #	SEQUENCE DESCRIPTOR	P D S #	FREQUENCY	
T980	AFW	MFW	D1	H2	GS	C	RS	CH	H1	P01	T980	TR	1.13E-08	52
										P02	T980C	TR	2.22E-08	52
										P03	T980CH	1	0.00E+00	
										P04	T980CRs	2	0.00E+00	
										P05	T980H2	21	7.26E-08	
										P06	T980H2Ch	22	0.00E+00	
										P07	T980H2Rs	23	0.00E+00	
										P08	T980D1	20	5.41E-08	
										P09	T980D1H1	21	1.40E-09	
										P10	T980D1Ch	22	0.00E+00	
										P11	T980D1Rs	23	0.00E+00	
										P12	T980D1Os	23	2.10E-09	
										P13	T980AFM	TR	5.36E-10	52
										P14	T980AFNC	TR	0.00E+00	52
										P15	T980AFNCCh	1	0.00E+00	
										P16	T980AFNCRs	2	0.00E+00	
										P17	T980AFMH2	21	0.00E+00	
										P18	T980AFMH2Ch	22	0.00E+00	
										P19	T980AFMH2Rs	23	0.00E+00	
										P20	T980AFHD1	20	0.00E+00	
										P21	T980AFHD1H1	21	0.00E+00	
										P22	T980AFHD1Ch	22	0.00E+00	
										P23	T980AFHD1Rs	23	0.00E+00	
										P24	T980AFHD1Os	23	0.00E+00	
										P25	T980AFMFN	20	0.00E+00	
										P26	T980AFMFH1	21	0.00E+00	
										P27	T980AFMFHCh	22	0.00E+00	
										P28	T980AFMFMRs	23	0.00E+00	
										P29	T980AFMFMDs	23	0.00E+00	

North Anna Probabilistic Safety Assessment


June 1995

T98 D: Loss Of Emergency Power 4160 V Bus 1J  
& Pressurizer PORV Falls Open

ATWS When Power Is Greater Than 40 %	Reactor Sub- Critical	Main Feedwater	Pressurizer PORV Opens Then Recloses	Maneuver Screw Late	Emergency Boration	Quench Spray	Recircu- lation Spray	Containment Heat Removal (SM to RS Heat Exchangers)	Low Head Safety Injection Cold Leg Recirculation	S E 0 6	SEQUENCE DESCRIPTOR	P D S #	FREQUENCY
TH	K	NFM	0	MSI	D4	0s	Rs	Ch	H3				
										P01	TH		OK
										P02	THK		OK
										P03	THKMS1		OK
										P04	THNMS104	B	1.04E-09
										P05	THNMS104H1	9	0.00E+00
										P06	THNMS104Ch	10	0.00E+00
										P07	THNMS104Rs	11	0.00E+00
										P08	THNMS1040s	11	0.00E+00
										P09	THKO	TR	0.41E-08
										P10	THKNS1	TR	5.34E-09
										P11	THNMS104	20	0.00E+00
										P12	THNMS104H1	21	0.00E+00
										P13	THNMS104Ch	22	0.00E+00
										P14	THNMS104Rs	23	0.00E+00
										P15	THNMS1040s	23	0.00E+00
										P16	THNFM	TR	9.59E-07THFM


North Anna Probabilistic Safety Assessment  
June 1995

TH Anticipated Transient Without a Scram (ATWS)  
When Greater Than 40% Reactor Power



North Anna Probabilistic Safety Assessment  
June 1995

TH New: Anticipated transient Without A Screen (ATHS)  
When Greater Than 40% Reactor Power & No Main Feedwater



01\W95\95NAME\ENTRIES\TL.GFT 7\34\1599 8-14-95 7\34\1739 8-14-95 TOTAL CPU = 4.23E-010

North Anna Probabilistic Safety Assessment  
June 1995

TL: Anticipated Transient Without Scram  
When Reactor Power Is Less Than 40%