U. S. NUCLEAR REGULATORY COMMISSION NRC FORM 366 (7-77) UPDATE REPORT: LICENSEE EVENT REPORT PREVIOUS REPORT DATE: 1/05/83 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) CONTROL BLOCK: 1200-010 0 - 0 0 3 4 0 EP 0 1 B CON'T 2 5 7 1 0 2 7 8 2 8 0 4 3 0 8 4 9 L 6 0 5 0 - 0 3 REPORT 0 1 SOURCE DOCKET NUMBER EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) During unit power operation, while investigating an event reported in LER 1-82-114, it was discovered that 0 2 RHR System discharge valves to the plant Radwaste System, 1-Ell-F040 and F049, would not fully close. 03 Subsequent testing of those respective values on Unit 2 on November 5, 1982, revealed the same condition. 04 In each case, both valves were declared inoperable, deactivated, and manually closed. These events did 0 5 not affect the health and safety of the public. 0 6 0 7 Technical Specifications 3.6.3, 6.9.1.9b COMP SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBCODE (13) VO P1(1. D D 0 9 REVISION OCCURRENCE SEQUENTIAL REPORT REPORT NO. CODE NO. LER/RO 2 REPORT NUMBER COMPONENT SUBMITTED NPRD-4 PRIME COMP METHOD OTION HOURS (22 MANUFACTURER FORM SUB 2 0 0 (26) 0 0 Z 0 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) Improperly assembled spring packs in the valves' operators, resulting from a deficient maintenance procedure, 1 0 caused the operators' motors to turn off at too low of a torque value. New spring packs were installed in 1 1 the F040 and F049 valve operators, Model Nos. SMB-000 and SMB-00, respectively, and the valves were 1 2 returned to service. On October 26, 1983, appropriate revisions to the subject maintenance procedure were 1 7 incorporated to help future similar events. 1 4 80 AETHOD OF (30) DISCOVERY DESCRIPTION (32) OTHER STATUS % POWER E (28) 0 6 0 29 NA Special Investigation 1 5 80 ACTIVITY CONTENT LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35 RELEASED OF RELEASE NA NA 2 (33) 80 PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER TYPE 0 (37) Z (38 NA 0 0 PERSONNEL INJURIES DESCRIPTION (41) NUMBER NA 0 0 0 (40) IE22 11 LOSS OF OR DAMAGE TO FACILITY (43) DESCRIPTION NA 2 (42) 8406190126 84043 PUBLICITY NRC USE ONLY ADOCK DESCRIPTION 4 SSUED N NA 1111 68 6.5 919-457-9521 M. J. Pastva, Jr. PHONE .. NAME OF PREPARED



Carolina Power & Light Company

3 P12:44

Brunswick Steam Electric Plant P. O. Box 10429 Southport, NC 28461-0429 April 30, 1984

FILE: B09-13510C SERIAL: BSEP/84-0893

Mr. James P. O'Reilly, Administrator U. S. Nuclear Regulatory Commission Regior II, Suite 3100 101 Marietta Street N.W. Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT 1 DOCKET NO. 50-325 LICENSE NO. DPR-71 SUPPLEMENT TO LICENSEE EVENT REPORT 1-82-116

Dear Mr. O'Reilly:

In accordance with Section 6.9.1.9b of the Technical Specifications for Brunswick Steam Electric Plant, Unit 1, the enclosed supplemental Licensee Event Report is submitted. The original report fulfilled the requirement for a written report within thirty (30) days of a reportable occurrence and both are in accordance with the format set forth in NUREG-0161, July, 1977.

Very truly yours,

Clif

C. R. Dietz, General Manager Brunswick Steam Electric Plant

OFFICIAL COPY

RMP/jlh/LETJH1

Enclosure

cc: Mr. R. C. DeYoung NRC Document Control Desk