

6-14-84

Docket: 50-298

Nebraska Public Power District
ATTN: J. M. Pilant, Manager, Technical
Staff-Nuclear Power Group
P.O. Box 499
Columbus, Nebraska 68601

SUBJECT: EMERGENCY PLAN AMENDMENTS REVIEW

Gentlemen:

The Region IV staff has completed review of the emergency plan changes which you submitted to this office by letter dated March 30, 1984.

The emergency plan changes do not appear to decrease the effectiveness of the Cooper Nuclear Station (CNS) emergency preparedness and response and, therefore, appear to comply with the requirements of 10 CFR Part 50.54(q).

There are several areas which need to be clarified or additional information provided:

1. Tables 4.1-3 and 4.1-4, under CNS actions, second paragraph should have the Media Response Center.
2. Section 5.1.2.A, "Emergency Director," (ED) is to provide management expertise to a particular operational emergency situation; he will spend the majority of his time in the control room.

The ED should be in the Emergency Operation Facility (EOF) or Technical Support Center (TSC), depends on the emergency class.

3. Figure 5.3-1A, the resident inspector will be in the control room; NRC response personnel will be in the TSC and the EOF.
4. Section 6.1.1.3, identify how General Office personnel are contacted, other than telephone, during off duty hours. This is to include General Office personnel that are designated as essential CNS backup personnel from the General Office.

EP *Cen*
CHackney/lr
6/8/84

ER&PS *JOB*
JBBaird
6/11/84

DRS *RLB*
RLBaird
6/12/84

PSA/RPBI *JJA*
JJaudon
6/13/84

RPBI *W*
EJohnson
6/13/84

AD 48
Not
RTV
1/0

8406190133 840614
PDR ADCK 05000298
F PDR

5. Section 6.1.2, the term exclusion area should read, "the protected area."
6. Section 6.1.2, should include activation of the General Office and Media Response Center.
7. Section 6.1.2, identify where the alternate assembly points are located.
8. Section 6.4.3, exclusion area should read, "the protected area."
9. Figure 8.1-1, General Office personnel column should have ** to match foot note.
10. Appendix D, provide updated copies of current letters of agreement or certification that letters are current.

If there are any questions in regard to these comments, please contact Charles Hackney (860-8188).

Sincerely,

E. H. Johnson, Chief
Reactor Project Branch 1

cc w/encl:
Paul V. Thomason, Division Manager
of Nuclear Operations
Cooper Nuclear Station
P.O. Box 98
Brownville, Nebraska 68321

bcc to DMB (A045)

bcc distrib. by RIV:

RPB1
KANSAS STATE DEPT. HEALTH
NEBRASKA STATE DEPT. HEALTH
J. T. Collins

Resident Inspector
Section Chief (RPB1/A)
R. Denise, DRS&P

C. Hackney
J. Montgomery
R. Bangart
RIV File