

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

- - -

CONFERENCE

NPC STAFF - GPU NUCLEAR TMI

- - -

7735 Old Georgetown Road
Room 6507
Bethesda, Maryland

Tuesday, 5 May 1984

The above-entitled meeting was convened at 10:00 a.m.

P R O C E E D I N G S

1
2 MR. THOMPSON: We're ready to roll.

3 Good morning, gentlemen. Welcome to sunny
4 downtown Bethesda.

5 The subject today is in-service testing of pumps
6 and valves.

7 We are going to address this subject in the format
8 of the two memos that were attached to the meeting notice
9 April 8, 1982, and May 2, 1984.

10 To bring us up to speed, let me just recap where
11 we are in ISG and see if everyone agrees.

12 We issued Amendment 71 in August 1981, and that
13 contained a list of reliefs granted and a list of reliefs
14 not granted, pending additional information from the
15 Licensee.

16 Then, we received three additional submittals, as
17 identified on the May 2, '84 memo -- September of '81,
18 December of '82, and March of '83.

19 And this discussion today is addressing the
20 comments that we have on those three memos.

21 The one topic that I believe we're not going to
22 be addressing is the request to endorse the 1980 version of
23 the ASME code.

24 Is that correct?

25 MR. PAGE: I believe so.

1 MR. THOMPSON: Pending in September is your
2 submittal for you next 120-month program. And at that time,
3 I believe we'll be looking at -- we expect to be looking at
4 the endorsement of the 1980 version of the code.

5 MR. PAGE: We are working on a previous '74 model,
6 and what it amounts to is this voluntary update, as indicated
7 in the May 2nd memo, which has not received any type of
8 review.

9 10CFR50 requires such updates -- require Commission
10 approval.

11 MR. COLITZ: Maybe you could clarify that for us,
12 because the NRC approved that latest edition of the code. If
13 we chose to adopt it -- we basically sent you a letter some
14 time ago indicating that.

15 MR. PAGE: That's correct. Just because you chose
16 to adopt something doesn't mean that it's automatic. It is
17 subject to the review and approval --

18 MR. COLITZ: Even though the NRC basically has
19 approved that code?

20 MR. PAGE: That's correct. It's right here in
21 this 50.55. It states it very clearly.

22 MR. COLITZ: You're saying the program we should
23 still be implementing at the plant is the '74?

24 MR. PAGE: That's according to the law.

25 MR. KNIGHT: We haven't heard back since our

1 December 7th letter notifying you we were going to get the
2 1980 edition. We haven't heard anything to that effect. We
3 haven't heard anything one way or another.

4 MR. PAGE: You don't work with 10CFR50?

5 MR. KNIGHT: 10CFR50 55(a) --

6 MR. CHERNEY: The paragraph he quoted in the
7 memo specifically indicates if you're going to use an addi-
8 tional addenda other than the one that is mandatorily re-
9 quired for your 120-month interval, that requires Commission
10 approval.

11 MR. COLITZ: Rick, have all our procedures been
12 changed back to '74? To the '80?

13 We updated everything to the '80. And our
14 present surveillance program is basically March into the 1980
15 code.

16 Is what you're telling me here, if I read you
17 correctly, I should go back and rechange all the procedures
18 back to the '74 code?

19 MR. CHERNEY: Why don't we leave that as kind of
20 an open issue to get back to. I don't think we should get
21 bogged down on it.

22 MR. PAGE: I think it's important for you to read
23 this particular paragraph of the 10CFR50, which very clearly
24 states such updates require Commission approval.

25 MR. SHIPMAN: Could you give us that reference

1 specifically again?

2 MR. THOMPSON: It's my understanding that that's
3 what you will be endorsing in the next 120 months' update.

4 And what we're looking at here is relief
5 requests that are still outstanding. And the reason we're
6 looking at these now, even though they will only theoretically
7 remain valid for a couple of months, is that these are the
8 same relief relief requests that you will need or want for
9 the next 120-month program.

10 That's correct. I think we all are pretty much in
11 agreement on that.

12 MR. PAGE: We really don't think it will be a big
13 sticking issue, to be quite honest.

14 MR. CHERNEY: This is a little bit analogous, I
15 think, to things that come up under -- in the licensing
16 review, a plant going through a licensing -- when you're
17 talking about additions and addenda of Section 3.

18 Quite often people will write in and say, "Hey,
19 you've endorsed such-and-such addenda in the latest version
20 of 10CFR. However mandatory. Section 3, for our particular
21 component is such-and-such, and we'd like to update this later
22 addendum," which is two or three years later.

23 Those always have to be approved on a case-by-case
24 base. So, I think it's quite analogous to that.

25 MR. THOMPSON: This is Bob Bosnak who just came in,

1 who is a branch chief, Mechanical Engineering Branch.

2 Bob, we're just covering background. And I think
3 we're ready now to move on to having the Licensee go through
4 each of these items one by one.

5 What we're intending to do now is to try to cover
6 them rather quickly. When we get into difficulties, we're
7 going to set them aside for later and keep moving on with the
8 goal of having, in the next couple of hours -- trying to get
9 through the entire list.

10 MR. KNIGHT: First of all, I'd like to introduce
11 our people to be in our part of the program.

12 Are we ready to do that?

13 MR. THOMPSON: I think so.

14 MR. KNIGHT: Starting in the back of the room,
15 this is Joe Bashista, mechanical engineer at the site --
16 TMI-1 site.

17 Rick Barley is next to Joe. Rick is our lead
18 mechanical engineer.

19 Henry Shipman, on his right, is senior operations
20 engineer.

21 Then, at the end, Joe Colitz is the TMI-1 plant
22 engineering director.

23 Then, on Joe's left, is Gary Capodanno, systems
24 director in Parsippany, New Jersey.

25 And to my right is Julian Abramovici, who is the

1 piping engineer and manager in Parsippany.

2 My name is Bob Knight. I'm senior licensing
3 engineer, TMI.

4 So, Joe has the rest of the program for TMI.

5 MR. COLITZ: In addition to what Bob says,
6 Joe Bashista and Rick are the two people at the plant that
7 have dealt most heavily with the IST program over the past
8 few years. That's one of the main reasons for bringing in
9 the Operations Department -- is all of the tests we wind up
10 committing to in the IST program. Most of the other
11 surveillance program -- it's he and his people that live
12 with the implementation of these procedures.

13 We made our submittal in March of '83, and we did
14 get the concerns that you people have on some of the relief
15 requests that we requested.

16 We spent a considerable amount of time in the last
17 two weeks reviewing, revisiting all of these relief requests.
18 We felt the best way to go through these is to take them one
19 by one.

20 We have prepared a presentation, and Julian is
21 going to be the main presenter.

22 Rather than just hit the issue, we felt it would
23 be good to go into a little more detail on what we have in
24 the way of systems and how they are configured.

25 And some of the things we do now, they kind of add

1 to some of the reasons we have come in for relief requests.

2 So, Julian, I turn it over to you.

3 And I agree, I think if we spend more than
4 10 minutes on any one item, we are probably getting bogged
5 down, we ought to go on to the next and table that one if
6 we plan to get through all 20 of them in a three-hour or so
7 period.

end 1

- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

21b1

1 I guess the first one I want to clarify, although
2 we don't have a slide on them, your item A-1, where we
3 talked about adding flow measuring instruments before
4 startup from the sixth refueling outage. You basically said
5 something there, it's our understanding that the next
6 refueling outage would be this cycle .5 outage and therefore
7 we consider this proposal as acceptable.

8 Cycle 6 refueling can be interpreted to be the
9 refueling outage after cycle 6. Then you talk about the
10 refueling outage will be -- the next one will be refueling
11 outage cycle 5. I'm not sure what you meant by that.

12 MR. PAGE: Can you clarify first which one is
13 which?

14 MR. COLITZ: We have planned basically on putting
15 that one in at the end of cycle 6, which would be at the
16 end of the cycle 6 refueling outage.

17 MR. PAGE: You're going into cycle 5?

18 MR. COLITZ: 5 now.

19 MR. PAGE: Basically, you're talking about two,
20 two and a half years?

21 MR. COLITZ: Yes.

22 MR. PAGE: There's no possibility for the upcoming
23 outage?

24 MR. COLITZ: It's just a matter of the number
25 of mods that we can continue to do to TMI is horrendous.

21b2

1 We've already got such a chokka block of mods for the
2 cycle 5 refueling outage on the book. We're trying to
3 manage these things in a reasonable time frame and that's
4 why we're committed to what we did there.

5 MR. PAGE: Personally, I still feel that's okay.

6 MR. COLITZ: Okay, Julien, the next one was item
7 A-2. I'll turn it over to you.

8 MR. ABRAMOVICI: What I would like to do on
9 every item is go through pretty much where the component
10 in question, what the service is, and go through -- you know,
11 functionally, what our backups are and so on, so everybody
12 understands what the component function is.

13 (Slide.)

14 Okay, the items in question were Item A2 CA-P1A
15 and CA-P1B are one of the duration sources to the reactor coolant
16 system via the makeup tank into the makeup pumps and
17 through the RCS. Additionally, borated water can be provided
18 from the reclaimed boric acid tanks, where we have two pumps
19 available in that system. And additionally, we have the three
20 reactor coolant heat tanks, two of which are at or about
21 reactor coolant boron concentration. There are three
22 pumps in that system, and any tank can be used with any pump.

23 The accident mitigation borated water source is
24 the borated water storage tank, which via the HPI pumps go
25 to the reactor coolant system.

21b3

1 Any questions on the alterante path of the
2 boration water for the RCS?

3 (No response.)

4 (Slide.)

5 Now I would like to go through the basis for our
6 exemption of request for deleting this item from the IST
7 program. We have a high degree of redundancy, as shown on
8 the previous slide. We have two boric acid mix pumps. We
9 have two reclaimed boric acid mixed pumps and only one
10 out of four is needed for normal plant operation.

11 Additionally, the borated water can be provided
12 from the bleed tanks which, again, at least two have borated
13 water in it. The other one usually has demineralized
14 water to make up the changes in PCS water and control.

15 We do have an operational test that occurs
16 periodically, whenever the pumps are in use.

17 Per Section 11, the chemical addition pumps are
18 powered from a safety grade, but they are only for convenience.
19 Section 11 recognizes, in paragraph IWP 1200B, that it can
20 be exempted from the code if they are for operating convenience
21 only. Additionally, in our FSAR, in Chapter 14, those pumps
22 are not included in any accident mitigation scenario. And as
23 I mentioned, in the previous slide, the borated water storage
24 tank is the accident mitigating water source and not the boric
25 acid mix tank.

21b4

1 Any questions?

2 MR. PAGE: Have you got a copy of your own tech
3 spec 3.2.2?

4 MR. THOMPSON: They've come in with a mod, a
5 revision, on that. Just in process right now. It hasn't
6 been approved.

7 MR. BOSNAK: It's an operability unit.

8 MR. PAGE: In other words, the operability that
9 he's describing right now is under a request, an open request,
10 to the NRC?

11 MR. COLITZ: The tech spec 3.2.2 there, where
12 it says one of any four of those pumps needs to be required
13 for operation, is the existing tech spec.

14 MR. PAGE: What I'm trying to straighten out here
15 is, under 3.2.2(a) and (b), the last sentence in each
16 section. And it says one boric acid pumps shall be operable,
17 one reclaimed boric acid pump shall be operable.

18 MR. ABRAMOVICI: I thought that said "or?"

19 MR. PAGE: You're saying any one of the four.
20 And if you don't do IST testing of these pumps, how can even
21 one of four be operable?

22 MR. ABROMOVICI: We haven't done a probabilistic
23 analysis, but we are fairly confident, since you need only
24 one out of seven, actually, and additionally the borated
25 water storage tank is the source for the accident mitigation.

1 MR. PAGE: I thought the discussion here was
2 one of four pumps?

3 MR. ABRAMOVICI: One of four for tech spec. One
4 of seven available, from a plant standpoint, from an operating
5 standpoint. Let me put this slide back up again.

6 (Slide.)

7 MR. PAGE: Even if the argument were one of seven,
8 how could you say that one of seven is operable, if they're
9 not all tested? After a long period of time, how do you
10 know if the component is operable indeed?

11 MR. ABRAMOVICI: Those pumps do get in operational
12 service. They're being used in the service to make up water.

13 MR. PAGE: Why not say you have six of them on
14 the bare bones edge of falling apart? They'd be running.
15 Would they make an accident run?

16 MR. ABRAMOVICI: They're not required in an
17 accident mitigation scenario.

18 MR. PAGE: None of them are, but they're required
19 to be operable. At least one of these four. I don't agree
20 with the argument, personally.

21 MR. SHIPMAN: What is different about, I believe,
22 what you offered Mr. Thompson was the tech spec change requested
23 is now under review for operability definition. We have an
24 operability definition in our tech spec now. We've been
25 requested to modify that to make it more current to what is

21b6

1 acceptable. The definition of operability, by the tech
2 spec change request that has been submitted is not affected
3 by this test. In other words, I can define that pump as
4 being operable outside the realm of this test.

5 MR. PAGE: How do you do that?

6 MR. SHIPMAN: By meeting the words that are defined
7 in operability?

8 MR. PAGE: Could you tell us what those words are?

9 MR. SHIPMAN: I think the words are, to paraphrase,
10 the pump will perform its intended function -- and this is
11 the old definition, is what I'm giving you, which is what I've
12 got in my head now. It will perform its intended function
13 within the design range when called upon. Something to that
14 effect.

15 MR. PAGE: Do you have something to verify --

16 MR. SHIPMAN: I have other things that would
17 verify that that pump would perform its design function
18 within the required range.

19 MR. PAGE: But it's not IST?

20 MR. SHIPMAN: It does not necessarily have to be
21 IST, from my point of view.

22 MR. THOMPSON: Let me see if I understand what
23 you're saying. A pump that is required to be operable does
24 not necessarily have to be part of the IST program? Is that
25 what you're saying? The tech specs call for operability on

21b7

1 these pumps under certain circumstances. And you're saying
2 that they still don't have to be in the IST program because --
3 and I don't know what the because is.

4 MR. CHERNY: I'd like to back up one step further.
5 Why are they required to be operable if they don't take credit
6 for them for any accident scenario? That doesn't make sense to me

7 MR. SHIPMAN: The issue that we're discussing is
8 the basis for the IST program and how we judge components
9 to be required to be in that program versus the criteria
10 that was established for here is your tech spec and here
11 is what has to be in your tech spec.

12 MR. CHERNY: You're saying they are two different
13 criteria?

14 MR. SHIPMAN: I'm saying the development of this
15 two different systems were not concurrent. And therefore,
16 there are idiosyncrasies within the two programs that need
17 to be evaluated on a case by case basis. And judged on their
18 merits, on a case by case basis, as to what the real require-
19 ments are, to satisfy the IST program, as defined by the ASME
20 code.

21 MR. BOSNAK: I think as far as we're concerned,
22 the bottom line is do you need it for accident situations?
23 Do they have to be listed in the tech specs? And if they
24 do, then you get into operational readiness, which is in the
25 regulations, Part 50.55(a) and (g). And if you get into

21b8

1 operational readiness, you're into the IST Program. So I
2 guess the question we're asking you is do you need these
3 pumps to respond to any of your postulated accidents?
4 And therefore, are they required to be tech specs?

5 MR. CHERNY: The answer to those two questions
6 apparently are different. No, they don't need them for
7 accident mitigation. Yes, they have to be in the tech specs.
8 And that doesn't make sense to me.

9 MR. BOSNAK: No, and that's what I don't under-
10 stand.

11 MR. PAGE: If I could break in for a second, could
12 I read -- this is a little bit long here. I have the tech
13 spec bases here. It talks about different ways to add boron
14 to the reactor coolant system. It says the primary method is
15 to pump concentrated boric acid solution into the makeup
16 tank, using either the 10 gpm boric acid pumps or the reclaimed
17 boric pumps. Using only one of the two boric acid pumps, the
18 required volume can be injected in less than 13 hours.

19 An alternate method is to inject from the borated
20 water storage tank -- those sound like accident scenarios
21 to me. I wouldn't imagine that just being normal run of
22 events. But it sounds to me like the discussion is right
23 down the center of some sort of scenario, where you have to
24 -- and then they're talking about with the single failure, even
25 with the rod stuff. One step control assembly.

21b9

1 MR. COLITZ: Again, in going back to our accident
2 analysis, people -- and I think he had it up there, in the
3 presentation, that none of the Chapter 14 accident analyses,
4 failure scenarios, take credit for these pumps, okay?
5 Basically, the BWST with the high pressure injection and
6 low pressure injection pumps. That's the source we take
7 credit for. We do agree that the boric acid, and the reclaimed
8 boric acid pumps, are in the tech specs and requires one of
9 four to be operable. Normally, we use those for normal
10 makeup to the makeup system during plant operations.

11 MR. BOSNAK: We probably need to bring other people
12 into this discussion at some future time.

13 MR. CHERNY: We'll have to get our systems people
14 to look in.

15 MR. COLITZ: The other thing, also, if you are
16 going to test those pumps, you're looking like -- we know
17 we're injecting into the reactor coolant system makeup tank
18 during normal operations, as part of boron control. If you're
19 going to test those right again, it's into plant modifications
20 which we have a very hard time justifying adding additional
21 plant modification --

22 MR. BOSNAK: What's the plant modification that you
23 need?

24 MR. COLITZ: You probably need to have recirc line
25 with flow instrumentation.

21b10

1 MR. PAGE: Why would you need flow instrumentation
2 on the recirc line?

3 MR. COLITZ: One other point that I guess I would
4 like to -- I was maybe going to save it for the end, when
5 we have a wrap up, but I'll bring it out now because I think
6 it flows through all of these. It is, if you look at any
7 one of these tests as a separate test, a lot of them whether
8 they are required or not required are nice to do things if
9 you look at them separately.

10 One of them -- my main concerns, as you go through
11 these, we are to the point now where we have the operations
12 department in a constant surveillance mode. And if we really
13 want ops to surveil we better make sure what they are surveilling
14 is required and really are the most important items. Because
15 I think, in some cases, we have them doing surveillance.
16 You can't really meet the whole intent, so you kind of come
17 up with something that gets close to proving what you want
18 to prove.

19 And I think we have them out there doing a lot of
20 testing. A lot of it is during heatups, when you're also
21 doing ES testing. They're trying to control the plant. I
22 think we're allowing taking them at a point where I'm concerned
23 that we have them focusing so much on surveillance right now
24 they're forgetting about the overall heatup, some of the
25 important PSA, reactor protection system tests that

21b11

1 .. take place during these things,

2 You look at that on a case by case basis. That
3 doesn't become a very good argument when you look at the
4 total scope here, and this is just one area we're looking
5 at additional surveillance. It's going on in every other
6 area. There's a real safety concern there that I think we
7 need to weigh, on do we have them concentrating and working
8 on really important surveillance or these nice to have type
9 things that are adding to their overall responsibility in
10 running a plant.

11 MR. THOMPSON: Joe, is that like saying you've
12 got seven pumps there and you only need one of them possibly
13 and that you've got enough that you really don't need to
14 surveil any of them because probabilistically surely one of
15 the seven is going to be operable. Is that sort of a
16 layman's summary?

17 MR. COLITZ: That's true. And we have meetings
18 daily. As soon as we find an indication with a problem with
19 a pump, we correct the maintenance department. There's a
20 pm program in all of these pumps, so it's not like that
21 pump is sitting down there for years without any attention
22 and all of a sudden it craps out and we may not even worry
23 about that then because we know there are six more.

24 So there's other additional arguments and programs
25 at the plant. I think in all of these pumps a certain degree

21b12

1 of special attention because they're tech spec pumps and
2 they are in the pm program.

3 MR. PAGE: I think we understand the one out of
4 seven argument, which I don't think is really included in
5 your tech specs because it should say one out of seven,
6 if that's the situation. But it doesn't even tell you how
7 you show one. No one really discusses what do you do if you
8 don't do IST. There's something that you said -- I forgot
9 your name back there, but there's some sort of testing
10 operational running, or whatever.

11 MR. SHIPMAN: The normal activities that you do,
12 if you look at just the boric acid mix tank for a moment.
13 The boric acid mix tank we use as a source tank to mix the
14 boric acid to make up the different other tanks. Thereby
15 those tanks and the pumps on the tank and the mixer and the
16 heaters, everything in that system is periodically, routinely
17 used to perform routine operations.

18 If you look at the reclaimed boric acid tanks,
19 there are requirements -- management requirements -- to sample
20 the tank. To sample the tank, we always put the tank on
21 recirc, which tests the pump. And the components in that
22 recirc path.

23 MR. CHERNY: You said tested. It turns them on
24 but you don't record pressures, blow rates, and all those
25 good stuff, do you?

1 MR. SHIPMAN: That's correct. We wouldn't, in
2 those routine evolutions. We would not be looking for
3 discharge pressure, per se, other than the operator would
4 start the pump, assure he has got discharge pressure, he
5 would not be comparing it to what he would routinely see
6 there to make sure that the pump is operating to his
7 satisfaction, that when the tank has been recircled, we have
8 assured ourselves that the tank, in fact, is on recirc.

end2

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 It's not a very documented evolution, which I
2 think your point was.

3 MR. BARLEY: These are positive displacement
4 pumps.

5 MR. THOMPSON: I see about four points that
6 you're making here.

7 One is, to do this IST, would require plant
8 modifications.

9 You indicate a potential problem with overdoing
10 the IST, too many things to test.

11 The point is that you do use these pumps -- all
12 seven of them -- frequently and do a subjective check during
13 regular use.

14 And the fourth point is that you've got many
15 redundancies, in other words seven pumps, of which you might
16 only need one, and also claim that it's not needed for
17 accident scenarios, which we didn't really get any agreement
18 on.

19 Is that about the five points that are being made?

20 MR. CAPODANNO: Yes.

21 MR. BARLEY: The other basic point I think ought
22 to be made on here is the design flowpath through the system
23 is to inject boric acid into the reactor.

24 To do the Section 11 work required sort of testing,
25 and that system requires you get boric acid into the reactor

1 -- which has associated reactivity effects and is a plant-
2 controlling test.

3 MR. PAGE: You're saying the way it's built now?

4 MR. BARLEY: Yes, the way the system is built now.

5 That's one of the major reasons that we have a
6 problem doing that test, because of the resultant effect on
7 the reactivity in the reactor in doing that test.

8 MR. PAGE: And these components here are only
9 attached to safety-grade power source for convenience only?

10 If you need one out of seven, how can that be
11 convenience?

12 If you have to have one, I can't consider that a
13 convenience-type connection.

14 MR. SHIPMAN: I think the point is the one out of
15 the seven that is required -- correct me if I am wrong,
16 Julian -- I thought that was the borated water storage tank
17 and is associated with the valving and pumps that get into
18 the reactor coolant system. **And those** are in IST program.

19 MR. ABRAMOVICI: The low-pressure injection,
20 high-pressure injection have built-in spray. They all take
21 suction from the borated water storage tank. That is the
22 water source, and that has a tech spec limit on the boron
23 concentration and the boron.

24 MR. PAGE: It seems to me a tremendous inconsistency
25 between the story you're giving and what your tech specs seem

1 to reflect, why these components need to be operating.

2 MR. ABRAMOVICI: One point I would like to make --
3 and correct me if I'm wrong -- is I think the tech specs were
4 written at a time when in-service testing for Section 11
5 didn't even exist or it wasn't about to come into existence.

6 MR. PAGE: My understanding was that was the
7 early spec before Section 11 was created, that they put that
8 stuff in the tech specs, which they felt were needed for
9 safety reasons.

10 Correct me if I'm wrong. That has been my
11 understanding of the early tech specs. They didn't have a
12 Section 11 to put in there.

13 MR. BARLEY: What Julian was referring to was the
14 tech spec on the boric acid pumps, the one out of four tech
15 spec. The 33.2 tech spec predates the issuance of any
16 version of Section 11.

17 MR. SHIPMAN: From the aspect of inconsistencies,
18 I think those inconsistencies need to be addressed -- no
19 question about it -- on a case-by-case basis, so that we all
20 understand the basis for the tech spec and the basis for the
21 IST program.

22 MR. BOSNAK: I think that's the way -- we're going
23 to recommend we resolve the inconsistencies and change the
24 tech specs. Therefore, there would be a basis for removing
25 this from the IST program.

1 But we do have to consult with the tech specs
2 people and our systems people to confirm all that.

3 I think that's the way we can proceed on this one.

4 MR. CHERNY: I think we're going to need to check
5 with the systems people.

6 We might as well go on to the next item.

7 MR. PAGE: Right.

8 MR. ABRAMOVICI: May I proceed?

9 (Slide.)

10 The next items for discussion -- the next three
11 items that will be coming up for discussion have to deal with
12 Event V from WASH-1400.

13 I would like to at least give a GPU interpretation
14 of what Event V is and a common evaluation for the following
15 three items.

16 Again, our interpretation is Event V deals with
17 two active valves in series in a high-pressure system failing
18 and allowing the low pressure of the system outside the
19 reactor building to be pressurized to reactor coolant
20 pressure, therefore causing a LOCA outside the reactor
21 building.

22 Event V was analyzed for TMI by Franklin Research
23 Institute Center for NRC and was submitted October 24th,
24 1980.

25 And the above analysis did not include any of the

1 following valves: the RC-V4 and 23, DH-VI and DH-V2,
2 MU-V107A through D, 94, 95, and 86 A and P.

3 It's worth mentioning that that evaluation -- as
4 a result of that we did make modifications to the plant for
5 other valves.

6 MR. PAGE: You restricted your discussion to the
7 Event V, pressure isolation valves only, the ones you
8 received an order on?

9 MR. ABROMOVICI: You will receive an order on one
10 of them.

11 MR. PAGE: My understanding is, on the operating
12 plants -- and you guys are probably familiar with what
13 happens on the new plants -- all these valves will definitely
14 be in there in your tech spec right off the bat, not just the
15 Event V group but the entire group of high-pressure, low-
16 pressure interface valves to the reactor coolant system.

17 MR. CHERNY: We have been asked, during the IST
18 reviews, to go back and pick up the Event V pressure isolation
19 valves and make sure that they are in the program and they
20 can be tested.

21 We can see they're not Event V valves. That's not
22 really a problem.

23 MR. ABRAMOVICI: I'm going to go through each and
24 every one on a separate -- this was a common slide for all.

25 (Slide.)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

The item B1 deals with RC-V4 and 23 on a pressurized spray line from decay heat system. This is not normally used during operation. It is isolated and outside the reactor building.

There is a locked, closed valve.

end 3

1 (Slide.)

2 Our bases for exemption requests are as follows.
3 During normal power operation at pressure the valves are
4 inactive. Any time the pressure is greater than 400 psig,
5 both of those valves are closed and do not serve any function
6 other than isolation.

7 They are active during boron precipitation mode,
8 however at that point the system pressure is less than the
9 400 psig and the entire system including inside and outside
10 reactor building is adequate for that pressure.

11 The second argument is that the valves' leakage
12 through those valves will be identified as part of the RCS
13 leak rate calculation, which is performed of course in
14 accordance with the tech specs. A leakage which would exceed
15 the tech spec limit is found within the relief valve upstream
16 of the subject valve.

17 (Slide.)

18 This might -- I'll put this back up again: DH-V67
19 has more than adequate capacity to take care of any tech spec
20 limit. The leakage from DH-V67 goes to the reactor coolant
21 drain tank and it is part of the identified leakage.

22 MR. PAGE: Could we stop on just that argument
23 here. I think we can cover a couple of basic concerns there.
24 First of all, you are testing in series, testing
25 more than one barrier at the same time.

1 MR. ABRAMOVICI: As part of the leakage count
2 that is correct.

3 MR. PAGE: One behind the other. So if you are
4 missing one of two valves, say the valve is disassembled in
5 the line, how did you know that that was -- how would you
6 know the valve wasn't there?

7 MR. ABRAMOVICI: In other than normal routine
8 maintenance plant control, you would not know that the valve
9 is there but if one valve is not there the other valve would
10 leak gradually, increasing to some limit, and it would be
11 picked up as part of the tech spec surveillance for leakage.

12 MR. PAGE: You are saying even if you had a single
13 barrier and you had already suffered a gross failure of one
14 valve, which subjects you by the way to single failure in
15 your second valve, that is the whole point of what we are
16 trying to get here is that we need two barriers.

17 MR. ABRAMOVICI: I think we are getting to the
18 third point, but we do have a backup check valve inside
19 containment and if both valves would fail, you know, open,
20 total failure, there is a very high probability that the
21 break would be inside the reactor building.

22 MR. PAGE: We understand that. We are trying to
23 prevent those too. This is the PRVs that are not -- these,
24 but it is obvious these blowdowns would be inside the
25 containment. That was the concern I believe we were directed

1 to handle in our normal review as opposed to sending an order.

2 I believe the ones that penetrate the containment
3 you could get an order on, which I believe was put in your
4 tech spec.

5 MR. BARLEY: Yes.

6 MR. CHERNY: Is valve DH-V69 a low pressure design
7 valve?

8 MR. ABRAMOVICI: That is a low pressure design
9 valve. I think high pressure - low pressure is here.

10 MR. CHERNY: What is the capacity of DH-V67?

11 MR. ABRAMOVICI: 36 gpm, 36 or 37 gpm.

12 MR. PAGE: The reason we normally don't let people
13 take credit for the relief system is that we are really not
14 concerned about the leakage in terms of leakage, but rather
15 as a precursor to a gross failure of the check valve. It
16 is the only think we have to determine a check valve condition.
17 For an MOV you have many other tests that can give you
18 information about the motor operated valve to assess whether
19 the internals are beginning to have problems.

20 Check valves we found so many disassembled in lines
21 for no apparent knowledge, no one knew about them. That is
22 the reason. I don't know if you are familiar with why we
23 use leakage.

24 You know, it is not really the leakage itself but
25 rather that it is a precursor to some sort of gross problem

1 inside the valve.

2 The values that we pick for leakage of course are
3 somewhat arbitrary and we are working on this right now, but
4 to date, I don't think we have accepted credit for the relief
5 systems because if you did have a gross failure, that relief
6 system would be useless instantly.

7 MR. ABRAMOVICI: That is true.

8 MR. PAGE: You would be so overwhelmed so quickly --

9 MR. ABRAMOVICI: Yes. If you had total failure,
10 yes, the relief valve would not take --

11 MR. PAGE: That is what we are really trying to
12 determine by this testing. That is where we are coming from.
13 We realize it is not perfect. It is far from perfect. We wish
14 there were better ways to do it, but that is about the only
15 handle we have on check valves, leak testing or reverse low
16 testing, however you want to determine that.

17 MR. CHERNY: You are emphasizing check valves an
18 awful lot. We require that the gate valves be checked too.

19 MR. PAGE: I am saying the check valves are far
20 more of a concern. I think we have experienced so many that
21 were disassembled and they haven't been tested for years.

22 There was never anything wrong with them -- that
23 is what I meant. We have less to look at in check valves.

24 MR. CHERNY: What is involved in being able to
25 leak test these two valves?

1 MR. ABRAMOVICI: I think to test those valves
2 require a major quantification, providing test actions, pumps
3 and so on.

4 MR. COLITZ: When we got the order to test CF-V4A,
5 DH-V5A, DH-V22, I think we spent close to a hundred thousand
6 dollars modifying the plant with connections, flow-ending
7 site glasses collection drums. I don't have the specifics
8 of those test right now to enable us to do those tests.

9 Again, they are done during heatup, which is a
10 controlling mode of the plant.

11 We also have still running those tests a safety
12 concern. Any time you have individuals collecting or standing
13 by to collect any leakage on an individual valve at tempera-
14 tures above 180 degrees or something, we get into real safety
15 concerns with our people.

16 So I guess you know to test these valves we would
17 probably have to have similar type connectors, drain lines
18 and so forth, where somebody could collect or monitor the
19 leakage past a specific valve.

20 MR. CAPODANNO: I think there is one other signifi-
21 cant difference here. The ones that Joe just mentioned just
22 be virtue of the piping arrangement, were fairly easy to
23 check. We had flooded lines connected to vessels that could
24 be pressurized to do a back leak check.

25 You will note from the diagram that is being

1 displayed, it is not that simple with this since this line
2 discharges into the vapor space of the pressurizer.

3 So it may quite likely be even more complex in the
4 one modification we did make.

5 MR. BARLEY: You can take that up to any significant
6 pressure requires the reactor coolant system be relatively
7 warm to get away from the MPD concerns in the reactor vessel.
8 to get it up to any significant pressure that would seat the
9 valve and do a valve relief check on it, so again you are
10 controlling the plant to pressurize the entire reactor coolant
11 system, to test this check valve for leakage.

12 You would be forced then to deal if you have any
13 leakage with the test connection you would be forced to deal
14 with high temperature, radioactive water, which produces
15 personnel safety concerns.

Side 2 BU 16 MR. CAPODANNO: I think the one thing we want to
17 emphasize again is the fact that this line is normally closed.
18 I think the previous slide said this thing is just not open
19 at pressures above 400 pounds.

20 MR. CHERNY: How much of a problem would it be to
21 do some other tests, other than leak testing to verify that
22 both valves are in a closed position?

23 Obviously if the valves are always closed and if
24 while you were shutdown, they verified they were closed, that
25 wouldn't be such a bad test for this particular configuration.

1 It is not like a case for example of decay heat
2 removal system isolation valves where you are operating those
3 things right until you isolate the system and go up to power.
4 These things, as you say, are basically always closed.

5 MR. BARLEY: We do stroke time, the RC-V4 the valve
6 is open and closed.

7 MR. CHERNY: That is done on a quarterly basis?

8 MR. ABRAMOVICI: That has got to be cold shutdown.
9 It has got to be below 400 psig before you can open the
10 valves.

11 MR. CHERNY: I am a little bit hung up on how we
12 are going to resolve this before we continue. We are going
13 to require that they be individually tested. Now it is a
14 question of mutually agreeing what those tests are going to
15 be.

16 We have no relief from our management to do other
17 than make sure those are individually tested, so what I am
18 trying to find is maybe we can find some other tests that
19 can be done if heat testing is a big problem.

20 MR. COLITZ: What is the requirement for these?

21 MR. CHERNY: Taking credit for two barriers between
22 the high and low pressure system, that is the basis for the
23 testing.

24 MR. COLITZ: You are saying it is a code require-
25 ment or NRC management requirement or what?

1 MR. CHERNY: NRC management requirement.

2 And as Joel was trying to say, if it was a new
3 plant, those would be tech spec valves. They'd be on the list.
4 No plant gets a licence anymore without committing to individual
5 leak test valves of that type.

6 MR. BOSNAK: The order went down just to separate
7 the event V configuration.

8 MR. CHERNY: Event V they thought had to be handled
9 in a little bit quicker fashion because of the outside
10 containment concern. That is why that was done that way.

11 The older plants, the management decision was made
12 at that time to pick up the rest of them as part of the
13 normalized heat review.

14 MR. PAGE: Additionally, on the new plants there
15 is a 1 gpm requirement on the leak rate which is very tight.

16 MR. CHERNY: We are not saying anything about the
17 leak rate, though. Whatever was in your Event " order is an
18 acceptable leak rate. That is really not an issue here.

19 It is the issue of getting the tests done in the
20 first place.

21 MR. BOSNAK: Perhaps you would have a way of
22 verifying that you have got some barriers. You may want to
23 think about it.

24 MR. CHERNY: When you stroke that RC-V4, is there
25 any pressure at all?

1 MR. BARLEY: We do that at low pressure.

2 MR. CHERNY: Zero psi, is that what you are saying?

3 MR. SHIPMAN: I don't think it is quite zero. I
4 think we take credit for that valve once we go on decay heat
5 removal and continue the cooldown when we open RC-V4 to
6 spray down. We do it to pressurize, I think we take credit
7 for that opening because we time that opening and that would
8 be at some pressure less than 400 pounds.

9 MR. CHERNY: I was wondering if you could do
10 something there to verify that the check valve was closed and
11 seated?

12 MR. SHIPMAN: At that time the check valves would
13 be open.

14 MR. CHERNY: It is going to have to ultimately
15 reclose again sooner or later if it works right.

16 That is something you are going to have to look
17 at, I guess.

End 4.

18

19

20

21

22

23

24

25

1 I guess what we're saying at this point is this
2 is an action item for them -- requiring leak testing or some
3 alternate individual valve test to verify that they are in a
4 closed position.

5 MR. PAGE: Do you gentlemen understand what this
6 means?

7 MR. CHERNY: They're going to have to come back
8 with a commitment or a counterproposal that satisfies the
9 requirement.

10 MR. THOMPSON: You mean after lunch?

11 MR. CHERNY: You set the schedule.

12 MR. THOMPSON: Can you come up with something?
13 Can you caucus and come up with something and figure out
14 something while we're here?

15 MR. CAPODANNO: I think there's a problem with
16 trying to do that, that usually decisions made in a hurry
17 turn out to be less than the optimum decisions.

18 I don't know, maybe somebody else can volunteer,
19 but I think our primary experience has been in a situation
20 where we have been able to pressurize across a valve. This
21 one was a little bit unique because it's open to the
22 pressurizer itself.

23 For that reason, I think we prefer to work up
24 something and get back to you with a final response to your
25 question here about what you require.

1 MR. THOMPSON: Does it seem reasonable, what
2 Staff is asking, that you come up with some method to check
3 this -- what is it, cold shutdown?

4 MR. CHERNY: I guess it has to be, from what they
5 were saying.

6 MR. BASHISTA: What acceptance criteria?

7 MR. CHERNY: The basic concern is to make sure the
8 disc are in place. The only way we know to do that for
9 99 percent of the cases is with leak testing.

10 That doesn't mean somebody with a particular
11 configuration can't come up with an alternate idea.

12 So, I'm not saying leak testing is the only way.
13 That's the only way we know of that everyone seems to be able
14 to do. And the criteria -- the leakage criteria has been
15 recommended by a whole bunch of different kinds of experts.
16 And that's kind of a lengthy story to go into here.

17 If you have another way of doing it, without
18 actually running a leak test, we'd certainly be willing to
19 look at it because, as Joel was trying to say, the real
20 concern is not leakage. It's just to make sure that the
21 disc is there in a reasonably sturdy configuration, not
22 severely degraded.

23 MR. SHIPMAN: Is valve inspection at an interval
24 that it would be realistic -- being considered?

25 MR. PAGE: Valve inspection wouldn't prove the

1 valve was closed. It would prove that it had the capability
2 to go open and to go closed.

3 But we've had them open and stay open before
4 although the valve was apparently in good condition. However,
5 if you leak-tested it, you'd find that it wasn't.

6 MR. SHIPMAN: When you say cold shutdown, any
7 meaningful test to see that it's in its closed position would
8 require pressure in the pressurizer.

9 If that pressure was steam pressure, it would be
10 an elevated temperature, even if you only have 80 pounds.
11 And we're talking about 300-and-some degrees of steam water.

12 MR. CHERNY: I don't want to get too carried away
13 on every cold shutdown. There was something in your -- I
14 guess I didn't bring that along. There was some kind of a
15 frequency of testing in the Event V order which escapes me
16 at the moment. But I don't think it was every cold shutdown.

17 MR. SHIPMAN: It was every nine months.

18 MR. CHERNY: What we were really thinking of is
19 something consistent with that.

20 I can't find it at the moment, but whatever that
21 was.

22 The new plants have to test them after each
23 disturbance.

24 MR. SHIPMAN: Do we have some experience with
25 these new plants that have tested them?

1 MR. CHERNY: We can give you some names.

2 The only thing you won't find for this particular
3 configuration is I don't think you will find that there's
4 any new B&W plants.

5 We looked the other day, and we couldn't find, on
6 the Westinghouse or ACE plant, this exact configuration
7 anywhere.

8 So, if you're looking for experience and just
9 that configuration, you may not find it.

10 But we can give you some other new plant names if
11 you want to talk to them. It would be the majority of the
12 PWRs licensed since the TMI-2 accident, starting with
13 North Anna 2, Sequoyah, McGuire, those kinds of plants,
14 Farley 2.

15 MR. BARLEY: Are there any old plants -- operating
16 plants -- that are living under the nuclear rules?

17 MR. CHERNY: We have been notoriously slow at
18 getting lengthy SERs out on IST. But I guess Farley 1 comes
19 to mind. That one wasn't too long ago -- although we're
20 under discussions with them at the moment, primarily about
21 the leak-rate thing, not so much the valve list.

22 I'm trying to think of another old plant.

23 What do we do about PRVs on Perry Island?

24 MR. PAGE: I don't think we have the argument about
25 the list.

1 MR. CHERNY: How about Calvert Cliffs?

2 Calvert Cliffs is another one that's an old one.

3 MR. THOMPSON: Can you summarize?

4 MR. CHERNY: We're on V-1, the first two valves.

5 MR. THOMPSON: Can you summarize the status of our
6 discussion here?

7 It would take major plant revisions to be able to
8 leak-test the way we're talking about at pressure, plus the
9 additional concern with personal safety if you do that and
10 you do have a leakage.

11 The next stage of the discussion went to, well,
12 we need to primarily verify that they are closed. And this
13 could be done at cold shutdown.

14 Is that right?

15 MR. CHERNY: The same frequency that they had in
16 their Event V order, which I think is less frequent than that,
17 but I'm not sure of what it is.

18 MR. THOMPSON: Some frequency.

19 And then you say choose any way you want to do
20 that.

21 The only way we know how to do it is to leak test.

22 MR. CHERNY: Yes. Right.

23 Now, we've had people talk to us, just conceptually,
24 about air or gas testing, radiography.

25 MR. PAGE: Pressure monitoring.

1 MR. CHERNY: That's another one.

2 MR. PAGE: Be aware though that we have looked at
3 some pressure monitoring schemes, and the only ones that
4 seem to be reasonable -- and there are very few of those --
5 are ones that are done at one distinct time, not continuous.

6 All the ones I've evaluated that are continuous
7 will -- you will always have an alarm, or you will never have
8 an alarm.

9 MR. SHIPMAN: Was radiography determined to be
10 acceptable?

11 MR. CHERNY: No one has tried it. They just
12 talked about it conceptually. We don't know.

13 MR. PAGE: To my knowledge, there's only one plant
14 -- did that on 8303, I believe, to prove those check valves.
15 It was either ultrasonics or radiography, I'm not sure which
16 one.

17 MR. CHERNY: I think that was radiography on that
18 one.

19 I don't know what the region was that reviewed that,
20 but the utility thought it was acceptable.

21 MR. THOMPSON: What about leak testing at low
22 pressures?

23 MR. CHERNY: That's what most people do when they
24 do leak testing, they do it at lower pressure and they
25 extrapolate to what the leak rate would be at high pressure.

1 That's what they do on Event V.

2 MR. THOMPSON: Okay.

3 MR. CHERNY: Do we want to move on to the next
4 two valves? Is that what we want to do?

5 That's their action item, I guess is the way
6 we're going to leave that for now.

7 (Slide.)

8 MR. ABRAMOVICI: The next series of valves are
9 in the high-pressure injection system. They are the MU-V107A,
10 B, C, and D; MU-V95, 94, 86A and 86B.

11 There is a low modification that really doesn't
12 affect the discussion from the slide that we have just
13 received.

14 The discharge MU-V222 comes downstream, rather
15 than upstream. It really does not affect the discussion;
16 it's just for correctness. I don't know if it came out
17 very clear, but this valve is MU-V220, not 270 -- this valve
18 right here. It's a new valve. We are going to put the HPI
19 cross-connects in. I think it came out as 220, but I'm not
20 sure what it came out on the handouts.

21 MR. PAGE: It's supposed to be 220?

22 MR. ABRAMOVICI: It is 220.

23 MR. PAGE: Okay. I see what you're talking about.

24 MR. ABRAMOVICI: Okay. During normal power
25 operation, flow is through the MU-V17, MU-V18, and to the

1 B loop, the HPI lines, MU-V16A, B, and C -- C and D are
2 normally closed.

3 On the HPI initiation, the 16 is open, 18 closes,
4 and the flow goes through these four loops.

5 (Slide.)

6 Our basis for exception of those valves from the
7 IST program is that we have four valves in series. We have
8 the loop check valve, which is right next to the reactor
9 coolant piping, which is depending on the loop MU-V94 and 95,
10 86 and 86B.

11 This is another correction on your handout. That
12 should be second loop check valve, which are the MU-V107A, B,
13 C, and D.

14 During normal power operation, the motor-operated
15 valves are closed, the MU-V16A, B, C, and D. And then,
16 outside reactor building, at the discharge of the pump, the
17 MU-V73A, B, and C.

18 (Slide.)

19 The 73s are here. The high-pressure to low-pressure
20 is a the pump.

21 MR. PAGE: You said there was one more correction
22 there on the other page?

23 (Slide.)

24 MR. ABRAMOVICI: On this page, the second line of
25 the exemption should be second loop check, rather than

1 containment isolation valve.

2 MR. COLITZ: I guess our major comment there was
3 with three check valves and a motor-operated valve that's
4 normally closed between the high-pressure and the low-
5 pressure system. We couldn't justify adding modifications
6 to the plant to go test.

7 MR. ABRAMOVICI: Okay.

8 (Slide.)

9 The next item, again, which is sort of part of the
10 Event VRDH-V --

11 MR. PAGE: Hold off. I think we're back to the
12 same argument we had before, is that they are not two
13 dedicated barriers.

14 You're saying those are four valves in a line, one
15 of the four will be good -- period.

16 MR. COLITZ: Yes.

17 MR. PAGE: I don't think we can even consider
18 an argument like that without some sort of PRA inputs to be
19 evaluated by someone, an analyst.

20 I don't know if that's such a good assumption
21 really.

22 MR. CHERNY: Could you repeat once more what is
23 the normal flow path.

24 MR. AGRAMOVICI: The normal flow path is through
25 this -- through the MU-V17, MU-V18, 219, 222, and 94, into

1 the B cold leg.

2 MR. CHERNY: When the plant is in normal
3 operation, is one of those three pumps that see there always
4 running?

5 MR. SHIPMAN: B.

6 MR. CHERNY: B is normally running?

7 MR. SHIPMAN: That's correct.

8 MR. CHERNY: Okay.

9 So, am I correct -- I'll just ask it.

10 If V-73A and C were not closed, would you be able
11 to sense that somehow by backflow through those other two
12 pumps?

13 MR. SHIPMAN: We presently do that, a test to
14 verify that those other discharge check valves are closed.

15 MR. CHERNY: How do you mean you do a test?

16 MR. SHIPMAN: Correct me if I am wrong -- it's
17 part of the IST program now, to verify that that check valve
18 is closed.

19 MR. CHERNY: 73A and C?

20 MR. SHIPMAN: Yes. Well, we go through all
21 three pumps in the test program to verify that they are
22 closed.

23 MR. CHERNY: How do you go about doing that?

24 MR. SHIPMAN: The current proposed test method
25 looks for a pressure increase on the upstream side of the

1 check valve on the outer pump.

2 MR. CHERNY: So, there's a pressure minder here
3 somewhere that's not drawn in?

4 MR. SHIPMAN: Yes. Those are simplified drawings
5 that should not be used for system design.

6 MR. PAGE: So, you have pressure monitors on the
7 upstream of all the pumps?

8 MR. CHERNY: Between the pump and the check valve.

9 MR. SHIPMAN: Yes.

10 MR. CHERNY: So, they are already verifying that
11 barrier. That's what it sounds like.

12 Okay. I guess the next question is --

13 MR. PAGE: The pressure monitoring is continuous?

14 MR. BASHISTA: Each quarter test.

15

16

17

18

19

20

21

22

23

24

25

end 5

1 MR. CHERNY: If you had any backflow through
2 the valves in loop A, C or D during normal operation, I
3 guess you wouldn't know it; is that correct?

4 MR. BARLEY: 16 valves are going to be shut.

5 MR. CHERNY: I understand that.

6 MR. ABRAMOVICI: That would be the ones you identify
7 leak rate conditions on that.

8 MR. SHIPMAN: The idea, from my understanding is,
9 we're looking for the pressure boundary. If the pressure
10 boundary wasn't there we would certainly see it.

11 MR. CHERNY: Yes, except that you -- that's an
12 interesting concept here. They are periodically checking
13 one barrier quarterly. That seems very clear. But they
14 have three other valves in series that are being checked.

15 Let's say that a little differently. They have
16 three other -- your reactor coolant inventory check would
17 only measure a total leakage, wouldn't it? You couldn't
18 really tell from that whether you were getting a combination
19 of leakages from A, C or D. You'd just get a total, wouldn't
20 you? Is that right?

21 MR. SHIPMAN: We would understand that we would
22 have a problem and then we would go look for that problem
23 and identify it. To say that we wouldn't understand which
24 leg it's coming from, I think is a wrong assumption.

25 There are methods that normal maintenance

1 troubleshooting methods that would occur that would identify
2 where that leakage is coming from. The easiest technique
3 would just be a temperature on the line.

4 MR. CHERNY: Would it be inappropriate to give
5 them credit? So what if they aren't individually leak
6 testing any one of these three, they're leak testing three
7 as one. And they only need one more barrier.

8 MR. PAGE: That's right, they're verifying one
9 barrier. It sounds like it might be useful. What about the
10 73 valves?

11 MR. CHERNY: They're doing those already.

12 MR. PAGE: You're saying you're leak testing them.
13 I thought you didn't want them.

14 MR. BARLEY: There are individual checks on the
15 HPI injection line, injection valves.

16 MR. CHERNY: It seems to me if they're measuring
17 quarterly the pressure build up, they're periodically
18 checking the backstroke of those valves to see whether this
19 is in place. Maybe they ought to get credit for that without
20 doing anything else.

21 MR. PAGE: You're saying they're testing three
22 in series, all the time periodically.

23 MR. CHERNY: Three sets of three.

24 MR. PAGE: What's the criteria you use to
25 determine if they're leaking?

1 MR. CHERNY: They have the reactor coolant
2 inventory check is what they're doing. What's the first
3 screening criteria, 1 gpm unidentified?

4 MR. COLITZ: Shut down.

5 MR. CHERNY: If they have more than one gpm than
6 they have to take action to track it down. Is that how
7 it works? From there you wouldn't shut down, but you'd
8 try to identify where it was coming from, right?

9 MR. SHIPMAN: If we would see the check spec
10 limit

11 MR. CHERNY: In a reasonably short time?

12 MR. SHIPMAN: A very reasonably short time.

13 MR. THOMPSON: Then I think if you determine what
14 loop it was coming from you could go up to 10 theoretically
15 probably before you have shutdown.

16 MR. SHIPMAN: The theory is, you cannot have
17 any leakage through a pressure boundary. Zero leakage through
18 a pressure boundary.

19 One gallon per minute unidentified leakage, ten
20 gallons per minute unidentified leakage, 30 gallons per
21 minute, what we call losses, recoverable losses.

22 MR. CHERNY: But no leakage from a pressure
23 boundary.

24 MR. SHIPMAN: A pressure boundary is defined by
25 a tech spec.

ck ck

320

1 MR. CHERNY: Does that include valve disks? Are
2 those pressure boundaries? I'm not sure that they are.

3 MR. BARLEY: That was intended to refer to piping
4 cracks.

5 MR. CHERNY: I think it was, too.

6 MR. PAGE: So when the water comes back through,
7 where does it go to?

8 MR. CHERNY: He doesn't have anything drawn on
9 here. They have to go to their inventory. I guess they
10 hadn't thought about this path.

11 MR. PAGE: If they -- say that one of these
12 barriers was not there, where would you pick it up?

13 MR. SHIPMAN: More than likely the makeup tank.

14 (Discussion off the record.)

15 MR. PAGE: As you leak through those three valves
16 on a continuous basis, and you're picking up your losses
17 at the drain tank, what's the flow path, what's the reverse
18 direction flow path?

19 MR. ABRAMOVICI: Reverse direction would eventually
20 wind up in the makeup tank.

21 MR. PAGE: Wouldn't that also be testing the
22 73 valves?

23 MR. ABRAMOVICI: You have to have leakage back
24 through 73 to get back.

25 MR. PAGE: You're testing all four at one time, not

1 three.

2 MR. ABRAMOVICI: The 73 are testing, are tested.

3 MR. PAGE: I'm saying the tests they're trying
4 to take credit for the three barriers, also include the 73
5 valves.

6 MR. ABRAMOVICI: In addition to, yes.

7 MR. PAGE: So that's testing all the barriers
8 simultaneously, so you're really only showing one barrier
9 on that kind of test, even though you're testing the 73
10 separately. The 73 may be the one that protecting you.

11 That's why I was concerned. I didn't see the
12 flow path going back for this balance.

13 MR. ABRAMOVICI: There's a makeup tank in here
14 that feeds all three pumps. Or it comes from the PW, as if
15 it's on the accident scenario.

16 MR. BARLEY: Excuse me, are you saying that
17 stroking the 16s to verify that those are at the lowest
18 position and the pressure monitoring test is done separately,
19 and the 73 check valves is not sufficient to establish the
20 barriers?

21 MR. PAGE: From the description I've been able to
22 establish here, it appears to me the 95s, the 107s, the 60s
23 and the 73s indeed all tested at exactly the same time
24 and series. Even though you test the 73s separately --

25 MR. BERNY: He's trying to say they test 16s

ck ck

372

1 separately.

2 MR. BARLEY: We do stroke down 16s.

3 MR. CHERNY: How often do you do that?

4 MR. SHIPMAN: We do that quarterly, part of the
5 ES testing.

6 MR. BASHISTA: They're timed each quarter.

7 MR. CHERNY: Yes. Do you stroke time them just
8 from what, indications in the control room or something?

9 MR. SHIPMAN: That's right. It satisfies the
10 surveillance testing for ES equipment availability.

11 MR. CHERNY: I'm just not convinced it tells you
12 that the disk is necessarily there, but the valve is indicated
13 as closed in the control room

14 MR. SHIPMAN: We also have flow indicators on
15 those valves, one those lines that indicate in the control
16 room. If the valve disks were not shown there we would
17 see flow in designs.

18 MR. PAGE: I don't see how that's possible.

19 MR. CHERNY: Were those indicators located?

20 MR. SHIPMAN: I think they're upstream of the
21 16. They're on each individual line.

22 MR. BARLEY: They're immediately upstream of the
23 16s. There's four of them, one on each.

24 MR. CHERNY: They're sort of where he drew that
25 one?

1 MR. CAPODANNO: Three more in the center location.

2 MR. SHIPMAN: One other aspect of this that might
3 add some realism to the concern is that we have operators
4 in the plant that routinely surveil these systems. And we
5 have shift tour readings and operators roving the plant.

6 These systems are normally somewhere around 100
7 degrees. If there was any significant barrier problem, I
8 would think there would be sufficient flow back from the
9 system that's hot, the operator would notice that he has
10 a very hot pipe.

11 MR. BOSNAK: What is your routine surveil that
12 you say you routinely surveil? What do they do?

13 MR. SHIPMAN: We have aux operators who shiftly
14 take management directed readings on equipment to assure
15 that the equipment is functioning properly. If you can
16 think in terms of a preventive maintenance program as like
17 as operators preventive maintenance program. He's out there
18 looking at the equipment to make sure it's functioning
19 properly.

20 MR. BOSNAK: What does he do?

21 MR. SHIPMAN: He actually takes discharge pressure
22 readings, flows, temperatures. He listens for normal noise.

23 MR. BOSNAK: I was trying to get a feel for it.

24 MR. SHIPMAN: It's that type of program.

25 MR. BARLEY: Let me propose the logic here that

1 convinces me that I don't have less than two barriers. Test
2 the 73 valves independently on a quarter basis. Pressure
3 valve stroke time is 16 valves, if the MEV 16 disks were not
4 there, the makeup pump pressure would be injecting flow from
5 the HPI valves during normal operation, or during the
6 quarterly makeup pump tests, when we test run the other
7 pumps.

8 MR. CHERNY: How sensitive are these flow elements
9 we're talking about? How are they calibrated?

10 MR. SHIPMAN: We use those flow instruments for
11 ES injection modes to verify that the pump is performing in
12 its ES mode properly. Although I can't tell you what
13 interval they're calibrated, or what their accuracy is,
14 it's consistent --

15 MR. CHERNY: I guess what I'm wondering is, what
16 is the lowest flow they would detect?

17 MR. SHIPMAN: Operationally I have got to be able
18 to show that I've got enough flow paths for those valves
19 to assure that on ES, the minimum recirc for those pumps
20 go close. The minimum recirc is 40 gallons per minute
21 per pump. The operator is directed to make sure that he's
22 got at least that much flow. And to be conservative we use
23 the number of 80. Because there's two pumps, 80 gallons
24 per minute minimum flow.

25 So operationally, those indicators are certainly

1 able to see that.

2 MR. PAGE: That's a lot of leakage though.

3 MR. SHIPMAN: This is flow into the system, not
4 leakage.

5 MR. PAGE: We were just talking about the ability
6 of the instruments that we're referring to.

7 MR. SHIPMAN: I'm not sure the instrument would
8 read backflow, if that's what you're --

9 MR. PAGE: We're talking about overflow.

10 MR. ABRAMOVICI: Those are what, zero --

11 MR. PAGE: What the delta P between the makeup
12 pumps and the RC disks?

13 MR. SHIPMAN: Maybe 50 pounds. Maybe more than
14 that. Discharge pressure of the pump is like 2750, and the
15 RCS is at 2155. The delta P across those valves I'm not
16 sure. It's not high, but we have a throttle valve --

17 MR. CHERNY: Is it true that there is always one
18 makeup pump running?

19 MR. COLITZ: Yes.

20 MR. SHIPMAN: Yes, sir.

21 MR. CHERNY: Never shut one of them off?

22 MR. BARLEY: They're supplying sealed water to
23 the RC pumps.

24 MR. CHERNY: Let me ask the question differently.
25 At what time do you normally shut them off? What point in

1 shutdown?

2 MR. SHIPMAN: We're required to have seal injection
3 anytime the RCS is above 190 degrees Fahrenheit, and 100 pounds.
4 That's to assure that you don't have -- that's a reactor
5 coolant pump limit, so you don't backflow unfiltered reactor
6 coolant system back to the seal cases.

7 MR. CHERNY: Under what conditions were you going
8 to be thinking about that?

9 MR. PAGE: They're going to be stroking them
10 quarterly. They're at the completion of the quarterly stroke
11 to verify that this element is picking up nothing.

12 MR. CHERNY: Aren't they doing that now?

13 MR. PAGE: I don't know if they are. I wouldn't
14 think so.

15 MR. COLITZ: The point is, when you stroke them
16 valves quarterly you basically have the valves down here
17 with the makeup pump to feed that line shut. Because if you
18 stroke that valve, you would automatically inject through
19 the -- in other words, when the V pump is running, if you
20 want to cycle these two valves, enclose these two, okay. So
21 you don't inject into the system.

22 I suggest we go on because we have a lot to
23 cover here.

24 MR. CHERNY: I think there's enough of a story
25 here to take this one to RSP also.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

MR. THOMPSON: That's going to be a Staff action to see that story is acceptable.

end 6.

MR. CHERNY: For this particular group of valves.

1 MR. BARLEY: For what it's worth, we have
2 disassembled and inspected all eight HPI check valves
3 we're talking about here in the recent refueling action.
4 And they were in operable condition.

5 MR. PAGE: No maintenance required?

6 MR. BARLEY: We did some modification to the
7 seat rings, to add some locking measurement in there, to
8 make sure that the seat rings would not come loose.

9 We also added a kicker pin to keep the disc from
10 moving up in --

11 MR. PAGE: And locking up inside the housing?

12 MR. BARLEY: Yes.

13 MR. CHERNY: Okay, we can move on.

14 (Slide.)

15 MR. ABRAMOVICI: The next two valves in question
16 are DH-V1 and DH-V2. The drop line in the D hot leg loop
17 suction to the decay heat system during normal operations,
18 during decay heat normal operations. Then the line, this
19 line, also has a leak valve, DH-V37 and DH-V3. It's the
20 outside containment isolation.

21 (Slide.)

22 Similarly, here the valves are inactive at pressure
23 during high pressure operation at greater than 400, these
24 valves are closed. They have an interlock and cannot be opened
25 above 400 psig. They are active during boron precipitation

1 control at low pressure. Again, at less than 400 psig.

2 Here any leakage, through those two valves, we
3 expect will be gradual and the reactant coolant RC leak
4 rate, they will pick it up. Again, on DH-V37, the relief
5 valve, the relief capacities were within the maximum tech
6 spec limit. The relief capacity for this one, I think, is
7 37 gpm. One was 36 and one was 37.

8 Additionally, the DH-V1 and DH-V2 were recently
9 opened and inspected and they were found to be in good
10 condition.

11 MR. PAGE: What was the reason for the inspection?

12 MR. ABRAMOVICI: In DH-V1 --

13 MR. BARLEY: There was a bonnet gasket leak that
14 we had several years ago. We opened up to inspect the
15 condition of the valve from the leak sealing compound,
16 removed the leak sealing compound, and replaced the bonnet
17 seal.

18 MR. PAGE: Using Fermanite leak sealant?

19 MR. BARLEY: Yes, as a leak sealing compound.

20 MR. ABRAMOVICI: Again, high pressure to low
21 pressure boundary is inside the reactor building.

22 (Slide.)

23 There is a closed valve outside containment, DH-V3.

24 Any questions?

25 MR. PAGE: Where is the high pressure, low pressure

1 break here? Okay, I see it.

2 MR. CHERNY: I think we have the same problem
3 with that one that we had on the first couple. We need some
4 kind of individual tests.

5 MR. PAGE: We're doing the test of two valves
6 in series.

7 MR. COLITZ: The only way you test those two is to
8 make plant modifications. And even to do DH-V2 you'd have
9 to tie in there with a hydro-pump in addition to that.
10 We looked at that.

11 MR. PAGE: You have a vent between the valves
12 here.

13 MR. COLITZ: You know --

14 MR. BARLEY: Again, you have to pressurize the
15 reactor coolant system to test the DH-V1. A big problem with
16 a lot of these valves is the necessity to pressurize the
17 reactor coolant side to do any sort of leak test.

18 MR. PAGE: I'm aware of that. Everybody has that
19 same problem.

20 MR. CHERNY: Let me ask, just a clarification-type
21 question. If you are below 400 psi, this is the interlock
22 set point, can you individually open and close V1 and V2, or
23 do they only open and close as a pair?

24 MR. SHIPMAN: Individually. And that is, in fact,
25 how we do it, open them individually. That's how the

1 system is brought on.

2 MR. CHERNY: There isn't any quick and easy way
3 of pressurizing on the RCS as opposed to DH-V1 and seeing
4 whether leaving V2 completely open and closing V1 and
5 see if you're getting leakage through the relief valve.
6 And then closing -- then doing the same thing with the reverse
7 and see if you're getting a leakage, just to see if they're
8 opening and closing. Is that feasible?

9 MR. SHIPMAN: I think that's, in fact, what we're
10 really doing when we bring that system on. We run that
11 system coincident with reactor coolant pumps, which requires
12 us to bring the system on at around above 320 pounds, above
13 310 pounds, something like that, so you can run the reactor
14 coolant pumps coincident with decay heat removal. And as
15 you open those valves, you open them one at a time and
16 then, if I open -- for instance -- DH-V1 and DH-V2 is not
17 there, at the wrong pressure there is that relief valve
18 and we would see that loss of reactor coolant from the system.

19 MR. PAGE: What's the setting on the relief valve?

20 MR. ABRAMOVICI: Which one?

21 MR. PAGE: 37.

22 MR. ABRAMOVICI: 520. One is 495 and one is
23 520.

24 MR. ABRAMOVICI: DH-V37 is 495?

25 MR. SHIPMAN: 495, yes. That's the number I believe

71b5

1 it is.

2 MR. CHERNY: Now in order to get anything,
3 to use that as a leak check path, you would have to do
4 something about altering that valve somehow, because with that
5 set point you wouldn't see anything, unless it was a real
6 bad leak.

7 MR. SHIPMAN: Or unless the set point for that
8 valve was wrong.

9 MR. CHERNY: Yes.

10 MR. SHIPMAN: I don't think I've got a document
11 here in front of me that's a controls document that tells
12 me what that relief valve set point is.

13 MR. BARLEY: It's around 500 or 520 pounds.

14 MR. CHERNY: Without spending a whole lot of time
15 on that, we're going to require some individual tests on
16 those two valves. And I guess they'll have to take another
17 look at it and come back to us, unless -- you know -- unless
18 management overrules us. But that's what we've been told
19 to insist on.

20 MR. BARLEY: When you talk about single failures
21 on these pressure barriers, are you talking about single
22 active failures, single passive failures?

23 MR. PAGE: It could be either one, in this case.
24 You could have an active failure, inadvertant opening of an
25 MOV. You could have a passive failure, of a disc falling off

1 an MOV or breaking in an MOV. Or you could have the
2 check valve just fall off and drop into the bottom. And we've
3 seen a lot of that. Those we've seen quite a few of.

4 That's also a passive failure.

5 MR. CHERNY: Gate valves have a way of telling
6 you they're closed all the way when they're not always closed
7 all the way. At least that's what been happening with gate
8 valves. We've seen a number of those in the recent past,
9 too.

10 MR. SHIPMAN: Is it a slightly open valve, or is
11 it just not there? Is the disc not there?

12 MR. PAGE: You can have one 15 percent open and
13 when you lose your check valve, which is the other barrier,
14 your relief system cannot handle it.

15 MR. CHERNY: In this case here, you lose one of
16 your barriers?

17 MR. PAGE: In this particular case, you'd lose
18 one of the barriers.

19 MR. SHIPMAN: Wouldn't you pick that up by the
20 normal testing we do on the valves already? I believe we
21 do stroke test those valves, time them. If there was something
22 wrong with the disc, and if no other way, wouldn't I see a
23 timing change?

24 MR. PAGE: You would expect to. I wouldn't know
25 that that would be a sure thing. I see what you're talking

1 about. I think sometimes we scoot over into the realm
2 of very small possibilities. But they are there.

3 MR. SHIPMAN: You know, from my perspective, the
4 reasonable judgment would be that I could tell whether the
5 discs were there or not and that it was stroking reasonably
6 well and that the valve was reasonable closed. And if
7 it weren't reasonably closed, operationally, it would impact
8 and I would find it.

9 MR. PAGE: I'm not so sure it would. You might
10 have a torque switch go off early.

11 MR. CHERNY: That's kind of what I was thinking
12 too.

13 MR. SHIPMAN: That is a real world type of a problem.
14 But again, I would think that a failure like that would either
15 be noticeable by the valve timing, would be noticeable by
16 the system operation.

17 MR. PAGE: But it only requires an increase in the
18 test frequency. It doesn't assure you that anything is
19 indeed fixed. Say you had a broken piece of a disc fall into
20 the bottom of the MOV when the MOV disc tried to come down,
21 it wouldn't seat itself. Say the torque switch goes off.
22 But in fact, it's up at a 20 percent open position. If you
23 repeated the test, it probably would be very repeatable and
24 you'd say oh well, we just have a new stroke time.

25 It could be that the packing is tighter now than it

1 was the last time. I can see a story like that coming about.

2 MR. SHIPMAN: The judgment that resets the
3 reference value for the stroke timing of the valve is not
4 a judgment that is taken lightly. I don't think we just
5 inadvertantly change the stroke time by any significant
6 new reference value without, in some cases, very lengthy
7 discussion of why, what possibly could it be, and perhaps
8 even some investigation. It's not -- the code does not
9 allow you to just change the stroke time of the valve because
10 it's repeatable.

11 MR. PAGE: I guess my own personal experience
12 is seeing people treat that quite differently, how deep that
13 analysis is. So we don't know how deep your analysis is.

14 MR. CHERNY: I don't see any way that stroke
15 timing --

16 MR. SHIPMAN: It's documented, also.

17 MR. CHERNY: The closest configuration I can
18 think of exactly like this, is a whole bunch of these kind
19 of things in the PWRs that have been going through licensing
20 in the last couple of years. The only thing that we have
21 said there is they still have to be individually leak tested
22 but it's only necessary to do them after some major valve
23 maintenance or at a refueling outage.

24 So we would be willing to think about something like
25 that here, but it still has to be individually tested.

1 MR. BOSNAK: Before you leave this one, would
2 you describe the high pressure/low pressure interface here?

3 (Slide.)

4 MR. ABRAMOVICI: I guess the logical high pressure/
5 low pressure interface should have been on the valves.

6 MR. BOSNAK: That's not the case?

7 MR. ABRAMOVICI: It's physically not the case.
8 There is a piece of pipe that is high pressure. I have not
9 been able to find out why that was done. But for all intents
10 and purposes, if we move it, it really doesn't change the
11 argument. It makes it better because they got more high
12 pressure.

13 MR. THOMPSON: So what I'm hearing you say is you
14 feel there is enough checks through -- what are these now,
15 if we could summarize them -- the inventory leakage? What
16 else do you have, as a way of checking?

17 MR. SHIPMAN: Stroking of the valve, which is
18 already in the program.

19 MR. THOMPSON: Stroking and -- what about the
20 shiftly check for temperature?

21 MR. COLITZ: There are some quarterly checks to
22 be made.

23 MR. SHIPMAN: All these valves are in the reactor
24 building and would not be normally looked at, on a very
25 routine basis. When I was talking about the inspection of the

1 makeup pumps, those are routinely inspected on a shiftly
2 basis because these components are in the reactor building.
3 We're not entering the reactor building on a shiftly basis.

4 MR. THOMPSON: So the two things that you have,
5 that give confidence to the operability of these valves --
6 that is that they will remain closed -- is the leakage
7 calculations and the stroking, was it quarterly?

8 MR. SHIPMAN: Yes, I'm sorry. It is not quarterly.
9 We've been shutdown too long. It's less than 400 pounds.

10 MR. BARLEY: You couldn't stroke those in
11 operation.

12 MR. PAGE: I'm sorry. I thought I put it in my
13 notes that you did it quarterly.

14 MR. COLITZ: I think we did it on the 16. We
15 said 16 were quarterly.

16 MR. THOMPSON: Are these having any disassembly
17 and inspection at any time?

18 MR. PAGE: One valve each ten years, ISI requirement?

19 MR. SHIPMAN: We have inspected these.

20 MR. PAGE: That's one of four, by the way, not one
21 of two. We're really discussing two valves, but the discussion
22 was expanded to include the DH-V5 valves, I believe, right?

23 MR. CHERNY: Why did you do that? We're on
24 DH-V1 and 2 only, right, hopefully?

25 MR. PAGE: I'm sorry. I slipped one.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

I slipped one paragraph down.

MR. CHERNY: You take part one of the two each ten years, is that right? Was one of these recently disassembled?

MR. SHIPMAN: Both have recently been disassembled.

MR. CHERNY: What kind of shape were they in?

MR. BARLEY: They were in good shape, as far as operability is concerned.

end7

1 MR. ABRAMOVICI: Shall I move on?

2 . . PAGE: Yes.

3 MR. CHERNY: They have the action on that one.

4 MR. THOMPSON: Right.

5 (Slide.)

6 MR. ABRAMOVICI: The next sets of valves are the
7 CF-V5B and V4B, CF-V4A, the core flood system normal power
8 operation -- it's inactive. Core flood valves 1A and 1B are
9 normally closed.

10 They would only come to play in a large break or
11 LOCA accident.

12 (Slide.)

13 The reason for exemption for stroke-testing of
14 this valve is as follows:

15 We do do a part-stroke test once per cycle --
16 fueling cycle. And I think the procedure has been submitted
17 to you for review.

18 The second item is the test is really impractical.
19 We could not do a full-flow test at reactor pressure because
20 of pressure considerations on the CF-V1s and 1A and 1B.

21 Additionally, we would put, we feel, unnecessary
22 cycles on the core flood injection nozzle.

23 The third point is similar valve design is tested
24 to CF-Vs, 5A and 5B tech specs. And we put a modification
25 for those on stroke testing during refueling outage.

1 MR. PAGE: How big of a flood stroke is that?

2 MR. ABRAMOVICI: We open the 1A and 1B, open and
3 close.

4 MR. SHIPMAN: We are required to verify that the
5 core flood tank's flowpath from the tank to the reactor
6 coolant system is not blocked. We have core-flood-type
7 pressure, approximately 50 pounds above RCS pressure. We
8 open isolation valve and watch the pressurizer level RCS
9 inventory to increase.

10 That shows that flowpath is available.

11 MR. CHERNY: Do that once per cycle?

12 MR. SHIPMAN: It's a refueling interal surveillance
13 is the technical specification.

14 MR. ABRAMOVICI: The tanks are what, 60 normally?
15 About 600 psig. The reactor is at 2100, 2155 during normal
16 operation.

17 MR. CHERNY: I think you lost me with those last
18 numbers.

19 The core flood tank is at 600?

20 MR. BARLEY: During the test.

21 MR. CHERNY: Reactor is at what pressure?

22 MR. ABRAMOVICI: 2155.

23 MR. SHIPMAN: Not during the test. And 600 pounds
24 I am not sure is quite what's required by the procedure. I
25 think it's between 500 and 600 pounds. It's about a

1 50-pound DP. The RCS would be about 50 pounds less than that.

2 MR. CHERNY: Okay.

3 MR. PAGE: These are pretty big valves; right?

4 MR. SHIPMAN: About a 10-inch line.

5 MR. ABRAMOVICI: 10- to 14-inch.

6 MR. SHIPMAN: 14.

7 MR. PAGE: You don't have any idea what size --
8 that psig stroke you do at refueling, what terms of percent?

9 MR. SHIPMAN: I don't have that information.

10 MR. ABRAMOVICI: I don't think Joe does either.
11 I think it would be very hard to really get a number, in
12 terms of stroking the valve time.

13 MR. BARLEY: That interflow and increase in
14 level.

15 MR. ABRAMOVICI: Shall I move on?

16 MR. PAGE: It appears we have a very small part
17 stroke. This is the one I accidentally talked about a minute
18 ago, was that you have brought in the C5 -- or the V5
19 discussion with the V4 discussion.

20 And disassembly is of one of four valves, each
21 10 years, which I presume one would never get disassembled.
22 Or at least from this point on it would never be disassembled.
23 So, you have less than 40 years to go.

24 MR. SHIPMAN: I'm not sure I follow that.

25 MR. PAGE: If you have a 40-year plant life and

1 you do one valve out of four every 10 years, won't there be
2 one valve that would never be disassembled in the life of the
3 plant?

4 I would assume -- I personally feel that
5 disassembly is not often enough.

6 MR. SHIPMAN: I think part of the other logic is
7 that the CF5 valve sees a much, much higher flow during a
8 separate test, a different test than what I was just
9 referring to, where we actually put low-pressure injection
10 design flow rate past the 5 valve, which is around 3000
11 gallons per minute.

12 Correct me if I am wrong.

13 The logic we were trying to establish was --

14 MR. PAGE: More severe environment -- more severe
15 service condition?

16 MR. SHIPMAN: More severe. It's a similar valve.

17 MR. PAGE: You say similar? It would be identical?
18 Same design, same manufacturer?

19 MR. BASHISTA: Same catalogue number.

20 MR. CHERNY: To put the whole thing in perspective,
21 the CF -- V5A and B, at full flow tested.

22 MR. PAGE: I'm not sure that is full flow.

23 MR. SHIPMAN: If you look at it strictly from the
24 design flow rate from the cord flood tanks, it may not be
25 design flow rate. The flow coming from that core flood tank

1 is probably a very, very large number.

2 MR. PAGE: Core flood is probably the one that
3 dominates, right, in that situation?

4 MR. CHERNY: The rest of the story is 5A and 5B
5 are already being periodically leak tested. And 4B and 4B
6 are going to be leak tested somehow.

7 MR. PAGE: Now we're talking about full stroke.
8 You say decay leak flow, 3000?

9 MR. SHIPMAN: Approximately.

10 MR. CHERNY: That's through each loop?

11 MR. SHIPMAN: Yes. Each loop is tested
12 separately.

13 MR. THOMPSON: Where does that leave us now?

14 MR. CHERNY: We had a session with Jim Knight on
15 one like this not very long ago. His position on that was
16 they ought to disassemble one valve each refueling outage.

17 MR. PAGE: One per refueling outage. Then the
18 others had to be disassembled if a serious problem were
19 found with the one, you know, at a sampling frequency.

20 Does that sound reasonable to you?

21 MR. SHIPMAN: Is their setup similar to ours?

22 MR. PAGE: This right here is common even to
23 Westinghouse -- I think this particular one we're looking at
24 here.

25 MR. SHIPMAN: Do they defuel in order to do that

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

inspection?

MR. PAGE: No.

Maybe the elevations may be a problem for you.

MR. SHIPMAN: Depending on the total perspective of what we're looking at, in order to do that inspection, you must disable one decay heat removal system, which takes away one of my means of decay heat removal during that inspection.

MR. PAGE: But you've already had a refueling outage.

(Discussion off the record.)

(Recess.)

end 8

1 MR. THOMPSON: What's our statement?

2 MR. CHERNY: Our statement is, it is our position
3 that one of those four valves should be disassembled each
4 refueling outage.

5 We understand the decay heat problem. We will
6 check with our systems people and see if that bothers them.

7 MR. PAGE: We would like to write it up that way.
8 We will put them down for concurrence to make sure they are
9 well aware of that, to see if they have the problem.

10 MR. SHIPMAN: I think you have already issued
11 us a bulletin about loss of decay heat while shut down. It
12 looks very carefully at disabling of the decay heat removal
13 system.

14 MR. CHERNY: Does it limit you how long you can
15 be without one train or anything like that?

16 MR. SHIPMAN? There is an awful lot of information
17 in it. I am not sure that there were any limits. But the
18 concern was that you would consciously do something that would
19 limit your availability of decay heat removal and the informa-
20 tion led you down the path to make sure that administratively
21 the Licensee, if they disabled the decay heat removal system,
22 they would do it consciously with an evaluation of what their
23 decay heat removal capabilities were at the time and your
24 decay heat generation at that particular time.

25 For instance, our decay heat generation is so low

1 that ambient losses takes care of it.

2 However, right at a refuel outage, your decay
3 heat generation is significantly higher and would pose a
4 much more -- more of a problem if you lost decay heat removal.

5 MR. CHERNY: When you say something was issued to
6 you, what kind of thing are you talking about that was issued?

7 MR. SHIPMAN: I can't give you --

8 MR. PAGE: You said it was a bulletin?

9 MR. CAPODANNO: I think it was an information
10 notice.

11 MR. SHIPMAN: It is a notice.

12 MR. CHERNY: It was in something sent to everybody
13 not just you guys.

14 MR. SHIPMAN: Yes, it is an information notice
15 that went through several incidents at several plants where
16 they lost total decay heat removability, and that was a
17 concern. The concern was being distributed to the utilities
18 and our response to that was I think requested if not
19 required.

20 But, are you familiar with it?

21 MR. KNIGHT: You mean the last round of questions
22 we just got?

23 MR. SHIPMAN: Yes.

24 MR. KNIGHT: We haven't gotten to that.

25 MR. MITZ: Do you want us to comment on your

1 position or do you want to save that for this afternoon?

2 MR. CHERNY: You can comment on it, I guess. I
3 thought you already had.

4 MR. COLITZ: On the disassembly of one of four
5 valves, each refuelling outage, there is no way we are going
6 to commit to that. We have disassembled many valves in this
7 last long outage that we have had that we haven't looked at
8 for nine or 10 years. We have gone into a fair number of
9 valves and found them like new.

10 MR. PAGE: I hate to stop you right in the middle
11 of your sentence -- would you be willing to issue -- did you
12 take pictures and everything and have your maintenance reports?

13 MR. COLITZ: I am sure we probably do.

14 We are going to be talking about some of them --

15 MR. PAGE: Would you be willing to generate a
16 report based on that? It looked like you did a lot of
17 disassemblies that might provide support of actual in situ --
18 those valves have been there for awhile. In other words, it
19 is not looking at some general valve thing from the industry
20 but these particular valves and the service they are seeing
21 and to me that is a lot stronger support for longer intervals.

22 Seems like you already have a lot of the information.

23 MR. CHERNY: Have you disassembled these valves?

24 MR. SHIPMAN: CFV4's?

25 MR. CHERNY: And 5's.

1 MR. SHIPMAN: 5's, definitely. We have been into
2 5B -- 4B, excuse me.

3 MR. BARLEY: I don't remember which one.

4 MR. SHIPMAN: 4B we were in.

5 MR. PAGE: That's one of the four.

6 MR. SHIPMAN: That I can say definitely. We were
7 in that. I think 4A we were in. I do not believe we have
8 been into the 5 valves yet.

9 MR. COLITZ: We would have to go back to the
10 maintenance records.

11 MR. PAGE: That would provide a lot more support
12 for that kind of request I think personally myself.

13 MR. CHERNY: Okay. If you would like to provide
14 additional comments based on those recent inspections, that
15 would be useful.

16 MR. COLITZ: There is a lot of ALARA principles.

17 MR. CHERNY: We understand that. That is why we
18 said one valve instead of all of them.

19 Once every 10 years is an infrequent test.

20 MR. COLITZ: Okay.

21 MR. ABRAMOVICI: Okay.

22 (Slide.)

23 The next set of valves is DH V14A and DH V14B.
24 They are in the suction line from the BWST, when we are in
25 the low pressure injection mode, when we take suction from

1 the boiling water storage tanks, they go through the pumps,
2 through the coolers, through the heat exchangers and into
3 the reactor vessel through DH V22 and CF V5A and 5B.

4 (Slide.)

5 Here I think you did not really ask -- we are not
6 asking for an exemption request. What we are saying when
7 the valve is tested with suction from BWST, we have 3000 gpm
8 approximate and we are in discussion with the valve
9 manufacturer. That translates to 73 percent open.

10 We have reverified that with a different branch
11 of Walworth. They came up with a different number. The
12 number was 71 percent.

13 The problem of taking the actual equation for the
14 percent open, they consider that proprietary. I have asked
15 them -- we will ask them for a letter saying that for 3000 gpm
16 the valve is 71 percent or 73 percent open. If that is
17 adequate, we will provide that.

18 MR. PAGE: Based on flow rate alone?

19 MR. ABRAMOVICI: Based on flow rate, they have
20 equation for the valve. If we give them for the flow rate
21 they will tell us what the percent is.

22 MR. PAGE: Isn't that related to some sort of
23 flow coefficient for that particular valve And it also re-
24 quires knowledge of the pressures on either side of the valve?

25 MR. ABRAMOVICI: No.

1 MR. PAGE: There is a certain pressure drop.

2 MR. ABRAMOVICI: But the manufacturer knows what
3 the pressure drop will be.

4 MR. PAGE: For the full open position? Without
5 delta p, you have to assume a position of the disc. Otherwise
6 your flow coefficient, C_V value will change. In other words, the
7 C_V is a fixed value for the valve in one position, in the
8 full open position. The only way you can know it's full
9 open is to know the delta p of the valve and so much line
10 is associated between the pressure gauges and the flow rate.

11 I don't understand how you can do without delta p's.
12 My second question was, did we skip an item?

13 MR. CHERNY: No. These are all items that we
14 agree with.

15 MR. PAGE: I don't see how you can do it without
16 delta p's.

17 MR. CHERNY: Let's back up a little bit. You gave
18 all the appropriate information to the valve manufacturer. He
19 did the calculation. This is the answer?

20 MR. ABRAMOVICI: Right.

21 MR. CHERNY: He doesn't want to give you all the
22 details because it is proprietary but he will give you a
23 letter.

24 MR. ABRAMOVICI: If you desire it, he will give
25 you a letter saying for 3000 gpm the valve is X percent open,

1 71 percent, 73 percent --

2 MR. CHERNY: Do you want a letter?

3 MR. PAGE: I don't see whether a letter is going
4 to help us any other than to address the valve manufacturer
5 directly, but really we are dealing with the utility rather
6 than a valve manufacturer.

7 MR. ABRAMOVICI: The letter will be addressed to
8 us.

9 MR. PAGE: I understand that. You are familiar
10 with the calculations, I presume.

11 Do you know how it is possible to make sure a
12 calculation, not knowing the delta p? I don't. That is the
13 reason I am asking.

14 MR. ABRAMOVICI: There is a CV versus flow, the
15 manufacturer has -- apparently there is a combination of
16 curves per discussion with them. I did not personally talk
17 to them.

18 I think one point maybe is worth mentioning. Again,
19 we are testing at 3000 gpm, so 3000 gpm is going through the
20 valve approximately during the test. Whether that is 71 percent
21 or 73 percent or 69 percent or 75 percent, I am not sure.

22 MR. PAGE: What percent of your accident flow rate
23 is the 3000?

24 MR. ABRAMOVICI: I think that should be 100 percent.

25 MR. PAGE: It can't be 100 percent.

1 MR. SHIPMAN: It can't be 100 percent because you
2 have 18 gallon going to the building spray, so I'd say about
3 60, a little less than 60 percent.

4 MR. PAGE: The maximum flow through that line would
5 be 5000?

6 MR. SHIPMAN: Close to 4800.

7 MR. PAGE: If you could get the letter from the
8 valve manufacturer and support it additionally with a
9 comparison with the maximum flow rate ever required through
10 that valve, I think that would probably give a lot more
11 support in terms of your testing at 3000. The max ever required
12 through the valve would be this many thousand.

13 I think that is a better angle although the other
14 would help coming from the valve manufacturer, a letter from
End 9. 15 him on the design.

16

17

18

19

20

21

22

23

24

25

1 (Discussion off the record.)

2 MR. ABRAMOVICI: Maybe it's worth clarifying some-
3 thing here. The 3000 gpm is full flow for the LPI system.
4 It's not full flow through the check valves because the
5 building spray takes suction off the same.

6 (Slide.)

7 MR. PAGE: You're saying your one pump is at
8 3,000, that's all?

9 MR. BARLEY: The LPI pump puts out 3,000. The
10 building spray pump, which operates in combination with it,
11 I think puts out 1500 gallons per minute for a total of 4500
12 gallons per minute.

13 MR. PAGE: You're not showing the building spray?

14 MR. CHERNY: He's drawing it up there.

15 MR. BARLEY: You can test the 3000. You can
16 test the 3000 gallons per minute by initiating decay heat
17 removal systems while you can't really add 1500 gallons per
18 minute building spray. So the test really is not practical.

19 MR. PAGE: You say you have to run your building
20 spray pumps at the same time.

21 MR. BARLEY: To prove the full flow through the
22 14 valve, the accident flow rate, which is your interpretation
23 of what is being proved. The only way to get that combined
24 flow is to run both of the systems. It's just impractical
25 to do that.

1 MR. PAGE: How much recirc can you get on your
2 building spray pumps? Would it be possible to run both those
3 tests on recirc, though -- where's your recirc to?

4 MR. BARLEY: It goes back to the borated water
5 storage tank.

6 MR. PAGE: I inquired about the possibility of
7 running the building spray pumps in recirc mode, at the same
8 time as running the 3000 gpm, so it would give you closer to
9 4000 on the test.

10 MR. ABRAMOVICI: Wasn't there something in our
11 procedure that prohibited us from testing together?

12 MR. SHIPMAN: We would have to look at it in
13 detail. If you are flowing at 3,000 gallons per minute, to
14 the RCS. Right off the top of my head, it seems to me, you
15 could still be on recirc with the building spray. However,
16 the benefit of that test versus the risk that that is not
17 an accident set up, and that there may be a consideration
18 that may not -- that I'm not thinking of right now.

19 In other words, if we have the accident, in order
20 to get the design flow, the reactor coolant system has to be
21 at zero. And the reactor building has to be at 30 pounds
22 and the flow has to be from the BWST, and one path going to
23 a depressurized reactor coolant system, in one case; and to
24 a pressurized reactor building.

25 I don't know to what degree you have got to take

1 this criteria for the test.

2 MR. PAGE: I think you try to make as much of a
3 full stroke as you can get. The arrangement may seem strange,
4 but it maybe doesn't sound strange to us maybe because we
5 haven't done it, but I don't see anything dangerous about
6 it. Basically we are dealing with a word called impracticality,
7 not inconvenience. I think that's the basic difference
8 we get into sometimes. It may be inconvenient, but we don't
9 see anything impractical or unsafe for the plant, or I don't
10 see anything. There could be.

11 Other people do similar things to get as much --
12 even though we'll still not get a full stroke, you'll get us
13 closer to a full stroke.

14 MR. SHIPMAN: There's one other point we could add
15 to this, and that is we've also looked at DH-V14.

16 MR. PAGE: You mean internal inspection?

17 MR. SHIPMAN: We've had that valve apart recently,
18 within the last year or two.

19 MR. PAGE: I thought you were trying to -- that
20 would help in terms of how often disassembly should take place
21 for full stroke. I thought we were trying to come up with a
22 way of only accepting a large part stroke, in lieu of that.

23 MR. SHIPMAN: I think that's what our initial
24 position was, is that we're putting 3,000 gallons through it
25 and that that provides reasonable assurance that the valve

1 would full stroke, were it called upon to do it in the
2 accident. The practicality of the test, I didn't think we
3 were talking about.

4 MR. ABRAMOVICI: I can give you, probably, some
5 ballpark numbers for what the valve would have to be for
6 full stroke. At 3,000 gpm the valve is 60 degrees from the
7 centerline open. At 3725, which would be approximately 3800,
8 we'll be 66 degrees open. The valve is 15 degrees as closed.

9 MR. PAGE: What have you got, 90 degree travel?

10 MR. ABRAMOVICI: 82 degrees is full open, so you
11 go from 15 to 82.

12 MR. PAGE: I think that would substantially make
13 the test better, personally. I don't know if you have a
14 problem with actually performing the test.

15 MR. BARLEY: That's what we have to look at.

16 MR. ABRAMOVICI: The point I was trying to make,
17 it only opens the valve another six degrees to get the
18 additional. And I think if it opened 60 degrees it would
19 probably open 66.

20 MR. PAGE: I thought we were talking 73 percent?

21 MR. ABRAMOVICI: 73 percent open, this is 60 degree.

22 MR. PAGE: Okay, the valve 15 degrees is closed.

23 82 percent is full open -- 82 degrees is full open. We
24 translate 15 degree open, to percent.

25 MR. CAPODANNO: Let me ask you a question in regard

101b5

1 to these check valves and testing. We have just identified
2 that with the decay heat running the valve will open a
3 certain amount, according to the available information from
4 the manufacturer. And that could be confirmed in more detail
5 via the manufacturer. Another thing that can go along
6 with that is, given that the valve is that much open --
7 X percent, 71 or thereabouts -- one could also do some
8 additional analysis that said if that valve never moved past
9 71 percent, its impact on system resistance would be something
10 -- let's say negligible, in terms of total flow in the
11 system.

12 Would a combination of something like that satisfy
13 you that that valve opening that 71 percent meets its
14 design function?

15 MR. PAGE: The reason it appears we're beating this
16 poor horse to death is I truly don't believe that the
17 manufacturer can make that statement and it be true without
18 knowing a delta P. That's the reason --

19 MR. CAPODANNO: I was giving you that that the
20 manufacturer would be able to satisfy anybody --

21 MR. PAGE: I really don't think it's possible. He
22 has to know the delta P because the flow coefficient changes
23 with the position of the disc. Basically, it's a configuration
24 of flow through some restriction. And depending on where
25 that disc is, your c sub V really is different. So you

1 have to know delta P to assure. So when we found out delta P
2 was not part of that discussion, he may put out such a
3 letter and it would help us support things, but I truly don't
4 believe that that could possibly be true.

5 MR. BOSNAK: Is that something you can clear up
6 easily with a call? Who is this, Walworth?

7 MR. ABRAMOVICI: Walworth.

8 MR. BOSNAK: You could get him on and see what
9 his basis is. And maybe it is based on a delta P for flow
10 of test conditions. I don't know.

11 MR. CHERNY: What are the parameters that you set
12 him, for him to come up with the answer?

13 MR. ABRAMOVICI: Flow only.

14 MR. CAPODANNO: I was going back to your question.
15 Let's assume we go to the vendor and say this check valve,
16 this system, this inlet pressure, this flow is what we need
17 in order to feed the vessel. The guy comes back and he
18 says okay, I know how to work that out, and here's your answer.
19 At that inlet pressure and that flow rate, this check valve
20 is 71 percent open.

21 MR. PAGE: He's assuming the check valve is
22 performing its job correctly. He's making that assumption.
23 We're trying to determine that it's operating --

24 MR. CAPODANNO: I'm looking at variable orifice.
25 If he knows how to calculate percent open, based on those

1 conditions, and the system is running on a different set
2 of conditions, clearly the valve is not open the amount he
3 said it was.

4 MR. PAGE: But your philosophy is a little off,
5 in that he is assuming first that the valve is performing
6 as intended, as designed, that there's nothing wrong with the
7 valve. We're looking to see if there's anything wrong.

8 In addition to exercising --

9 MR. CAPODANNO: I'm saying if it didn't open the way
10 he predicted, then something in the system would have to be
11 different, pump discharge pressure, flow rate would have to
12 be different.

13 MR. PAGE: You're dealing with flow rates and
14 discharge pressure. It doesn't appear to me pressures are
15 a part of this argument. And that's what threw me. You
16 can't do it on flow rate alone.

17 MR. CAPODANNO: Understand that. All I'm saying
18 is let's say we can get past that hurdle. Everybody would be
19 convinced that indeed one could predict that the valve was
20 opening 71 percent with the system discharge pressures on the
21 pumps, as it should be. And with the flow from the pumps
22 as it should be. Then can I go the next step and say, all
23 right, if I never assume it goes any further open than that,
24 simply and analytically demonstrate that the additional gpm
25 going from 3,000 to 4,500 has very minimal impact.

1 MR. PAGE: Right. That's a good argument, but I
2 think the problem is the initial part of the argument,
3 without the delta Ps.

4 MR. CAPODANNO: Okay.

5 MR. PAGE: I think you're right. I would follow
6 it, but it's just that first section.

7 MR. CHERNY: What is it you want them to provide?

8 MR. PAGE: We were going to get a letter from
9 the manufacturer.

10 MR. CHERNY: What's it going to say?

11 MR. PAGE: For some given conditions, that I guess
12 you guys can provide, under tests, the valve will be X percent
13 open or will provide X percent of this flow rate.

14 MR. CHERNY: And it's going to have things like
15 pressures, and so on, in the letter? Is that what you're
16 saying?

17 MR. PAGE: I don't see how it cannot be in there,
18 really. Basically, c sub V is a description of a flow path.

19 MR. COLITZ: One thing we haven't brought up. In
20 a lot of these, you've asked for a copy of the reference
21 procedure, which was sent to you people. So we haven't
22 really been discussing that.

23 MR. PAGE: Yes, I've looked through some of those.
24 It indicates here, in this note, that we would be getting
25 the calculations here at the meeting.

1 MR. KNIGHT: I thought we would. That's why I
2 wrote it in the note. I wasn't really aware of the situation
3 that is discussed.

4 MR. ABRAMOVICI: The next item --

5 (Slide.)

6 -- next the valves in the B-2 category are the
7 MS V9A and 9B which are the steam supplied to the turbine
8 driven emergency feed pump. During normal operation that line
9 is not used, only during quarterly testing of emergency
10 feedwater that line would be used. And again, in emergency
11 feedwater initiation, and you need the emergency feed pump
12 turbine, that line would be used.

13 (Slide.)

14 Our reason for asking exemption request is the
15 emergency feedwater is tested quarterly with the emergency
16 feed pump on recirc and to successfully pass the recirc test
17 we require 48 percent of design steam flow to the turbine.

18 MR. PAGE: Okay, so you're backing into it the
19 other way around.

20 MR. ABRAMOVICI: Right.

21 MR. PAGE: Do you have a time requirement on how
22 long it takes to come to speed?

23 MR. ABRAMOVICI: I have that information.

24 MR. PAGE: I'm sure it's in here somewhere. I was
25 going through these pretty quick.

101b10

1 MR. ABRAMOVICI: There is a time for the turbine
2 to come up to full speed.

end10
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

11pbl

1 For TMI we started the turbine driven pump requires
2 18 seconds to reach full flow. Restart report 2.1.7.4.

3 MR. PAGE: That's tech spec number? Is this a
4 tech spec requirement to maintain that starting time?

5 MR. ABRAMOVICI: I don't think so. Gary?

6 MR. CAPODANNO: I don't believe it is.

7 MR. PAGE: Would you be willing to use that for
8 IST purposes to assure that those valves are coming open?
9 I don't know is that presents another technical problem or
10 not. It's somewhat sort of acceptance criteria in terms
11 of full open.

12 Would you be willing to maintain that 18 seconds
13 for your IST also?

14 MR. CHERNY: Why is that necessary?

15 MR. ABRAMOVICI: The only problem I see with that,
16 it may not be a valve problem, may be a pump.

17 MR. PAGE: It could be a valve instead of something
18 else. If you fix whatever the something else was, and
19 the valve was working right. You'd want to fix whatever
20 it was, anyway, if it didn't make 18 seconds.

21 So whether it be the valve or something in the
22 turbine or some sort of throttle valve you may have associated
23 with that. It's kind of a strobe time as to how fast that
24 thing comes up to speed. The valve is going open 48 percent --
25 no, 80 percent.

11pb2

1 MR. CHERNY: It can't be that it doesn't go 48
2 percent open.

3 MR. PAGE: You mean doesn't go 80 percent open?
4 At 70 percent open you could still get up to full speed. It
5 would just take you a longer time.

6 MR. CHERNY: Not really true.

7 MR. PAGE: I think so. Some cut off in there,
8 probably between 50 and 80. But I don't know how far back
9 it goes, depends on the line size, I'm sure.

10 MR. CHERNY: You're disagreeing with this sentence
11 then. You're saying they could do it with less and still
12 get a successful test.

13 MR. ABRAMOVICI: To achieve the given horsepower
14 required for the recirc flow, we need 48 percent steam flow
15 based on the pump data.

16 MR. PAGE: Couldn't you also get 48 percent steam
17 flow at 70 percent open? We're talking about flow rates
18 and pressure drops.

19 MR. ABRAMOVICI: We're going back to the same
20 argument as we had before.

21 MR. PAGE: Well, we're always talking about
22 two. We leave the third one out. And we've got flow
23 coefficient.

24 I think you would still get up to speed. It
25 would just take you longer, wouldn't it?

11pb3

1 MR. ABRAMOVICI: If you don't have the required
2 flow, you would not be able to --

3 MR. CAPODANNO: You can accelerate the speed. But
4 the total equation on horsepower is flow times head over
5 constant, approximately 4,000.

6 MR. PAGE: But you'd be getting your pressure drop,
7 in this case, across -- a partially restricted flow through a
8 valve. For some reason we're saying -- we're philosophizing
9 here. Wouldn't that tend to give you a pressure drop and
10 make it slower and slower to get up to speed?

11 MR. CHERNY: Doesn't it depend on the flow going
12 through there? If you have a short flow, you're not going
13 to show enough stuff in there to get that pump up to speed.

14 MR. PAGE: You can get a restricting orifice and
15 still show the same amount of flow rate through it. You
16 just have a greater pressure drop.

17 MR. CHERNY: Think of a simpler case, like a
18 safety valve that's only 50 percent of rated lift. It ain't
19 going to flow 100 percent flow. It can't, and it won't.

20 Okay? That's why I'm confused by your example.

21 MR. THOMPSON: Does it matter if you're going to
22 get up to speed within that time frame that --

23 MR. PAGE: That's what I'm trying to do, keep it
24 within the time frame.

25 MR. THOMPSON: -- then you're going to show your

11pb4

1 valves open enough to give it what you need. And what I
2 think you are saying is, would they be prepared to tech
3 spec that. And my question would be --

4 MR. PAGE: Would it be fair to stick yourself with
5 the 18 seconds, or 20 seconds, something would give you a
6 little margin for instruments or something like that. To
7 stick with this 18 seconds is pretty close, but really in
8 terms of the check valve, although we all agree it could be
9 something else. But even if you found something else, you'd
10 probably want that fixed also.

11 I assume the aux feed pump is very important.

12 MR. CHERNY: I'm still having trouble figuring
13 out if it's necessary though. It's neat to do, but I don't
14 know if it's necessary. That's what bothers me.

15 MR. THOMPSON: I certainly would question whether
16 it needs to be a tech spec. It's in the procedures, right?
17 It's in your procedures.

18 MR. COLITZ: No.

19 MR. CHERNY: Either agree with the sentence or
20 you don't. If you don't agree with it, say so.

21 MR. PAGE: I thought I disagreed with it. I said
22 if they come up with 18 seconds, okay.

23 MR. CHERNY: No, you're not understanding my
24 question. The sentence says, successful test requires
25 48 percent of design steam flow. True or false?

11pb5

1 MR. PAGE: They said this was also part of the
2 successful test.

3 MR. CHERNY: I didn't hear that said that way.

4 MR. PAGE: The 18 seconds is part of the successful
5 test.

6 MR. CHERNY: Is that absolutely true?

7 MR. SHIPMAN: That's not true. The statements
8 that were made during restart hearings, I believe, were
9 statements of the fact that in here under these conditions,
10 here's how long it takes for these emergency feed pumps to
11 deliver feedwater flow into the steam generator.

12 For one thing, I'm not sure, doing the IST on
13 recirc has those same assumptions in it. So I'm not sure
14 the timing's going to be the same. But certainly, when
15 we call that emergency feed pump to start and it doesn't
16 start --

17 MR. PAGE: That's one kind of test. That's go
18 or no go, period. How long it takes to come up to speed
19 is another part of the test.

20 MR. SHIPMAN: And we presently do not measure
21 how long it takes to come up to speed, because generally,
22 that occurs --

23 MR. PAGE: I think we're getting back in the
24 same old argument.

25 MR. CHERNY: The only thing that's confusing me

11pb6

1 is that we don't ordinarily stroke time shut valves. That's
2 the only thing I'm confused about.

3 MR. PAGE: I'm not stroke timing the check valve.
4 We're talking about percent open.

5 MR. CHERNY: I realize that.

6 MR. PAGE: Percent open tells you how fast that
7 thing is going to come up to speed. There may be a certain
8 percent open. And once it's there, it will make no
9 difference. It will come up to speed at the same rate anyway.

10 But if you start restricting that channel, it
11 will take longer and longer time to come up to speed.

12 MR. CHERNY: Okay. I guess I'm having trouble
13 with what you just said about the safety valve example.

14 MR. PAGE: I'm not so sure we can relate this
15 to safety valve.

16 MR. CHERNY: It ain't never going to flow to
17 full capacity, no matter how long you do it.

18 MR. BOSNAK: If you know what you've got when
19 you start you can tell what you have later on, if you've got
20 a degradation.

21 MR. PAGE: That's what I was trying to get at.

22 MR. CHERNY: You think it might hang up and open
23 in stages, or something like that?

24 MR. BOSNAK: If you're looking for degradation,
25 if you know what you have when you're starting, and you have

11pb7

1 a certain percent open --

2 MR. PAGE: You have a reference value.

3 MR. BOSNAK: You have a reference value. Is there
4 any problem with that, having a reference value?

5 MR. COLITZ: We'd have to go back. I have no
6 understanding on what basis the 18 seconds was laid forward --

7 MR. BOSNAK: Whatever time you wish to pick. That
8 will tell them, you know, with the valve stroke, this amount
9 that you are getting this response. Then you stroke the
10 valve again at some later time and you don't get that
11 response --

12 MR. PAGE: You might be indicating a problem with
13 the valve. It could easily be.

14 MR. SHIPMAN: The test is to provide reasonable
15 assurance that the check valve will deliver steam.

16 MR. PAGE: The steam required under the worst
17 condition.

18 MR. SHIPMAN: We don't do that test. We can't
19 do that test because we can't flow water to the steam
20 generator. We're doing this test on recirc.

21 And we do believe, and I personally believe, that
22 the confidence of that test is very high. That when I run
23 that pump on recirc that the check valve will deliver the
24 steam required to do that test.

25 MR. BOSNAK: That's what you're looking for.

llpb8

1 MR. SHIPMAN: I don't know what the time limit
2 should be for the pump to come up to speed. I'm not sure
3 I fully understand your issue. But certainly, when we run
4 that test, we expect the pump to come up to speed. And not
5 for it to take five minutes to come up to speed.

6 MR. PAGE: Then you have some acceptance criteria
7 associated with how long.

8 MR. SHIPMAN: It's not specified in the procedures,
9 sir. We certainly have some reasonable assurance that
10 the steam was delivered to that feed pump turbine as it was
11 designed. It is not a full stroke test of the check valve,
12 but it does provide reasonable assurance that the check
13 valve cycles properly.

14 MR. CHERNY: What's the steam source for that?

15 MR. SHIPMAN: Beginning of three, it could be
16 from the auxiliary boiler to 100-pound boiler. It can be
17 from main steam.

18 MR. ABRAMOVICI: You have to have main steam to
19 use that line, right?

20 MR. SHIPMAN: For this test there's main steam.

21 MR. ABRAMOVICI: For this test there's got to
22 be main steam. So the plant must be running, otherwise
23 you can't do the test.

24 MR. BARLEY: The problem here with this test is
25 you have to be hot at main steam to get full flow, you need

1 emergency feedwater. And you need full flow cold water into
2 the hot steam generator, which normally cycles emergency
3 feed levels.

4 That's the practicality of the test.

5 MR. CHERNY: So the steam source for the turbine
6 is always available at the same pressure and temperature
7 and all that, right?

8 MR. SHIPMAN: Plus or minus.

9 MR. CHERNY: Reasonably close.

10 MR. BARLEY: When you say always available --

11 MR. CHERNY: We're talking now, just when you
12 can run this test.

13 MR. SHIPMAN: To check that check valve.

14 MR. PAGE: You can always use your aux boiler
15 to get that steam. He says the steam source is always
16 available.

17 MR. BARLEY: But these valves are not flow path,
18 that's the problem.

19 MR. CHERNY: That's what I was trying to get.
20 Within some reasonably short tolerance they always have the
21 same --

22 MR. ABRAMOVICI: You can test emergency feed pumps
23 without -- with aux steam, but you can't check those valves.

24 MR. BARLEY: Main steam valves you can only
25 check when you're hot.

11pb10

1 MR. CHERNY: Right.

2 MR. PAGE: Can you think of some other acceptance
3 criteria, other than just the fact that it will reach its
4 speed?

5 MR. SHIPMAN: I would leave that to the technical
6 end of our organization. But the reasonable assurance that
7 that turbine would deliver feedwater, we were discussing
8 the aux boiler steam supplies. There are various sources
9 of steam. There is various tests we do on the feedwater
10 pumps already. There is various operational things that we
11 do routinely to verify that that is available.

12 MR. PAGE: Is there some restriction on the pump
13 as to what is the minimum required steam to get it to speed?
14 Surely that should be right in the specifications. Can you
15 provide us just that part then? Because that way I'll know
16 how much steam flow is the minimum required to get to speed.

17 MR. SHIPMAN: On recirc?

18 MR. PAGE: Yes, on recirc. At that flow rate.
19 Because then the time element goes away. Maybe it won't be
20 important.

21 But I was picturing in my mind that it would be
22 if you did have a valve problem that you could see it very
23 easily, and how long.

24 MR. SHIPMAN: From my experience, I would think
25 you'd have a no go. The valve would either give you enough

11pb11

1 steam to put it on restart, or it would not. There would
2 not be a decreased time.

3 MR. PAGE: So you think the check valves, when
4 you go into the open position is either go or no go?

5 MR. SHIPMAN: In this particular case, for the
6 reasonable assurance that you want, the check valve in
7 consideration of the full stroke. We're not going to get
8 the full stroke unless we are required to pump water to
9 the steam generator on main steam for the design condition
10 which you are assuming for this component.

11 If we back off from that design condition, it
12 will require very different amounts of steam to run that
13 pump. And my feeling is that the amount of steam to run
14 that pump on recirc is probably minimal compared to what the
15 steam is required to run it in the design event that we are
16 supposed to be considering.

17 But it provides satisfactory system performance
18 that the component will be available when it's required.

19 MR. PAGE: I think we have a breakdown of
20 philosophy here.

21 MR. SHIPMAN: Well, the reasonableness of the
22 issue is, I think, the main point of interest. Certainly,
23 if we can pump water to the steam generator --

24 MR. PAGE: Would you put the same argument forth
25 for diesel generator cooling water check valves which have

11pb12

1 been operating for many, many years cooling a diesel for
2 monthly tests. And yet when they were disassembled it was
3 found all of them were disassembled in the Dresden and
4 Quad City situation they had been testing those monthly under
5 less than full flow.

6 Your argument is that less than full flow is
7 adequate to show that a component is there and available
8 to do its job. On a check valve, you're saying part stroke --

9 MR. SHIPMAN: What I'm saying is you cannot set
10 up the design accident condition to run the test to prove
11 a component will operate during that accident.

12 MR. PAGE: That's one part of the argument. The
13 other part of the argument is a part stroke is adequate to
14 show that component is there, available, and will perform
15 its job as designed.

16 I'm saying the Dresden/Quad Cities tends to take
17 the exact opposite situation there. Valves that have
18 been going through testing on a monthly basis had part stroke.

19 MR. SHIPMAN: What was the conclusion of Dresden?

20 MR. PAGE: The conclusion was they had all the
21 valves disassembled in the line and didn't know about it
22 for many years. Which means that debris can act in just
23 any old fashion it wants to.

24 In one case it finally decided to restrict flow.
25 The diesel started heating up, even under reduced loading

llpbl3

1 condition. Had they been running those tests at full load,
2 I think they would have found out much sooner.

3 MR. SHIPMAN: So I don't understand.

4 MR. PAGE: Your philosophy was saying, part stroke
5 is adequate to show that the component will do its whole
6 job. That's exactly what you're saying, and I totally
7 disagree.

8 MR. SHIPMAN: Your side of the argument is we
9 should set up a design accident condition?

10 MR. PAGE: I'm saying you should set up something
11 that verifies at least there's no change from your reference
12 condition.

13 MR. SHIPMAN: And the code requirements, define
14 what those requirements are.

15 MR. PAGE: You shall full stroke the valve. That's
16 what the requirement is.

17 MR. SHIPMAN: So ideally in my position, if we
18 put a handle on the valve and opened it, you know we put an
19 external handle on the valve, opened it, and closed it --

20 MR. PAGE: That would be great.

21 MR. SHIPMAN: That would be great for me, I agree.

22 MR. PAGE: As a matter of fact there's some valves
23 you can do that to.

24 MR. SHIPMAN: We have some. They're not in
25 this program.

ck ck 275

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. PAGE: There are some you can put an MPT tap into run something inside of it and actually latch onto the swing mechanism and take it for a full stroke, then MPT it back closed. That is somewhat cheap modifications, rather than actually building all sorts of fancy recirc lines. There are people that do things like that to get a full stroke.

MR. BOSNAK: We have reached 1:00. I think it's time we take a break.

MR. CHERNY: How much more do we have?

MR. COLITZ: We have covered about seven of 20 items.

MR. CHERNY: I think having the ADs at 2:30 is a waste of time. We'd be lucky just to get through the items today, the first time through them, assuming we continue at this kind of speed.

MR. THOMPSON: We have to do that before we can do anything.

MR. CHERNY: I don't think there's anything the ADs can do yet.

MR. PAGE: Before we leave these items, are these items in the same calculation as the other? This came from a different manufacturer.

MR. ABRAMOVICI: I'm not sure. I'd have to check.

MR. CHERNY: As I understand your concern, you don't agree with the 80 percent. That's your main concern.

11pb15

1 You think it's not proper.

2 MR. PAGE: I'm saying you have to assume the
3 position of the valve to make that statement, not using
4 pressure differentials. Same thing that we had here.

5 MR. CHERNY: Okay. But if you knew the 80 percent.

6 MR. PAGE: That would be fine.

7 MR. CHERNY: You would have no problem.

8 MR. PAGE: If they had some way to reassure that
9 every time they did this test it was still 80 percent.

10 MR. CHERNY: You want this quasi stroke time thing
11 because you don't agree with the 80 percent is your real
12 concern.

13 MR. PAGE: They may have 80 percent now, but I'm
14 saying as time goes on it may go down to 60 percent. What
15 you're saying is the turbine is coming up to speed much
16 slower. What in fact is there is not a turbine problem, is
17 in fact a valve problem.

18 MR. CHERNY: The thing is to get the thing up
19 to speed. It all requires some flow rate.

20 MR. PAGE: That's right. We don't know what that
21 flow rate is.

22 MR. CHERNY: Maybe we don't, but somebody could
23 find out.

24 MR. PAGE: That's what I asked a little while
25 ago, if that could be incorporated to try to do away with

11pb16

1 any sort of time consideration. You know, could we look at
2 that number. Maybe that number --

3 MR. CHERNY: Then somebody could do maybe some
4 sort of boundary calculation. Maybe you could go down, as
5 you say, to 60 percent.

6 MR. PAGE: I would say the turbine manufacturer
7 probably could tell you that what the minimum was. The
8 trouble is, I think we have that recirc situation. To bring
9 it up to full speed on recirc may be some minimal flow, may
10 be 10, 15, 20 percent.

11 MR. CHERNY: Whatever it is.

12 MR. SHIPMAN: But the code allows you some
13 reasonable judgment based on the available testing capabilities
14 you have, doesn't it?

15 MR. PAGE: The code does? Where?

16 MR. SHIPMAN: The three items.

17 MR. BARLEY: The code says, you know, the code
18 says -- all the code says is you're not required to do
19 testing if it would be unsafe.

20 MR. PAGE: Could you tell me what paragraph that's
21 in? I don't remember reading that? Not that we disagree
22 with the statement, I just don't know where it's in the code.

23 MR. BARLEY: I'm sorry. Maybe it's the Staff
24 position I'm referring to.

25 MR. PAGE: All right.

11pbl7

1 MR. CHERNY: I don't think we want them to run
2 a test that's going to put thermal stresses on steam
3 generators. I don't think we want them to do that.

4 There may be some other way out of this dilemma,
5 but that isn't it. I don't really think I fully understand
6 how we're leaving this item at this point, except for
7 making a lot of remarks. What do you think they ought to do?

8 MR. PAGE: My feeling was that using that time
9 to come up to speed is a back door way of verifying that
10 the check valve also is operating correctly. Maybe not.

11 MR. CHERNY: Does anybody know what that number
12 is that you're talking about? That correct number to use
13 for coming up to speed.

14 MR. PAGE: I haven't heard it today.

15 MR. CHERNY: I'm not sure they know what it is
16 either. I mean in terms of what you're talking about.

17 MR. BOSNAK: Why can't you select a value of
18 your own choosing. You don't even have to get to the
19 manufacturer, assuming everything is correct today.

20 MR. CHERNY: In order to back out a number for
21 time up to speed though, don't you still have to do some
22 kind of assumption in your calculation? They would say
23 18 seconds corresponds to 80 percent. But what is that
24 based on? I don't understand that. We've got to have a
25 relationship somewhere.

11.

1 You want them to set a criteria -- what's it based
2 on? What should they use to base it on?

3 MR. PAGE: Like Bob says, you'd pick a reference
4 value. That's what you start with. You can only allow a
5 certain amount of degradation.

6 MR. CHERNY: I understand that.

7 But let's say a number changes. You're still not
8 going to know from what you just did that that thing opens
9 80 percent.

10 MR. PAGE: You're assuming it opened 80 percent
11 the first test.

12 That's what Bob was saying, to assume it's okay
13 when you start.

14 MR. CHERNY: All that's going to do, that's just
15 a screening criteria to check future degradation. But it
16 still doesn't tell you that even now --

17 MR. PAGE: The only way you're going to know that
18 it doesn't now is to take it apart or get inside the valve
19 and actually move it through there because they can't run
20 water into --

21 MR. CHERNY: I understand that.

22 Have they taken this valve apart?

23 MR. SHIPMAN: Not to my knowledge.

24 MR. CHERNY: This one has not been. That's a
25 definite statement.

1 MR. BOSNAK: Again, assume you're getting
2 performance today, it will tell you whether you're getting a
3 degradation in the future. And that's what we're looking
4 for.

5 MR. CHERNY: I can't say that gives me an overly
6 warm feel here, because it's been in service 10 years.

7 MR. SHIPMAN: Dresden wouldn't support that.

8 My understanding is that his example from Dresden
9 wouldn't support that.

10 MR. BOSNAK: It would, in that -- assuming you
11 were okay now. If you aren't, you already have some blockage.
12 Then, it wouldn't. But making the assumption, you're all
13 right now. Then, if you had a disc come off and it changed
14 your characteristics, then it would.

15 MR. PAGE: Or even if you had debris somehow in
16 that line -- God knows where it comes from; it seems like it
17 gets into some lines -- should it lodge in a valve, you might
18 really see differences in that stuff.

19 MR. CHERNY: No one knows how many GPM puts out
20 on recirc. Is that what I heard before?

21 MR. SHIPMAN: We have a recirc office. We do know
22 what that number is.

23 MR. BOSNAK: Is this a critical pump?

24 MR. CAPODANNO: Yes. It's on the order of 180.

25 MR. CHERNY: 180 gpm?

1 And what's the accident flowrate supposed to be?

2 MR. CAPODANNO: 350.

3 MR. BARLEY: This pump was rated at 920 gallons
4 per minute. Accident flowrate requires something like 350.

5 MR. BOSNAK: You don't have to worry about the
6 accident condition necessarily. You can have the pump
7 throttle way back or however you have it on recirc. If
8 your turbine comes up to whatever speed that you've got,
9 at least you know that there is enough steam to do that.

10 And if you've got blockage, then it won't --
11 enough blockage. That's what you're talking about, something
12 gross that's happening with the check valve.

13 MR. SHIPMAN: And the test we do right now does
14 that.

15 MR. CHERNY: They put about half the flow rates
16 there for accidents, it sounds like, for recirc right now.

17 MR. SHIPMAN: We do the highest high on that pump
18 by getting it at that rate of speed and verifying that the
19 discharge pressures were what they were previously.

20 MR. CHERNY: Under accident conditions, they would
21 have to have the same speed, more flow. They would have to
22 go through that.

23 MR. BOSNAK: Can you tell -- I guess the main
24 thing is can you discern whether or not you've got something
25 that is blocking the steam flow to the turbine?

1 MR. SHIPMAN: Yes.

2 MR. BOSNAK: That's the key.

3 MR. SHIPMAN: But to what degree can you tell that?

4 MR. BOSNAK: You're never going to have something
5 that will discern what will happen under accident conditions,
6 I don't think. You're looking to see whether you've got the
7 dissociation of the valve disc. That's the key.

8 MR. SHIPMAN: I think I agree with that.

9 At full stroke is not the key to determining the
10 availability of that system.

11 MR. BOSNAK: It may not be.

12 Can you differentiate between a disc that's in
13 place and one that is not, that has left the stem?

14 Is the test that you are doing now sufficient to
15 differentiate that particular condition?

16 And if we get a positive answer to that, I think
17 that would be the end.

18 MR. CHERNY: How do you think we just left that
19 item? I'm not totally clear.

20 MR. BOSNAK: If we can get a positive answer on
21 that -- I'm asking.

22 MR. CAPODANNO: I think the answer is it can't be
23 positive.

24 You know, there's a pressure control valve in the
25 system, which is downstream of these check valves. And it's

1 going to react to try and maintain adequate steam flow to the
2 turbine.

3 So, you could confirm, by turbine operability,
4 speed-up time, that there wasn't some restriction upstream.

5 But if I was to postulate, say that the disc came
6 out of the valve and somehow got aligned nicely along the
7 center line of the valve so it made virtually no obstruction
8 to steam flow, the pressure control valve would still
9 regulate flow to the turbine drive. It's not inconceivable
10 that the turbine would run perfectly normally and I might,
11 at this disc, dislocated, might not be able to discern it.

12 MR. BOSNAK: That sounds like maybe the only
13 condition. But other than that --

14 MR. PAGE: What if it had a restriction of flow?

15 MR. CAPODANNO: It's more likely that if a disc
16 came off its hinge pin it's going to restrict flow.

17 MR. BOSNAK: The regulator will call for more
18 steam. But if there's no more steam available --

19 MR. CAPODANNO: If it can't get past the
20 obstruction; right.

21 MR. PAGE: Then, it would definitely affect the
22 start time, how long it took to get up to speed.

23 MR. CAPODANNO: So, I think, realistically, that
24 degraded valve would, more likely, have a negative impact on
25 turbine performance.

1 MR. BOSNAK: Yes.

2 So, is there a turbine parameter that you could
3 measure that would help assure that? That's all we're
4 asking.

5 MR. COLITZ: We would have to take a look at that,
6 put something meaningful into the test.

7 MR. CAPODANNO: We're a little concerned about too
8 many variables.

9 If I end up having to track the turbine performance
10 itself, how quickly does it come up to speed? Was it pumping
11 as an indication of this performance?

12 I've also got to go back and look at this
13 regulating valve and try to figure exactly where it is and
14 what its position may tell me about the condition of this
15 check valve.

16 I've got a juggling act going on.

17 I'm trying to draw a conclusion from a dynamic
18 situation. If there's any kind of variability in the steam
19 flow, which I'm sure there would be, it's not exactly static.
20 The control valve is going to modulate somewhat. And it
21 becomes just ever more difficult to understand what the
22 turbine performance on the control valve position is telling
23 you about the condition of the check valve.

24 MR. BOSNAK: I guess all you can do is take another
25 look at it. If you feel that it's going to be complicating

1 the whole situation, then let us know and we'll go with what
2 we have here -- if you've taken an honest look at the
3 situation that you have.

4 MR. CAPODANNO: My reaction would be that the
5 thing words because the flowpath is open. Whether it's open
6 exactly theoretically the way it should be or not, I could
7 obviously not guarantee that 100 percent.

8 It also tells me the converse -- is that if the
9 check valve is so poorly degraded that the disc has come off,
10 I'm likely not to get any turbine operation. It's going to
11 be so poorly degraded that it's going to be extremely obvious.

12 MR. PAGE: At Dresden, they did get operation at
13 the start, because they were restricting the water flow. But
14 it didn' stop the water flow, it just restricted it.

15 MR. CAPODANNO: I'm saying the restriction should
16 reflect itself somehow in performance.

17 MR. PAGE: What we're looking for is some
18 performance that you can see that you feel good about.

19 MR. CAPODANNO: I'm just cautioning you against
20 the fact that you can't go in, say that the valve is not
21 50 percent over and is 42-1/2.

22 MR. PAGE: You couldn't do that. There could be
23 some indication you might make a gross judgment on. "Say,
24 I think I've got a valve problem," you know.

25 I don't know how you control valve acts.

1 But if that system is as variable as you say, I
2 think you've got a problem.

3 MR. CHERNY: What do you do with these valves
4 during normal operation? Are they normally closed -- these
5 gate valves?

6 MR. CAPODANNO: No; they are open.

7 MR. CHERNY: Those are left open, between the
8 steam generators and the check valves?

9 MR. SHIPMAN: Before I answer that question, let
10 me interject -- you indicated previously that if we have
11 actual, valid inspection information that shows -- that
12 documents what we saw the valve in an as-down condition after
13 opening up after X amount of service, that that may add some
14 credibility to a different interval of inspection.

15 I thought I also heard earlier that physical
16 inspection of the valve is not adequate to include full
17 stroke.

18 MR. PAGE: You have to use it sometimes if there's
19 no other way.

20 MR. CHERNY: I thought I heard you say you didn't
21 have that kind of data on these though?

22 MR. SHIPMAN: I don't.

23 But I think from my perspective, without making any
24 -- other than just conversation, I think that historically
25 there is data that will show valves of this service. And I

1 feel we could develop that data as we go along, also.

2 But I think there is some method or some interval
3 of physical inspection, and combined with our normal test of
4 the turbine, builds a very strong case that a hypothetical
5 degradation that you have been considering --

6 MR. PAGE: You're talking about data from just
7 around the industry?

8 MR. SHIPMAN: Our own data that we have developed
9 by inspecting our valves and inspection of this valve in
10 particular. If I would open this valve, this valve has
11 seen quite a bit of service -- if I were to open that valve
12 right now and it were to look brand new inside, that would
13 indicate to me that it's reasonable to assume that the next
14 10 years of service, with identical frequency of tests, you
15 wouldn't expect much different.

16 Is that unreasonable?

17 MR. PAGE: I'm drying on some earlier information
18 that I remember on HPSI and RCSI -- turbine valves, check
19 valves.

20 I don't know if you guys have a system that's
21 subsequent to that type of problem, where the system was
22 perturbing so much it was literally heating the valves to
23 death. That's a pretty severe environment, you know, turbine
24 supplies.

25 MR. SHIPMAN: But that environment wouldn't have

1 changed from our previous operational years. Okay?

2 So, whatever that mode of vibration --

3 MR. CHERNY: You're saying it's got 10 years or
4 something and the valves are new?

5 MR. BOSNAK: It depends on the valve design and
6 the service. If you've got 10 years of service, you'd
7 expect to have the same condition --

8 MR. PAGE: If you address it that way, it's best
9 to include everything you know about the valve, everything
10 in a nutshell. Even pictures sometimes are helpful. If you
11 shoot a picture while they open the thing up,
12 this is what the internals look like. We have similar
13 reports like that; and they tell you the history of it, in
14 terms of when it was put in, what kind of service it has seen,
15 what kind of repairs have been required to the valve over
16 time.

17 MR. BOSNAK: Let's go off the record here and
18 talk about logistics.

19 (Discussion off the record.)

20 (Whereupon, at 1:15 p.m., the hearing was
21 recessed, to reconvene at 2:15 p.m. this same day.)
22
23
24
25

AFTERNOON SESSION

(2:15 p.m.)

1
2
3 MR. ABRAMOVICI: We're starting with BS-V52.

4 (Slide.)

5 Let me point out a little typo, which should be
6 BS-V54A.

7 MR. COLITZ: The first letter we got was all
8 garbled there. You sent us a rewrite.

9 BS-V21 was the next one in there, the revised
10 letter.

11 MR. ABRAMOVICI: All right.

12 (Slide.)

13 Okay. The valves in question are the check valve,
14 BS-V21A and 21B. These valves were in the line supplying
15 sodium diosulfate.

16 Since then, sodium diosulfate tank has been
17 deleted from the system. The line has been kept -- and kept
18 the flanges.

19 And therefore, the valves no longer serve a
20 function.

21 MR. PAGE: What do they do now?

22 MR. ABRAMOVICI: Nothing.

23 MR. PAGE: There's no flow, no nothing?

24 MR. ABRAMOVICI: No.

25 The line has been cut and kept inside the

1 auxiliary building, with the flange. Those valves, I think,
2 are lopped closed.

3 MR. COLITZ: All three valves you're looking at
4 there are lopped closed.

5 MR. PAGE: So, basically, the system is just
6 totally a piece of pipe sitting there. There's absolutely
7 no requirement on the system anymore.

8 MR. ABRAMOVICI: That's correct.

9 (Slide.)

10 Again; just to make it complete, it's deleted from
11 the building spray; common line from the tank has been cut
12 and capped.

13 (Slide.)

14 Now, we can go to BS-V52.

15 This is the BS -- 52A -- came out as 44A.

16 The purpose of this line, as far as the building
17 spray system, is to provide sodium hydroxide to the LPI system
18 and the building spray for fission control and post-accident
19 cooling.

20 During normal operation this line is isolated
21 only during accident.

22 BS-V2s are open and would allow sodium hydroxide
23 to the LPI.

24 MR. PAGE: The point of discussion is the full
25 stroke on the 52 valves?

1 MR. ABRAMOVICI: Yes.

2 (Slide.)

3 We feel, by testing these valves, we would
4 introduce or increase the potential for sodium intrusion into
5 the reactor coolant and increase the sodium 24 activity
6 levels.

7 Secondly, we inspected those valves this year,
8 and they appeared in as-new condition.

9 MR. COLITZ: Inspected both valves?

10 MR. ABRAMOVICI: Both valves.

11 Any questions?

12 MR. PAGE: You said you wanted a part stroke each
13 refueling; is that what you said originally? Maybe you
14 changed that.

15 MR. ABRAMOVICI: I think in our submittal we said
16 part stroke because of the sodium intrusion potential and
17 so on, the difficulty of flushing out the lines.

18 MR. PAGE: So, you're withdrawing that proposal
19 for part stroke?

20 MR. ABRAMOVICI: Yes.

21 MR. CHERNY: The proposal on that is what? Just
22 to disassemble every 10 years; is that what you're saying?

23 MR. ABRAMOVICI: That what we supplied in the
24 original.

25 MR. PAGE: Would you be amenable to all the roles

1 we have been discussing here which you have inspected to
2 generate a single report based on what you found in this
3 inspection? I don't know if you took pictures or not, but
4 just whatever you did find in terms of the history of the
5 valves, what kind of maintenance, something to try to support
6 longer intervals between inspections or whatever we're talking
7 about here, put that under a single cover, something like
8 that.

9 MR. COLITZ: I think for these two valves and
10 other valves, if we need to give you that kind of history
11 to support our longer length of time versus -- on every
12 refueling-type thing, we're going to probably have to do that.

13 MR. ABRAMOVICI: If we did not inspect a particular
14 valve that's on the list, but it's a similar design -- I
15 should say identical design has been inspected, would you
16 want that, also?

17 MR. PAGE: Identical design and identical loading
18 conditions.

19 MR. CHERNY: It's a combination of the design and
20 the environment.

21 MR. ABRAMOVICI: If we test the one for 3000 gpm
22 and this service would be 2000 gpm, I think it would be using
23 the same --

24 MR. CHERNY: It's hard to say.

25 MR. PAGE: Stating it the way you stated it, it's

1 hard to make an exact --

2 MR. ABRAMOVICI: Using 14-inch Walworth Model X
3 that we looked at in a 3000 gpm service, with the same type
4 of fluid.

5 MR. PAGE: I hate to make it sound like you're
6 all in a Catch-22 or anything. But what it amounts to is
7 some valves suffer problems even from maintenance. So, the
8 loading condition is probably the primary thing.

9 We've seen ones that suffered bad maintenance
10 before, and their loading condition wasn't all that terrible.
11 So, it's a combination of a little bit of all those things.

12 I think we had two sets of two earlier that we
13 kind of grouped into one set of four valves. We felt that
14 was about as close as you could get in that particular
15 scenario.

16 Some of them aren't quite that close as far as how
17 similar they really are.

18 I think maintenance -- there are other things that
19 degrade valves.

20 MR. ABRAMOVICI: I was just asking if you want
21 that information. We have it available.

22 MR. PAGE: Of course, the more information you
23 have, it strengthens that case -- definitely strengthens.

24 MR. ABRAMOVICI: Slide.

25 The next item on the fluid block valves -- this is

1 a typical representation of fluid block connections to the
2 valve, getting fluid block.

3 During the accident, the primary boundary between
4 the reactor building environment would be the piping. The
5 second boundary would be the disc in the valve. And then,
6 you would have to go back to the check valve -- there will be
7 a third boundary -- to get a release on a breakthrough to the
8 auxiliary building.

9 And again -- I'll go through the next slide -- this
10 is pretty much a pictorial representation of how fluid block
11 is connected to the valves.

12 And those are the valves in question.

13 (Slide.)

14 We believe all these valves do not serve a
15 safety function. And -- their safety function is to remain
16 closed.

17 And we have submitted a request through the tech
18 spec Change Request 113 to delete those valves from our tech
19 spec.

20 MR. COLITZ: Delete the whole fluid block system?

21 MR. ABRAMOVICI: Right.

22 MR. PAGE: On what basis?

23 MR. COLITZ: It serves no function. We have never
24 been able to take credit for it. So, we asked basically to
25 have it deleted from the tech specs.

1 MR. PAGE: Do you know what the status is on that
2 now?

3 MR. CHERNY: I'm going to have to check that out.

4 MR. THOMPSON: I'm going to have to check it out.

5 MR. ABRAMOVICI: As I indicated before, significant
6 numbers of failures would have to occur for this system to be
7 needed.

8 And again, it's not taken credit for in any of the
9 accident analysis performed. And the valves are leak-tightness
10 tested for Appendix J as Type C.

11 The reason I included that was, in your letter,
12 that information was requested.

13 MR. PAGE: A lot of that hinges on whether the
14 system should or should not remain included.

15
16
17
18
19
20
21
22
23
24
25
end 13

1 MR.CHERNY: We'll have to check on that review or
2 not doing that review.

3 MR. PAGE: Containment Systems Branch.

4 MR. COLITZ: I don't know what you could do for
5 maybe get a feel for where that tech spec change is, but I
6 think it would be prudent to get that maybe for you to at
7 least act upon so we don't all agree that we have got to go
8 do this, write test procedures, start doing this and find out
9 a week later that the tech spec change has been approved and
10 we delete the whole system.

11 MR. THOMPSON: We will do that. We will do that
12 tech spec change concurrently.

13 MR. PAGE: That could be handled easier because
14 if you have got one in like that, you could shoot that in on
15 a single relief request saying based on that record we want
16 to delete this from the IST program, which can be handled
17 easier from relief request.

18 Do you want to handle it? Do you want to handle
19 it separately? We could discuss this one now, should it not
20 be deleted is what it amounts to.

21 MR. CHERNY: Let's not get into that now.

22 (Slide.)

23 MR. ABRAMOVICI: The next set of valves are the
24 pump discharge check valves MU-V 73, A, B and C and MU-V 17,
25 A,B,C and D stroke testing.

1 (Slide.)

2 Again here we are not asking for an exemption
3 request. We are full-stroke stroking the valves, each refuel-
4 ing outage additionally for correctness. As far as was stated
5 in the letter, the MUV-73 A,B,C are stroked whenever the
6 particular pump is in operation and it is at least quarterly.

7 MR. PAGE: Basically, even though I felt that you
8 had it, you didn't include it as part of the writeup.

9 MR. ABRAMOVICI: That is why it is written up.

10 MR. COLITZ: It is only the 73s though that get
11 part stroked, the 107's don't.

12 MR. PAGE: The 107's don't get part stroked?

13 MR. ABRAMOVICI: Just full stroked.

14 (Slide.)

15 I apologize for the MU-V14. There should be the
16 motor showing the other way. It is not physically installed
17 this way.

18 The MU-V14's are the suction stop check valves from
19 the BWST to the makeup in the HPI system. This is a little
20 bit of a missing portion on the schematic for the HPI.

21 (Slide.)

22 Again, we do not require relief request on this
23 one. We full stroke every refueling outage.

24 MR. PAGE: You said there is no part stroke here?

25 MR. ABRAMOVICI: Full stroke, no part stroke.

1 (Slide.)

2 Same slide back up again. This deals with stroke
3 testing both MU-V95, 94, 86B and 86A and we have added to the
4 list MU-V220 because at time of submittal I guess originally
5 HPI cross connects were not in.

6 (Slide.)

7 Flows through all those valves is verified at each
8 refuelling outage and we will be trying to develop a correla-
9 tion between the main flow instruments, the one that I showed
10 circled--

11 (Slide.)

12 -- on here, which is typical of all the lines in each
13 cavitating Venturi flow instrument on those lines.

14 MR. PAGE: Are these the flow instruments I
15 indicated in my writeups?

16 MR. ABRAMOVICI: Yes.

17 MR. PAGE: 385, 386, 384. What my question was
18 on there, do you have any details of what your startup test
19 plans are based on what your readings are?

20 Are you going to assure that the flow elements
21 stay within a certain acceptable band of where they were at
22 startup?

23 MR. ABRAMOVICI: All I can tell you is we will be
24 trying to correlate the flow instrument on the main lines and
25 flow instrument individually and see if we can somehow

1 correlate the flow split between each line, the required flow
2 strip.

3 MR. PAGE: In terms of IST, you are going to be
4 flow checking the test valves. Are you going to make a basis
5 based on what you find here? Based on what your flow elements
6 are reading for future acceptability?

7 MR. ABRAMOVICI: You will be trying to develop that.

8 MR. SHIPMAN: There is not a direct readout of the
9 flow element, the 380 number that you gave us. Those are
10 the cavitating Venturies; we do not have any DP instrument
11 across them.

12 MR. ABRAMOVICI: They are temporary flow instruments.

13 MR. PAGE: Let's start over again.

14 The FE-384 and 385, 386 and 387, which you referred
15 to, are cavitating Venturies, there is no DP sensing or
16 indication provided with those.

17 Those are merely flow limiters. Flow indicators
18 that we were talking about using during the startup testings,
19 are the ones that Julien has indicated on the transparency
20 there upstream of the individual 16 valves.

21 These are permanent instruments. There is a
22 startup test that I think are given in the draft of the
23 startup test procedures, 655 -- there is a startup test
24 procedure developed that installs temporary controlatron
25 strap-on flow meters at several locations on the cross connect

1 piping. It is that test, the information from those temporary
2 instruments that we hope to correlate back to the MU-23 flow
3 instruments upstream at 16 valves to determine how adequately
4 we can say we have tested individual valves.

5 MR. PAGE: Based on what you find with those
6 instruments, do you have any idea of what percent deviation
7 will allow in terms of --

8 MR. ABRAMOVICI: Don't know at this point. Until
9 we run the test, it is going to be very difficult to predict.

10 MR. COLITZ: We should be running that test within
11 the next two weeks. We'll really wait and see the results,
12 what information we could gather before we do.

13 MR. PAGE: I was wondering, it seems like -- I
14 don't know if we have had a situation like this before. You
15 already know about what you are going to get, at least ballpark,
16 what you should get, what you hope --

17 MR. SHIPMAN: Yes.

18 MR. PAGE: I was wondering based on that if you
19 allow a certain amount of deviation for instruments and stuff
20 like that but you will try to incorporate that, right, in
21 terms of the valve testing?

22 That is basically what the question really is.

23 MR. ABRAMOVICI: We will definitely try.

24 MR. BARLEY: It is dependent on how good we can
25 correlate back to the installed flow instruments in the piping

1 is what the dependency is and we don't know how well we are
2 going to be able to do that until we have the startup test
3 data to really analyze it.

End 14. 4

(Slide.)

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. ABRAMOVICI: The next item for discussion, I
2 think, is Item B-3 and that deals with stroke testing of
3 emergency feedwater valve V3, which is from the emergency
4 river water service. The normal water to emergency feedwater
5 system is supplied by the two condensate storage tanks. We
6 have backups to that, the main condensor and the demineralized
7 water storage tank. When all those four sources of water are
8 lost, then the alternate source of water would be from the
9 emergency river water.

10 This line has normally two closed valves and is
11 not being used.

12 MR. PAGE: Why do you have it there at all?
13 I don't see what the valves are doing for you.

14 MR. COLITZ: Check valves.

15 MR. CAPODANNO: It's beyond us. We don't either.
16 It's something that was put in there when the AE designed the
17 plant. The way the plant is now operated, that check valve
18 is really gilding the lily.

19 MR. PAGE: I was just wondering, would you all
20 consider just stuffing it and putting the top back on? I
21 can't think of any use for the thing. It's a component that
22 sits there. It could get in your way. You're going to know
23 the MOVs work. I hope you do stroke testing on those, at some
24 point. I can't imagine what that V3 valve does. I can't
25 figure it out from that drawing. It's an extra piece of

151b2

1 equipment that is unneeded.

2 (Slide.)

3 MR. ABRAMOVICI: Again, just for correctness,
4 this is supposed to be a symbol for the turbine driven
5 feed pumps. There are two motor driven and one turbine
6 driven. So this is the turbine driven. Those were two
7 motor driven.

8 MR. COLITZ: Are you going on to the next sheet?

9 MR. ABRAMOVICI: Yes.

10 (Slide.)

11 He's still presenting on this one. Again, the
12 basis for exemption, the system has diverse backup to the
13 normal water I just explained. And secondly, if we use river
14 water, the water chemistry can cause steam generator damage.
15 We don't want to use river water.

16 MR. PAGE: You can disassemble, though, right?

17 EF is 82?

18 MR. ABRAMOVICI: 81.

19 MR. PAGE: 81 would show the two MOVs. I don't
20 think I got that one.

21 MR. SHIPMAN: Both motor operators are shown on
22 610.

23 MR. ABRAMOVICI: The four and five.

24 MR. PAGE: The 610?

25 MR. SHIPMAN: I believe so. It's the river water.

1 (Discussion off the record.)

2 MR. COLITZ: The point we were trying to make,
3 I think, is that the condensate tanks and the million gallon
4 demin water storage tank and the condensor, the likelihood
5 of ever having to go to the river is pretty far, and the
6 concern considering the chemistry concerns with getting
7 river water into the piping of the steam generators, we can't
8 justify doing anything to the check valve. We can't even
9 justify what we're doing right now to the motor operated valve.

10 MR. PAGE: But you've taken credit for having that
11 ultimate source of water. If you can't get it somewhere else,
12 there is credit. And let's see, if I remember looking at
13 these right, that's seismic 1 all the way back to the river.
14 So I assume there's a certain amount of importance given to that
15 line. Other people have the same problem. They have event
16 between the two MOVs. They don't have the check valve. That's
17 a new one. That's why I asked about it.

18 But they have the two MOVs with a vent drain
19 between them. The last people we talked to, I think you're
20 going to put a vent in the top. So after they stroked the
21 two MOVs, they can steam it out. They leave the middle vent
22 open. That way, if water does come in between the two valves
23 it goes back down on the ground.

24 They don't have to worry about getting it into
25 their -- it can't leak out of the system, but they're not going

1 to leak in, is what it amounts to. Do any of those things
2 sound reasonable, or even removing the guts from the check
3 valve, which personally would be my first choice?

4 MR. COLITZ: We can look at removing the guts
5 from the check valve. I don't want to commit to that without
6 looking at all the design requirements, why it went in there,
7 and have somebody come up with a good reason. I don't see
8 a reason why it's there.

9 MR. PAGE: I don't either. The reason I ask is
10 because I've seen the system in other plants and we don't have
11 it.

12 MR. ABRAMOVICI: There's a check valve up the river
13 system for emergency feedwater.

14 MR. CHERNY: Four valves in that line?

15 MR. CAPODANNO: Two motor operating valves and
16 the check valve. I think [redacted] might have been referring
17 to a check valve on the discharge side of the pumps. But there
18 is between the river water pumps and the suction header,
19 for emergency feedwater system, two motor operated valves
20 and this check valve.

21 MR. CHERNY: There's not another one out here?

22 MR. CAPODANNO: No. If you go back that way, you
23 know, into the river water system itself, but that's really
24 no longer the interface between the river water system and
25 emergency feedwater.

151b5

1 MR. THOMPSON: So the resolution of this, firstly
2 you will look -- investigate on eliminating that valve?

3 MR. CAPODANNO: Yes.

4 MR. THOMPSON: And should we go further than
5 if you cannot do that or are you holding high hopes that that
6 can be done?

7 MR. COLITZ: I think it could be done. We need
8 to look at that, though.

9 MR. CAPODANNO: The real point Joe is trying to
10 make and Julie is trying to make is simply this is kind of
11 the redundancy on top of the redundancy, so to speak.

12 MR. THOMPSON: But the issue, with that particular
13 valve, is that it needs to open when you need it, which is
14 going to be assuming essentially never. And I see what Joe's
15 point is. And if that seems like a particularly vulnerable
16 spot there, if it sits there for a long period of time and
17 never gets used or tested, it seems like it's a weak point in
18 the system.

19 MR. COLITZ: Chemistry is a major concern, too.
20 Another reason we had problems with our two steam generators
21 is due to some of the surveillance testing we did.

22 MR. PAGE: This thing isn't going to help in
23 chemistry. It's pointed in the wrong direction to help,
24 in terms of chemistry.

25 MR. COLITZ: If I get that river water in the

1 steam generators, it doesn't help.

2 MR. PAGE: I hope this valve doesn't keep it
3 from going in there. It's headed in the wrong direction.

4 MR. COLITZ: What I'm saying is every time I
5 cycle those valves, the two motor operated valves --

6 MR. PAGE: I understand that. But I'm saying this
7 should have no restriction whatsoever.

8 MR. CAPODANNO: The check valve doesn't.

9 MR. PAGE: Not in the flow direction. So the
10 contamination, if you should get this contaminated, the only
11 thing that's helping you, I guess, is the pressure holding
12 the valve closed. Do you have a drain between your two
13 MOVs?

14 MR. CAPODANNO: No.

15 MR. BARLEY: Physically, there's about a foot
16 of pipe between the two valves.

17 MR. PAGE: That's probably why it's there. There's
18 no drainage between the two MOVs.

19 (Discussion off the record.)

20 MR. THOMPSON: I think we would like to go
21 a step further because it seems there may be some good reasons
22 for having that check valve in there. And I think I would
23 like to hear us discuss the other alternative or another
24 alternative.

25 MR. CHERNY: Maybe you'd like to state what you

151b7

1 just said a minute ago, why you think it's in there.

2 MR. PAGE: It appears you're right. The
3 contamination was a concern. What they did was put the
4 vent behind the check. Had they put the vent between the MOVs
5 there would be no reason at all for having that valve. But
6 here, by putting it in here, you can vent or through this
7 flush connection, you're essentially putting your barrier
8 between your contaminated water and your system here.

9 And that's -- they shouldn't have done it that way.
10 It's not a particularly design, I don't think.

11 MR. SHIPMAN: One other point that should be made,
12 I don't think, if we had a valve there, that that would not
13 necessarily be a flush valve, it would be a drain valve.
14 And to convince our chemists that we have adequately flushed
15 that area is a task that sometimes takes a long, long time.

16 MR. CHERNY: I don't think I understood what he
17 just said about convincing the chemists. What's the problem
18 there?

19 MR. CAPODANNO: The concern was that you can do
20 one of two things, if you're concerned about chemistry. You
21 can simply drain the volume, but that doesn't flush it with
22 clean water. I think Henry's point was that simply draining
23 it may not satisfy the chemists that that volume, that has
24 been drained, is really totally flushed of contaminants. You
25 fill it back up again, you may in fact introduce contamination

1 in the steam generator anyway, even though you theoretically
2 drained it.

3 MR. SHIPMAN: And theoretically flushed it, Gary.
4 There's no guarantee that filling it back up with steam and
5 water and then draining it again has removed the contamination.
6 We used to have a flush for the thiosulfate tank test. And
7 we're being questioned whether that flush was adequate and
8 what contribution that had into the failure of the steam
9 generators.

10 MR. PAGE: The line itself has always had higher
11 pressure than the river, obviously.

12 MR. SHIPMAN: No.

13 MR. PAGE: You always have higher pressure in the
14 system than you do out here, attached to the end of this pipe,
15 coming from the river. Is that correct?

16 MR. CAPODANNO: Only if the river pumps aren't
17 operating, running off the static head from the water in the
18 condensate storage tank against that check valve.

19 MR. SHIPMAN: Those motor operated valves are
20 locked closed --

21 MR. PAGE: Is the pressure always higher downstream
22 of the check valve than upstream, of the check valve?

23 MR. POLITZ: The fours and fives are locked closed.

24 MR. CAPODANNO: If the river water pump is operating
25 and the motor operated valves are open, clearly the river water

151b9

1 pressure is at higher guage pressure than is the other side
2 of the check valve.

3 MR. THOMPSON: So the question appears to be one,
4 can you essentially remove that check valve by taking out
5 the internals and if that's not a viable option, what can
6 be done to do an inservice testing program on it?

7 MR. PAGE: Can you include this in the disassembly
8 report, if that be the answer, as opposed to gutting the
9 valve?

10 MR. COLITZ: I don't know if we've ever done any-
11 thing of this type.

12 MR. SHIPMAN: I don't know if we've ever opened
13 these two valves. The position I thought we were trying to
14 persuade you with was the argument that we have a tech spec
15 requirement for condensate tank storage. We have
16 additional water in the hotwell that is available to us. We
17 have an additional water in both the hotwell and this
18 additional source, which is the demin gallon tank, are not
19 tech spec reliable, but are available as a source of water
20 to the emergency feedwater system.

21 We have procedures to categorize these as the
22 sources of water you go to, and for any design basis accident,
23 I believe those sources of water ruled out the use of these
24 valves. And if, in the remote chance that we had to use
25 these valves, there is time enough to take the valve apart, if

151b10

1 the valve didn't work, for some reason, we have enough talent
2 and energy and material that we would find some juryrig.

3 In a real sense, there are things that we did, during
4 the Unit 2 accident, that weren't ISI tested that were thought
5 of on the spur of the moment that helped mitigate that accident.

6 MR. PAGE: Would you like to rely on that
7 procedure again, to get out of another one?

8 MR. SHIPMAN: For the one item that I have in mind,
9 it would be adequate for me.

10 MR. PAGE: At least the way we look at it -- I know
11 everyone doesn't look at it this way, is that what is required
12 for the IST program is any level -- you may have three or
13 four levels of protection or potential sources of water,
14 whatever they are, that if their credit had been assumed through
15 some reactor system auxiliary systems or whatever, we feel
16 they should be in the IST program in testing. That's a real
17 basic concept. We just feel that all components that have
18 been taking credit for them, it may be the fourth level, it
19 may be the second level in a different scenario. But that's
20 kind of where we're coming from.

21 We would just like to see the thing in the program
22 and tested at some level.

23 MR. CHERNY: Is there any accident scenario that
24 you do take credit for this system, this source of water?

25 MR. SHIPMAN: I'm not prepared to answer that

1 question. I have always read that if you run out of demin
2 water, you've got a river water source. I don't know, to
3 my recollection, I have no tech spec that tells me that that
4 source of water has to be available.

5 MR. CAPODANNO: I think the answer --

6 MR. SHIPMAN: Yes, I do, fire service.

7 MR. CAPODANNO: It's really no. We have identified
8 this as a backup source of water that could be used. But in
9 every analysis that I'm aware of, every presentation or
10 inquiry that's been made about the emergency feedwater system,
11 we have had to demonstrate that we had adequate inventory
12 available in the two condensate storage tanks and with the
13 loss of one tank or the other, we would then go through a
14 description how the backup inventory available in the hotwell
15 and demin water tank was also available as "good quality
16 water."

17 So long as I know, most of the source has gotten
18 kind of a casual mention and said, if everything you could
19 possibly think of went wrong, regardless of how improbably that
20 was, this was still an available source of water.

21 MR. PAGE: Is it possible to leave your two tanks
22 for a common mode?

23 MR. CAPODANNO: No.

24 MR. COLITZ: They're opposite sides of the plant.

25 MR. CAPODANNO: We went through that issue

1 separately, in responding to the 81-14 generic letter on
2 emergency feedwater systems. In particular, how ours
3 functions.

end15

4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

16pbl

1 I think probably a point Henry was trying to
2 get to in regard to these valves maybe didn't come across
3 entirely clearly. As part of our evaluation emergency
4 feedwater analysis of the amount of water available in the
5 storage tanks and so on, we have established procedures to
6 assure that inventory is available and that it gives you
7 at least eight hours or so of cooling water inventory.

8 And I think Henry's point was, given I have that
9 eight hours, I certainly have enough time to go down and
10 simply take the internals out of these valves. Once they
11 are an open conduit that river water source is available.

12 So there's plenty of time to respond to this
13 extremely remote condition of having to use this in the
14 first place.

15 MR. THOMPSON: How long would it take to go down
16 there and strip it out and cap it and get your line back
17 into operation? I mean, I just think of a situation where
18 all of a sudden you realize, hey, we're suddenly out of
19 other sources. We may have to go to the source. You may
20 not have the eight hours --

21 MR. SHIPMAN: Correct me if I'm wrong, Gary.
22 The eight hours is based upon the tech spec required source
23 of water. That does not include the two --

24 MR. SPODANNO: That's correct. The eight hours
25 does not include the hot well or the backup million gallon

16pb2

1 tank. I couldn't answer your question specifically. I
2 haven't time for somebody taking these valves apart. They're
3 in an area in the intermediate building. They're easy to
4 get to. They're about waist high. They're not big valves.

5 I would say --

6 MR. THOMPSON: Hours at the most?

7 MR. ABRAMOVICI: They have eight bolts, I would
8 say, half inch or less.

9 MR. CAPODANNO: I would say probably one individual
10 could take a valve apart and certainly two working as a
11 crew can get it apart in very short order.

12 MR. CHERNY: I think we're going to have to talk
13 to some systems people about that. I don't think we'll
14 be able to answer that now.

15 (Slide.)

16 MR. THOMPSON: Have you agreed to look at the
17 possibility of taking that apart now, eliminating it? Or
18 did you reserve judgment on whether you'd even look at that?

19 MR. COLITZ: We're going to go back and see
20 whether that valve is required or can be taken out.

21 (Slide.)

22 MR. ABRAMOVICI: The next item is Item B-4 and
23 it deals with check valve exercising on feedwater system
24 valve 12-A and 12-B. This line is the normal line from
25 which feedwater comes into the generator into normal power

16pb3

1 operation.

2 So the valves will be stroked tested every time
3 the generator is put into service, the feedwater system is
4 put into service.

5 (Slide.)

6 This is the basis for our exemption request. We
7 have again inspected those valves, in approximately 1981,
8 and we can include that with the submittal of the final
9 inspection report.

10 I think one of the two has been inspected to be
11 correct.

12 MR. SHIPMAN: B has been inspected I know.

13 MR. ABRAMOVICI: At least one has been inspected.

14 MR. PAGE: This valve has to shut on loss of
15 main feedwater?

side 2 bu

16 MR. ABRAMOVICI: Yes.

17 MR. CHERNY: Let me understand that right --

18 MR. PAGE: We're talking leak rate testing in
19 this particular instance we're back off full stroking and
20 backup to close position type testing.

21 MR. CHERNY: What you just said though --

22 MR. PAGE: On loss of main feed the valve has
23 to close to prevent flowing back up that line.

24 MR. BARLEY: Let me correct the record on one
25 item. We did inspect both A and B valves.

1 MR. PAGE: Both valves?

2 MR. CHERNY: So it's to prevent reverse flow in
3 the feedwater line.

4 MR. PAGE: It's hard to tell from this drawing.
5 (Discussion off the record.)

6 MR. CHERNY: Where does the auxiliary feedwater
7 come in?

8 MR. COLITZ: It's a separate line.

9 MR. CAPODANNO: Entirely separate.

10 MR. PAGE: I think the isolation would be the
11 V5A and V12A if you should lose main feed.

12 MR. ABRAMOVICI: Yes. I think it's 5 and 12.
13 Yes, motor operated 5A and 12A.

14 MR. CHERNY: How often do you experience a loss
15 of feedwater?

16 MR. COLITZ: Have we ever had a loss of feedwater
17 at TMI? Not that I know of.

18 MR. SHIPMAN: Yes. Remember when we had the
19 acid induction? We had a problem around 1977 when we were
20 regenerating our demineralizing machine, that makes
21 demineralized water. We had a valve problem that inadvertently
22 put some sulfuric acid into the hot well. And at that
23 point we shut off main feedwater and went on emergency
24 feedwater.

25 MR. CHERNY: That's the only time?

16pb5

1 MR. SHIPMAN: But that was a chemistry concern
2 with the steam generator. It's not a loss of feedwater
3 event. It was at about 50 percent power.

4 MR. PAGE: Loss of off-site power would also
5 lose main feed.

6 MR. SHIPMAN: Yes. We also have -- we presently
7 have a feedwater isolation criteria on low steam generator
8 pressure, if that helps in the understanding. The 5 and the
9 92, 16 and 17 valves are closed, which are just upstream
10 of that power.

11 MR. PAGE: Going through most of these design
12 concepts, it seems like we always put two barriers on
13 something. When we go from an injection mode or a recirc
14 mode, it seems like there are always two barriers, single
15 failure criteria, which I guess is a very basic design
16 concept.

17 In looking at this one, it seems like the 12
18 and the 5 valve would be the ones for that particular concept
19 of losing your main feed for whatever reason you lost it,
20 whether it was a line break or whatever. That's why I
21 was wondering, it seems like the V12 valve should receive
22 something like a reverse flow test just to see that it
23 checks.

24 MR. CHERNY: What are the consequences of one
25 of those valves not closing as it's supposed to. Obviously

16pb6

1 it will blow the steam generator down.

2 MR. COLITZ: I think manual control of the 5s
3 and 12s would close them, whatever the other one is, the
4 two series.

5 MR. SHIPMAN: 5s and 92s, 16 and 17. If we had
6 a loss of feedwater because of either a line severage, a
7 feedwater line break on either side of that check valve,
8 inside or outside the reactor building. The consequences
9 to me as an operator, and I'm a licensed operator, are that
10 I have procedures that would prevent me from removing heat
11 from the reactor, emergency feedwater.

12 MR. PAGE: Would this valve be part of that
13 procedure?

14 MR. SHIPMAN: No, that valve is not part of that
15 procedure.

16 MR. PAGE: In other words, this valve would not
17 be included in any credit taken for that isolation.

18 MR. SHIPMAN: I'm an operator, I'm not the
19 safety analysis guide. To me, as an operator, that valve
20 plays no role in that loss of feedwater accident.

21 In the safety analysis, I can't answer that
22 question at this moment.

23 MR. PAGE: My guess would be, safety analysis
24 would take credit for it and the operator would have to
25 close the 5 valve just for insurance. I imagine that's the

16pb7

1 one that shows up on the procedure.

2 MR. SHIPMAN: The 5 and the 92 and the 16 and the
3 17 show in the procedure. They are automatically closed on
4 a system that senses steam generator pressure. When that
5 steam generator pressure decreases to 600 pounds, those
6 valves would close and the steam generator would blow down
7 and decrease in pressure on loss of feedwater.

8 MR. PAGE: The 92 valve?

9 MR. SHIPMAN: 92 is the block on the startup
10 valve 16.

11 MR. BARLEY: It's a bypass, flow-pass.

12 (Discussion off the record.)

13 MR. CAPODANNO: You had said something earlier,
14 I'm not sure, but maybe there's a murkiness in the
15 understanding.

16 The reason that the valves that were just pointed
17 out to you are there to get the isolation signal is to
18 make sure you cease to add water to an affected steam
19 generator, not working in a reverse direction to back up the
20 check valve.

21 I thought I heard you say earlier, that you have
22 an understanding that they might also be backups to the
23 check valve. It's really not what they're in there for.

24 MR. PAGE: I'm saying that they look like the
25 likely partner to do this reverse flow situation.

16pb8

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

MR. CAPODANNO: They're there. You can close them if you choose to, but their real isolation function is to prevent further water addition to an affected steam generator.

MR. PAGE: This may be their secondary responsibility if they show up in a procedure something for that particular scenario, they may have been designed for use in that just in case.

end 16.

1 MR. CHERNY: That is another systems configuration.
2 (Slide.)

3 MR. ABRAMOVICI: The last item on the list is
4 Item B-5, which is the building spray check valves inside the
5 reactor building to the spray headers, BS-V30A and B in
6 particular. Normally the system is inactive. The only time
7 the system would be active is on 30 pounds of building pressure
8 and water would be supplied from the borated water storage
9 tank to the building spray pump. BS-V1A's and B's will be
10 open and water will flow through the check valves to the
11 spray header inside the building.

12 Again, if the BWST water is depleted, then the
13 suction would be switched to reactor building sump and the
14 decay to the RPI system.

15 (Slide.)

16 The basis for exemption is if we would do a full
17 flow test on the reactor building spray. With those valves
18 the reactor building spray will activate and spray down the
19 reactor building. We do do a part stroke test for plant
20 procedure with 1303A; that is an air test.

21 MR. PAGE: Very small part stroke?

22 MR. ABRAMOVICI: Yes.

23 MR. CHERNY: Where are these valves physically
24 located?

25 MR. ABRAMOVICI: Inside the reactor building, lower

1 elevation.

2 MR. CHERNY: Lower elevation?

3 MR. ABRAMOVICI: Yes.

4 MR. SHIPMAN: About 10 feet off the floor, the
5 floor, 281 elevation.

6 MR. PAGE: Have they been disassembled at all?

7 I guess you have disassembled quite a few valves it seems like
8 in the last few years?

9 MR. BARLEY: These weren't disassembled to my
10 knowledge.

11 MR. ABRAMOVICI: We can check.

12 MR. CHERNY: They do a part stroke quarterly.

13 MR. PAGE: Do you have a permanent --

14 MR. COLITZ: That's another operator burden.

15 MR. PAGE: Do you run in there?

16 MR. COLITZ: His people do it.

17 MR. SHIPMAN: I believe the actual connection that
18 we make to connect the areas in the auxiliary building, down
19 in the reactor building to the vent, just this side of the
20 wall but it still requires manipulation of a bottle of
21 compressed air, connection of the bottle to a contaminated
22 system in an RWT area.

23 MR. PAGE: You have two different connections, one
24 on either side of the valve, so you can blow air one way and
25 blow it the other to make sure it is closed?

1 MR. SHIPMAN: Just blow it in the one direction,
2 in the open direction. We also do another air test that is
3 inconsequential but we are required to do a path free open
4 test up to the hozzles on the spray headers. That is another
5 air test.

6 I am not sure it checks the BS-V30 but I think it
7 is kind of downstream of the 30.

8 MR. PAGE: So you are using a three-quarter inch
9 connection basically to check an 8 inch valve -- a 6 inch
10 valve?

11 MR. SHIPMAN: I think it is 8 -- the 6 inch is a
12 cross connector used for recirculation purposes. It is an
13 8 inch system.

14 MR. PAGE: It's 8 inch.

15 MR. SHIPMAN: Yes, sir.

16 MR. CHERNY: These have not been recently inspected?

17 MR. ABRAMOVICI: Yes.

18 That concludes my presentation.

19 MR. THOMPSON: So where did we finish? Would that
20 be 5?

21 MR. CHERNY: This is essentially a static lull
22 except when they run their air testing.

23 (Discussion off the record.)

24 MR. CHERNY: Well, in this fairly quiet environment,
25 I think we have to discuss a little further whether once in

1 ten years isn't very often. On the other hand, I don't know
2 if in a particular situation once every refuelling is necessary.
3 That is generally a proposal for a line that is not so quiet.

4 MR. PAGE: Could you include this in that disassembly
5 report?

6 MR. COLITZ: I think we could go back and find out
7 that we probably have not disassembled as often.

8 MR. PAGE: There may be one or two that we talked
9 about in terms of disassembly. I was wondering if maybe you
10 were to do it as a complete package, would go ahead and do
11 those as part of the sequence and just make it one complete
12 report and we could look at it in toto and see what intervals
13 would be appropriate for those groups of outages.

14 MR. THOMPSON: Are you suggesting that they go
15 ahead and actually inspect this one?

16 MR. PAGE: I think we have two or three that have
17 not been but they have a pile that have been, but to make it
18 a complete package would be to sample from each of these
19 other systems which I think there may have been two, to go
20 ahead and do those and make a complete report requesting under
21 intervals other than refueling outages.

22 MR. CHERNY: I think that is a general comment to
23 make on all of those.

24 MR. THOMPSON: Do you have any response to that?
25 I think what we are saying, if I am correct, is to go ahead

1 and inspect a selected small number of valves additionally
2 now, report all the results of those inspections along with
3 all the others you have done by grouping them into similar
4 types of environment and types of valves or models and so on.

5 MR. PAGE: I think we handled them under discussion
6 in groups.

7 MR. THOMPSON: And the result of all that, too,
8 for example on this last item, to say we have checked one of
9 these that is 10 years old and no significant deterioration
10 therefore there is a basis for going another 10 years before
11 checking the next one, is that what we are saying, Joel?

12 MR. PAGE: I don't know if 10 years is going to be
13 the appropriate interval. I am saying they ask for definitely
14 longer intervals on each refuel, to sample each refueling.

15 MR. THOMPSON: This is what they are asking for now,
16 ten years. They have gone 10 years, not looked at either as
17 I understand it, so you want to make it 20 years before you
18 look at them.

19 Now what we are suggesting is that you look at
20 maybe inspecting one of them now and giving a compromise time
21 for the next inspection.

22 MR. COLITZ: We will go back and look at all these
23 valves you talked about, go back to the machinery history.

24 We are in the process of getting ready to heat up
25 at the end of this week. I am not sure plant conditions are

1 going to allow me to go in and inspect any valves in the
2 immediate future that kind of add to the package.

3 What we can do is look at what we have done to date
4 and put that type thing together.

5 We'll look at it and I may find out that I just
6 don't recollect ever taking this apart, but there was a period
7 of time I wasn't at the plant and we may find out the
8 machinery history, 1974-75 or something, that we did some
9 repairs to this valve, had it disassembled, I don't know --
10 but we will go back to the machinery history on all of the
11 valves we talked about.

12 MR. PAGE: All the candidates for disassembly?

13 MR. COLITZ: Yes.

14 MR. PAGE: That sounds good.

15 MR. THOMPSON: Now the tough part is to go back and
16 summarize what we have covered so far.

17 MR. CHERNY: I think we have to talk in generalities
18 first.

19 MR. THOMPSON: Before we get to generalities,
20 there is a couple more items on this April 8, 1982 memo that
21 I don't know were addressed.

22 Item 2 was to grant relief for P sub I and
23 T sub B but not for delta P on that spent fuel pumps.

24 MR. COLITZ: Where do we stand on that one?

25 MR. WASHISTA: I guess we have to look at them.

1 We are not prepared to address this.

2 MR. BARLEY: I wasn't prepared to address this
3 subject. We have taken the spent fuel pool level into account.
4 I am not certain whether we have taken the spent fuel pool
5 level into account in the delta P calculation for that pump.
6 I have to go back to that procedure and look at it.

7 MR. THOMPSON: So you are not prepared to look at
8 that or discuss that one relief request that was not granted,
9 is that right?

10 MR. COLITZ: I think we concentrated on this last
11 memo. I didn't go back, taking this memo to see what we did
12 with that one. I don't recollect either.

13 MR. THOMPSON: You only got this with this packet.
14 That had not been formally submitted prior to --

15 MR. COLITZ: This never came in back in '82?

16 MR. THOMPSON: No. That has not been issued to you
End 17 17 other than as an attachment to this meeting notice.

18

19

20

21

22

23

24

25

1 MR. COLITZ: I guess item 3 is only other item,
2 and that has to do with those boric acid mix tank pumps.

3 MR. THOMPSON: Which may go away.

4 MR. COLITZ: Which we discussed at great length.

5 MR. CHERNY: Who is going to do what? And by when?
6 Let's go off the record.

7 (Discussion off the record.)

8 MR. THOMPSON: Let's go back on the record.

9 I think what we need to do at this point is I'd
10 like to see us summarize what we have here, send them home
11 to do their homework, us to do ours, and set some time in the
12 very immediate future to get back together by telephone and
13 then see what we have left for the managements to argue out.

14 MR. COLITZ: Let me ask you, because it's not clear
15 to me, the letter that was formally submitted to that, has
16 that been signed? And is that an official NRC letter that
17 we are supposed to respond to or what?

18 MR. CHERNY: These two letters -- you're referring
19 to this April 8 of '82 and May 2 of '84?

20 MR. COLITZ: Yes.

21 MR. THOMPSON: They are in the docket room by
22 virtue of being attached to the meeting notice. They have
23 not been formally submitted to you.

24 What we have been trying to do is to resolve open
25 items by discussion, rather than by paper.

1 I had hoped that we would be ready to put something
2 down in writing by the end of this meeting. Now it looks like
3 we've still got more things. We could put that down in
4 writing as a partial submittal, just taking resources to do
5 that. If you feel that needs to be done, we can certainly do
6 that.

7 MR. CHERNY: You lost me with that statement.

8 What's the partial submittal?

9 MR. THOMPSON: We still have a lot of open items.
10 We have to talk to our systems people. They have to provide
11 more information to go ahead and document that --

12 MR. CHERNY: The transcript is a partial submittal.

13 MR. THOMPSON: More than on a transfer from today
14 -- if we can agree, of what we are each going to do, I would
15 hope we could get back together in the next few days, next
16 week or something like that, and resolve them and try to do
17 it without back and forward letters.

18 But if you feel you need more than that, I would
19 like to know that.

20 MR. COLITZ: Maybe what I want to do is go down --
21 again, we ought to go down each of the items and summarize
22 where we think we're at.

23 MR. THOMPSON: We can put that on the transcript
24 and excerpt that as a --

25 MR. CHERNY: Let's do it that way.

1 MR. COLITZ: Some of these are, to be honest with
2 you, tough issues -- on primary to secondary or primary high-
3 pressure to low-pressure isolation. To go in and check each
4 valve -- okay, understand now today -- and I don't think I
5 understood it before, that it's not an Event V, but an NRC
6 management requirement, not required by the codes or anything
7 else other than a management requirement.

8 We've gone to our management with those three
9 different situations. We presented to them what we are doing.
10 We presented to them the safety hazards, the personal hazards
11 of doing it, the fact that we're going to have to put in
12 plant modifications, the fact that it takes critical path
13 time.

14 In no way in God's name am I able to commit to
15 do that, because we kind of have their backing and that, hey,
16 we don't intend to commit to that right now. It's not
17 justifiable. It's critical path time on the heatup. We're
18 doing other more important surveillance. It's going to require
19 plant modification, and so forth.

20 So, I'm not sure if we're going to be able to
21 resolve that one between us at all levels.

22 MR. PAGE: I'd like to add something.

23 You say it's not a code requirement. That's not
24 necessarily true.

25 Category A valves are required to be leak tested

1 by the code -- any valve whose leakage is important. And
2 these valves, leakage is important -- are Category A and
3 require leak testing.

4 So, in fact, if you follow the letter of the code,
5 I think you'll find a lot more Category A valves than you
6 really have listed in your program.

7 If you followed it right down -- I mean, for any
8 kind of water hammer concerns or anything, you'll find
9 Category A valves that are out there in the industry,
10 including your plant, that are not being tested and are not
11 categorized A.

12 MR. THOMPSON: Joel, I don't think it's the point --

13 MR. PAGE: You said it's not a code --

14 MR. COLITZ: I think if we looked long and hard
15 enough we could come up with good rationale for testing every
16 valve in the plant.

17 MR. PAGE: Almost every check valve, to be sure.

18 MR. THOMPSON: But irrespective of whether or not,
19 where it is, I think that what I'm hearing is that they are
20 not, at this point, prepared to commit to doing some of these
21 things; and we're asking them to do them.

22 The next step is escalated to a higher level of
23 management. And that's what we have to do, get those very
24 clearly identified, what problems do we have that have to get
25 escalated and get them escalated and do it soon so that these

1 things will get done.

2 MR. CAPODANNO: I don't want to immediately
3 escalate things instantaneously. I think what Joe has said
4 is there are some issues here, in our first assessment and
5 discussion with our management, are things that they are not
6 immediately going to commit to.

7 I think what we're looking for now is something
8 that gets on paper what you feel are the things that you
9 want to ask of us so it's very clear and something that we
10 can take to somebody who has not participated in this meeting
11 and show them and say: "That's, from the Staff's point of
12 view, the outcome of this meeting, what additional items they
13 would like GPU to accomplish."

14 Then, that becomes a point of --

15 MR. PAGE: This isn't a new issue. You got an SER
16 in 1980, four years ago. That's not immediately raising it
17 to the management.

18 MR. CAPODANNO: I understand, but I believe this
19 draft came in about a week and a half ago with your comments.

20 I'm talking about the early May letter. We hadn't
21 had the benefit of that detailed comment, I don't believe,
22 until about a week and a half ago.

23 MR. THOMPSON: Okay. Let me clarify my statement.

24 When I say immediately raise it, I mean immediately
25 raise it after we gone as far as we can go, but not leave it

1 for another three years.

2 MR. CAPODANNO: Okay. I just didn't want the sense
3 to be that we've suddenly come to absolute loggerheads here.

4 I think Joe's point is we would like to get some-
5 thing that you feel is your position on paper so that it's
6 clear and we can either question it if we don't understand it
7 or, if it's abundantly clear, simply show it to higher levels
8 of management and proceed to discuss what it is we feel we're
9 going to do about it.

10 MR. THOMPSON: Will you be agreeable to get that
11 down on paper now via the recorder?

12 MR. CAPODANNO: Is that something we can take back
13 with us?

14 MR. THOMPSON: It will be available in 24 hours, I
15 believe.

16 MR. CAPODANNO: I'm not sure it's good or bad. My
17 past experience coming here has been Staff personnel worked
18 up a list of the things they wanted. We simply Xeroxed it,
19 and they turned that into a letter ultimately.

20 MR. THOMPSON: You're talking about a handwritten
21 list?

22 MR. CAPODANNO: Yes.

23 MR. THOMPSON: Let's do that then.

24 We're going to make a handwritten list, rather than
25 rely on the reporter to get the list -- a handwritten list

1 that they will take back to their management, and we will
2 formalize that.

3 MR. CAPODANNO: Joe has suggested that we work
4 up the wording of this handwritten list so, hopefully, we
5 all understand what it says. And we'll take another shot at
6 things sometime next week.

7 MR. COLITZ: I think what we cannot resolve by
8 phone next week basically boils down into the NRC deciding
9 what they're going to require of us and sending, probably, a
10 formal letter to our company for us to formally respond.

11 MR. CAPODANNO: That would just give us some time
12 to discuss with our management where, collectively, we think
13 we are.

14 MR. THOMPSON: Good.

15

16

17

18

19

20

21

22

23

24

25

end 18

1 MR. THOMPSON: Let's start on April 8, 1982, then.

2 MR. CHERNY: You're going to do the April '82

3 first?

4 MR. THOMPSON: Let's do it in order.

5 Item 1 is okay.

6 Item 2, GPU to review the Delta P issue.

7 MR. COLITZ: We owe you are position on that item.

8 MR. THOMPSON: Item 3 -- we will relegate that to

9 the --

10 MR. COLITZ: That's A-2.

11 MR. THOMPSON: To item A-2.

12 Item 4 is okay.

13 MR. PAGE: You're talking about B-1?

14 MR. THOMPSON: We're talking about the first

15 April '82 --

16 MR. PAGE: Okay.

17 MR. THOMPSON: Now, we are going to the 5/2/84
18 letter, A-1.

19 MR. COLITZ: The only thing on item A-1 was I
20 want to clarify for the record that that was an end of Cycle
21 6 commitment, and I think we agreed to that.

22 MR. CHERNY: That's the refueling after next?

23 MR. COLITZ: Right.

24 MR. CHERNY: We said okay.

25 MR. PAGE: We said before -- in view of the rest

1 of this, I don't know whether we should consider that okay or
2 not.

3 MR. CHERNY: We said okay.

4 MR. THOMPSON: A-2 is that first paragraph.

5 It's our understanding that your new 20-month
6 program is scheduled for September, will endorse the 1980
7 code.

8 And are we just electing to delay any comment on
9 that until we review the 1980 -- the total review of the new
10 120-month program?

11 MR. CHERNY: All right. Do you want to take that
12 at the same time as the 120-month review?

13 MR. PAGE: Uh-huh.

14 MR. CHERNY: Which is coming in when, this fall?
15 Is that right?

16 It should be coming in soon.

17 MR. THOMPSON: It's supposed to become effective
18 in September.

19 MR. COLITZ: What were we looking at for submittal,
20 June?

21 Early June on that.

22 MR. KNIGHT: We had said June 1 on that. But
23 since it's getting to be more work filtering in on all this
24 additional work, a couple of weeks more might be in order.
25 It will give us more time.

1 MR. THOMPSON: You wanted to revise that date then?

2 MR. KNIGHT: How much additional work are we going
3 to have to put into the submittal as a result of what we
4 talked about here?

5 MR. BARLEY: It sounds like we're going to be
6 preparing a report on the disassembled valve inspections.

7 MR. KNIGHT: Are we talking about a submittal date
8 for two pieces then? The submittal that we had talked about
9 earlier, plus this additional work?

10 So, what is the appropriate submittal date, then,
11 for everything that we have discussed?

12 MR. THOMPSON: I would like to separate out the
13 disassembly report from --

14 MR. CHERNY: From that submittal?

15 MR. THOMPSON: From that.

16 Keep that as somehow sort of a separate submittal.
17 Maybe we can write off -- I don't know how we're going to do
18 that, but maybe we can write some of these things off
19 contingent upon a justification from -- we're also thinking
20 in terms of how to show some completion on this, at least
21 show some progress.

22 And a way to do that is --

23 MR. CHERNY: All of these items can be closed
24 separate from that other submittal. These are all loose ends
25 from the previous review.

1 MR. THOMPSON: Yes. And that's what I'm trying to
2 get to. I would like to try to get these resolved and
3 completed, even if we have to complete them contingent upon
4 the disassembly report. I think we can sort of do that.

5 MR. CHERNY: I don't know how we can do that. We
6 need the disassembly report to do it.

7 How can we -- what basis can we use to write
8 anything up if we haven't seen the data?

9 MR. THOMPSON: At least some of these things we
10 can.

11 MR. CHERNY: I don't see how.

12 Most of those where we have a disagreement on
13 disassembly I think are in that category.

14 MR. THOMPSON: How long is it going to take you
15 to prepare that report on all the valve work you have done?

16 MR. COLITZ: A minimum of a week.

17 Somewhere in a week to two-week time frame to go
18 back through all the machinery history.

19 MR. BARLEY: Particularly to gather photos and
20 what have you.

21 MR. COLITZ: To see what we have in the way of
22 photos.

23 MR. CHERNY: Photos would be very helpful.

24 MR. THOMPSON: Okay. That still puts us within the
25 time frame of being able to get all of these issues out by

1 mid-June, with the Commission decision now scheduled for late
2 June. It still puts us within a doable time frame.

3 I would certainly rather see the submittal of the
4 new program slip rather than completing out these.

5 Talk about a delay -- and with the limited amount
6 of resources they have -- they can't get everything done this
7 week, clearly.

8 So, I think it would be agreeable to give a -- I
9 mean, to agree to some sort of a slip. Can we do that?
10 Agree to a slip on the --

11 MR. CHERNY: You're not talking about a big, long
12 slip, are you? You're just saying do this first, and then
13 doing the other -- do the others. Is that what you're saying?

14 MR. THOMPSON: If we put it to you that way,
15 complete these items and your disassembly report first,
16 followed by, then, your 120-month program, when could you
17 give us the 120-month program? Certainly not by June 1.

18 MR. CHERNY: Let's back up a minute before you get
19 to that part.

20 When do you want them to send this stuff in?

21 MR. THOMPSON: We're talking two weeks.

22 In the meantime, we're going to be resolving a lot
23 of the other items.

24 MR. CHERNY: We'll do some homework while they're
25 doing their work.

new bu

1 MR. KNIGHT: Mid-June?

2 MR. THOMPSON: June 15th.

3 If it's a Sunday, you get a day's grace.

4 MR. KNIGHT: The following workday, past June 15th.

5 If it's a Friday --

6 MR. CAPODANNO: The 15th is a Friday.

7 MR. KNIGHT: June 1 for the disassembly, and

8 June 15th for the program.

9 MR. THOMPSON: Let's move on to item A-2.

10 We already covered the update. So, that GPU
11 submittal expected June 15.

12 The second part of that, A-2, boric acid pumps,
13 my understanding is that the Staff is going to check tech
14 specs and, with our systems group, to look at these five or
15 six points that you have made as your justification for not
16 including the system.

17 MR. SHIPMAN: Correct me if I am wrong. We can't
18 meet the code requirements with the system we have installed.
19 To do some testing that would satisfy some intermediate goal
20 is a burden for the following reasons, which would be the
21 points you already have.

22 And that burden, when measured against the benefit
23 of some intermediate test, has to be considered.

24 MR. THOMPSON: Let's see if I can get some wording
25 here. We're working on wording.

1 I said the Staff is to review the tech specs and
2 discuss with NRC Systems Group to evaluate Licensee's basis
3 for not meeting code. Licensee cannot meet code with the
4 present system, for the reasons -- and there are about five
5 reasons stated in transcript.

6 MR. CAPODANNO: I thought you had made some rather
7 concise notes earlier about the reasons.

8 Are you going to enter them on your list, versus
9 judging on our memories as to how clear the transcript is?

10 MR. THOMPSON: Joel, did we get to the stage
11 where we would look at that and possibly agree with the
12 Licensee that this boric acid system could be excluded from
13 the ISP program?

14 MR. PAGE: My notes tell me we were going to
15 check with the systems people. But the way it looks right
16 now I don't see any way that that should be removed.

17 MR. THOMPSON: The other question, of course, was
18 changing the tech specs to eliminate -- if they don't need
19 that -- did we get to that? Was that still a viable option
20 when you completed that talk?

21 MR. CHERNY: I had written down there was an
22 apparent inconsistency between the tech specs and Section 11
23 that we have to get resolved.

24 MR. PAGE: That isn't the inconsistency, the
25 inconsistency, according to their statements, of whether the

1 system is needed or not.

2 MR. CHERNY: It's almost the same thing if they
3 have it on emergency power for convenience. I question why
4 it's in the tech spec.

5 Somebody did something before Section 11 came out,
6 and now they have to figure out why they did it.

7 MR. PAGE: They put some of the systems in the
8 early tech specs with specific testing requirements because
9 there was no standardized testing requirements for all safety
10 systems.

11 MR. CHERNY: But maybe it doesn't have to be that
12 way.

13 We'll have to check into it.

14 MR. CAPADANNO: So, the action is you would review
15 with systems and tech spec people this issue of deleting these
16 pumps?

17 MR. CHERNY: Another thing I wrote down is they're
18 not required in any Chapter 14 accident scenarios. So, that
19 also -- there's a problem there for me. They don't belong in
20 the tech specs if they're not taking credit for it in
21 Chapter 14 accidents. I don't understand that.

22

23

24

25

1 MR. CAPODANNO: I am still groping with how that
2 tabulation comes out on your official scrub list here.

3 MR. CHERNY: I think at this point we have the
4 ball on that one, that's how I see that one. We may throw
5 it back but right now we have it.

6 MR. CAPODANNO: You're going to check with your
7 people, the reasons being because of the number of pumps,
8 because of the fact that they are powered for convenience only,
9 for emergency power, because of the fact that the Chapter 14
10 accident analysis does not account for these?

11 MR. CHERNY: Right.

12 MR. THOMPSON: Okay. Let me just read what I have
13 here so far. The Staff is to review the tech specs and discuss
14 with NRC systems group to evaluate Licensee's bases for not
15 including the boric acid pumps and valves. That is, system
16 is not needed for accident scenario. Would require a plant
17 modifications. Creates problems with a large amount of IST.
18 The system is used frequently, giving a subjective check.
19 You have got many redundant pumps and to test would inject
20 boric acid into the reactor.

21 MR. CHERNY: That's about it.

22 MR. THOMPSON: Okay.

23 And let's see, we will -- Staff to discuss with
24 GPU by -- we make them give us dates. We ought to give them
25 dates too.

1 MR. CAPODANNO: I will go along with that.

2 MR. COLITZ: I think sometimes we need to maybe get
3 back in a telephone conversation on all of these items where
4 either you owe us or we need to look at ours.

5 MR. CAPODANNO: Do we want to set a target? Let's
6 at least keep something in mind.

7 MR. ABRAMOVICI: Let me make a suggestion. As we
8 go down the line, maybe there'll be a lot of action items for
9 you and a lot of action items for us. Maybe we could come to
10 a common date and discuss them all.

11 MR. COLITZ: That is what I would hope, a common
12 conference call where we address all of our items and vice
13 versa.

14 MR. THOMPSON: Today is Tuesday. Next Tuesday --
15 that is a week.

16 MR. CHERNY: I think what we are going to do, we
17 are going to do most of this this week because I am going to
18 be on travel all next week myself. So we are going to try
19 just for that reason, we are going to try to do whatever --
20 we are going to mount a drive this week. If we don't make
21 any progress this week, it is not going to be our fault.

22 So I am not quite sure what you want to hear. I
23 guess maybe what you want to hear is if we are going to throw
24 the ball back to you, you want to hear it as soon as possible.

25 We ought to be in a position by next Monday to tell.

1 MR. THOMPSON: Monday?

2 MR. CHERNY: Unless you can think of a reason why
3 we wouldn't be.

4 MR. PAGE: I have got a pretty tight week this
5 week.

6 MR. THOMPSON: You can't make that schedule?

7 MR. PAGE: I don't know if I can or not. I don't
8 even know if those systems people are going to be available.

9 MR. CHERNY: We are going to have our management
10 call their management.

11 MR. THOMPSON: I've got Monday, 5/21.

12 MR. CHERNY: If we can't get Bosnak or somebody's
13 help to get the right systems people immediately, we are going
14 to call you guys, okay? If I am not sure how much pull we
15 are going to have, we are going to depend on your help .

16 MR. CAPODANNO: So that would be complete by you --

17 MR. CHERNY: We intend to be able to say something
18 by next Monday.

19 MR. CAPODANNO: Should we be scheduling your call,
20 then, on Tuesday, the 22nd?

21 MR. CHERNY: Let me say further, I'm not sure
22 what I envision for us to do may take a lot less time than
23 what you guys may have to do. We are just going to check on
24 some of your statements about system redundancy and not
25 meeting them for accident scenarios.

1 That is the kind of stuff we are going to do. If
2 the systems people don't agree with you, we are just going to
3 report that back to you.

4 It is kind of out of our hands at that point.

5 MR. THOMPSON: Then we are back to negotiation,
6 aren't we?

7 MR. CHERNY: Then we are back to "They have got
8 to do some kind of tests."

9 MR. CAPODANNO: Why don't we do this? Your
10 tentative date is 5/21, let's get to the rest of the list and
11 then decide when GPU thinks they can finish their pieces, then
12 we'll pick a conference call date.

13 MR. THOMPSON: Okay, Item B-1, valve categories.
14 Did you get those, Joel?

15 MR. PAGE: Yes.

16 MR. THOMPSON: So, paragraph 1 is okay. Paragraph 2 --

17 MR. COLITZ: CFV 4 A and B, you wanted a copy of
18 the procedure.

19 MR. THOMPSON: Do you have any comment on that,
20 Joel? Did you get a chance to look at it?

21 MR. PAGE: Sure, I had all the time in the world.
22 I got them yesterday afternoon. It is only that thick.

23 MR. THOMPSON: Are you in a position to make a
24 comment on that?

25 MR. PAGE: No.

1 MR. CHERNY: Still under review.

2 MR. THOMPSON: Okay. Staff-2, complete rêview,
3 paragraph 3, RC-V4.

4 MR. CHERNY: RC-V4 and 23, right?

5 MR. THOMPSON: What I have got here is Staff still
6 is wanting to have some check, some sort of testing that will
7 check that these valves are closed.

8 MR. CHERNY: Staff requires individual tests,
9 preferably leak tests.

10 MR. THOMPSON: But didn't we already cover that that
11 was impractical, to leak test.

12 MR. CHERNY: Plant modifications would be needed
13 to do that. We said maybe.

14 MR. COLITZ: I think maybe -- I am not trying to
15 speed things up but for these three RC-V4, 23 and then the
16 next set, which were in the high pressure injection lines
17 and DH-V1 and V2, I think your position was the same on all
18 of them. That was, you require individual leak tests on
19 these valves. Okay.

20 MR. CHERNY: Wait a second. I think he went too
21 far. My notes had down for this next group I think it was,
22 107, 86 and 95, that was the bunch where the pump was running
23 at all times as I recall.

24 MR. CAPODANNO: I thought what you had said there
25 was that you had an interest in the low flow measurement

1 capability of the existing instruments as a possible means
2 of indicating valve integrity.

3 MR. CHERNY: That was one thing that we said, yes.

4 MR. PAGE: That is the leak free test on the MOV,
5 on that one MOV, to see if the instruments work.

6 MR. CAPODANNO: I thought therefore you were
7 expecting us to get back to you and say, we will measure
8 whatever it does.

9 MR. PAGE: You said you had already leak free
10 tested the others.

11 MR. CHERNY: The 73A and C are tested.

12 MR. SHIPMAN: On the 16, they are cycled quarterly.

13 MR. CAPODANNO: Maybe we ought to clear this up.
14 Probably in my mind the easiest way to attack it is exactly
15 what is your position with respect to this middle group here,
16 the 107 A,B,C,C, 86A,B and 95?

17 MR. THOMPSON: You were presenting some additional
18 support for operability for those. You said you are stroking
19 the 16s, you are shiftly checking by the operators in the
20 sense that you would detect a hot pipe, which would indicate
21 leakage, and you have got your inventory check.

22 So you have got three things that you are doing
23 there and your position is that that is adequate to verify
24 that they are closed.

25 MR. CHERY: I thought we said too there was another

1 potential barrier. I think there was another point that
2 somebody made.

3 MR. CAPODANNO: Didn't we also have a discussion
4 of the MU-V 73 valves as well?

5 MR. CHERNY: Yes, those are the ones that were
6 tested quarterly, right?

7 MR. CAPODANNO: Pump discharge check. My note
8 was after all that discussion, then the issue of flow
9 instrumentation came up as yet another means of getting an
10 indication of the flow path and leak tightness.

11 MR. CHERNY: That's right.

12 MR. CAPODANNO: So I have got all of that down but
13 I am not clear --

14 MR. CHERNY: I am not clear what the action item
15 was on the flow assembly. I guess I didn't write that down.

16 These were the flow instruments that were upstream
17 of MU-16 and I have an 80 gpm. What was the bottom line on
18 the flow instrumentation?

19 MR. PAGE: The leak tests in the forward flow
20 direction.

21 MR. CHERNY: When did they do that?

22 MR. PAGE: They don't right now.

23 MR. ABRAMOVICI: I thing the testing of the 80 gpm
24 was the recirc, the 80 gpm I think --

25 MR. BARLEY: The pumps are tested recirc.

1 MR. CAPODANNO: Henry was making a comparison with
2 minimum flow requirements. With two pumps operating, you
3 would have to at least see those on those indicators to be
4 satisfied you were getting adequate flow as far as pump
5 protection goes.

6 But that didn't really answer the question of how
7 low can you go. It was just a number as far as minimum flow
8 out of the pump.

End 20.

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. THOMPSON: I'm still at the top of the page,
2 on V4 and V23 -- haven't got past that yet.

3 MR. CHERNY: There's nothing to write down
4 except that they're going to individually test them.

5 MR. COLITZ: I think these three items -- we're
6 just rehashing everything we hashed already.

7 Their position is, in all three cases, you've got
8 to individually check valves, preferably leak check them.

9 MR. CAPODANNO: That's what I'm trying to get to.
10 TH-V1 and 2 I thought you were very clear on -- and the
11 RC-V4 and RC-V23.

12 MR. CHERNY: That's correct.

13 MR. CAPODANNO: I came away with a feeling -- I
14 didn't write down a specific note on this, but I thought, on
15 the third block of valves, you were, in essence, going to
16 mull over the whole scenario that we presented and also the
17 possibility of a flow instrument being an additional leak
18 indicator.

19 I didn't come away with any clear action item out
20 of that.

21 MR. PAGE: You weren't going to verify the
22 capability of that instrument?

23 MR. CAPODANNO: I thought we were.

24 MR. PAGE: That's an action item.

25 MR. CAPODANNO: I though that was a GPUN item --

1 try to feed back to you the information.

2 MR. CHERNY: I think that's write.

3 MR. CAPODANNO: For your part, there was another
4 piece --

5 MR. CHERNY: I thought we were going to check
6 with the systems people to see --

7 MR. PAGE: To see whether a continuously running
8 pump -- the pressure itself --

9 MR. CHERNY: So, I think we both have an action
10 item on that.

11 We're going to check with our systems people to
12 see if continuous running of one makeup pump is sufficient to
13 -- and one adequate pressure barrier. That's what we're
14 going to do.

15 And they're going to check on, I guess, the
16 accuracy of those flow-measuring devices upstream of the
17 MU-V16 valves.

18 Is that right?

19 MR. CAPODANNO: Yes.

20 MR. THOMPSON: I didn't get down the other valves
21 that Staff requires individual tests, preferably leak tests.

22 That was V4, V23 --

23 MR. COLITZ: TH-71 and 2.

24 MR. CHERNY: When you check those MU-73s quarterly,
25 with pressure, what do you do if you see some pressure? What

1 is the action item?

2 What's your criteria? That's the check. What's
3 the acceptance level.

4 MR. BASHISTA: Right now we only have a draft
5 procedure that we're working on. I guess we're not ready to
6 comment about what that acceptance criteria is going to be.

7 MR. CHERNY: The basic procedure, the concept is
8 not bad. But they haven't developed it far enough along yet
9 before we discuss it apparently, on MU-73, A through C --
10 V73, A through C.

11 MR. THOMPSON: Okay. Give it to me again. GPU to
12 check what?

13 MR. CHERNY: They're going to advise us of what
14 their acceptance criteria is for pressure of monitoring those
15 valves during these quarterly tests.

16 MR. THOMPSON: Give me two of those --

17 MR. CHERNY: MU-V73A, B, and C.

18 MR. THOMPSON: V73.

19 MR. CHERNY: Does that, by implication, mean you
20 weren't running that test before currency checkout?

21 MR. BASHISTA: We were running a different type
22 test before. The test we're proposing is well refined.

23 MR. CHERNY: In the interest of time, I move on
24 to the next item.

25 Have you got down TH-V1 and TH-V2?

1 MR. THOMPSON: I included them up with IC-V4 and
2 IC-V23.

3 MR. CHERNY: Okay.

4 Are we ready to go on to B-2?

5 MR. THOMPSON: We're going to check with our
6 system people on --

7 MR. ABRAMOVICI: For the record, DH-V1 and DH-V2
8 are not check valves.

9 MR. CHERNY: That's right.

10 MR. CAPODANNO: The heading in the memorandum --

11 MR. CHERNY: It says suction check valves; that's
12 right.

13 MR. CHERNY: I want to find out how they feel
14 about disabling one train of DH, decay heat refueling valves.

15 MR. COLITZ: Are we on item B-2 now?

16 MR. CHERNY: Right.

17 MR. THOMPSON: And GPU is to develop comments from
18 their testing disassembly program.

19 MR. CAPODANNO: We talked about checking with the
20 systems people and disabling a decay heat train.

21 Does that mean, aside from their comments, your
22 position is you want one of those valves opened up on some
23 specified interval?

24 MR. CHERNY: Each refueling outage.

25 MR. CAPODANNO: So, that would be one of the

1 CF-V4s or CF-V5s. Your position is open it up, inspect it
2 each refueling outage.

3 Owen, could we get that in your notes? That's
4 your specific position? Then, you're going to check with
5 your systems people?

6 MR. PAGE: Well, mostly there's somebody interject-
7 ing they didn't want that to happen or something.

8 MR. THOMPSON: I was off on a tangent. So, come
9 back.

10 Do you want to give that to me again?

11 MR. CHERNY: We want them to disassemble -- the
12 numbering is a little bit confusing to me here. They're
13 having a CF-V4A and B. But down in the body it says CF-V --

14 MR. PAGE: They use the discussion of C5s to support
15 the C4 operability -- sort of augmented discussion.

16 MR. CHERNY: We'd better write all the numbers
17 down, I guess.

18 MR. THOMPSON: Okay.

19 Staff --

20 MR. CHERNY: For his notes, we want them to
21 disassemble each refueling outage, one of the four, C-4A or
22 B, CF-V4A/B -- or CF-V5A/B -- one of those four -- unless the
23 systems people tell us that they have a problem with
24 disabling one train of decay heat removal -- we're not sure
25 about that.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. THOMPSON: You want to add alternately,
between the 4s and the 5s?

MR. CHERNY: You can add all that. I would hope
that that would be just done.

MR. PAGE: That's a detail that can be taken care
of at a later date.

MR. THOMPSON: All right.

end 21

1 MR. THOMPSON: Top of page 4, next two paragraphs
2 are okay.

3 MR. CHERNY: Right. Okay, 14 and 16.

4 MR. THOMPSON: Now GPU is going to get that
5 information from the manufacturer?

6 MR. CHERNY: I wrote down they are going to
7 obtain information from valve manufacturer to define testable
8 system parameters that can be used to verify valve disc
9 position.

10 MR. THOMPSON: Give me those words again please.

11 MR. CHERNY: Licensee to obtain letter from valve
12 manufacturer to define testable system parameters that can
13 be used to verify valve disc position.

14 MR. ABRAMOVICI: Again, if I may, I think the
15 discussion revolves around DH-V14 A and B; DH V16 A and B
16 are getting a full stroke, right? Those are the pump
17 discharge.

18 MR. COLITZ: Just on the 14.

19 MR. CHERNY: So V-16 is okay.

20 MR. CAPODANNO: I think there is another minor
21 nit in this memorandum. I believe it describes the 16 valves
22 as discharge check valves also -- I am sorry the 14s and the
23 16s are both identified as pump discharge check valves. It
24 is only the 16s that are --

25 MR. THOMPSON: The 14 are not check?

1 MR. PAGE: The 14 are suction. It should say
2 suction discharge.

3 MR. ABRAMOVICI: Again, what are we going to get
4 from the vendors? Whatever parameters are required and that the
5 flow is 3000 gpm, the valve is open based on that X percent,
6 one flow condition.

7 MR. PAGE: If that is what it says.

8 MR. THOMPSON: So I'll say at 3000 gpm.

9 MR. CHERNY: 3000 gpm is one parameter.

10 MR. ABRAMOVICI: Oh, I am trying to point out if
11 indeed he used all the parameters we would get the other
12 parameters, but I am using the flow condition of 3000 gpm.

13 MR. CHERNY: That's right.

14 MR. THOMPSON: That can be used to verify valve
15 disc position at 3000 gpm.

16 MR. COLITZ: The 14s also we'll include them. Since
17 we inspected them, we'll include them in that valve disassembly
18 package.

19 MR. THOMPSON: Main steam V-9 and we are awaiting
20 those calculations then, right?

21 MR. CAPODANNO: Yes.

22 MR. CHERNY: Awaiting which calculations?

23 Oh, that is similar to the other one. We are down
24 on this one now.

25 MR. THOMPSON: MS-V9 A and B. We are awaiting

1 the Licensee's calculations.

2 (Discussion off the record.)

3 MR. PAGE: The original request was to get copies
4 of the calculations to show an 80 percent open position for
5 a 48 percent flow rate.

6 Subsequent to that, during our discussions it
7 appears possibly something to do with the turbine coming up
8 to speed could play an important role on the disc position
9 of the check valves. That I believe they were going to check
10 out to see which is the best way to do that.

11 MR. CHERNY: You want to tell them what to write
12 in their master notes?

13 MR. THOMPSON: Read on.

14 What am I going to put down here, GPU to provide
15 calculations?

16 MR. PAGE: Concerning turbine parameters, open
17 parentheses, i.e., time to reach operating speed, et cetera.
18 That will verify check valve disc position.

19 MR. THOMPSON: BS-V21.

20 MR. CHERNY: Lines have been cut and capped.

21 MR. THOMPSON: Okay.

Side 2 BU 22 MR. CHERNY: Let's see if we can get this
23 done in about 15 more minutes.

24 MR. THOMPSON: Good. V-21 A and B is okay, lines
25 cut and capped.

1 MR. CAPODANNO: No action items.

2 MR. THOMPSON: Okay, 52.

3 MR. CAPODANNO: Are you going to note there at
4 least as of today's meeting you accept the obvious?

5 MR. THOMPSON: I called it okay.

6 MR. COLITZ: That is the one we had unanimous
7 agreement on.

8 MR. CAPODANNO: One. Not bad.

9 MR. THOMPSON: Okay, 52 A and B, as I understand
10 it, is to be included in your disassembly report, to provide
11 justification for extended testing --

12 MR. CHERNY: Extended disassembly interval.

13 MR. THOMPSON: Why don't we call it the disassembly
14 report, all right?

15 MR. PAGE: Fluid block system valves are open for
16 the NRC to check with probably containment systems or
17 auxiliary systems as to whether they should be included in
18 the program.

19 MR. CHERNY: That's along with the tech spec
20 change?

End 23. 21 MR. PAGE: Right.

22

23

24

25

1 MR. PAGE: MU-V73A/B/C, MU-V107A/B/C/D -- the
2 valves are part-stroke quarterly -- 73 valves are part-stroke
3 quarterly.

4 MR. THOMPSON: I have that. It's okay.

5 MR. PAGE: That's okay. No open items.

6 The following one is the same, the V14A and B
7 received no part strokes.

8 MR. THOMPSON: MU-V14.

9 MR. CHERNY: That's okay, too.

10 MR. PAGE: And then the MU-V94/95 -- 86A, and B,
11 220 -- Licensee, I believe, is to supply some sort of
12 information on how you're going to use it, how you're going
13 to set up acceptance criteria for your check valves.

14 MR. COLITZ: That test should be complete this
15 month. So, we will need to evaluate the results and come up
16 with our criteria.

17 MR. CHERNY: I think what I hear him saying is I
18 need a little more time on that one.

19 MR. THOMPSON: For GPU to complete, you're going
20 to need some more time on that.

21 How much time do you need on that?

22 MR. BARLEY: They're going to start the test later
23 this week. It should be done sometime next week.

24 (Discussion off the record.)

25 MR. ABRAMOVICI: The problem, as I see it, once

1 we get the data, we've got, somehow, to do some kind of
2 sensitivity analysis to see how much one would change versus
3 the other. We'll have to set up some kind of mathematical
4 model to go and get the results, and then getting from a
5 modeling guide into a systems guide to interpret the results.

6 MR. CHERNY: How much time do you estimate?

7 I see a good reason for more time on that one.

8 MR. CAPODANNO: What Julien describes may take
9 three to four weeks, total, first having to run the test to
10 get the data, analyze it, put it in to understand the whole
11 form.

12 So, we're talking about, I think, basically four
13 weeks from today.

14 MR. THOMPSON: You're talking about mid-June.

15 MR. CAPODANNO: Yes.

16 MR. CHERNY: Okay. We'd better jot that down.

17 That's a separate date for this item.

18 MR. SHIPMAN: Four weeks from today.

19 MR. CHERNY: Four weeks from today, June 15.

20 MR. CAPODANNO: June 15.

21 MR. ABRAMOVICI: Assuming the test is done in a
22 week.

23 MR. CHERNY: Maybe you'd rather do it differently
24 and commit to sometime two weeks after completion of tests
25 or something like that.

1 MR. BARLEY: It should be noted here that the tests
2 this time will satisfy the testing requirements on the valves,
3 because of the temporary strap-on flow instruments that will
4 be installed for the start-up tests.

5 MR. CHERNY: It will satisfy the code tests is
6 what you're saying?

7 MR. BARLEY: For this performance, but not
8 necessarily for future, because those instruments are
9 temporary.

10 MR. THOMPSON: For three weeks after --

11 MR. CHERNY: Three weeks after completion of tests.
12 Is that all right?

13 MR. CAPODANNO: Right.

14 MR. PAGE: Open item B-3 has to do with EF-V3.

15 They're going to investigate the possibility of
16 removing the valve internals, and we are going to talk
17 amongst ourselves in terms of their other proposal with the
18 system people.

19 MR. CHERNY: Right.

20 MR. PAGE: Before FW-V12A and B -- both were
21 inspected in 1981, or approximately in 1981 -- these will be
22 included in the disassembly inspection report.

23 ESV30A and B --

24 MR. THOMPSON: Wait a second. I got left behind.
25 The one -- V12?

1 MR. PAGE: V12A and B were both inspected
2 approximately in 1981. The results of that will be
3 included in the Disassembly Inspection Report.

4 MR. THOMPSON: Give me the data again.

5 MR. PAGE: Approximately in 1981.

6 MR. COLITZ: We'll give you specific dates in that
7 report.

8 MR. PAGE: The last item, B-5, is on ES-V30A and
9 B. They're not sure if there was any previous disassembly.
10 They're going to do a record search to see if there's any
11 information available.

12 And if it's available, they will include it in
13 their report. If it's not available, we will continue to
14 discuss this item.

15 MR. THOMPSON: What were the dates --

16 MR. CHERNY: I think we need to make a copy of
17 these for everybody.

18 MR. THOMPSON: I was going to do that.

19 What were the dates we had now they would have the
20 submittal --

21 MR. CHERNY: Disassembly report, June 1; 120-month
22 program, June 15th; and the MU-94/95 and V86A and B -- that
23 was three weeks after completion of tests for the items.

24 MR. THOMPSON: What about the rest of these items,
25 then, that we were going to discuss -- discussion of items

1 below -- did we have a date?

2 MR. CHERNY: There is no specific date.

3 Well, we're going to have a discussion -- we plan
4 to have a discussion next Monday, I think, on the phone.

5 With our items, I think we should report whatever
6 we've been able to find out.

7 If we have any trouble getting together with our
8 system people, we're going to call on the Division of
9 Licensing for help.

end 23

10 MR. THOMPSON: Discussion -- that will be 5/21.

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 (Off the record.)

2 MR. THOMPSON: We have very rough handwritten notes
3 which I will put together in complete form here in the next
4 day or so and probably issue these as summary minutes of the
5 meeting or whatever.

6 We are going to get together on Monday by telephone,
7 hopefully have --

8 MR. CHERNY: We'll set a time a little later, rather
9 than doing that today.

10 MR. COLITZ: As long as we know by tomorrow.

11 MR. CHERNY: I envision that as more of our stuff
12 to you.

13 MR. COLITZ: If we have anything like vendor
14 calculations, those things that don't fit the disassembly
15 report, if we have them available Monday we will pass them
16 on to you.

17 MR. CHERNY: Okay.

18 MR. THOMPSON: Gentlemen, I think we will declare
19 this meeting closed.

20 (Whereupon, at 4:45 p.m., the hearing
21 was recessed.)

End 24.

22 * * * *

23

24

25

CERTIFICATE OF PROCEEDINGS

This is to certify that the attached proceedings before the
NRC COMMISSION

In the matter of: GPU Nuclear TMI in Service Testing for
Pumps and Vales

Date of Proceeding: 15 May 1984

Place of Proceeding: Bethesda, Md.

were held as herein appears, and that this is the original
transcript for the file of the Commission.

Mimie Meltzer
Official Reporter - Typed

Mimie Meltzer
Official Reporter - Signature

OPEN ITEM: A-2

COMPONENT IDENTIFICATION: CA-PIA/B

ASME SECTION XI REQUIREMENTS: TEST PUMP OPERABILITY ON QUARTERLY BASIS

COMPONENT FUNCTION: PROVIDES FOR BORIC ACID TRANSFER FROM BORIC ACID MIX TANK TO MAKE-UP TANK FOR RCS BORON CONTROL

BASIS FOR EXEMPTION REQUEST:

1. HIGH DEGREE OF REDUNDANCY (DIVERSITY EXISTS)

- PER TECH. SPEC. 3.2.2 EITHER ONE BORIC ACID MIX PUMP OUT OF (2) OR ONE RECLAIMED BORIC ACID PUMPS OUT OF (2) MUST BE OPERABLE. ONLY ONE PUMP NEEDED (OUT OF FOUR) FOR NORMAL PLANT OPERATION (HIGH RELIABILITY).
- BORATED WATER CAN ALSO BE PROVIDED FROM THE RC BLEED TANKS VIA THE THREE RC WASTE TRANSFER PUMPS.


2. OPERATIONAL TEST OCCURS AND WOULD SHOW FAILURE

- CA-PIA/B ARE PERIODICALLY USED TO CONTROL RCS BORON CONCENTRATION AND THEY DO, THEREFORE, GET AN OPERATIONAL CHECK.

3. NOT REQUIRED BY SECTION XI

- CA-PIA/B ARE POWERED FROM A SAFETY GRADE POWER SOURCE FOR CONVENIENCE ONLY (ASME XI ALLOWS EXEMPTION IF ONLY FOR CONVENIENCE USE). [IWP-1200(B)]
- PUMPS NOT RELIED UPON IN CHAPTER 14 FOR ACCIDENT MITIGATION.
- BORATED WATER STORAGE TANK IS THE ACCIDENT SOURCE OF BORATED WATER VIA THE MAKE-UP PUMPS (3) OR DECAY HEAT PUMPS (2).

BORATED WATER SOURCES TO RCS



EVENT V (WASH 1400)

GPUN INTERPRETATION

- FAILURE OF TWO CHECK (ACTIVE) VALVES IN SERIES IN A HIGH PRESSURE SYSTEM ALLOWING THE LOW PRESSURE PORTION OF THE SYSTEM OUTSIDE THE REACTOR BUILDING TO BE PRESSURIZED TO RCS PRESSURE, CAUSING A LOCA OUTSIDE THE REACTOR BUILDING.

EVALUATION

- EVENT V FOR TMI-1 ANALYSIS PERFORMED BY FRANKLIN RESEARCH CENTER FOR NRC (OCTOBER 24, 1980).
- PER ANALYSIS ABOVE, THE FOLLOWING VALVES WERE NOT IDENTIFIED AS EVENT V:
 - RC-V4 AND RC-V23
 - DH-V1 AND DH-V2
 - MU-V107A/B/C/D, 94, 95 AND 86A/B

OPEN ITEM:

B-1

COMPONENT IDENTIFICATION:

RC-V4, RC-V23

ASME SECTION XI REQUIREMENTS:

LEAK TIGHTNESS VERIFICATION

COMPONENT FUNCTION:

RCS ISOLATION FROM DECAY HEAT SYSTEM
PRESSURIZER SPRAY LINE

BASIS FOR EXEMPTION REQUEST:

1. VALVES ARE INACTIVE AT PRESSURE


- AT HIGH PRESSURE (GREATER THAN 400 PSIG) BOTH VALVES ARE CLOSED AND DO NOT SERVE ANY FUNCTION OTHER THAN ISOLATION.
- THEY ARE ONLY ACTIVE DURING BORON PRECIPITATION MODE WHEN SYSTEM PRESSURE IS LOW (LESS THAN 400 PSIG).

2. SIMULTANEOUS LEAKAGE THROUGH BOTH VALVES WILL BE DETECTED

- IF LEAKAGE WAS EXPERIENCED, IT WOULD BE GRADUAL AND THE RCS LEAK RATE CALCULATION WOULD IDENTIFY IT (LEAK RATE PERFORMED IN ACCORDANCE WITH TECH. SPEC. REQUIREMENTS).
- A LEAKAGE THAT WOULD EXCEED TECHNICAL SPECIFICATION LIMIT IS WELL WITHIN THE RELIEF VALVE UPSTREAM OF THE SUBJECT VALVES (DH-V-67).

3. BACKUP CHECK VALVE INSIDE CONTAINMENT

- IF BOTH SUBJECT VALVES FAILED OPEN AND THE RELIEF VALVE FAILED TO LIFT, THERE IS HIGH PROBABILITY THAT THE BREAK WOULD BE INSIDE THE REACTOR BUILDING (DH-V-69 CLOSED).
- HIGH PRESSURE TO LOW PRESSURE INTERFACE IS INSIDE CONTAINMENT.
- LOCKED CLOSED VALVE OUTSIDE CONTAINMENT.



PRESSURIZER AUXILIARY SPRAY FROM DECAY HEAT (LPI)

OPEN ITEM:

B-1

COMPONENT IDENTIFICATION:

MU-V107A/B/C/D, 94 & 95
86A/B

ASME SECTION XI REQUIREMENTS:


LEAK TIGHTNESS VERIFICATION

COMPONENT FUNCTION:

PREVENT RCS BACKFLOW TO MAKE-UP SYSTEM

BASIS FOR EXEMPTION REQUEST:

- HP AND LP ARE SEPARATED BY FOUR VALVES IN SERIES.
 - LOOP CHECK VALVE (MU-V94/95/86A/B)
 - *SECOND LOOP CHECK*
- ~~CONTAINMENT ISOLATION~~ VALVE (MU-V107A/B/C/D)
 - HPI MOTOR OPERATED VALVE (MU-V16A/B/C/D)
 - PUMP DISCHARGE CHECK (MU-V73A/B/C)



Simplified Schematic HPI

OPEN ITEM:

B-1

COMPONENT IDENTIFICATION:

DH-V1 AND 2

ASME SECTION XI REQUIREMENTS:

LEAK TIGHTNESS VERIFICATION

COMPONENT FUNCTION:

RCS ISOLATION FROM DECAY HEAT SYSTEM

BASIS FOR EXEMPTION REQUEST:

1. VALVES ARE INACTIVE AT PRESSURE

- DURING HIGH PRESSURE OPERATION (GREATER THAN 400 PSIG) BOTH VALVES ARE CLOSED AND DO NOT SERVE ANY FUNCTION OTHER THAN ISOLATION.


ONLY ACTIVE DURING BORON PRECIPITATION CONTROL AT LOW PRESSURE (LESS THAN 400 PSIG).

2. SIMULTANEOUS LEAKAGE THROUGH BOTH VALVES WILL BE DETECTED

- IF LEAKAGE WAS EXPERIENCED, IT WOULD BE GRADUAL AND THE RCS LEAK RATE CALCULATION WOULD IDENTIFY IT (LEAK RATE PERFORMED IN ACCORDANCE WITH TECH. SPEC. REQUIREMENTS).
- A LEAKAGE THAT WOULD EXCEED TECHNICAL SPECIFICATION LIMITS IS WELL WITHIN THE RELIEF VALVE UPSTREAM OF THE SUBJECT VALVES (DH-V-37).

3. PREVIOUS INSPECTION SHOWS GOOD CONDITION

- DH-V-1 AND 2 RECENTLY OPENED AND INSPECTED.
- HIGH PRESSURE TO LOW PRESSURE IS INSIDE CONTAINMENT.
- CLOSED VALVE OUTSIDE CONTAINMENT (DH-V3).



DECAY HEAT DROP LINE

OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

CF-V4A/B

ASME SECTION XI REQUIREMENTS:

STROKE TESTING OF CHECK VALVES

COMPONENT FUNCTION:

ALLOWS COREFLOOD TANK WATER INTO THE
RCS UPON A LARGE BREAK LOCA.

BASIS FOR EXEMPTION REQUEST:

1. PART FLOW TESTING PERFORMED

- PART STROKE TESTING PERFORMED (1303-11.21) ONCE PER CYCLE.


2. TEST IS IMPRACTICAL

- FULL FLOW TEST AT REACTOR OPERATING PRESSURE NOT ACHIEVABLE DUE TO PRESSURE CONSIDERATIONS (ABOVE CF TANKS PRESSURE ACTUATION SETPOINT).
- NOZZLE CYCLES USED, (POSSIBLY THERMAL).

3. SIMILAR VALVE DESIGN IS TESTED

- SIMILAR DESIGN VALVES (CF-V 5A/B) DO GET STROKE TESTING EACH REFUELING DURING LPI FULL FLOW INJECTION TESTING.

Core Flood



OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

DH-V14A/B

ASME SECTION XI REQUIREMENTS:


FULL STROKE TESTING

COMPONENT FUNCTION:

ALLOWS BWST WATER INTO THE LPI SYSTEM
UPON ITS INITIATION.

BASIS FOR EXEMPTION REQUEST:

- PER DISCUSSION WITH VALVE MANUFACTURER, WALWORTH, FOR VALVE AT LPI PUMP TEST FLOW TO BWST (3000 GPM) THE VALVE IS OPEN 73%.



DECAY HEAT REMOVAL

OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

MS-V9A/B

ASME SECTION XI REQUIREMENTS:


FULL STROKE TESTING

COMPONENT FUNCTION:

ALLOWS MAIN STEAM TO TURBINE DRIVEN
EMERGENCY FEEDWATER PUMP.

BASIS FOR EXEMPTION REQUEST:

- EF SYSTEM IS TESTED QUARTERLY WITH EF ON RECIRCULATION. SUCCESSFUL TEST REQUIRES 4% OF DESIGN STEAM FLOW.



MAIN STEAM TO E. F. PUMP TURBINE

OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

BS-V52A/B

ASME SECTION XI REQUIREMENTS:


STROKE TESTING

COMPONENT FUNCTION:

ALLOW SODIUM HYDROXIDE TO ENTER
LPI/BUILDING SPRAY FROM POST ACCIDENT
COOLING/FISSION PRODUCT CONTROL.

BASIS FOR EXEMPTION REQUEST:

- TESTING OF THESE VALVES WOULD INTRODUCE AND/OR INCREASE POTENTIAL FOR NA INTRUSION AND HIGH REACTOR COOLANT ^{24}Na ACTIVITY LEVELS.
- VALVES WERE INSPECTED IN JANUARY 1984 WITH NO VISUAL DAMAGE (APPEARED IN AS-NEW CONDITION).



SODIUM HYDROXIDE TO DECAY HEAT AND BUILDING SPRAY SYSTEM.

OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

BS-V21A/B

ASME SECTION XI REQUIREMENTS:


FULL STROKE TESTING

COMPONENT FUNCTION:

NONE

BASIS FOR EXEMPTION REQUEST:

- SODIUM THIOSULFATE TANK HAS BEEN DELETED FROM THE BUILDING SPRAY SYSTEM.
- COMMON LINE FROM TANK HAS BEEN CUT AND CAPPED.



SODIUM THIOSULFATE TANK DELETION FROM
BUILDING SPRAY SYSTEM

OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

FLUID BLOCK

ASME SECTION XI REQUIREMENTS:

FULL STROKE TESTING

COMPONENT SAFETY FUNCTION:

NONE

BASIS FOR EXEMPTION REQUEST:


1. VALVE SAFETY FUNCTION IS TO REMAIN CLOSED
(EXTENSION OF CONTAINMENT ISOLATION)

- GPU HAS SUBMITTED TO NRC REQUEST TO DELETE THIS SYSTEM FROM TECH. SPECS. (TSC 113)
- A SIGNIFICANT NUMBER OF FAILURES WOULD HAVE TO OCCUR FOR THIS SYSTEM TO BE NEEDED (I.E., PIPE FAILURE, DISC LEAKAGE AND FLUID BLOCK CHECK VALVE FAILURE AS A RESULT OF A LOCA).
- NOT NEEDED TO OPEN TO MITIGATE ACCIDENT.

2. VALVE LEAKTIGHTNESS IS TESTED

- TESTED AS PART OF 10CFR50 APPENDIX J VALVES AS TYPE C.

Typical Fluid Block Connection



OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

MU-V73A/B/C, MU-V107A/B/C/D

ASME SECTION XI REQUIREMENTS:


FULL FLOW STROKE TESTING

COMPONENT FUNCTION:

DISCHARGE OF HPI/MAKE-UP PUMPS

BASIS FOR EXEMPTION REQUEST:

- NONE.
- FULL STROKING IS VERIFIED EACH REFUELING OUTAGE.
- ADDITIONALLY, MU-V73A/B/C ARE STROKED WHENEVER THE RESPECTIVE PUMP IS IN OPERATION (AT LEAST QUARTERLY PER 1300-3H).



Simplified Schematic HPI

OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

MU-V14A/B

ASME SECTION XI REQUIREMENTS:


FULL STROKE TESTING

COMPONENT FUNCTION:

MAKE-UP SUCTION FROM BWST

BASIS FOR EXEMPTION REQUEST:

- NONE.
- VALVES ARE FULL STROKE TESTED EACH REFUELING OUTAGE.



HPI SUCTION FROM BWST

OPEN ITEM:

B-2

COMPONENT IDENTIFICATION:

MU-V94, 95, 86A/B, 220

ASME SECTION XI REQUIREMENTS:


FULL STROKE TESTING

COMPONENT FUNCTION:

HPI INJECTION LINES CHECK VALVES

BASIS FOR EXEMPTION REQUEST:

- FLOW THROUGH THESE VALVES IS VERIFIED EACH REFUELING OUTAGE.
- GPUN IS DEVELOPING CORRELATION BETWEEN FLOW INSTRUMENT INDICATION AND VALVE POSITION.



Simplified Schematic HPI

OPEN ITEM:

B-3

COMPONENT IDENTIFICATION:

EF-V3

ASME SECTION XI REQUIREMENTS:

FULL STROKE TESTING

COMPONENT FUNCTION:

EMERGENCY FEEDWATER BACKUP SUPPLY FROM
EMERGENCY RIVER WATER SYSTEM


BASIS FOR EXEMPTION REQUEST:

1. SYSTEM IS DIVERSE BACKUP TO NORMAL WATER SUPPLY

- EMERGENCY RIVER WATER IS USED ONLY IF CONDENSATE STORAGE TANK, DEMINERALIZED WATER TANK AND CONDENSER HOTWELL ARE LOST OR SOURCE DEPLETED.

2. FULL FLOW TEST WOULD RESULT IN OTSG CHEMISTRY EXCURSION

- RIVER WATER CHEMISTRY CAN CAUSE OTSG DAMAGE.



EMERGENCY FEEDWATER ALTERNATE
WATER SOURCES

OPEN ITEM:

B-4

COMPONENT IDENTIFICATION:

FW-V12A/B

ASME SECTION XI REQUIREMENTS:


CHECK VALVE EXERCISING

COMPONENT FUNCTION:

OTSG ISOLATION

BASIS FOR EXEMPTION REQUEST:

- VALVE INSPECTION PERFORMED WITH NO VISUAL DAMAGE (APPROX. 1981).



FEEDWATER

OPEN ITEM:

B-5

COMPONENT IDENTIFICATION:

BS-V30A/B

ASME SECTION XI REQUIREMENTS:


FULL STROKE TESTING

COMPONENT FUNCTION:

RB SPRAY DISCHARGE CHECK VALVES

BASIS FOR EXEMPTION REQUEST:

- IF FULL FLOW TESTED RB SPRAY WILL ACTIVATE AND SPRAY DOWN ENTIRE REACTOR BUILDING.
- PART STROKED BY PLANT PROCEDURE LSOU-5A.



REACTOR BUILDING SPRAY TO SPRAY HEADERS

UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D. C. 20555

May 4, 1984

Docket No. 50-289

MEMORANDUM FOR: John F. Stolz, Chief, Operating Reactors Branch #4, DL

FROM: Owen O. Thompson, Project Manager, Operating Reactors Branch #4, DL

SUBJECT: FORTHCOMING MEETING WITH GPU NUCLEAR (THREE MILE ISLAND 1) INSERVICE TESTING (IST) FOR PUMPS AND VALVES

Time & Date: Tuesday, May 15, 1984
 10:00am & 2:00pm

Location: Maryland National Bank Building, Rm. 6507
 Bethesda, Maryland

Purpose: Morning - To discuss IST open items as outlined in NRC memos dated April 8, 1982 and May 2, 1984 (attached).
Afternoon - To resolve open items -- licensee and NRC staff, with management assistance.

Requested

Participants: NRC Morning -RBosnak, FCherny, JPage, OThompson;
Afternoon -JKnight, GLainas, JStolz

Licensee-JColitz, RBarley, JBashista, CSmyth, et al

Owen O. Thompson
 Owen O. Thompson, Project Manager
 Operating Reactors Branch #4, DL

cc: See next page

Dupe PDR
~~8-145180240~~