

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

April 30, 1984

34 MAY 4 A 8:47

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Re: Oconee Nuclear Station
Docket No. 50-269

Dear Mr. O'Reilly:

On January 11, 1984, Duke Power Company submitted for your information Reportable Occurrence Report RO-269/83-20 which concerned two control rod drive breakers experiencing a delay while being tested. In that submittal, Duke committed to advise the NRC of the final schedule for delivery and installation of new trip shaft and bearing assemblies. These are part of the new Control Rod Drive (CRD) Breaker Front Frame Assemblies. The General Electric Company has advised Duke that the CRD breaker front frame assemblies will be shipped on May 14, 1984. Based on this information, Duke plans to complete installation of the new front frames on all three Oconee units by July 31, 1984.

Very truly yours,

H. B. Tucker

Hal B. Tucker

JCP/php

cc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Ms. Helen Nicolaras
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8406190179 840430
PDR ADOCK 05000269
S PDR

OFFICIAL COPY
1522

1/0