

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

PRP
OFFICIAL COPY

84 JUN 11 1984
June 6, 1984
P 1:15

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James F. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - QA BREAKDOWN - DEFICIENT FILLET
WELDS - NCRs 1188, 1203, AND 1563 - SUPPLEMENTAL REPORT


On May 7, 1980, R. W. Wright, NRC-OIE Region II, was informed that nonconformance report (NCR) 1188 was determined to be reportable in accordance with 10 CFR 50.55(e). Subsequently, related NCR 1203 was also determined to be reportable in accordance with 10 CFR 50.55(e). This was followed by our interim reports dated June 6, September 19, and December 15, 1980 and March 6 and June 10, 1981. Some of the affected welds were found to be inaccessible for inspection; therefore, NCR 1563 was written to disposition these welds. This was followed by our interim reports dated August 27 and December 11, 1981 and March 5, May 18, and November 10, 1982, and a final report on August 24, 1983. Below is our supplemental report on NCR 1203.

As discussed with NRC-OIE Inspector P. E. Fredrickson on May 25, 1984, the date of May 30, 1984 for completion of corrective actions indicated in our final report on this matter would not be met. The unit 1 fuel bundles are still being stored in the unit 2 spent fuel area. This has left the area inaccessible for reworking welds. The corrective action on this matter will be completed by November 30, 1984.

If you have any questions concerning this matter, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

OFFICIAL COPY

IE 27 1/0