

Mr. Jerry W. Yelverton
Vice President, Operations ANO
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

September 8, 1995

SUBJECT: CHANGES TO TECHNICAL SPECIFICATION BASES SECTION 3.11 FOR ARKANSAS
NUCLEAR ONE, UNIT 1 AND SECTION 3/4.7.4 FOR UNIT 2 (TAC NOS. M92058
AND M92061)

Dear Mr. Yelverton:

In a letter dated March 28, 1995, Entergy Operations (the licensee) proposed a change to the Technical Specification Bases for Arkansas Nuclear One Unit 1 (ANO-1) Section 3.11, and also for Arkansas Nuclear One, Unit 2 (ANO-2) Section 3/4.7.4. The proposed changes to the ANO-1 and ANO-2 Bases add a statement describing the actions required when transferring the service water system from the lake to the emergency cooling pond (ECP) and the basis for the required actions to assure a 30-day ECP inventory.

The staff has reviewed your request and agrees that the change is appropriate. We have, therefore, approved the change. Enclosed is a copy of the revised Bases. This concludes the staff's action regarding your submittal.

Sincerely,

Original Signed By:

George Kalman, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-313 and 50-368

Enclosure: Bases pages

cc w/encl: See next page

DISTRIBUTION:

Docket File	EFuentes	Public	JRoe	GHill (4)
ACRS (4)	OGC	GKalman	JDyer, RIV	PDIV-1 r/f
TClark	CGrimes			

Document Name: AR92058.LTR

OFC	(A)LA/PD4-1	INTERN/PD4-1	PM/PD4-1
NAME	T. J. K. <i>JK</i>	EFuentes:sw	GKalman
DATE	9/18/95	9/18/95	9/18/95
COPY	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

9509110138 950908
PDR ADOCK 05000313
P PDR

NRC FILE CENTER COPY

DF



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 8, 1995

Mr. Jerry W. Yelverton
Vice President, Operations ANO
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

SUBJECT: CHANGES TO TECHNICAL SPECIFICATION BASES SECTION 3.11 FOR ARKANSAS
NUCLEAR ONE, UNIT 1 AND SECTION 3/4.7.4 FOR UNIT 2 (TAC NOS. M92058
AND M92061)

Dear Mr. Yelverton:

In a letter dated March 28, 1995, Entergy Operations (the licensee) proposed a change to the Technical Specification Bases for Arkansas Nuclear One Unit 1 (ANO-1) Section 3.11, and also for Arkansas Nuclear One, Unit 2 (ANO-2) Section 3/4.7.4. The proposed changes to the ANO-1 and ANO-2 Bases add a statement describing the actions required when transferring the service water system from the lake to the emergency cooling pond (ECP) and the basis for the required actions to assure a 30-day ECP inventory.

The staff has reviewed your request and agrees that the change is appropriate. We have, therefore, approved the change. Enclosed is a copy of the revised Bases. This concludes the staff's action regarding your submittal.

Sincerely,

A handwritten signature in cursive script, appearing to read "George Kalman".

George Kalman, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-313 and 50-368

Enclosure: Bases pages

cc w/encl: See next page

Mr. Jerry W. Yelverton
Entergy Operations, Inc.

Arkansas Nuclear One, Units 1 & 2

cc:

Mr. Harry W. Keiser, Executive Vice
President & Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Mr. Jerrold G. Dewease
Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Ms. Greta Dicus, Director
Division of Radiation Control
and Emergency Management
Arkansas Department of Health
4815 West Markham Street
Little Rock, AR 72205-3867

Mr. Robert B. McGehee
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

Mr. Nicholas S. Reynolds
Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Mr. Robert B. Borsum, Manager
Rockville Nuclear Licensing
B&W Nuclear Technologies
1700 Rockville Pike, Suite 525
Rockville, MD 20852

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, AR 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

County Judge of Pope County
Pope County Courthouse
Russellville, AR 72801