

February 4, 1992

Docket Nos. 50-413  
and 50-414

Mr. M. S. Tuckman  
Vice President, Catawba Site  
Duke Power Company  
P. O. Box 256  
Clover, South Carolina 29710

DISTRIBUTION

|                        |          |
|------------------------|----------|
| <del>Docket File</del> | SVarga   |
| NRC/LOCAL PDRs         | GLainas  |
| PDII-3 Reading         | OGC      |
| Catawba Reading        | DHagan   |
| RMartin                | ACRS(10) |
| LBerry                 | OPA      |
| DMatthews              | OC/LFMB  |
| LReyes,RII             |          |

Dear Mr. Tuckman:

SUBJECT: WITHDRAWAL OF AMENDMENT REQUEST - CATAWBA NUCLEAR STATION, UNITS 1  
AND 2 (TAC NOS. M76647 AND M76648)

By letter dated April 24, 1990, you applied for amendments to Catawba Units 1 and 2 Technical Specifications (TS). The proposed change would have relocated the tabular listing of containment penetration conductor overcurrent protective devices from TS Tables 3.8-1a and 3.8-1b to Chapter 16 of the Final Safety Analysis Report, "Selected Licensee Commitment Manual." Proposed changes to TS 3/4.8.4 were also associated with this change.

Generic letter (GL) 91-08, "Removal of Component Lists from Technical Specifications," was issued on May 6, 1991, to provide guidance for the removal of such component lists from the TS. My letter to you of May 10, 1991, indicated that your application for this amendment would be reviewed against the guidance provided in the generic letter. Subsequently, by letter dated January 16, 1992, you indicated that additional time was needed to review the impact of GL 91-08 on the amendment request and withdrew the request to be resubmitted at a later date.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendments to Facility Operating Licenses with the Office of the Federal Register for publication. This completes our activities on this application pursuant to TAC Nos. M76647 and M76648.

Sincerely,

/s/

Robert E. Martin, Senior Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

NRC FILE CENTER COPY

|      |             |              |             |   |   |
|------|-------------|--------------|-------------|---|---|
| OFF  | : PDII-3/LA | : PDII-3/PM  | : PDII-3/AD | : | : |
| NAME | : LBerry    | : RMartin:cw | : DMatthews | : | : |
| DATE | : 02/3/92   | : 02/4/92    | : 02/4/92   | : | : |

OFFICIAL RECORD COPY

Document Name: CATAWBA W/DRAWAL 76647

9202100420 920204  
PDR ADOCK 05000413  
PDR

DF01  
11



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20565

February 4, 1992

Docket Nos. 50-413  
and 50-414

Mr. J. S. Tuckman  
Vice President, Catawba Site  
Duke Power Company  
P. O. Box 256  
Clover, South Carolina 29710

Dear Mr. Tuckman:

SUBJECT: WITHDRAWAL OF AMENDMENT REQUEST - CATAWBA NUCLEAR STATION, UNITS 1  
AND 2 (TAC NOS. M76647 AND M76648)

By letter dated April 24, 1990, you applied for amendments to Catawba Units 1 and 2 Technical Specifications (TS). The proposed change would have relocated the tabular listing of containment penetration conductor overcurrent protective devices from TS Tables 3.8-1a and 3.8-1b to Chapter 16 of the Final Safety Analysis Report, "Selected Licensee Commitment Manual." Proposed changes to TS 3/4.8.4 were also associated with this change.

Generic Letter (GL) 91-08, "Removal of Component Lists from Technical Specifications," was issued on May 6, 1991, to provide guidance for the removal of such component lists from the TS. My letter to you of May 10, 1991, indicated that your application for this amendment would be reviewed against the guidance provided in the generic letter. Subsequently, by letter dated January 16, 1992, you indicated that additional time was needed to review the impact of GL 91-08 on the amendment request and withdrew the request to be resubmitted at a later date.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendments to Facility Operating Licenses with the Office of the Federal Register for publication. This completes our activities on this application pursuant to TAC Nos. M76647 and M76648.

Sincerely,

A handwritten signature in cursive script that reads "Robert E. Martin".

Robert E. Martin, Senior Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

Mr. M. S. Tuckman  
Duke Power Company

Catawba Nuclear Station

cc:

Mr. R. C. Futrell  
Regulatory Compliance Manager  
Duke Power Company  
P. O. Box 256  
Clover, South Carolina 29710

Mr. Alan R. Herdt, Chief  
Project Branch #3  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. A.V. Carr, Esq.  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242-0001

North Carolina Electric Membership  
Corp.  
P.O. Box 27306  
Raleigh, North Carolina 27611

J. Michael McGarry, III, Esq.  
Winston and Strawn  
1400 L Street, N.W.  
Washington, D. C. 20005

Saluda River Electric Cooperative,  
Inc.  
P.O. Box 929  
Laurens, South Carolina 29360

North Carolina MPA-1  
Suite 600  
P.O. Box 29513  
Raleigh, North Carolina 27626-513

Senior Resident Inspector  
Route 2, Box 179N  
York, South Carolina 29745

Mr. Frank Modrak  
Project Manager, Mid-South Area  
ESSD Projects  
Westinghouse Electric Corp.  
MNC West Tower - Bay 241  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

County Manager of York County  
York County Courthouse  
York, South Carolina 29745

Mr. Heyward G. Shealy, Chief  
Bureau of Radiological Health  
South Carolina Dept. of Health  
and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Richard P. Wilson, Esq.  
Assistant Attorney General  
S.C. Attorney General's Office  
P.O. Box 11549  
Columbia, South Carolina 29211

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Dept. of Justice  
P.O. Box 629  
Raleigh, North Carolina 27602

Piedmont Municipal Power Agency  
121 Village Drive  
Greer, South Carolina 29651

Mr. R. L. Gill, Jr.  
Licensing  
Duke Power Company  
P.O. Box 1007  
Charlotte, North Carolina 28201-1007