

ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000 June 15, 1984

1CANØ684Ø1

Director of Nuclear Reactor Regulation ATTN: Mr. J. F. Stolz, Chief Operating Reactors Branch #: Division of Licensing U. S. Nuclear Regulatory Commissi Washington, DC 20555

SUBJECT: Arkansas Nuclear One - Unit 1

Docket No. 50-313 License No. DPR-51

ANO-1 Technical Specification Revision for Safety-Related Snubber Surveillance

Gentlemen:

The purpose of this letter is to transmit the enclosed Technical Specification Change Request (TSCR) concerning the safety-related snubber surveillance requirements for ANO-1. For reasons stated in ØCAN9484Ø3 dated April 23, 1984, the subject TSCR submittal date for ANO-1 was revised to June 15, 1984. Our ANO-2 submittal on this issue was made on May 19, 1984 (2CANØ584Ø1).

In our letter dated June 30, 1983, (ØCANØ68315), AP&L submitted an ANO-1 TSCR to reference ANSI/ASME OM4-1982, "Examination and Performance Testing of Nuclear Power Plant Dynamic Restraints (Snubbers)" as our proposed means to functionally test the ANO-1 & 2 nuclear safety-related mechanical and hydraulic snubbers. Subsequently, in a meeting at Bethesda on August 23, 1983, it was agreed that AP&L would resubmit the ANO-1 & 2 TSCRs in as close a format as practicable to the Standard Technical Specifications (STS), yet retain the essential elements of the OM4 Standard. Because we are proposing to define an increase in the total number of safety-related snubbers and thereby expand the scope of our surveillance requirements, we request that the enclosed TSCR be approved and made effective coincident with the next ANO-1 refueling outage (1R6). Further, we will consider that all snubbers were operable prior to the first inspection governed by this Technical Specification during 1R6 for the purpose of determining the initial sample size. We feel this to be appropriate because (1) no known functional deficiencies exist with any of our safety-related snubbers following inspections performed during the 1R5 outage, and (2) this would allow sufficient time to incorporate representative safety-related

8406200137 840615 PDR ADOCK 05000313 P PDR floo!

Mr. J. F. Stolz -2-June 15, 1984 mechanical snubbers into our functional test sample according to the criteria of proposed Specification 4.16.1.d. Also, we have concluded that we will be able to test the greater than 50,000 lb. capacity snubbers for ANO-1 which are safety-related according to the enclosed ANO-1 TSCR. Therefore by its absence, we have herein proposed the deletion of this exemption. In accordance with 10CFR50.92(c), we have determined the attached proposed amendment as having no significant hazards considerations. Consequently, we have attached our Significant Hazards Determination to this letter in consideration of the Sholly amendment provisions. Additionally, a copy of this letter and proposed ANO-1 TSCR has been sent to Mr. E. Frank Wilson, Director, Division of Environmental Health Protection, Arkansas State Health Department. Finally, since this is an NRC requested revision to a TSCR presently undergoing regulatory review, no additional fee is enclosed. Very truly yours, John M. Griffin Senior Vice President Energy Supply JMG: DET: ac Enclosures (2) cc: Director of Nuclear Reactor Regulation Mr. James R. Miller, Chief Operating Reactors Branch #3 Division of Licensing U. S. Nuclear Regulatory Commission Washington, DC 20555

COUNTY OF PULASKI

I, John M. Griffin, being duly sworn, subscribe to and say that I am Senior Vice President, Energy Supply, for Arkansas Power & Light Company; that I have full authority to execute this oath; that I have read the document numbered 1CANØ684Ø1 and know the contents thereof; and that to the best of my knowledge, information and belief the statements in it are true.

John M. Griffin

Notary Public

My Commission Expires:

9-19-89