

JUN 7 1984

Mr. Glen L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
P.O. Box 208
Witchita, Kansas 67201

Dear Mr. Koester:

SUBJECT: DESIGN VERIFICATION ACTIVITIES - WOLF CREEK 1

By letter dated January 4, 1984 the NRC staff requested that KG&E submit additional information which could possibly support the conclusion that the design process for Wolf Creek, has been properly implemented. KG&E responded via letter dated March 9, 1984. To complete its review the NRC staff requests the following information regarding Wolf Creek:

- (a) Audit records or other documentation which verify that Sargent and Lundy had performed and updated the calculations needed to support the current ultimate heat sink design.
- (b) Audit records or other documentation which verify that Sargent and Lundy had maintained and updated the ultimate heat sink design criteria document/ data and that this updated information had been properly coordinated with the other design interfacing organizations (i.e., Bechtel, Dames and Moore).
- (c) Audit records or other documentation which verify that Sargent and Lundy had performed adequate internal interdivisional coordination associated with the ultimate heat sink design.

Pending satisfactory review and evaluation of the requested information, the staff concludes that an independent design verification program does not appear necessary. A copy of the staff's preliminary evaluation is enclosed.

Sincerely,

*Original signed by
Darrell G. Eisenhut*

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Enclosure:
Preliminary Evaluation

cc w/enclosure:
See next page

RWP
IE:QAB
RParkhill
5/15/84

IE:QAB
JLMilhoan
5/15/84
*Tele 5-15-84
RWP*

IE:QAB
GTankrum
5/1/84

IE:DD/QASIP
JGPartlow
5/17/84

JRG
IE:DIR/QASIP
JNGrace
5/21/84

PAD
NRR/DDR/LIC
DGE Eisenhut
5/15/84

*Reylon
checked
on 5-14-84
for R. Davis
RWP 6/7/84*



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUN 7 1984

Docket No. 50-482

Mr. Glen L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
P.O. Box 208
Wichita, Kansas 67201

Dear Mr. Koester:

SUBJECT: DESIGN VERIFICATION ACTIVITIES - WOLF CREEK 1

By letter dated January 4, 1984 the NRC staff requested that KG&E submit additional information which could possibly support the conclusion that the design process for Wolf Creek, has been properly implemented. KG&E responded via letter dated March 9, 1984. To complete its review the NRC staff requests the following information regarding Wolf Creek:

- (a) Audit records or other documentation which verify that Sargent and Lundy had performed and updated the calculations needed to support the current ultimate heat sink design.
- (b) Audit records or other documentation which verify that Sargent and Lundy had maintained and updated the ultimate heat sink design criteria document/data and that this updated information had been properly coordinated with the other design interfacing organizations (i.e., Bechtel, Dames and Moore).
- (c) Audit records or other documentation which verify that Sargent and Lundy had performed adequate internal interdivisional coordination associated with the ultimate heat sink design.

Pending satisfactory review and evaluation of the requested information, the staff concludes that an independent design verification program does not appear necessary. A copy of the staff's preliminary evaluation is enclosed.

Sincerely,

A handwritten signature in dark ink, appearing to read "Darrell G. Eisenhut".

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Enclosure:
Preliminary Evaluation

cc w/enclosure:
See next page

WOLF CREEK

Mr. Glenn L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
201 North Market Street
Post Office Box 208
Wichita, Kansas 67201

cc: Mr. Nicholas A. Petrick
Executive Director, SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. Donald T. McPhee
Vice President - Production
Kansas City Power & Light Company
1330 Baltimore Avenue
Kansas City, Missouri 64141

Ms. Mary Ellen Salava
Route 1, Box 56
Burlington, Kansas 66839

A. Scott Cauger
Assistant General Counsel
Public Service Commission
P. O. Box 360
Jefferson City, Missouri 65101

Mr. Howard Bundy
Resident Inspector/Wolf Creek NPS
c/o U.S.N.R.C.
Post Office Box 311
Burlington, Kansas 66839

Mr. Robert M. Fillmore
State Corporation Commission
State of Kansas
Fourth Floor, State Office Bldg.
Topeka, Kansas 66612

Terri Sculley, Director
Special Projects Division
Kansas Corporation Commission
State Office Building, Fourth Floor
Topeka, Kansas 66612

Ms. Wanda Christy
515 N. 1st Street
Burlington, Kansas

Eric A. Eisen, Esq.
Birch, Horton, Bittner & Moore
1140 Connecticut Avenue, N. W.
Washington, D. C. 20036

C. Edward Peterson, Esq.
Legal Division
Kansas Corporation Commission
State Office Building, Fourth Floor
Topeka, Kansas 66612

John M. Simpson, Esq.
Attorney for Intervenors
4350 Johnson Drive, Suite 120
Shawnee Mission, Kansas 66205

Mr. John T. Collins
U.S.N.R.C. - Region IV
611 Ryan Plaza
Suite 1000
Arlington, Texas 76011

Mr. Joe Mulholland
Manager of Power Supply & Engineering
Kansas Electric Power Cooperative, Inc.
Post Office Box 4877
Gage Center Station
Topeka, Kansas 66604

Mr. James G. Keppler
U.S.N.R.C. - Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Brian P. Cassidy, Regional Counsel
Federal Emergency Management Agency
Region I
J. W. McCormack POCH
Boston, Massachusetts 02109