



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038-0236

Nuclear Business Unit

SEP 05 1995

LR-N95145

LCR 94-36

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

**SUPPLEMENT TO LICENSE AMENDMENT APPLICATION FOR  
ELIMINATION OF SELECTED RESPONSE TIME TESTING  
FACILITY OPERATING LICENSE NPF-57  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354**

Public Service Electric & Gas Co. (PSE&G) submits the following supplemental information relative to a previously submitted license amendment request, transmitted to the NRC via letter LR-N95040, dated March 30, 1995. This amendment request involved elimination of selected response time testing (RTT) requirements from Technical Specifications, and associated Bases changes. Specifically, the RTT requirements to be eliminated included: 1) the instrumentation loop RTT for the Emergency Core Cooling System and Isolation Actuation Systems (except Main Steam Isolation Valve actuation and radiation loops for Secondary Containment Isolation) and 2) the sensor RTT for selected Reactor Protection System signals and the Main Steam Isolation Valve (MSIV) actuation instrumentation.

The proposed Technical Specification changes are supported by the analysis documented in General Electric (GE) Licensing Topical Report (LTR) NEDO-32291, "System Analysis for Elimination of Selected Response Time Testing Requirements." This analysis demonstrated that other periodic tests required by Technical Specifications (i.e., channel calibrations, channel checks, channel functional tests, and logic system functional tests) ensure that instrument response times are within acceptable limits. An NRC Safety Evaluation Report (SER), approving the GE LTR NEDO-32291, was issued on December 28, 1994.

110091

ADD 1/0

The power is in your hands.

9509120060 950905  
PDR ADDCK 05000354  
P PDR

SEP 05 1995


Document Control Desk  
LR-N95145

2

This supplement to the amendment request formally documents and commits that the actions supporting the requirements delineated in the NRC's SER, as stated in the amendment request, will be completed prior to implementation of the amendment.

Should you have any questions or comments, please do not hesitate to contact us.

Sincerely,



J. A. Benjamin  
Director - Quality Assurance &  
Nuclear Safety Review

C Mr. T. T. Martin, Administrator - Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. D. Jaffe, Licensing Project Manager  
U. S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Mail Stop 14E21  
Rockville, MD 20852

Mr. R. Summers (S09)  
USNRC Senior Resident Inspector

Mr. K. Tosch, Manager IV  
NJ Department of Environmental Protection  
Division of Environmental Quality  
Bureau of Nuclear Engineering  
CN 415  
Trenton, NJ 08625