

Georgia Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 877 7229

J. T. Beckham, Jr.
Vice President—Nuclear
Hatch Project



HL-2040
000116

February 7, 1992


U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

PLANT HATCH - UNITS 1, 2
NRC DOCKETS 50-321, 50-366
OPERATING LICENSES DPR-57, NPF-5
MONTHLY OPERATING REPORTS

Gentlemen:

Enclosed are the January 1992 Monthly Operating Reports for Edwin I. Hatch Nuclear Plant - Unit 1, Docket No. 50-321, and Unit 2, Docket No. 50-366. These reports are submitted in accordance with the requirements of Technical Specifications Section 6.9.1.10.

Sincerely,


J. T. Beckham, Jr.

SRP/sp

Enclosures:

1. Monthly Operating Report for Plant Hatch - Unit 1
2. Monthly Operating Report for Plant Hatch - Unit 2

c: (See next page.)

9202110230 920131
PDR ADOCK 05000321
R PDR

JE24 1/1

U.S. Nuclear Regulatory Commission

February 7, 1992

Page Two

c: Georgia Power Company

Mr. H. L. Sumner, General Manager - Nuclear Plant
NORMS

U.S. Nuclear Regulatory Commission, Washington, D.C.

Mr. K. Jabbour, Licensing Project Manager - Hatch

U.S. Nuclear Regulatory Commission, Region II

Mr. S. D. Ebner, Regional Administrator

Mr. L. D. Wert, Senior Resident Inspector - Hatch

ENCLOSURE 1

PLANT HATCH UNIT 1
NRC DOCKET 50-321
MONTHLY OPERATING REPORT
January 1992

TABLE OF CONTENTS

	<u>Page</u>
Narrative Report	E1-1
Operating Data Report	E1-2
Average Daily Power Level	E1-3
Unit Shutdowns and Power Reductions	E1-4

PLANT E. I. HATCH - UNIT ONE

NARRATIVE REPORT

DOCKET NO.: 50-321
DATE: FEBRUARY 3, 1992
COMPLETED BY: R. M. BEARD
TELEPHONE: (912) 367-7781 x2878

JANUARY 1	0000	Shift continued to maintain rated thermal power.
JANUARY 24	0005	Shift reduced power to approximately 700 GMWe to perform Turbine Control Valve and Turbine Bypass Valve Testing.
JANUARY 24	0200	Shift reduced load to approximately 650 GMWe to investigate the performance of a relay associated with the No. 1 Turbine Stop Valve.
JANUARY 24	0637	The unit was returned to rated thermal power.
JANUARY 31	2400	Shift continued to maintain rated thermal power.

OPERATING DATA REPORT

DOCKET NO.: 50-321
 DATE: FEBRUARY 3, 1992
 COMPLETED BY: R. M. BEARD
 TELEPHONE: (912) 367-7781 x2878

OPERATING STATUS

- | | |
|---|------------------------|
| 1. UNIT NAME: | E. I. HATCH - UNIT ONE |
| 2. REPORT PERIOD: | JANUARY 1992 |
| 3. LICENSED THERMAL POWER (MWt): | 2436 |
| 4. NAMEPLATE RATING (GROSS MWe): | 850 |
| 5. DESIGN ELECTRICAL RATING (NET MWe): | 776.3 |
| 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): | 774 |
| 7. MAXIMUM DEPENDABLE CAPACITY (NET MWe): | 741 |
| 8. IF CHANGES OCCUR IN CAPACITY RATINGS
(ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: | NO CHANGES |
| 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWe): | NO RESTRICTIONS |
| 10. REASONS FOR RESTRICTION, IF ANY: | N/A |

	THIS MONTH	YEAR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD:	744.0	744	140999
12. NUMBER OF HOURS REACTOR WAS CRITICAL:	744.0	744.0	103081.8
13. REACTOR RESERVE SHUTDOWN HOURS:	0.0	0.0	0.0
14. HOURS GENERATOR ON LINE:	744.0	744.0	98337.1
15. UNIT RESERVE SHUTDOWN HOURS:	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWh):	1808472	1808472	218315492
17. GROSS ELECTRICAL ENERGY GENERATED (MWe):	583170	583170	70289850
18. NET ELECTRICAL ENERGY GENERATED (MWe):	558750	558750	66839670
19. UNIT SERVICE FACTOR:	100.0%	100.0%	69.7%
20. UNIT AVAILABILITY FACTOR:	100.0%	100.0%	69.7%
21. UNIT CAPACITY FACTOR (USING MDC NET):	101.4%	101.4%	63.2%
22. UNIT CAPACITY FACTOR (USING DER NET):	96.7%	96.7%	60.8%
23. UNIT FORCED OUTAGE RATE:	0.0%	0.0%	13.0%
24. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			N/A
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:			N/A
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):			N/A

PLANT E. I. HATCH - UNIT O&E
AVERAGE DAILY POWER LEVEL
JANUARY 1992

DOCKET NO.: 50-321
DATE: FEBRUARY 3, 1992
COMPLETED BY: R. M. BEARD
TELEPHONE: (912) 367-7781 x2878

DAY	Net MWe
1	753
2	751
3	749
4	753
5	752
6	753
7	753
8	751
9	748
10	752
11	756
12	752
13	745
14	751
15	755
16	754
17	755
18	755
19	756
20	755
21	754
22	753
23	747
24	754
25	725
26	753
27	751
28	751
29	750
30	749
31	746

UNIT SHUTDOWNS AND POWER REDUCTIONS

UNIT NAME: E. I. HATCH - UNIT ONE

REPORT MONTH: JANUARY 1992

DOCKET NO.: 50-321
 DATE: FEBRUARY 3, 1992
 COMPLETED BY: R. M.
 TELEPHONE: (912) 367-7761 x2878

NO.	DATE	T Y P E	DURATION (HOURS)	R E A S O N	M E T H O D	LICENSEE EVENT REPORT NUMBER	S Y S T E M	COMPONENT CODE (SUBCODE)	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
									No significant power reductions this month.

TYPE:

- F-FORCED
- S-SCHEDULED

REASON:

- A-EQUIPMENT FAILURE (EXPLAIN)
- B-MAINTENANCE OR TEST
- C-REFUELING
- D-REGULATORY RESTRICTION
- E-OPERATOR TRAINING & LICENSE
- F-ADMINISTRATIVE
- G-OPERATIONAL ERROR (EXPLAIN)
- H-OTHER (EXPLAIN)

METHOD:

- 1-MANUAL
- 2-MANUAL SCRAM
- 3-AUTOMATIC SCRAM
- 4-CONTINUATIONS
- 5-LOAD REDUCTION
- 9-OTHER (EXPLAIN)

EVENTS REPORTED INVOLVE
 A GREATER THAN 20%
 REDUCTION IN AVERAGE
 DAILY POWER LEVEL FOR
 THE PRECEDING 24 HOURS.

ENCLOSURE 2

PLANT HATCH UNIT 2
NRC DOCKET 50-366
MONTHLY OPERATING REPORT
January 1992

TABLE OF CONTENTS

	<u>Page</u>
Narrative Report	E2-1
Operating Data Report	E2-2
Average Daily Power Level	E2-3
Unit Shutdowns and Power Reductions	E2-4

PLANT E. I. HATCH - UNIT TWO
NARRATIVE REPORT

DOCKET NO: 50-366
DATE: FEBRUARY 3, 1992
COMPLETED BY: R. M. BEARD
TELEPHONE: (912) 367-7781 x2878

JANUARY 1 0000 Shift continued to maintain rated thermal power.

JANUARY 23 1800 Shift began reducing load for unit shutdown to identify and repair the source of increased drywell floor drain leakage.

JANUARY 24 0455 The generator was removed from the grid.

JANUARY 24 0948 The reactor was manually scrammed.

JANUARY 28 1354 Shift began withdrawing control rods to bring the reactor critical.

JANUARY 28 1710 The reactor achieved critical status.

JANUARY 28 2240 Shift began returning the unit to hot shutdown to investigate and repair the source of high turbine vibration.

JANUARY 29 0043 The reactor was placed in hot shutdown.

JANUARY 30 1240 Power ascension activities were initiated.

JANUARY 31 0232 The generator was tied to the grid.

JANUARY 31 2400 Shift continued returning the unit to rated thermal power. Fuel preconditioning measures were implemented to minimize the possibility of further fuel damage.

OPERATING DATA REPORT

DOCKET NO: 50-366
 DATE: FEBRUARY 3, 1992
 COMPLETED BY: R. M. BEARD
 TELEPHONE: (912) 367-7781 x2878

OPERATING STATUS:

- | | |
|---|---|
| 1. UNIT NAME: | E. I. HATCH - UNIT TWO |
| 2. REPORTING PERIOD: | JANUARY 1992 |
| 3. LICENSED THERMAL POWER (MWt): | 2436 |
| 4. NAMEPLATE RATING (GROSS MWe): | 850 |
| 5. DESIGN ELECTRICAL RATING (NET MWe): | 784 |
| 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): | 798 |
| 7. MAXIMUM DEPENDABLE CAPACITY (NET MWe): | 765 |
| 8. IF CHANGES OCCUR IN CAPACITY RATINGS
(ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: | |
| | Maximum Dependable Capacities for 1992 are 798 MWe (Gross) and 765 MWe (Net).
Southern Company Services determined the values using 1991 operational data. |
| 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWe): | NO RESTRICTIONS |
| 10. REASONS FOR RESTRICTION, IF ANY: | N/A |

	THIS MONTH	YEAR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD:	744.0	744	108625
12. NUMBER OF HOURS REACTOR WAS CRITICAL:	640.8	640.8	81502.3
13. REACTOR RESERVE SHUTDOWN HOURS:	0.0	0.0	0.0
14. HOURS GENERATOR ON LINE:	578.4	578.4	78398.0
15. UNIT RESERVE SHUTDOWN HOURS:	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWh):	1372643	1372643	17352091
17. GROSS ELECTRICAL ENERGY GENERATED (MWe):	444900	444900	56883020
18. NET ELECTRICAL ENERGY GENERATED (MWe):	424722	424722	54171136
19. UNIT SERVICE FACTOR:	77.7%	77.7%	72.2%
20. UNIT AVAILABILITY FACTOR:	77.7%	77.7%	72.2%
21. UNIT CAPACITY FACTOR (USING MDC NET):	74.6%	74.6%	65.2%
22. UNIT CAPACITY FACTOR (USING DER NET):	72.8%	72.8%	63.6%
23. UNIT FORCED OUTAGE RATE:	4.6%	4.6%	7.4%
24. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			N/A
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:			N/A
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):			N/A

PLANT E. I. HATCH - UNIT TWO
AVERAGE DAILY POWER LEVEL
JANUARY 1992

DOCKET NO: 50-366
DATE: FEBRUARY 3, 1992
COMPLETED BY: R. M. BEARD
TELEPHONE: (912) 367-7781 x2878

DAY	Net MWe
1	768
2	765
3	765
4	762
5	768
6	768
7	767
8	767
9	764
10	766
11	771
12	767
13	762
14	767
15	770
16	768
17	768
18	770
19	769
20	770
21	769
22	769
23	688
24	24
25	0
26	0
27	0
28	0
29	0
30	0
31	174

UNIT SHUTDOWNS AND POWER REDUCTIONS

UNIT NAME: E. I. HATCH - UNIT TWO

DOCKET NO: 50-366

DATE: FEBRUARY 3, 1992

COMPLETED BY: R. M. BEARD

TELEPHONE: (912) 367-7781 x2878

REPORT MONTH: JANUARY 1992

NO.	DATE	T Y P E	DURATION (HOURS)	R E A S O N	M E T H O D	LICENSEE EVENT REPORT NUMBER	S Y S T O M E	COMPONENT CODE (SUBCODE)	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
92-001	920124	S	137.7	D	2	N/A	CB	PIPEXX (A)	The unit was shut down due to an unidentified source of floor drain leakage inside the drywell. Investigation revealed the Packing Leakoff Line for the "B" Reactor Recirculation Pump's Discharge Isolation Valve had separated. The discharge valve was repacked and the leakoff line reconnected.
92-002	920129	F	27.9	B	4	N/A	HA	TURBINE	The turbine could not be placed in service due to high vibration. Investigation revealed the rotor for the "B" Low Pressure Turbine was not properly balanced. A balance shot was installed and the turbine returned to service.

TYPE:

F-FORCED
S-SCHEDULED

REASON:

A-EQUIPMENT FAILURE (EXPLAIN)
B-MAINTENANCE OR TEST
C-REFUELING
D-REGULATORY RESTRICTION
E-OPERATOR TRAINING & LICENSE
F-ADMINISTRATIVE
G-OPERATIONAL ERROR (EXPLAIN)
H-OTHER (EXPLAIN)

METHOD:

1-MANUAL
2-MANUAL SCRAM
3-AUTOMATIC SCRAM
4-CONTINGATIONS
5-LOAD REDUCTION
9-OTHER (EXPLAIN)

EVENTS REPORTED INVOLVE
A GREATER THAN 20%
REDUCTION IN AVERAGE
DAILY POWER LEVEL FOR
THE PRECEDING 24 HOURS.