

UNIT SHUTDOWNS AND POWER REDUCTIONS (>20%)

Docket No. 50-412
 Unit Name BVPS Unit #2
 Date February 5, 1992
 Completed By David T. Jones
 Telephone (412) 393-7612

REPORT MONTH DECEMBER 1991 (revised)

| No. | Date | Type ¹ | Duration (Hours) | Reason ² | Method of Shutting Down Reactor ³ | Licensee Event Report # | System Code ⁴ | Component Code ⁵ | Cause & Corrective Action to Prevent Recurrence |
|-----|--------|-------------------|------------------|---------------------|--|-------------------------|--------------------------|-----------------------------|--|
| 15 | 911201 | S | 0 | H | 4 | N/A | ZZ | ZZZZZ | Unit continued to operate at 46% output to load follow. |
| 16 | 911206 | S | 0 | H | 5 | N/A | ZZ | ZZZZZ | Unit operated at 45% output to load follow. |
| 17 | 911225 | S | 0 | H | 5 | N/A | ZZ | HTEXCH | Unit reduced output from 100% to 28% for boric acid treatment of the steam generators. |

¹
 F-Forced
 S-Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont'd. from Previous Month
 5-Reduction
 9-Other

⁴
 Exhibit F-Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG0161).

⁵
 Exhibit H-Same Source.