




KANSAS GAS AND ELECTRIC COMPANY

GLENN L KOESTER
VICE PRESIDENT - NUCLEAR

June 15, 1984



Mr. E. H. Johnson, Acting Chief
Reactor Projects Branch 2
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

KMLNRC 84-089
Re: Docket No. STN 50-482
Ref: Interim Report KMLNRC 84-063 dated 4/19/84 from
GLKoester, KG&E, to JEGagliardo, NRC
Subj: Withdrawal of Potential 10CFR50.55(e) - Safety
Injection Accumulators

Dear Mr. Johnson:

This letter withdraws the potential 10CFR50.55(e) concerning the safety injection accumulators at Wolf Creek Generation Station. This matter was initially reported on March 19, 1984. Additional information was submitted in the reference.

It has been determined through a review of the pressurization records and procedures for the safety injection accumulators and subsequent fracture evaluation performed by the Nuclear Steam Supply System (NSSS) vendor, that the subject procedural deviation as stated in the reference did not affect the integrity of function of the subject tanks. Therefore, KG&E has concluded that this matter is not reportable pursuant to 10CFR50.55(e).

If you have any questions concerning this subject, please contact me or Mr. Otto Maynard of my staff.

Yours very truly,

GLK:cks

cc: PO'Connor
HBundy

8406210035 840615
PDR ADOCK 05000482
S PDR

IE-27 1/0