




KANSAS GAS AND ELECTRIC COMPANY

GLENN L KOESTER
VICE PRESIDENT - NUCLEAR

June 15, 1984

Mr. E. H. Johnson, Acting Chief
Reactor Project Branch 2
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



KMLNRC 84-090
Re: Docket No. 50-482
Ref: Interim Report KMLNRC 83-164 dated 12/16/83
from GLKoester, KG&E, to JEGagliardo, NRC
Subj: Withdrawal of Potential 10CFR50.55(e) -
Mechanical Cable Termination Lugs

Dear Mr. Johnson:

This letter withdraws the potential 10CFR50.55(e) concerning Mechanical Cable Termination Lugs at Wolf Creek Generating Station. This matter was initially reported by Kansas Gas and Electric Company (KG&E) on November 18, 1983, and additional information was submitted in the reference.

A review of specifications for the safety-related load centers (NG01, NG02, NG03, NG04) has insured that either the mechanical or compression type cable termination lugs are acceptable for use in these load centers. Due to the need to completely remove the mechanical type lugs from the subject load centers for inspection, KG&E opted to replace the existing mechanical type lugs with qualified compression type lugs. However, no damaged mechanical type lugs were found during the complete inspection of the safety-related load centers. Based on the aforementioned activities, KG&E has concluded that this matter is not reportable pursuant to 10CFR50.55(e).

If you have any questions concerning this subject, please contact me or Mr. Otto Maynard of my staff.

Yours very truly,

8406210088 840615
PDR ADOC 05000482
S PDR

GLK:cks

cc: PO'Connor
HBundy

IE-27 1/0