



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-338

NORTH ANNA POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 58
License No. NPF-4

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated March 15, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8406210120 840607
PDR ADOCK 05000338
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.D.(2) of Facility Operating License No. NPF-4 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 58, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 7, 1984

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 58 TO FACILITY OPERATING LICENSE NO. NPF-4

DOCKET NO. 50-338

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contains vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Page

3/4 4-34

3/4 4-35

B 3/4 4-12

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>		<u>PAGE</u>
3/4.5.4	BORON INJECTION SYSTEM	
	Boron Injection Tank.....	3/4 5-7
	Heat Tracing.....	3/4 5-8
3/4.5.5	REFUELING WATER STORAGE TANK.....	3/4 5-9

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
3/4.4.2 SAFETY VALVES - SHUTDOWN.....	3/4 4-6
3/4.4.3 SAFETY VALVES - OPERATING.....	3/4 4-7
SAFETY and RELIEF VALVES - OPERATING	
Safety Valves.....	3/4 4-7
Relief Valves.....	3/4 4-7a
3/4.4.4 PRESSURIZER.....	3/4 4-8
3/4.4.5 STEAM GENERATORS.....	3/4 4-9
3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE	
Leakage Detection Systems.....	3/4 4-16
Operational Leakage.....	3/4 4-17
3/4.4.7 CHEMISTRY.....	3/4 4-19
3/4.4.8 SPECIFIC ACTIVITY.....	3/4 4-22
3/4.4.9 PRESSURE/TEMPERATURE LIMITS	
Reactor Coolant System.....	3/4 4-26
Pressurizer.....	3/4 4-30
Overpressure Protection Systems.....	3/4 4-31
3/4.4.10 STRUCTURAL INTEGRITY	
ASME Code Class 1, 2 and 3 Components.....	3/4 4-33
3/4.5 <u>EMERGENCY CORE COOLING SYSTEMS (ECCS)</u>	
3/4.5.1 ACCUMULATORS.....	3/4 5-1
3/4.5.2 ECCS SUBSYSTEMS - $T_{avg} \geq 350^{\circ}F$	3/4 5-3
3/4.5.3 ECCS SUBSYSTEMS - $T_{avg} < 350^{\circ}F$	3/4 5-6

REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS

4.4.10.1.1 In addition to the requirements of Specification 4.0.5, 1) the Reactor Coolant pump flywheels shall be inspected per the recommendations of Regulatory Position C.4.b of Regulatory Guide 1.14, Revision 1, August 1975, and 2) the flow straighteners in each steam generator-to-RCP elbow shall be ultrasonically examined whenever a RCP shaft deflection of greater than 20 mils is indicated and at least once per 18 months.

4.4.10.1.2 In addition to the requirements of Specification 4.0.5, at least one third of the main member to main member welds, joining A572 material, in the steam generator supports, shall be visually examined during each 40 month inspection interval.

REACTOR COOLANT SYSTEM

3/4.4.10 STRUCTURAL INTEGRITY

ASME CODE CLASS 1, 2 & 3 COMPONENTS

LIMITING CONDITION FOR OPERATION

3.4.10.1 The structural integrity of ASME Code Class 1, 2 and 3 components shall be maintained in accordance with Specification 4.4.10.1.

APPLICABILITY: ALL MODES.

ACTION:

- a. With the structural integrity of any ASME Code Class 1 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature more than 50°F above the minimum temperature required by NDT considerations.
- b. With the structural integrity of any ASME Code Class 2 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature above 200°F.
- c. With the structural integrity of any ASME Code Class 3 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) from service.
- d. With any RCP shaft deflection indication greater than 20 mils, the reactor shall be placed in at least HOT STANDBY within 1 hour, the affected RCP(s) tripped and then affected flow straightener plate(s) ultrasonically examined.
- e. The provisions of Specification 3.0.4 are not applicable.

THIS PAGE WAS INTENTIONALLY LEFT BLANK

REACTOR COOLANT SYSTEM

BASES

3/4.4.10 STRUCTURAL INTEGRITY

3/4.4.10.1 ASME CODE CLASS 1, 2 AND 3 COMPONENTS

The inspection programs for ASME Code Class 1, 2 and 3 Reactor Coolant System components ensure that the structural integrity of these components will be maintained at an acceptable level throughout the life of the plant. To the extent applicable, the inspection program for components is in compliance with Section XI of the ASME Boiler and Pressure Vessel Code.

REACTOR COOLANT SYSTEM

BASES

vessel inside radius are essentially identical, the measured transition shift for a sample can be applied with confidence to the adjacent section of the reactor vessel. The heatup and cooldown curves must be recalculated when the ΔRT_{NDT} determined from the surveillance capsule is different from the calculated ΔRT_{NDT} for the equivalent capsule radiation exposure.

The pressure-temperature limit lines shown on Figure 3.4-2 for reactor criticality and for inservice leak and hydrostatic testing have been provided to assure compliance with the minimum temperature requirements of Appendix G to 10 CFR 50.

The number of reactor vessel irradiation surveillance specimens and the frequencies for removing and testing these specimens are provided in Table 4.4-3 to assure compliance with the requirements of Appendix H to 10 CFR Part 50.

The limitations imposed on pressurizer heatup and cooldown and spray water temperature differential are provided to assure that the pressurizer is operated within the design criteria assumed for the fatigue analysis performed in accordance with the ASME Code requirements.

The OPERABILITY of two PORVs or an RCS vent opening of greater than 2.07 square inches ensures that the RCS will be protected from pressure transients which could exceed the limits of Appendix G to 10 CFR Part 50 when one or more of the RCS cold legs are less than or equal to 320°F. Either PORV has adequate relieving capability to protect the RCS from overpressurization when the transient is limited to either (1) the start of an idle RCP with the secondary water temperature of the steam generator less than or equal to 50°F above the RCS cold leg temperatures or (2) the start of a charging pump and its injection into a water solid RCS.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-339

NORTH ANNA POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 40
License No. NPF-7

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated March 15, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-7 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 40, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 7, 1984

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 40 TO FACILITY OPERATING LICENSE NO. NPF-7

DOCKET NO. 50-339

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contains vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Page

3/4 4-32

3/4 4-33

B 3/4 4-17

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.6 CONTAINMENT SYSTEMS</u>	
3/4.6.1 CONTAINMENT	
Containment Integrity.....	3/4 6-1
Containment Leakage.....	3/4 6-2
Containment Air Locks.....	3/4 6-4
Internal Pressure.....	3/4 6-6
Air Temperature.....	3/4 6-8
Containment Structural Integrity.....	3/4 6-9
3/4.6.2 DEPRESSURIZATION AND COOLING SYSTEMS	
Containment Quench Spray System.....	3/4 6-10
Containment Recirculation Spray System.....	3/4 6-11
Chemical Addition System.....	3/4 6-13
3/4.6.3 CONTAINMENT ISOLATION VALVES.....	3/4 6-14
3/4.6.4 COMBUSTIBLE GAS CONTROL	
Hydrogen Analyzers.....	3/4 6-32
Electric Hydrogen Recombiners.....	3/4 6-33
Waste Gas Charcoal Filter System.....	3/4 6-34
3/4.6.5 SUBATMOSPHERIC PRESSURE CONTROL SYSTEM	
Steam Jet Air Ejector.....	3/4 6-36

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
3/4.4.2 SAFETY VALVES - SHUTDOWN	3/4 4-6
3/4.4.3 SAFETY RELIEF VALVES - OPERATING	
Safety Valves	3/4 4-7
Relief Valves	3/4 4-7a
3/4.4.4 PRESSURIZER	3/4 4-8
3/4.4.5 STEAM GENERATORS	3/4 4-9
3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE	
Leakage Detection Systems	3/4 4-16
Operational Leakage	3/4 4-17
3/4.4.7 CHEMISTRY	3/4 4-19
3/4.4.8 SPECIFIC ACTIVITY	3/4 4-22
3/4.4.9 PRESSURE/TEMPERATURE LIMITS	
Reactor Coolant System	3/4 4-29
Pressurizer	3/4 4-30
Overpressure Protection Systems	3/4 4-31
3/4.4.10 STRUCTURAL INTEGRITY	
ASME Code Class 1, 2 and 3 Components	3/4 4-32
<u>3/4.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)</u>	
3/4.5.1 ACCUMULATORS	3/4 5-1
3/4.5.2 ECCS SUBSYSTEMS - $T_{avg} \geq 350^{\circ}F$	3/4 5-3
3/4.5.3 ECCS SUBSYSTEMS - $T_{avg} < 350^{\circ}F$	3/4 5-6
3/4.5.4 BORON INJECTION SYSTEM	
Boron Injection Tank	3/4 5-8
Heat Tracing	3/4 5-9
3/4.5.5 REFUELING WATER STORAGE TANK	3/4 5-10

REACTOR COOLANT SYSTEM

3/4.4.10 STRUCTURAL INTEGRITY

ASME CODE CLASS 1, 2 & 3 COMPONENTS

LIMITING CONDITION FOR OPERATION

3/4.10.1 The structural integrity of ASME Code Class 1, 2 and 3 components shall be maintained in accordance with Specification 4.4.10.1.

APPLICABILITY: ALL MODES

ACTION:

- a. With the structural integrity of any ASME Code Class 1 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limits or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature more than 50°F above the minimum temperature required by NDT considerations.
- b. With the structural integrity of any ASME Code Class 2 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature above 200°F.
- c. With the structural integrity of any ASME Code Class 3 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) from service.
- d. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.4.10.1.1 In addition to the requirements of Specification 4.0.5, the Reactor Coolant pump flywheels shall be inspected per the recommendations of Regulatory Position C.4.b of Regulatory Guide 1.14, Revision 1, August 1975.

4.4.10.1.2 In addition to the requirements of Specification 4.0.5, at least one third of the main member to main member welds, joining A572 material, in the steam generator supports, shall be visually examined during each 40 month inspection interval.

REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS

4.4.9.3.1 Each PORV shall be demonstrated OPERABLE by:

- a. Performance of a CHANNEL FUNCTIONAL TEST on the PORV actuation channel, but excluding valve operation, within 31 days prior to entering a condition in which the PORV is required OPERABLE and at least once per 31 days thereafter when the PORV is required OPERABLE.
- b. Performance of a CHANNEL CALIBRATION on the PORV actuation channel, at least once per 18 months.
- c. Verifying the PORV key switch is in the AUTO position and the PORV isolation valve is open at least once per 72 hours when the PORV is being used for overpressure protection.
- d. Testing pursuant to Specification 4.0.5.

4.4.9.3.2 The RCS vent(s) shall be verified to be open at least once per 12 hours* when the vent(s) is being used for overpressure protection.

4.4.9.3.3 The pressurizer water volume shall be verified to be less than or equal to 457 cubic feet at least once per 12 hours when the pressurizer is being used for overpressure protection

*Except when the vent pathway is provided with a valve which is locked, sealed, or otherwise secured in the open position, then verify these valves open at least once per 31 days.

THIS PAGE INTENTIONALLY LEFT BLANK

THIS PAGE INTENTIONALLY LEFT BLANK