

JUN 11 1984

Docket No. 50-373

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

SUBJECT: SAFETY EVALUATION OF THE IMPLEMENTATION OF NUREG-0313,
REVISION 1 FOR LA SALLE COUNTY STATION, UNIT 1

Generic Letter 81-04, dated February 26, 1981, requested that you review all ASME-Code Class 1 and 2 pressure boundary piping, safe ends, and fitting materials, including the weld metal in La Salle County Station, Unit 1 to determine if they were in compliance with the guidelines of NUREG-0313, Revision 1 "Technical Report on Material Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping," dated July 1980. By letters dated July 7, 1981, December 28, 1982 and January 18, 1983, you provided information in response to this Generic Letter.

The NRC staff has completed its review of your responses to Generic Letter 81-04. Our contractor, EG&G, concluded that your responses did not fully meet the guidelines set forth in NUREG-0313, Revision 1. However, recent experience related to intergranular stress corrosion cracking (IGSCC) and evaluation of the results of inspections conducted in response to I.E. Bulletins 82-03 and 83-02 and orders were outside of the scope of the review of issues addressed in Generic Letter 81-04. Therefore, we conclude that the assessment regarding conformance with NUREG-0313, Revision 1 guidelines is not currently germane because of the recently issued generic letters (Generic Letters 84-07 and 84-11) on this subject.

We are transmitting the enclosed Safety Evaluation, which also includes the Technical Evaluation Report prepared by our contractor, for your information and for assisting you in preparing your responses to Generic Letters 84-07 and 84-11 addressing this issue in terms of both short term reinspection and guidance for replacement of any affected system piping in your plant.

8406210170 840611
PDR ADOCK 05000373
P PDR

This completes our action in reviewing your responses to Generic Letter 81-04 (NUREG-0313, Revision 1).

Sincerely,

A. Schwencer, Chief
Licensing Branch #2
Division of Licensing


Enclosure:
As stated


cc w/enclosure:
See next page

DISTRIBUTION

Docket File

NRC PDR
Local PDR
LB#2 Reading
ABournia
ASchwencer
DEisenhut
OELD
RHermann
ELJordan
JNGrace
ACRS (10)
Gray File
EHytton


DL:LB#2
ABournia
06/06/84


DL:LB#2
ASchwencer
06/06/84