September 6, 1995

Mr. M. S. Tuckman Senior Vice President Nuclear Generation Duke Power Company P. O. Box 1006 Charlotte, NC 28201

REQUEST FOR ADDITIONAL INFORMATION - DPC-NE-3000. THERMAL-HYDRAULIC SUBJECT: TRANSIENT ANALYSIS METHODOLOGY - MCGUIRE NUCLEAR STATION, UNITS 1 AND 2: AND CATAWBA NUCLEAR STATION, UNIT 1 (TAC NOS. M90143, M90144, AND M90145)

### Dear Mr. Tuckman:

By letter dated August 9, 1994, you submitted for staff review and approval a report identified as Revision 3 of Topical Report DPC-NE-3000, "Thermal-Hydraulic Transient Analysis Methodology." Based on our review of your report conducted to date, the NRC staff has identified a need for additional information as indicated in the enclosure. Proprietary information in the enclosure was identified by your staff and documented by your letter dated April 9, 1994. The enclosure should be controlled and distribution limited to personnel with a "need to know." The enclosure is considered exempt from Public Disclosure in accordance with Title 10, Code of Federal Regulations, Part 2.790. However, a copy of this letter, with a non-proprietary version of the enclosure, will be placed in the NRC Public Document Room. Please provide a response within sixty (60) days of receipt of this letter to enable us to complete our review.

This requirement affects nine or fewer respondents, and therefore, it is not subject to the Office of Management and Budget review under P.L. 96-511.

Sincerely,

Original signed by:

is decontrolled.

Robert E. Martin, Senior Project Manager Project Directorate II-2 Directorate for Reactor Projects - I/II Office of Nuclear Reactor Regulation

Document transmitted herewith contains

sensitive unclassified information. When

separated from enclosure, this document

Docket Nos. 50-369, 50-370. and 50-413

Enclosure: Request For Information (Proprietary)

cc w/Non-Proprietary enclosure: See next page

#### DISTRIBUTION:

w/Proprietary enclosure: Docket File L.Lois PDI1-2 R/F V.Nerses R.Martin R.Crlenjack,RII ACRS (4) CHENGE: NECEDER INP CHENGE: NECEDER INP

w/Non-Propri	etary enclosure:
Docket File	J.Zwolinski
PUBLIC	E.Merschoff, RII
S.Varga	OGC

To receive a copy of	this document,	indicate in the box: "C"	= Copy without
attachment/enclosure	"E" = Copy wi	th attachment/enclosure	"N" = No copy

OFFICE	LA:PD22:DRPE	PA:PD22;DRPE E	PT::22:DRPE E	D: PD22 EHPE		
NAME	LBERRY X	RMARTIN:	MERSES	HBERKOW		
DATE	4 16 195	916195 1	916195	01 5 195	/ /95	/ /95
Berner and a restorable a summaria	DOCUMENT NAME.	CALCETALIDELC	AT00143 1T0			

DOCUMENT NAME: G:\CATAWBA\CAT90143.LTR 9509130187 950906 PDR ADOCK 05000369 PDR

NRC FILE CENTER COPY

Mr. M. S. Tuckman Senior Vice President Nuclear Generation Duke Power Company P. O. Box 1006 Charlotte, NC 28201

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - DPC-NE-3000, THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY - McGUIRE NUCLEAR STATION, UNITS 1 AND 2; AND CATAWBA NUCLEAR STATION, UNIT 1 (TAC NOS. M90143, M90144, AND M90145)

September 6, 1995

Dear Mr. Tuckman:

By letter dated August 9, 1994, you submitted for staff review and approval a report identified as Revision 3 of Topical Report DPC-NE-3000, "Thermal-Hydraulic Transient Analysis Methodology." Based on our review of your report conducted to date, the NRC staff has identified a need for additional information as indicated in the enclosure. Proprietary information in the enclosure was identified by your staff and documented by your letter dated April 9, 1994. The enclosure should be controlled and distribution limited to personnel with a "need to know." The enclosure is considered exempt from Public Disclosure in accordance with Title 10, Code of Federal Regulations, Part 2.790. However, a copy of this letter, with a non-proprietary version of the enclosure, will be placed in the NRC Public Document Room. Please provide a response within sixty (60) days of receipt of this letter to enable us to complete our review.

This requirement affects nine or fewer respondents, and therefore, it is not subject to the Office of Management and Budget review under P.L. 96-511.

Sincerely,

Original signed by:

Robert E. Martin, Senior Project Manager Project Directorate II-2 Directorate for Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-369, 50-370, and 50-413

Enclosure: Request For Information (Proprietary) Document transmitted herewith contains sensitive unclassified information. When separated from enclosure, this document is decontrolled.

cc w/Non-Proprietary enclosure: See next page

#### DISTRIBUTION:

w/Proprietary enclosure: Docket File L.Lois PDII-2 R/F V.Nerses R.Martin R.Crlenjack,RII w/Non-Proprietary enclosure: Docket File J.Zwolinski ACRS (4) PUBLIC E.Merschoff,RII S.Varga OGC

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD22:DAPE. E	PACPD2210886 E	PI:221DRPE E	D: POZZYEMPE		L
NAME	LBERRY	RNARTIN:	AMERSES	HBERKO		
DATE	4 16 195	916195	1916195	91 5 195	/ /95	/ /95

DOCUMENT NAME: G:\CATAWBA\CAT90143.LTR



# UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 6, 1995

Mr. M. S. Tuckman Senior Vice President Nuclear Generation Duke Power Company P. O. Box 1006 Charlotte, NC 28201

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - DPC-NE-3000, THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY - McGUIRE NUCLEAR STATION, UNITS 1 AND 2; AND CATAWBA NUCLEAR STATION, UNIT 1 (TAC NOS. M90143, M90144, AND M90145)

Dear Mr. Tuckman:

By letter dated August 9, 1994, you submitted for staff review and approval a report identified as Revision 3 of Topical Report DPC-NE-3000, "Thermal-Hydraulic Transient Analysis Methodology." Based on our review of your report conducted to date, the NRC staff has identified a need for additional information as indicated in the enclosure. Proprietary information in the enclosure was identified by your staff and documented by your letter dated April 9, 1994. The enclosure should be controlled and distribution limited to personnel with a "need to know." The enclosure is considered exempt from Public Disclosure in accordance with Title 10, Code of Federal Regulations, Part 2.790. However, a copy of this letter, with a non-proprietary version of the enclosure, will be placed in the NRC Public Document Room. Please provide a response within sixty (60) days of receipt of this letter to enable us to complete our review.

This requirement affects nine or fewer respondents, and therefore, it is not subject to the Office of Management and Budget review under P.L. 96-511.

Sincerely,

Robert E Martin

Robert E. Martin, Senior Project Manager Project Directorate II-2 Directorate for Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-369, 50-370, and 50-413 Enclosure:

Request for Information (Proprietary)

cc w/non-proprietary enclosure: See next page Document transmitted herewith contains sensitive unclassified information. When separated from enclosure, this document is decontrolled. Duke Power Company

CC:

A. V. Carr, Esquire Duke Power Company 422 South Church Street Charlotte, North Carolina 28242-0001

County Manager of Mecklenburg County 720 East Fourth Street Charlotte, North Carolina 28202

Mr. J. E. Snyder Regulatory Compliance Manager Duke Power Company McGuire Nuclear Site 12700 Hagers Ferry Road Huntersville, North Carolina 28078

J. Michael McGarry, III, Esquire Winston and Strawn 1400 L Street, NW. Washington, DC 20005

Senior Resident Inspector c/o U. S. Nuclear Regulatory Commission 12700 Hagers Ferry Road Huntersville, North Carolina 28078

Mr. T. Richard Puryear Nuclear Technical Services Manager Westinghouse Electric Corporation Carolinas District 2709 Water Ridge Parkway, Suite 430 Charlotte, North Carolina 28217

Dr. John M. Barry Mecklenburg County Department of Environmental Protection 700 N. Tryon Street Charlotte, North Carolina 28202 McGuire Nuclear Station Catawba Nuclear Station

Mr. Dayne H. Brown, Director Department of Environmental, Health and Natural Resources Division of Radiation Protection P. O. Box 27687 Raleigh, North Carolina 27611-7687

Ms. Karen E. Long Assistant Attorney General North Carolina Department of Justice P. O. Box 629 Raleigh, North Carolina 27602

Mr. G. A. Copp Licensing - EC050 Duke Power Company 526 South Church Street Charlotte, North Carolina 28242-0001

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, NW. Suite 2900 Atlanta, Georgia 30323

Elaine Wathen Lead REP Planner Division of Emergency Management 116 West Jones Street Raleigh, North Carolina 27603-1335 Duke Power Company

cc:

Mr. Z. L. Taylor Regulatory Compliance Manager Duke Power Company 4800 Concord Road York, South Carolina 29745

North Carolina Municipal Power Agency Number 1 1427 Meadowwood Boulevard P. O. Box 29513 Raleigh, North Carolina 27626-0513

County Manager of York County York County Courthouse York, South Carolina 29745

Richard P. Wilson, Esquire Assistant Attorney General South Carolina Attorney General's Office P. O. Box 11549 Columbia, South Carolina 29211

Piedmont Municipal Power Agency 121 Village Drive Greer, South Carolina 29651

Saluda River Electric P. O. Box 929 Laurens, South Carolina 29360

Max Batavia, Chief Bureau of Radiological Health South Carolina Department of Health and Environmental Control 2600 Bull Street Columbia, South Carolina 29201 McGuire Nuclear Station Catawba Nuclear Station

North Carolina Electric Membership Corporation P. O. Box 27306 Raleigh, North Carolina 27611

Senior Resident Inspector 4830 Concord Road York, South Carolina 29745

Mr. William R. McCollum Site Vice President Catawba Nuclear Station Duke Power Company 4800 Concord Road York, South Carolina 29745

Mr. T. C. McMeekin Vice President, McGuire Site Duke Power Company 12700 Hagers Ferry Road Huntersville, North Carolina 28078

# NON-PROPRIETARY INFORMATION

### REQUEST FOR ADDITIONAL INFORMATION

### THERMAL-HYDRAULIC TRANSIENT

#### ANALYSIS METHODOLOGY

- 1. Justify the proposed use of the [ ] for material properties and the [ ] for the fuel gap conductivity by demonstrating that computations will result in conservative system predictions for all transients. (p.2-40)
- 2. Discuss the situations in which [ ] during steady-state initialization may not result in conservative prediction of the transient calculations and reconcile that result with the response to Question 1. (p.2-40)
- 3. In the previously submitted model with the original topical report, DPC observed that a large adjustment in the [ ] was necessary during the outsurge portion of any transient containing a strong outsurge. Discuss how this problem is addressed by the use of the revised PZR model which includes modeling of the surge line.
- 4. Demonstrate by reanalysis of transients/tests that the revised PZR model with heat conductors results in adequately conservative predictions. In addition, DPC should qualify its PZR water level prediction procedure.(p.2-42 & p.3-47)
- Discuss modeling of phase separation including the selected BR velocity in the [ ] (p.2-49 & 51).
- 6. Provide thorough discussion and qualification of the revised SG model for feedring SGs including steady-state initialization and nodalization sensitivities, and demonstrate that the model produces an adequately conservative prediction of heat transfer. In addition, DPC should qualify the SG level calculator for the feedring SG against the data.
- Discuss the source(s) of the significant reduction in trip setpoints for the load rejection controller for Catawba.
- 8. Clarify the new paragraph to be inserted in page 3-16 regarding the SG level control. Do both Catawba Units have the DFCS? Discuss how this system is simulated and qualified in the RETRAN analysis.

## NON-PROPRIETARY INFORMATION

- 2 -

- 9. Discuss the source(s) and reasons for changes and impact on safety analysis in the following plant models, setpoints and values:
  - a. HHSI pump characteristics
  - b. IHSI pump characteristics
  - c. LHSI pump characteristics
  - d. Steam line pressure for SI signal & steam line isolation
  - e. elimination of a RPS condition for reactor trip
  - f. steam line safety valve opening setpoints
  - g. HHSI and IHSI injection after 7 hours
- 10. Once the planned steam generator replacement takes place, what does DPC plan to do with respect to the aspects of the report addressing the old SGs for McGuire #1 and 2 and Catawba #1 which would no longer be applicable? Provide comparable benchmark analysis to be included in the topical report in support of the new steam generators.
- 11. Clarify Section 3.1.6.2. Which unit at Catawba does the revised AFW runout protection apply to and how is the other unit protected?
- Discuss the impact of installation of feedring steam generators and its accompanying changes on transient analysis such as the MFW and AFW flow.
- 13. Discuss in detail how the general transport model is used to ismulate boron transport, including the nodalization of injection site, mixing coefficient, analysis for which this is credited, and demonstrate that the model produces conservative results.
- Discuss the change in assumed steady-state pump head and flow for various transients (§ 2.2.6.2).