

February 10, 1992

Docket Nos. 50-334
and 50-412
Serial No. BV-92-004

Distribution:
Docket File
NRC & Local PDRs
PD I-4 Plant
SVarga
JCalvo
SNorris
OGC
ACRS (10)
ADeAgazio
CWHehl, RI
LEngle

Mr. J. D. Sieber, Vice President
Nuclear Group
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077-0004

Dear Mr. Sieber:

SUBJECT: BULLETIN 89-01, SUPPLEMENT 2 - ACCEPTABLE RESPONSE RECEIVED
(TAC M81590 AND M81591)

On June 28, 1991, NRC Bulletin 89-01, Supplement 2, "Failure of Westinghouse Steam Generator Mechanical Plugs", was issued. This bulletin requested that actions similar to those requested in NRC Bulletin 89-01 be extended to apply to include all Westinghouse mechanical plugs fabricated from thermally-treated Inconel 600. These actions were necessary to assure reactor coolant system pressure boundary integrity under normal operating, transient, and postulated accident conditions.

Duquesne Light Company responded to Supplement 2 by letter dated July 30, 1991. This response provided the information addressed in the Actions Requested section of the supplement. We have reviewed your response for Beaver Valley Power Station, Units 1 and 2 and find the information and accomplished/planned actions to be acceptable.

Sincerely,

/s/

Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

cc: See next page

OFFICIAL RECORD COPY

Document Name: 81590LET

OFC	:LA:PDI-4	:PM:PDI-4	:D:PDI-4	:	:	:
NAME	:SNorris	:ADeAgazio:cn:	JStolz	:	:	:
DATE	:2/6/92	:2/6/92	:2/7/92	:	:	:

9202120189 920210
PDR ADOCK 05000334
PDR

NRC FILE CENTER COPY

DF01
110

Mr. J. D. Sieber
Duquesne Light Company

Beaver Valley Power Station
Units 1 & 2

cc:

Jay E. Silberg, Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037

Nelson Tonet, Manager
Nuclear Safety
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077

Commissioner Roy M. Smith
West Virginia Department of Labor
Building 3, Room 319
Capitol Complex
Charleston, West Virginia 25305

John D. Borrows
Director, Utilities Department
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Director, Pennsylvania Emergency
Management Agency
Post Office Box 3321
Harrisburg, Pennsylvania 17105-3321

Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
ATTN: R. Janati
Post Office Box 2063
Harrisburg, Pennsylvania 17120

Mayor of the Borough of
Shippingport
Post Office Box 3
Shippingport, Pennsylvania 15077

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406