

Docket No. 50-219

Distribution:

Mr. John J. Barton  
Vice President and Director  
GPU Nuclear Corporation  
Oyster Creek Nuclear Generating Station  
Post Office Box 388  
Forked River, New Jersey 08731

Docket File  
NRC & Local PDRs  
PD I-4 Plant  
SVarga  
JCalvo  
SNorris  
ADromerick  
OGC  
ACRS (10)  
CWHehl, RI  
OChopra  
SHoffman

Dear Mr. Barton:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF  
GENERIC ISSUE 48, 'LCO'S FOR CLASS 1E VITAL INSTRUMENT  
BUSES,' AND 49, 'INTERLOCKS AND LCO'S FOR CLASS 1E TIE  
BREAKERS,' PURSUANT TO 10 CFR 50.54(f)" FOR  
OYSTER CREEK NUCLEAR GENERATING STATION (TAC NO. M82442)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11 which contained the staff resolution of Generic Issues 48 and 49. The GL required that licensees certify that procedures exist which contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters or other onsite power sources for VIB, and tie breakers. If procedures do not exist, a justification demonstrating the reasons why the controls are not needed is required.

By letter dated January 29, 1992, you responded to the GL. You indicated that procedures for time limitations and surveillance requirements are in place at your site.

The staff has reviewed your response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC No. M82442.

Sincerely,

/s/

Alexander W. Dromerick, Sr. Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page

OFFICIAL RECORD COPY

Document Name: 9111RES

OFC	:LA:PDI-4	:PM:PDI-4	:D:PDI-4	:	:	:
NAME	:SNorris	:ADromerick	:cn:JStolz	:	:	:
DATE	:2/10/92	:2/10/92	:2/10/92	:	:	:

9202120233 920210  
PDR ADDCK 05000219  
P PDR

NRC FILE CENTER COPY

DF01  
1/0

Mr. John J. Barton  
GPU Nuclear Corporation

Oyster Creek Nuclear  
Generating Station

cc:

Ernest L. Blake, Jr., Esquire  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, NW.  
Washington, DC 20037

Resident Inspector  
c/o U.S. Nuclear Regulatory Commission  
Post Office Box 445  
Forked River, New Jersey 08731

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allentown Road  
King of Prussia, Pennsylvania 19406

Kent Tosch, Chief  
New Jersey Department of Environmental  
Protection  
Bureau of Nuclear Engineering  
CN 415  
Trenton, New Jersey 08625

BWR Licensing Manager  
GPU Nuclear Corporation  
1 Upper Pond Road  
Parsippany, New Jersey 07054

Mayor  
Lacey Township  
818 West Lacey Road  
Forked River, New Jersey 08731

Licensing Manager  
Oyster Creek Nuclear Generating Station  
Mail Stop: Site Emergency Bldg.  
P. O. Box 388  
Forked River, New Jersey 08731