



Northern States Power Company

Prairie Island Nuclear Generating Plant

1717 Wakonade Dr. East
Weich, Minnesota 55089

September 8, 1995

10 CFR Part 50
Section 50.73

U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

Deficiencies Discovered In Inservice
Surveillance of Cooling Water System

The Licensee Event Report for this occurrence is attached. In the report, we made four new NRC commitments:


Hydrostatic tests of the untested piping sections and the cooling water strainers will be performed by December 31, 1995.

Cooling water system inservice pressure test procedures will be reviewed and revised as necessary by December 31, 1995.

Standing procedures for ASME Code Class 3 systems will be reviewed for adequacy by December 31, 1995.

The 10-year hydrostatic test procedures for cooling water piping will be written and revised as necessary by May 31, 1996.

Please contact us if you require additional information related to this event.


Michael D Wadley
Plant Manager
Prairie Island Nuclear Generating Plant

c: Regional Administrator - Region III, NRC
NRR Project Manager, NRC
Senior Resident Inspector, NRC
Kris Sanda, State of Minnesota

Attachment

9509140008 950908
PDR ADOCK 05000282
S PDR

JE 22/1