

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company
Hatch

Docket No. 50-366
License No. NPF-5

The following violations were identified during an inspection conducted on April 3 - 6, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50, Apper.dix B, Criterion XII, as implemented by Section 12 of the Hatch Nuclear Plant Quality Assurance Manual, requires that measures be established to assure that tools, gages, instruments, and other measuring and testing devices used in activities affecting quality are properly controlled, calibrated, and adjusted at specified periods to maintain accuracy within necessary limits.

Contrary to the above, on April 4, 1984, measures were not established to assure control and calibration of measuring devices in that procedures were not issued for control and calibration of automatic welding equipment being used for welding of RECIRC system piping.

This is a Severity Level V violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: APR 19 1984

8406210475 840531
PDR ADOCK 05000321
G PDR