

APPENDIX A
NOTICE OF VIOLATION

Kansas Gas and Electric Company
Wolf Creek Generating Station

Docket: 50-482/84-09
Permit: CPPR 147

Based on the results of an NRC inspection conducted during the period of April 1 - 28, 1984, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 49 FR 8583, dated March 8, 1984, the following violation was identified:

Failure to Control Activities Affecting Quality

10 CFR Part 50, Appendix B, Criterion II, requires, in part, that activities affecting quality shall be accomplished under suitably controlled conditions.

Contrary to the above, during a tour of the facility on April 3, 1984, the NRC inspector discovered the safety-related battery rooms for NK 13 and NK 14 were uncontrolled for access and the NK 13 battery room was being used for weld preparation of piping. Additionally, Battery NK 14 had scaffolding erected around it and the battery appeared to have been walked on.

These activities were being conducted in these rooms after the battery preoperational test was completed and the rooms should have been controlled.

This is a Severity Level IV Violation. (Supplement II)
(482/8409-01)

Pursuant to the provisions of 10 CFR 2.201, Kansas Gas and Electric Company is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

16 MAY 1984

Dated: _____

8406210519 840516
PDR ADOCK 05000482
G PDR