



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

IOWA ELECTRIC LIGHT AND POWER COMPANY
CENTRAL IOWA POWER COOPERATIVE
CORN BELT POWER COOPERATIVE

DOCKET NO. 50-331

DUANE ARNOLD ENERGY CENTER

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 101
License No. DPR-49

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Iowa Electric Light & Power Company, et al, dated January 26, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-49 is hereby amended to read as follows:


8406210522 840601
PDR ADOCK 05000331
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 101, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Domenic B. Vassallo, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the
Technical Specifications

Date of Issuance: June 1, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 101

FACILITY OPERATING LICENSE NO. DPR-49

DOCKET NO. 50-331

Revise the Appendix A Technical Specifications by removing the current page and inserting the revised page listed below. The revised areas are identified by vertical lines.

LIST OF AFFECTED PAGES

3.3 - 2

LIMITING CONDITION FOR OPERATION	SURVEILLANCE REQUIREMENT
<p>b. The control rod directional control valves for inoperable control rods shall be disarmed electrically and the control rods shall be in such position that Specification 3.3.A.1 is met.</p>	<p>b. A second licensed operator shall verify the conformance to Specification 3.3.A.2d before a rod may be bypassed in the Rod Sequence Control System.</p>
<p>c. Control rods with inoperable accumulators or those whose position cannot be positively determined shall be considered inoperable.</p>	<p>c. Once per week when the plant is in operation, check status of pressure and level alarms for each CRD accumulator.</p>
<p>d. Control rods with a failed "Full-in" or "Full-out" position switch may be bypassed in the Rod Sequence Control System and considered operable if the actual rod position is known. These rods must be moved in sequence to their correct positions (full-in on insertion or full-out on withdrawal).</p>	<p>d. Once per quarter verify that:</p> <ol style="list-style-type: none"> (1) the Scram Discharge Volume (SDV) vent and drain valves close within 30 seconds after receipt of a close signal, and (2) after removal of the close signal, that the SDV vent and drain valves are open. Once per month verify that the SDV vent and drain valve position indicating lights located in the control room indicate that the valves are open.
<p>e. Control rods with scram times greater than those permitted by Specification 3.3.C.3 are inoperable, but if they can be inserted with control rod drive pressure they need not be disarmed electrically.</p>	<p>e. Once per cycle verify that:</p> <ol style="list-style-type: none"> (1) the SDV vent and drain valves close within 30 seconds after receipt of a signal for the control rods to scram, and
<p>f. Inoperable control rods shall be positioned such that Specification 3.3.A.1 is met.</p>	<ol style="list-style-type: none"> (2) open when the scram signal is reset.