

APR 20 1984

ENCLOSURE 1

NOTICE OF VIOLATION

South Carolina Electric & Gas Co.
V. C. Summer

Docket No. 50-395
License No. NPF-12

The following violations were identified during an inspection conducted on March 1-31, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 6.8.1.f requires that written procedures be established, implemented and maintained for the Fire Protection Program. Preventative Test Procedure (PTP) 114.002, Fire Extinguisher Checks, Fire Protection Procedure (FPP)-003, Control of Transient Combustibles, and Fire Protection Procedure (FPP)-005, Burn Permits, implement the Fire Protection Program.

Contrary to the above, procedures were not adequately implemented in that:

1. Although PTP 114.002 requires monthly fire extinguisher checks, fire extinguisher no. 664 was not inspected (checked) during the period of September 1, 1983 to March 5, 1984.
2. Although PTP 114.002 requires monthly fire extinguisher checks, fire extinguishers Nos. 34 and 37 did not receive their monthly check during the March 10, 1984 performance of PTP 114.002.
3. Although FPP-003 requires that transient combustibles be removed or protected from ignition sources in areas containing safety related equipment, an unprotected transient combustible was found stored adjacent to service water pump "B" on March 8, 1984.
4. Although FPP-003 requires that transient combustibles be removed or protected from ignition sources in areas containing safety related equipment, unprotected transient combustibles were found stored in the "A" emergency diesel generator room on March 12, 1984.
5. Although FPP-005 requires that for welding operations; combustible materials within a 35 ft. radius be removed or covered with non-flammable materials and open deck grating directly below the work area be covered with non-flammable materials and protective screens be used to protect passers by from eye flashburns, no such precautions were taken during a welding operation on March 12, 1984.

This is a Severity Level IV violation (Supplement I).

8406220009 840531
PDR ADOCK 05000395
PDR
Q

South Carolina Electric & Gas Company 2
V. C. Summer

Docket No. 50-395
License No. NPF-12

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: APR 20 1964