



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

NUCLEAR PRODUCTION DEPARTMENT

February 3, 1984

U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/15525/15526
I.E. Report 50-416/83-38 of
August 15-19 and August 30-
September 1, 1983.
AECM-84/0065

Reference: 1. MAEC-83/0319
2. AECM-83/0694
3. MAEC-84/0001

This letter provides our supplementary response to Violation 83-38-10 per your request of January 4, 1984. Please add the contents of the attached supplement to the appropriate paragraphs shown.

Yours truly,

L. F. Dale
Manager of Nuclear Services

PRH:scb
Attachment

cc: Mr. J. B. Richard, w/a
Mr. R. B. McGehee, w/a
Mr. T. B. Conner, w/a
Mr. G. B. Taylor, w/a

Mr. Richard C. DeYoung, Director, w/a
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

B406220045 B40330
PDR ADOCK 05000416
Q PDR

ber Middle South Utilities System

bcc: Mr. A. Zaccaria, w/o
Mr. R. W. Jackson, w/a
Mr. C. D. Wood, w/o
Mr. J. F. Hudson, Jr., w/o
Mr. T. H. Cloninger, w/a
Mr. J. P. McGaughy, w/o
Mr. T. E. Reaves, w/o
Mr. J. E. Cross, w/a
Mr. S. M. Feich, w/a
Mr. A. R. Smith, w/o
Mr. A. G. Wagner, w/a
Mr. C. C. Hayes, w/a
Mr. M. D. Houston, w/a
Mr. J. F. Pinto, w/a
Mr. M. D. Archdeacon, w/a
Mr. L. F. Dale, w/a
Mr. A. C. Pearson, w/a
Mr. A. S. McCurdy, w/o
Mr. P. J. Richardson, w/a
Mr. P. R. Hughes, w/a
Mr. J. G. Cesare, w/a
SRC Secretary, w/a
Middle South Services Nuclear Activities, w/a
File (LCTS), w/a
File (Plant), w/a
File (Project), w/a [4]

SUPPLEMENTARY RESPONSE

VIOLATION

83-38-10

Paragraph IV:

Corrective steps which have been taken to avoid further violation.

Plant Procedure 10-S-03-1 "Fire Protection System Impairment", will be revised to provide guidance to plant personnel on what action must be taken when blocking open a (Tech. Spec.) fire door.

Paragraph V:

Date when full compliance will be achieved.

The revision to the procedure should be completed by February 24, 1984.