

ATTACHMENT B

PHILADELPHIA ELECTRIC COMPANY
PEACH BOTTOM ATOMIC POWER STATION

UNIT 3

DOCKET NO. 50-278

GENERAL ELECTRIC COMPANY'S
FRACTURE MECHANICS EVALUATION
AND OVERLAY WELD REPAIR DESIGN


8406220118 840620
PDR ADOCK 05000278
P PDR

DRF #137-0010
MAR 84-19
SR03.DA

EVALUATION OF THE INDICATIONS
IN THE PEACH BOTTOM 3 JET PUMP
INSTRUMENTATION NOZZLE SAFE END-REDUCER WELD

June 1984

Prepared By:



S. Ranganath, Manager
Mechanics Analysis

1. EVALUATION BASIS

Evaluation was performed for two sets of assumed flaw configurations as measured flaw sizes.

- (1) A Loop weld: Composite flaw 1.87 inches long 0.075 inch deep
- B Loop weld: 0.75 inch long, 0.175 inch deep circumferential flaw

These flaw sizes were based on best estimates of Level II Inspector.

- (11) In the second evaluation, a through-wall flaw equal to 1/6 of the circumference (16.7%) was postulated. This conservative assumption was made since the UT inspection was somewhat restricted over approximately 1/3 of the circumference. The Level III Inspector felt that in this position, the UT results were effective over half the length (or 1/6 of the circumference). The assumption of a 16.7% through-wall flaw therefore represents a limiting condition.

The following stress values were used for the purpose of predicting crack growth and allowable flaw sizes.

$$P_m = 3 \text{ ksi} \quad (\text{pressure stress} = pd/4t)$$

$$P_m + P_b = 5 \text{ ksi}$$

The $P_m + P_b$ was an estimate since the information was not available in the stress report. Nevertheless, it is reasonable since the reducer is not connected to any piping and therefore experiences no piping loads. Seismic loads are also insignificant.

For crack growth analysis a residual (bending) stress of 30 ksi is assumed. Crack growth rates corresponding to furnace sensitized material in 8 ppm oxygenated water (Figure 1) was used. This is appropriate since the environment in the reducer is stagnant.

2. EVALUATION OF CRACKS PER UT SIZING

Figures 2 and 3 show the allowable flaw sizes per IWB-3642 (safety factor of 3) on the same plot, the as-measured initial flaw size, and predicted crack is shown. Based on the assumed conservative furnace sensitized crack growth rate, both cracks are predicted to grow to through-wall in approximately 3000 hours. Although a through-wall crack is predicted, it is still within the allowable value since the safety factor of 3 can be maintained with a through-wall crack of over 40% of the circumference. Even after the crack becomes through-wall, further circumferential crack growth can be tolerated before the Code allowable length is exceeded. Thus, the component is acceptable for continued operation for at least 3000 hours.

3. EVALUATION ASSUMING THROUGH-WALL FLAW

In this limiting calculation a through-wall crack of 16.7% circumference is assumed. Figure 4 shows that this is within the allowable crack length per IWB-3642 of Section XI ASME Code. Assuming an average circumferential crack growth rate of 2×10^{-4} in/hr (corresponding to the plateau growth rates for furnace-sensitized material), it would take 9000 hours before the Code limits are reached. Thus, the flaw is acceptable even with the limiting assumptions.

4. LEAK-BEFORE-BREAK CONSIDERATIONS

Experience has shown that cracks in small diameter piping lead to leaks which are detected by leak detection systems. The circumferential variations in weld residual stress produce preferential crack growth which leads eventually to local leak. In fact, if one assumes a through-wall crack equal to 1/6 of the circumference, the expected leakage rate is of the order of 0.5 gpm. This could be detected by special leak monitors such as moisture sensitive tape. In any case, leak-before-break remains valid and provides inherent safety margins.

5. CONCLUSION

Continued operation can be justified for at least 3000 hours of operation, even with conservative assumptions on initial crack size and crack growth rate. Even if the indication becomes a through-wall flaw, Code safety margins would be preserved for a much longer period. Leak-before-break provides additional safety margin.

NEDE-30538
 GENERAL ELECTRIC COMPANY
 PROPRIETARY INFORMATION
 CLASS III





Figure . 1 Summary of 304SS Constant Load Crack Growth Data

Fig 2.
 Peachbottom TE
 Loop A Flaw Failure Diagram
 Buchholz Reinforced
 FURNACE SENSITIZED




Loop B Flaw
 Circumferential
 length = 1.87"
 through wall = .075"
 measured thickness =
 .340

$a/f = .04$
 $a/t = 22\%$

6/12/84

Fig Peachbottom II
Loop B Flaw Failure Diagram
SECTION II

FAILURE REGIMES



Loop A Flaw
Circumferential
length = .75"
through wall = .175"
measured thickness =
.360"

$$a/R = .23$$

$$a/L = 48.6\%$$

6/12/84

6/12/84

Fig. 4

Peachbottom II
 167% Through Wall Flow Failure Diagram
 UPPER 2011D CRACK GROWTH RATE
 (2x 10⁻⁴ in/hr)

