

APPENDIX A

NOTICE OF VIOLATION

Arkansas Power and Light Company
Arkansas Nuclear One, Unit 2

Docket: 50-368/84-12
License: NPF-6

Based on the results of an NRC inspection conducted during the period of April 1-30, 1984, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 8583, dated March 8, 1984, the following violation was identified:

Control of Combustibles

Unit 2 Technical Specification 6.8.1 requires that, "Written procedures shall be established, implemented and maintained covering... f. Fire Protection Program implementation."

Administrative Procedure 1000.47, "Control of Combustibles," Revision 0, has been established in accordance with this Technical Specification.

Step 6.4.1 of this procedure requires that transient combustibles should not exceed the limits specified in Attachment 2.

Attachment 2 of this procedure permits no more than 5 pounds of ordinary combustibles in the Unit 2 steam pipe area (Fire Zone 2155-A).

Contrary to the above, on April 18, 1984, the NRC inspectors found an excessive amount (approximately 20 pounds) of combustibles located in the Unit 2 steam pipe area.

This is a Severity Level V Violation. (Supplement I.E) (368/8412-01)

Pursuant to the provisions of 10 CFR 2.201, Arkansas Power and Light Company is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

MAY 16 1984

Dated: _____

8406220156 840516
PDR ADOCK 05000313
Q PDR