

DOCKET NO. 50-301  
UNIT NAME Point Beach Unit 2  
DATE February 5, 1992  
COMPLETED BY D. C. Peterson  
TELEPHONE 414/755-2321, Ext. 361

Unit 2 operated at approximately 500 MWe net throughout this report period with no significant load reductions.

Safety-related maintenance included the following: replaced the firing logic in the supply breaker for the "C" charging pump and tightened fittings to repair leaks on two containment electrical penetrations.

9202140304 920210  
PDR ADDCK 05000266  
R PDR