

September 8, 1995

Mr. George A. Hunger, Jr.  
Director-Licensing, MC 62A-1  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, PA 19087-0195

SUBJECT: GENERIC LETTER (GL) 89-10, SUPPLEMENT 6, "INFORMATION ON SCHEDULE AND GROUPING, AND STAFF RESPONSES TO ADDITIONAL PUBLIC QUESTIONS" PEACH BOTTOM ATOMIC POWER STATION (PBAPS), UNIT 3 (TAC NO. M89822)

Dear Mr. Hunger:

By letter dated August 2, 1995, PECO Energy Company (PECO) provided an update of schedule commitments related to GL 89-10, motor-operated valve (MOV) testing commitments and capability verifications. PECO requested an additional 90 days following the completion of PBAPS, Unit 3, refueling outage 3R10 to assess the new data obtained and to compare it to the best available information used to set up the PBAPS, Unit 3, MOVs to assure that the most appropriate test data has been applied. The staff has reviewed this schedule extension and grants you an extension until December 31, 1995. The staff requests that prior to startup from refueling outage 3R10 you complete your verification that all GL 89-10 MOVs are capable of performing their design basis function. In addition, the staff requests that you notify us, in writing, of your program completion for verifying the MOVs design basis capability. Therefore, the staff expects your letter notifying us of the GL 89-10 programs completion for PBAPS, Unit 3 by December 31, 1995.

Sincerely,

Original signed by  
Joseph W. Shea, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-278

cc: See next page

DISTRIBUTION:

Docket File JShea  
PUBLIC JZimmerman  
PDI-2 Reading OGC  
SVarga ACRS (4)  
JZwolinski JLinville, RGN-I  
MO'Brien RWessman

TScarbrough

OFFICE	PDI-2/D	PDI-2/PM	PDI-2/PM	BC:EMEB	PDI-2/D
NAME	MO'Brien	JZimmerman:mw	JShea	RWessman	JStolz
DATE	9/10/95	9/7/95	9/11/95	1/95	9/8/95

OFFICIAL RECORD COPY

DOCUMENT NAME: PBM89822.LET

9509140334 950908  
PDR ADOCK 05000278  
P PDR

NRC FILE CENTER COPY

DF 10/10



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 8, 1995

Mr. George A. Hunger, Jr.  
Director-Licensing, MC 62A-1  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, PA 19087-0195

SUBJECT: GENERIC LETTER (GL) 89-10, SUPPLEMENT 6, "INFORMATION ON SCHEDULE AND GROUPING, AND STAFF RESPONSES TO ADDITIONAL PUBLIC QUESTIONS" PEACH BOTTOM ATOMIC POWER STATION (PBAPS), UNIT 3 (TAC NO. M89822)

Dear Mr. Hunger:

By letter dated August 2, 1995, PECO Energy Company (PECO) provided an update of schedule commitments related to GL 89-10, motor-operated valve (MOV) testing commitments and capability verifications. PECO requested an additional 90 days following the completion of PBAPS, Unit 3, refueling outage 3R10 to assess the new data obtained and to compare it to the best available information used to set up the PBAPS, Unit 3, MOVs to assure that the most appropriate test data has been applied. The staff has reviewed this schedule extension and grants you an extension until December 31, 1995. The staff requests that prior to startup from refueling outage 3R10 you complete your verification that all GL 89-10 MOVs are capable of performing their design basis function. In addition, the staff requests that you notify us, in writing, of your program completion for verifying the MOVs design basis capability. Therefore, the staff expects your letter notifying us of the GL 89-10 programs completion for PBAPS, Unit 3 by December 31, 1995.

Sincerely,

A handwritten signature in black ink, appearing to read "Joseph W. Shea".

Joseph W. Shea, Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-278

cc: See next page

Mr. George A. Hunger, Jr.  
PECO Energy Company

Peach Bottom Atomic Power Station,  
Units 2 and 3

cc:

J. W. Durham, Sr., Esquire  
Sr. V.P. & General Counsel  
PECO Energy Company  
2301 Market Street, 526-1  
Philadelphia, Pennsylvania 19101

Mr. Rich R. Janati, Chief  
Division of Nuclear Safety  
Pennsylvania Department of  
Environmental Resources  
P. O. Box 8469  
Harrisburg, Pennsylvania 17105-8469

PECO Energy Company  
ATTN: Mr. G. R. Rainey, Vice President  
Peach Bottom Atomic Power Station  
Route 1, Box 208  
Delta, Pennsylvania 17314

Board of Supervisors  
Peach Bottom Township  
R. D. #1  
Delta, Pennsylvania 17314

PECO Energy Company  
ATTN: Regulatory Engineer, A4-5S  
Peach Bottom Atomic Power Station  
Route 1, Box 208  
Delta, Pennsylvania 17314

Public Service Commission of Maryland  
Engineering Division  
Chief Engineer  
6 St. Paul Centre  
Baltimore, MD 21202-6806

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Peach Bottom Atomic Power Station  
P.O. Box 399  
Delta, Pennsylvania 17314

Mr. Richard McLean  
Power Plant and Environmental  
Review Division  
Department of Natural Resources  
B-3, Tawes State Office Building  
Annapolis, Maryland 21401

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Mr. Roland Fletcher  
Department of Environment  
201 West Preston Street  
Baltimore, Maryland 21201

A. F. Kirby, III  
External Operations - Nuclear  
Delmarva Power & Light Company  
P.O. Box 231  
Wilmington, DE 19899