



PECO ENERGY

Robert W. Boyce  
Plant Manager  
Limerick Generating Station

PECO Energy Company  
Limerick Generating Station  
PO Box 2300  
Sanatoga, PA 19464-0920  
215 327 1200 Ext. 2000

September 9, 1995  
Docket Nos. 50-352  
50-353  
License Nos. NPF-39  
NPF-85

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

SUBJECT: Licensee Event Report  
Limerick Generating Station - Units 1 and 2

This voluntary LER concerns pressure setpoint drift of the Main Steam System safety relief valves (SRV) due to corrosion induced bonding within the valves. This report provides information regarding SRV setpoint test results for the previous Unit 1 operating cycle and the previous two Unit 2 operating cycles.

Reference: Docket No. 50-352  
50-353  
Report Number: 2-95-009  
Revision Number: 00  
Discovery Date: August 10, 1995  
Report Date: September 9, 1995  
Facility: Limerick Generating Station  
P.O. Box 2300, Sanatoga, PA  
19464-2300

Very truly yours,

DMS:cah

cc: T. T. Martin, Administrator Region I, USNRC  
N. S. Perry, USNRC Senior Resident Inspector, LGS

100017

9509150033 950909  
PDR ADOCK 05000353  
S PDR