



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

FEB 05 1992

Docket No. 50-461

License No. NPF-62

Illinois Power Company
ATTN: Mr. J. S. Perry
Vice President
Clinton Power Station
Mail Code V-275
Post Office Box 678
Clinton, IL 61727

SUBJECT: NOTICE OF VIOLATION (NRC INSPECTION REPORT NO.
50-461/91020(DRP))

Dear Mr. Perry:

We have received your letter, dated January 9, 1992, responding to the subject Notice of Violation issued on November 29, 1991. We have reviewed your corrective actions and have no further questions at this time. These corrective actions will be examined during future inspections.

With regard to the first supplemental issue that we requested you address, we understand that the results of the inspection of the wall thickness of the fuel oil storage tanks did not identify any wall thinning. We have no further questions at this time. With regard to the second issue, we understand that you have not yet completed developing plans to improve the overall performance and reliability of the fire water supply system, and the fire pump diesels in particular. We would appreciate your providing the resident office with an outline of your plan, including dates when you expect to complete the actions, after you have completed your evaluations.

Sincerely,

Edward G. Greenman, Director
Division of Reactor Projects

See Attached Distribution

JED 1/0

FEB 05 1932

Distribution

cc:

J. Cook, Manager - Clinton Power Station
F. Spangenberg, III, Manager - Licensing
and Safety
DCD/DCB (RIDS)
OC/LFDCB
Clinton SRI
A. Gody, Jr., NRR PM
J. McCaffrey, Chief, Public
Utilities Division
Patrica O'Brien, Governor's
Office of Consumer Services
K. K. Berry, Licensing Services Manager
General Electric Company
S. Zabel, Esquire, Schiff,
Hardin, & Waite
Chairman, DeWitt County Board
Illinois Department of
Nuclear Safety
Perry SRI
Robert Newmann, Office of Public Counsel
State of Illinois Center