



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ENERGY OPERATIONS, INC.

DOCKET NO. 50-368

ARKANSAS NUCLEAR ONE, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 130
License No. NPF-6

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Energy Operations, Inc. (the licensee) dated February 20, 1991, as supplemented October 11, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-6 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 130, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John T. Larkins, Director
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 11, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 130

FACILITY OPERATING LICENSE NO. NPF-6

DOCKET NO. 50-368

Revise the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE PAGES

3/4 3-25
3/4 3-26
3/4 3-27
B3/4 3-2

INSERT PAGES

3/4 3-25
3/4 3-26
3/4 3-27
B 3/4 3-2

TABLE 3.3-6

RADIATION MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ALARM/TRIP SETPOINT</u>	<u>MEASUREMENT RANGE</u>	<u>ACTION</u>
1. AREA MONITORS					
a. Spent Fuel Pool Area Monitor	1	Note 1	$\leq 1.5 \times 10^{-2}$ R/hr	10^{-4} - 10^1 R/hr	13
b. Containment High Range	2	1, 2, 3 & 4	Not Applicable	$1 - 10^7$ R/hr	18
2. PROCESS MONITORS					
a. Containment					
i. Gaseous Activity					
a) Purge & Exhaust Isolation	1	5 & 6	$\leq 2 \times$ background	$10 - 10^6$ cpm	16
b) RCS Leakage Detection	1	1, 2, 3 & 4	Not Applicable	$10 - 10^6$ cpm	14
ii. Particulate Activity					
a) RCS Leakage Detection	1	1, 2, 3 & 4	Not Applicable	$10 - 10^6$ cpm	14
b. Control Room Ventilation Intake Duct Monitor	1	ALL MODES	$\leq 2 \times$ background	$10 - 10^6$ cpm	17

Note 1 - With fuel in the spent fuel pool or building

TABLE 3.3-6 (Continued)

TABLE NOTATION

- ACTION 13 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, perform area surveys of the monitored area with portable monitoring instrumentation at least once per 24 hours.
- ACTION 14 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, comply with the ACTION Requirements of Specification 3.4.6.1.
- ACTION 16 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, complete the following:
- a. If performing CORE ALTERATIONS or moving irradiated fuel within the reactor building, secure the containment purge system or suspend CORE ALTERATIONS and movement of irradiated fuel within the reactor building.
 - b. If a containment PURGE is in progress, secure the containment purge system.
 - c. If continuously ventilating, verify the SPING monitor operable or perform the ACTIONS of 3.3.3.9, or secure the containment purge system.
- ACTION 17 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, within 1 hour initiate and maintain operation of the control room emergency ventilation system in the recirculation mode of operation.
- ACTION 18 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, (1) either restore the inoperable channel to OPERABLE status within 7 days or (2) prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 30 days following the event, outlining the action taken, the cause of the inoperability, and the plans and schedule for restoring the system to OPERABLE status. With both channels inoperable, initiate alternate methods of monitoring the containment radiation level within 72 hours in addition to the actions described above.

TABLE 4.3-3

IONIZING RADIATION MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
1. AREA MONITORS				
a. Spent Fuel Pool Area Monitor	S	R	M	Note 1
b. Containment High Range	S	R Note 4	M	1, 2, 3, & 4
2. PROCESS MONITORS				
a. Containment				
i. Gaseous Activity				
a) Purge & Exhaust Isolation	Note 2	R	Note 3	5 & 6
b) RCS Leakage Detection	S	R	M	1, 2, 3, & 4
ii. Particulate Activity				
a) RCS Leakage Detection	S	R	M	1, 2, 3, & 4
b. Control Room Ventilation Intake Duct Monitor	S	R	M	ALL MODES

Note 1 - With fuel in the spent fuel pool or building.

Note 2 - Within 8 hours prior to initiating containment purge operations and at least once per 12 hours during containment purge operations.

Note 3 - Within 31 days prior to initiating containment purge operations and at least once per 31 days during containment purge operations.

Note 4 - Acceptable criteria for calibration are provided in Table II.F.1-3 of NUREG-0737.

3/4.3 INSTRUMENTATION

BASES

3/4.3.3 MONITORING INSTRUMENTATION

3/4.3.3.1 RADIATION MONITORING INSTRUMENTATION

The OPERABILITY of the radiation monitoring channels ensures that 1) the radiation levels are continually measured in the areas served by the individual channels and 2) the alarm or automatic action is initiated when the radiation level trip setpoint is exceeded.

The PURGE as defined in the definitions section is a release under a purge permit, whereas continuous ventilation is defined as operation of the purge system after the requirements of the purge permit have been satisfied. When securing the containment purge system to meet the ACTION requirements of this Specification, at least one supply valve and one exhaust valve is to be closed, and the supply and exhaust fans secured.

3/4.3.3.2 INCORE DETECTORS

The OPERABILITY of the incore detectors with the specified minimum complement of equipment ensures that the measurements obtained from use of this system accurately represent the spatial neutron flux distribution of the reactor core.

3/4.3.3.3 SEISMIC INSTRUMENTATION

The OPERABILITY of the seismic instrumentation ensures that sufficient capability is available to promptly determine the magnitude of a seismic event and evaluate the response of those features important to safety. This capability is required to permit comparison of the measured response to that used in the design basis for the facility to determine if plant shutdown is required pursuant to Appendix "A" of 10 CFR Part 100. The instrumentation is consistent with the recommendations of Safety Guide 12, "Instrumentation for Earthquakes," March, 1971.

3/4.3.3.4 METEOROLOGICAL INSTRUMENTATION

The OPERABILITY of the meteorological instrumentation ensures that sufficient meteorological data is available for estimating potential radiation doses to the public as a result of routine or accidental release of radioactive materials to the atmosphere. This capability is required to evaluate the need for initiating protective measures to protect the health and safety of the public and is consistent with the recommendations of Regulatory Guide 1.23 "Onsite Meteorological Programs," February 1972.

3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the remote shutdown instrumentation ensures that sufficient capability is available to permit shutdown and maintenance of HGT STANDBY of the facility from locations outside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criteria 19 of 10 CFR 50.