

The Light company

Houston Lighting & Power

South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

February 14, 1992
ST-HL-AE-4007
File No.: G02
10CFR50.71


U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

South Texas Project
Units 1 & 2
Docket Nos. STN 50-498 & 50-499
Monthly Operating Reports for January, 1992

Pursuant to 10CFR50.71(a) and South Texas Project Electric Generating Station (STPEGS) Technical Specification 6.9.1.5, attached are the Monthly Operating Reports for January, 1992.

HL&P has revised its methodology for calculation of net generation during unit shutdown periods. The revised methodology complies with the guidance provided in Regulatory Guide 1.16 Revision 4 in accordance with the South Texas UFSAR commitment.

If you should have any questions on this matter, please contact Mr. C. A. Ayala at (512) 972-8628.


William J. Jump
Manager
Nuclear Licensing

MKJ/amp

Attachments: 1) STPEGS Unit 1 Monthly Operating Report - January, 1992
2) STPEGS Unit 2 Monthly Operating Report - January, 1992

190015

REF: 92042001.1&2

A Subsidiary of Houston Industries Incorporated

9202180275 920231
PDR ADOCK 05000498
R PDR

IE24
1/1

Houston Lighting & Power Company
South Texas Project Electric Generating Station

ST-HL-AE- 4007
File No.: G02
Page 2

cc:

Regional Administrator, Region IV
Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

George Dick, Project Manager
U.S. Nuclear Regulatory Commission
Washington, DC 20555

J. I. Tapia
Senior Resident Inspector
c/o U. S. Nuclear Regulatory
Commission
P. O. Box 910
Bay City, TX 77414

J. R. Newman, Esquire
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20036

D. E. Ward/T. M. Puckett
Central Power and Light Company
P. O. Box 2121
Corpus Christi, TX 78403

J. C. Lanier/M. B. Lee
City of Austin
Electric Utility Department
P.O. Box 1088
Austin, TX 78767

K. J. Fiedler/M. T. Hardt
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Rufus S. Scott
Associate General Counsel
Houston Lighting & Power Company
P. O. Box 61857
Houston, TX 77208

INPO
Records Center
1100 Circle 75 Parkway
Atlanta, GA 30339-3064

Dr. Joseph M. Hendrie
50 Bellport Lane
Bellport, NY 11713

D. K. Lacker
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Revised 10/11/91

L4/NRC/

SOUTH TEXAS PROJECT
ELECTRIC GENERATING STATION
UNIT 1
MONTHLY OPERATING REPORT
JANUARY 1992
HOUSTON LIGHTING AND POWER CO.
NRC DOCKET NO. 50-498
LICENSE NO. NPF-76

Reviewed By:	<u>Al P. Galt</u>	<u>2-5-92</u>
	Supervisor	Date
Reviewed by:	<u>D. C. Lopez</u>	<u>2-6-92</u>
	Plant Engineering Manager	Date
Approved By:	<u>W. J. [Signature]</u>	<u>2/10/92</u>
	Plant Manager	Date

Monthly Summary

STPEGS Unit 1 operated during the reporting period with no unit shutdowns or significant power reductions.

OPERATING DATA REPORT

DOCKET NO. 50-498
 UNIT 1
 DATE Feb. 3, 1992
 COMPLETED BY A.P. Kent
 TELEPHONE 512/972-7786

OPERATING STATUS

1. REPORTING PERIOD: 01/01-01/31 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (Mwt): 3800
 MAX.DEPEND.CAPACITY (MWe-Net): 1250.6
 DESIGN ELECTRICAL RATING (MWe-Net): 1250.6
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY)(MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL.....	<u>744.0</u>	<u>744.0</u>	<u>20763.9</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE.....	<u>744.0</u>	<u>744.0</u>	<u>19956.3</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (Mwt).....	<u>2837741</u>	<u>2837741</u>	<u>72992063</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)..	<u>974080</u>	<u>974080</u>	<u>24682080</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)....	<u>934194</u>	<u>934194</u>	<u>23262563</u>
12. REACTOR SERVICE FACTOR.....	<u>100.0%</u>	<u>100.0%</u>	<u>68.9%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>100.0%</u>	<u>68.9%</u>
14. UNIT SERVICE FACTOR.....	<u>100.0%</u>	<u>100.0%</u>	<u>66.3%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>100.0%</u>	<u>66.3%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>100.4%</u>	<u>100.4%</u>	<u>61.8%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)..	<u>100.4%</u>	<u>100.4%</u>	<u>61.8%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>0.0%</u>	<u>0.0%</u>	<u>13.8%</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):	<u>N/A</u>		
20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:	<u>N/A</u>		

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-498
UNIT 1
DATE Feb. 3, 1992
COMPLETED BY A.P. Kent
TELEPHONE 512/972-7786

MONTH JANUARY

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1260</u>	17	<u>1256</u>
2	<u>1259</u>	18	<u>1255</u>
3	<u>1260</u>	19	<u>1258</u>
4	<u>1260</u>	20	<u>1256</u>
5	<u>1260</u>	21	<u>1258</u>
6	<u>1259</u>	22	<u>1258</u>
7	<u>1258</u>	23	<u>1253</u>
8	<u>1258</u>	24	<u>1252</u>
9	<u>1257</u>	25	<u>1251</u>
10	<u>1257</u>	26	<u>1250</u>
11	<u>1257</u>	27	<u>1248</u>
12	<u>1257</u>	28	<u>1232</u>
13	<u>1258</u>	29	<u>1255</u>
14	<u>1257</u>	30	<u>1257</u>
15	<u>1257</u>	31	<u>1258</u>
16	<u>1255</u>		

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-498
 UNIT 1
 DATE Feb. 3, 1992
 COMPLETED BY A.P. Kent
 TELEPHONE 512/972-7786

REPORT MONTH JANUARY

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
THERE WERE NO UNIT SHUTDOWNS OR SIGNIFICANT POWER REDUCTIONS DURING THE REPORTING PERIOD									

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont. of Existing
 Outage
 5-Reduction
 9-Other

⁴
 IEEE 805-1983

⁵
 IEEE 803A-1983

ATTACHMENT 1
 ST-HI-AE-4007
 PAGE 5 OF 6

PORVs and Safety Valves Summary

There were no PORV or Safety Valves challenged during the reporting period.

SOUTH TEXAS PROJECT
ELECTRIC GENERATING STATION
UNIT 2
MONTHLY OPERATING REPORT
JANUARY 1992
HOUSTON LIGHTING AND POWER CO.
NRC DOCKET NO. 50-499
LICENSE NO. NPF-80

Reviewed By:	<u>C. P. G. H.</u>	<u>2-13-92</u>
	Supervisor	Date
Reviewed By:	<u>D. G. Lagan</u>	<u>2-13-92</u>
	Plant Engineering Manager	Date
Approved By:	<u>W. J. [Signature]</u>	<u>2/13/92</u>
	Plant Manager	Date

Monthly Summary

STPEGS Unit 2 began the reporting period at 100% reactor power.

On 1/22/92 at 0910 the unit automatically shutdown when Control Rod H-6 dropped causing a power range rate trip. The control rod dropped when a diode failed in the Stationary Gripper Coil Circuit of the Rod Control System. The diode was replaced along with a number of other diodes of the same lot. All blocking diodes were tested and were within the required manufacturers operating specifications. Additional testing was done by Westinghouse resulting in no additional findings relating to the failure. The outage was extended to repair a steam leak from an 8-3/4 inch handhole cover on the 2D Steam Generator. The handhole cover and gasket were replaced.

The unit was returned to service on 1/28/92 at 1910 and concluded the reporting period at 100% reactor power.

OPERATING DATA REPORT

DOCKET NO. 50-499
 UNIT 2
 DATE Feb. 3, 1992
 COMPLETED BY A.P. Kent
 TELEPHONE 512/972-7786

OPERATING STATUS

1. REPORTING PERIOD: 01/01-01/31 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 3800
 MAX. DEPEND. CAPACITY (MWe-Net): 1250.6
 DESIGN ELECTRICAL RATING (MWe-Net): 1250.6
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL.....	<u>617.9</u>	<u>617.9</u>	<u>16040.5</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE.....	<u>590.0</u>	<u>590.0</u>	<u>15072.2</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWt)....	<u>2191813</u>	<u>2191813</u>	<u>54585084</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)..	<u>745390</u>	<u>745390</u>	<u>18412750</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)....	<u>714131</u>	<u>714131</u>	<u>17418134</u>
12. REACTOR SERVICE FACTOR.....	<u>83.0%</u>	<u>83.0%</u>	<u>69.8%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>83.0%</u>	<u>83.0%</u>	<u>69.8%</u>
14. UNIT SERVICE FACTOR.....	<u>79.3%</u>	<u>79.3%</u>	<u>65.6%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>79.3%</u>	<u>79.3%</u>	<u>65.6%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>76.8%</u>	<u>76.8%</u>	<u>60.6%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)..	<u>76.8%</u>	<u>76.8%</u>	<u>60.6%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>20.7%</u>	<u>20.7%</u>	<u>16.6%</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE AND DURATION OF EACH): N/A			
20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: <u>N/A</u>			

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-499
UNIT 2
DATE Feb. 3, 1992
COMPLETED BY A.P. Kent
TELEPHONE 512/972-7786

MONTH JANUARY

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1234</u>
2	<u>1244</u>
3	<u>1241</u>
4	<u>1254</u>
5	<u>1251</u>
6	<u>1245</u>
7	<u>1258</u>
8	<u>1258</u>
9	<u>1257</u>
10	<u>1258</u>
11	<u>1258</u>
12	<u>1256</u>
13	<u>1256</u>
14	<u>1258</u>
15	<u>1258</u>
16	<u>1256</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>1257</u>
18	<u>1256</u>
19	<u>1256</u>
20	<u>1258</u>
21	<u>1256</u>
22	<u>452</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>500</u>
30	<u>1237</u>
31	<u>1244</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-499
 UNIT 2
 DATE Feb. 3, 1992
 COMPLETED BY A.P. Kent
 TELEPHONE 512/972-7786

REPORT MONTH JANUARY

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
92-01	920122	F	154.0	A	3	2-92-001	AA	BLK	<p>The unit automatically shutdown when Control Rod H-6 dropped causing a power range rate trip. The control rod dropped when a diode failed in the Stationary Gripper Coil Circuit of the Rod Control System. The diode was replaced along with a number of other diodes of the same lot. All blocking diodes were tested and were within the required manufacturers operating specifications. Additional testing was done by Westinghouse resulting in no additional findings relating to the failure. Corrective actions to prevent recurrence will be discussed in the LER.</p> <p>The outage was extended to repair a steam leak from an 8 3/4 inch handhole cover on the 2D Steam Generator. The handhole cover and gasket were replaced.</p>

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont. of Existing Outage
 5-Reduction
 9-Other

⁴ IEEE 805-1983

⁵ IEEE 803A-1983

ATTACHMENT 2
 ST-HL-AE-4007
 PAGE 5 OF 6

PORVs and Safety Valves Summary

There were no PORV or Safety Valves challenged during the reporting period.