

CHALLENGES TO MAIN STEAM SAFETY/RELIEF VALVES

Month January 1992

None

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-461
UNIT Clinton 1
DATE 01/31/92
COMPLETED BY F. A. Spangenberg, III
TELEPHONE (217) 935-8881 X3400

MONTH January 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>928</u>
2	<u>927</u>
3	<u>924</u>
4	<u>66</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>126</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>539</u>
18	<u>728</u>
19	<u>873</u>
20	<u>855</u>
21	<u>887</u>
22	<u>875</u>
23	<u>871</u>
24	<u>876</u>
25	<u>877</u>
26	<u>876</u>
27	<u>878</u>
28	<u>877</u>
29	<u>877</u>
30	<u>878</u>
31	<u>878</u>

OPERATING DATA REPORT

DOCKET NO. 50-461
UNIT Clinton 1
DATE 01/31/92
COMPLETED BY F. A. Spangenberg, III
TELEPHONE (217) 935-8881 X3400

OPERATING STATUS

1. REPORTING PERIOD: January 1992 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2894
MAX. DEPEND. CAPACITY (MDC) (MWe-Net): 930
DESIGN ELECTRICAL RATING (MWe-Net): 933
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL...	<u>470.8</u>	<u>470.8</u>	<u>24,919.1</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
7. HOURS GENERATOR ON LINE.....	<u>450.9</u>	<u>450.9</u>	<u>24,080.0</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)...	<u>1,180,614</u>	<u>1,180,614</u>	<u>61,939,347</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>391,720</u>	<u>391,720</u>	<u>20,468,810</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)...	<u>368,273</u>	<u>368,273</u>	<u>19,419,650</u>
12. REACTOR SERVICE FACTOR.....	<u>63.2%</u>	<u>63.3%</u>	<u>67.9%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>63.3%</u>	<u>63.3%</u>	<u>67.9%</u>
14. UNIT SERVICE FACTOR.....	<u>60.6%</u>	<u>60.6%</u>	<u>65.6%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>60.6%</u>	<u>60.6%</u>	<u>65.6%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>53.2%</u>	<u>53.2%</u>	<u>55.9%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>53.1%</u>	<u>53.1%</u>	<u>56.7%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>39.4%</u>	<u>39.4%</u>	<u>14.6%</u>

19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, DURATION OF EACH):

The third refueling outage is currently scheduled to begin March 1, 1992 and last approximately 70 days.

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: N/A

UNIT SHUTDOWNS AND POWER REDUCTIONS

POCKET NO. 50-461
UNIT Clinton 1
DATE 01/31/92
COMPLETED BY F. A. Spangenberg, III
TELEPHONE (217) 935-8881 X3400

REPORT MONTH January 1992

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON(1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)		CORRECTIVE ACTIONS /COMMENTS
92-01	920104	F	293.1	A: An internal fault occurred in the "B" Main Power Transformer causing the sudden pressure relay to actuate. This actuation caused a main generator trip and subsequently a main turbine trip and reactor scram.	3: An automatic scram signal was generated as a result of the main turbine trip.		The "B" Main Power Transformer was replaced with a spare transformer. (See LER 92-001). The forced outage was extended due to the clean up of an unrelated Electrohydraulic Control (EHC) fluid spill in the suppression pool. Upon completion of cleanup, the plant was returned to power operation.

- (1) Reason
A-Equipment Failure (explain), B-Maintenance or Test, C-Refueling, D-Regulatory Restriction, E-Operator Training & License Examination, F-Administrative, G-Operational Error (explain), H-Other (explain)
- (2) Method
1-Manual, 2-Manual Scram, 3-Automatic Scram, 4-Other (explain)