

February 12, 1992

Docket No. 50-382

Mr. Ross P. Barkhurst
Vice President Operations
Energy Operations, Inc.
Post Office Box B
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF GENERIC ISSUE 48, 'LOC'S FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND 49, 'INTERLOCKS AND LOC'S FOR CLASS 1E TIE BREAKERS,' PURSUANT TO 10 CFR 50.54(f)," FOR WATERFORD STEAM ELECTRIC STATION, UNIT NO. 3 (TAC NO. M82485)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11, which contained the staff resolution of Generic Issues 48 and 49. The GL required that licensees certify that procedures exist which contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters or other onsite power sources for VIB, and tie breakers. If procedures do not exist, a justification demonstrating the reasons why the controls are not needed is required.

By letter dated January 14, 1992, Entergy Operations, Inc., responded to the GL and indicated that procedures for time limitations and surveillance requirements are in place at its site.

The staff has reviewed the response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC No. M82485.

Sincerely,

Original signed by:
David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket File	OChopra	MVirgilio
NRC & Local PDRs	PNoonan	PD4-1 Plant File
PD4-1 Reading	OGC	DWigginton
BBoger	ACRS (10)	ABBeach
SHoffman		

OFC	LA:PD4-1 <i>PK</i>	PM:PD4-1 <i>PK</i>	D:PD4-1 <i>PK</i>
NAME	PNoonan	DWigginton:pk	JL...ins
DATE	2/12/92	2/12/92	2/12/92

OFFICIAL RECORD COPY Document Name: WAT82485.1tr

DF01
1/0



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 12, 1992

Docket No. 50-382

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
Post Office Box B
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF GENERIC ISSUE 48, 'LOC'S FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND 49, 'INTERLOCKS AND LOC'S FOR CLASS 1E TIE BREAKERS,' PURSUANT TO 10 CFR 50.54(f)," FOR WATERFORD STEAM ELECTRIC STATION, UNIT NO. 3 (TAC NO. M82485)

On 11/18, 1991, the NRC issued Generic Letter (GL) 91-11, which contained the staff resolution of Generic Issues 48 and 49. The GL required that licensees certify that procedures exist which contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters or other onsite power sources for VIB, and tie breakers. If procedures do not exist, a justification demonstrating the reasons why the controls are not needed is required.

By letter dated January 14, 1992, Entergy Operations, Inc., responded to the GL and indicated that procedures for time limitations and surveillance requirements are in place at its site.

The staff has reviewed the response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC No. M82485.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. L. Wigginton".

David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Ross P. Barkhurst
Entergy Operations, Inc.

Waterford 3

cc:

Mr. Glenn Miller, Administrator
Radiation Protection Division
Office of Air Quality and Nuclear Energy
Post Office Box 82135
Baton Rouge, Louisiana 70884-2135

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. John R. McGaha
Vice President, Operations
Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Resident Inspector/Waterford NPS
Post Office Box 822
Killona, Louisiana 70066

President, Parish Council
St. Charles Parish
Hahnville, Louisiana 70057

William A. Cross
Bethesda Licensing Office
3 Metro Center
Suite 610
Bethesda, Maryland 20814

Mr. Donald C. Hintz
Executive Vice President and
Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Mr. Robert B. McGenee
Wise, Carter, Child & Caraway
P.O. Box 651
Jackson, Mississippi 39205

Chairman
Louisiana Public Service Commission
One American Place, Suite 1630
Baton Rouge, Louisiana 70825-1697

Mr. D. F. Packer
General Manager Plant Operations
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Mr. R. F. Burski, Director
Nuclear Safety
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Mr. L. V. Laughlin, Licensing Manager
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Winston & Strawn
Attn: N.S. Reynolds
1400 L Street, N.W.
Washington, DC 20005-3502