

Docket No. 50-387

JUN 4 1984

License No. NPF-14

Pennsylvania Power & Light Company  
ATTN: Mr. Bruce D. Kenyon  
Vice President  
Nuclear Operations  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Gentlemen:

Subject: Enforcement Conference for Inspection No. 50-387/84-11

This refers to the enforcement conference held on March 20, 1984, in the Region I office, King of Prussia, Pennsylvania, to discuss the findings of Special Inspection Report 50-387/84-11. Specific topics discussed at this meeting related to the inoperability of the High Pressure Coolant Injection and Reactor Core Isolation Cooling systems during Unit 1 startup on February 21, 1984, following the December 1983 - February 1984 tie-in outage. Other events (radioactive fluid spills and previous violations) which had occurred over the past year were also discussed, to analyze the potential development of any adverse trends related to Susquehanna Station operations. Conference details are described in the report enclosed with this letter. Also enclosed is your presentation which was distributed at the meeting.

This transmittal will be made public unless you notify this office, within 10 days of the date of this letter, that you intend to request withholding of information under 10 CFR 2.790(b)(1). That notification may be made to the Supervisor, Files, Mail and Records, USNRC Region I, at (215) 337-5223.

No reply to this letter is required.

Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:

*Edward B. Blackwood for*

Richard W. Starostecki, Director  
Division of Project and Resident  
Programs

OFFICIAL RECORD COPY

ENCONFERENCE5/21/84 - 0001.0.0  
05/23/84

8406230461 840604  
PDR ADOCK 05000387  
Q PDR

1E01 1/1

Enclosures:

1. NRC Region I Enforcement Conference Report
2. Pennsylvania Power & Light Presentation

cc w/encls:

Norman W. Curtis, Vice President, Engineering and Construction - Nuclear  
A. R. Sabol, Manager, Nuclear Quality Assurance  
W. E. Barberich, Licensing Engineer  
H. W. Keiser, Superintendent of Plant  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania

bcc w/encls:

Region I Docket Room (with concurrences)  
Senior Operations Officer (w/o encls)  
T. Murley  
D. Holody  
T. Martin  
R. Bellamy  
E. McCabe  
E. Blackwood  
R. Perch, NRR  
P. Farron, IE  
E. Kelly  
R. Nimitz

*am Kelly*  
RI:DPRP /  
Kelly/mlb  
5/23/84

*Ⓢ*  
RI:DPRP  
McCabe  
5/25/84

*DBB*  
RI:DPRP  
Blackwood  
5/31/84

~~RI:DPRP  
Starostecki  
5/ /84~~