

ENCLOSURE 1

NOTICE OF DEVIATION

Wolf Creek Nuclear Operating Corporation
Wolf Creek Generating Station

Docket: 50-482
License: NPF-42

During an NRC inspection conducted on July 16 through August 26, 1995, one deviation from your Updated Safety analysis Report was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Action," (60 FR 34381; June 30, 1995), the deviation is listed below:

Updated Safety Analysis Report (USAR) Section 3.10(B), Table 3.10(B)-1, lists batteries and battery racks as Seismic Category I instrumentation and electrical equipment as specified in Specification E-050.

Specification E-050 requires vendor technical manuals to be supplied with the applicable batteries.

The vendor supplied the NK13 battery per Specification E-050, with Vendor Technical Manual E-050-G0016. The technical manual contained seismic installation instructions which required the battery rack end-to-cell gap to be 1/4 inch or less.

Contrary to the above, on July 18, 1995, the inspector noted that the NK13 battery rack end-to-cell gap was approximately 1/2 inch (482/9517-01).

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region IV, 611 Ryan Plaza Drive, Suite 400, Arlington, Texas 76011, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, in writing within 30 days of the date of this Notice, (1) the reason for the deviation, or if contested, the basis for disputing the deviation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further deviations, and (4) the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Because the response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. However, if it is necessary to include such information, it should clearly indicate the specific information that should not be placed in the PDR, and provide the legal basis to support the request for withholding the information from the public.

Dated at *Arlington*
the *11* day of *Sept.* 1995

9509180299 950911
PDR ADCCK 05000482
G PDR