

NOTICE OF DEVIATION

Carolina Power & Light Company
Brunswick Units 1 & 2

Docket Nos.: 50-325, 50-324
License Nos.: DPR-71, DPR-62

During an NRC inspection conducted on June 19-23, and July 1 - August 4, 1995, a deviation of your Updated Final Safety Analysis Report (UFSAR) was identified. In accordance with the "General Statement of Policy and Procedures for NRC Enforcement Actions," (60 FR 34381), the deviation is listed below:

Updated Final Safety Analysis Report, Section 3.4.1.1.1, Protection of Access Openings Below Maximum High Water Elevation, states in part, that "Doors and door frames were designed to...limit the inleakage from the Probable Maximum Hurricane (PMH) condition to 5 gallons per minute for personnel doors..." Section 3.4.1.1.1.d, Service Water Intake Structure, addresses two personnel doors at elevation 23.0 foot mean sea level.

Contrary to the above, on June 23, 1995, it was identified that the two Service Water Intake Structure flood doors did not meet this design requirement for some unknown time period. The North door was missing the bottom portion of the door frame sill preventing the bottom portion of the door from sealing. The South door had a one inch gap rusted completely through the metal door.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice," in writing within 30 days of the date of this Notice, (1) the reason for the deviation, or if contested, the basis for disputing the deviation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further deviations, and (4) the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Because your response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. However, if you find it necessary to include such information, you should clearly indicate the specific information that you desire not to be placed in the PDR, and provide the legal basis to support your request for withholding the information from the public.

Dated at Atlanta, Georgia
this 1st day of September 1995

ENCLOSURE 1

9509190009 950901
PDR ADOCK 05000324
G PDR